



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

July 14, 2021

Mr. David P. Rhoades
Senior Vice President
Exelon Generation Company, LLC
President and Chief Nuclear Officer
Exelon Nuclear
4300 Winfield Road
Warrenville, IL 60555

SUBJECT: CLINTON POWER STATION, UNIT NO. 1 – CORRECTION TO AMENDMENT NO. 238 ISSUED JUNE 28, 2021, RE: TECHNICAL SPECIFICATIONS TASK FORCE TRAVELER TSTF-505, REVISION 2, “PROVIDE RISK-INFORMED EXTENDED COMPLETION TIMES – RITSTF INITIATIVE 4B” (EPID L-2020-LLA-0097)

Dear Mr. Rhoades:

By letter dated June 28, 2021 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML21132A288), the U.S. Nuclear Regulatory Commission (NRC) issued Amendment No. 238 to Facility Operating License No. NPF-62 for the Clinton Power Station, Unit No. 1. The amendment was in response to your application dated April 30, 2020 (ADAMS Accession No. ML20121A178) as supplemented by letters dated November 24, 2020 (ADAMS Accession No. ML20329A433) and March 23, 2021 (ADAMS Accession No. ML21082A268).

Subsequent to issuance of the amendment, your staff informed me that there were unintended characters on issued technical specification (TS) page 3.5-12 and an unintended underscore on issued TS page 3.3-2. The attached TS pages correct these unintended changes. These corrections do not change any of the conclusions in the safety evaluation associated with the issuance of the amendment.

D. Rhoades

- 2 -

If you have any questions, please contact me at 301-415-6606 or Joel.Wiebe@nrc.gov.

Sincerely,

/RA/

Joel S. Wiebe, Senior Project Manager
Plant Licensing Branch III
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-461

Enclosure:
Corrected TS pages

cc: Listserv

ENCLOSURE

CLINTON POWER STATION, UNIT NO. 1

CORRECTED TS PAGES FOR AMENDMENT NO. 238

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
D. Required Action and associated Completion Time of Condition A, B, or C not met.	D.1 Enter the Condition referenced in Table 3.3.1.1-1 for the channel.	Immediately
E. As required by Required Action D.1 and referenced in Table 3.3.1.1-1.	E.1 Reduce THERMAL POWER to < 33.3% RTP.	8 hours
F. As required by Required Action D.1 and referenced in Table 3.3.1.1-1.	F.1 Reduce THERMAL POWER to < 21.6% RTP.	8 hours
G. As required by Required Action D.1 and referenced in Table 3.3.1.1-1.	G.1 Be in MODE 2.	8 hours
H. As required by Required Action D.1 and referenced in Table 3.3.1.1-1.	H.1 Be in MODE 3.	12 hours
I. As required by Required Action D.1 and referenced in Table 3.3.1.1-1.	I.1 Initiate action to fully insert all insertable control rods in core cells containing one or more fuel assemblies.	Immediately

3.5 EMERGENCY CORE COOLING SYSTEMS (ECCS), REACTOR PRESSURE VESSEL (RPV) WATER INVENTORY CONTROL, AND REACTOR CORE ISOLATION COOLING (RCIC) SYSTEM

3.5.3 RCIC System

LCO 3.5.3 The RCIC System shall be OPERABLE.

APPLICABILITY: MODE 1,
MODES 2 and 3 with reactor steam dome pressure > 150 psig.

ACTIONS

-----NOTE-----
LCO 3.0.4.b is not applicable to RCIC.

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. RCIC System inoperable.	A.1 Verify by administrative means High Pressure Core Spray System is OPERABLE.	1 hour
	<u>AND</u> A.2 Restore RCIC System to OPERABLE status.	14 days <u>OR</u> In accordance with the Risk Informed Completion Time Program
B. Required Action and associated Completion Time not met.	B.1 Be in MODE 3.	12 hours
	<u>AND</u> B.2 Reduce reactor steam dome pressure to ≤ 150 psig.	36 hours

SUBJECT: CLINTON POWER STATION, UNIT NO. 1 – CORRECTION TO AMENDMENT NO. 238 ISSUED JUNE 28, 2021, RE: TECHNICAL SPECIFICATIONS TASK FORCE TRAVELER TSTF-505, REVISION 2, “PROVIDE RISK-INFORMED EXTENDED COMPLETION TIMES – RITSTF INITIATIVE 4B” (EPID L-2020-LLA-0097) DATED JULY 14, 2021

DISTRIBUTION:

Public
PM File Copy
RidsNrrDssStsb Resource
RidsRgn3MailCenter Resource
RidsNrrPMClinton Resource

RidsNrrLASRohrer Resource
RidsACRS_MailCTR Resource
RidsNrrDorlLpl3 Resource

ADAMS Accession No.: ML21193A130

OFFICE	NRR/DORL/LPL3/PM	NRR/DORL/LPL3/LA	NRR/DORL/LPL3/BC
NAME	JWiebe	SRohrer	NSalgado
DATE	7/13/21	7/13/21	7/14/21
OFFICE	NRR/DORL/LPL3/PM		
NAME	JWiebe		
DATE	7/14/21		

OFFICIAL RECORD COPY