

# CHAPTER TABLE OF CONTENTS

## CHAPTER 3.9

### REFUELING OPERATIONS

<u>Section</u>		<u>Page</u>
3.9.1	Boron Concentration .....	3.9-1
	ACTIONS .....	3.9-1
	SURVEILLANCE REQUIREMENTS .....	3.9-2
3.9.2	Unborated Water Source Isolation Valves .....	3.9-3
	ACTIONS .....	3.9-3
	SURVEILLANCE REQUIREMENTS .....	3.9-4
3.9.3	Nuclear Instrumentation .....	3.9-5
	ACTIONS .....	3.9-5
	SURVEILLANCE REQUIREMENTS .....	3.9-6
3.9.4	Containment Penetrations .....	3.9-7
	ACTIONS .....	3.9-7
	SURVEILLANCE REQUIREMENTS .....	3.9-8
3.9.5	Residual Heat Removal (RHR) and Coolant Circulation - High Water Level .....	3.9-9
	ACTIONS .....	3.9-9
	SURVEILLANCE REQUIREMENTS .....	3.9-10
3.9.6	Residual Heat Removal (RHR) and Coolant Circulation - Low Water Level .....	3.9-11
	ACTIONS .....	3.9-11
	SURVEILLANCE REQUIREMENTS .....	3.9-12
3.9.7	Refueling Pool Water Level .....	3.9-14
	ACTIONS .....	3.9-14
	SURVEILLANCE REQUIREMENTS .....	3.9-14

3.9 REFUELING OPERATIONS

3.9.1 Boron Concentration

LCO 3.9.1 Boron concentrations of all filled portions of the Reactor Coolant System and the refueling pool that have direct access to the reactor vessel, shall be maintained sufficient to ensure that the more restrictive of the following reactivity conditions is met:

- a. A  $k_{\text{eff}} \leq 0.95$ , or
- b. A boron concentration of  $\geq 2000$  ppm.

APPLICABILITY: MODE 6.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. Boron concentration not within limit.	A.1 Suspend CORE ALTERATIONS.	Immediately
	<u>AND</u>	
	A.2 Suspend positive reactivity additions.	Immediately
	<u>AND</u>	
	A.3 Initiate action to restore boron concentration to within limit.	Immediately

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.9.1.1	Verify boron concentration is within the limit.	In accordance with the Surveillance Frequency Control Program

3.9 REFUELING OPERATIONS

3.9.2 Unborated Water Source Isolation Valves

LCO 3.9.2 Each valve used to isolate unborated water sources shall be secured in the closed position.

----- NOTE -----  
Unborated water sources may be unisolated under administrative controls for planned boron dilution evolutions.  
-----

APPLICABILITY: MODE 6.

ACTIONS

----- NOTE -----  
Separate Condition entry is allowed for each unborated water source isolation valve.  
-----

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. ----- NOTE ----- Required Action A.3 must be completed whenever Condition A is entered. ----- One or more valves not secured in closed position.	A.1 Suspend CORE ALTERATIONS.  <u>AND</u>	Immediately
	A.2 Initiate actions to secure valve in closed position.  <u>AND</u>	Immediately
	A.3 Perform <b>SR 3.9.1.1</b> .	4 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.9.2.1	Verify each valve that isolates unborated water sources is secured in the closed position.	In accordance with the Surveillance Frequency Control Program

3.9 REFUELING OPERATIONS

3.9.3 Nuclear Instrumentation

LCO 3.9.3 Two source range neutron flux monitors shall be OPERABLE.

APPLICABILITY: MODE 6.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One required source range neutron flux monitor inoperable.	A.1 Suspend CORE ALTERATIONS.	Immediately
	<u>AND</u> A.2 Suspend operations that would cause introduction into the RCS, coolant with boron concentration less than required to meet the boron concentration of LCO 3.9.1.	Immediately
B. Two required source range neutron flux monitors inoperable.	B.1 Initiate action to restore one source range neutron flux monitor to OPERABLE status.	Immediately
	<u>AND</u> B.2 Perform SR 3.9.1.1.	Once per 12 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.9.3.1	Perform CHANNEL CHECK.	In accordance with the Surveillance Frequency Control Program
SR 3.9.3.2	<p>----- NOTE -----  Neutron detectors are excluded from CHANNEL CALIBRATION.  -----</p> <p>Perform CHANNEL CALIBRATION.</p>	In accordance with the Surveillance Frequency Control Program

### 3.9 REFUELING OPERATIONS

#### 3.9.4 Containment Penetrations

- LCO 3.9.4            The containment penetrations shall be in the following status:
- a.     The equipment hatch closed and held in place by four bolts, or if open, capable of being closed;
  - b.     One door in the emergency air lock and one door in the personnel air lock capable of being closed; and
  - c.     Each penetration providing direct access from the containment atmosphere to the outside atmosphere either:
    1.     closed by a manual or automatic isolation valve, blind flange, or equivalent, or
    2.     capable of being closed by an OPERABLE Containment Purge Isolation valve.

----- NOTE -----  
 Penetration flow path(s) providing direct access from the containment atmosphere to the outside atmosphere may be unisolated under administrative controls.  
 -----

APPLICABILITY:    During CORE ALTERATIONS,  
 During movement of irradiated fuel assemblies within containment.

#### ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or more containment penetrations not in required status.	A.1     Suspend CORE ALTERATIONS.	Immediately
	<u>AND</u> A.2     Suspend movement of irradiated fuel assemblies within containment.	



SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.9.4.1	Verify each required containment penetration is in the required status.	In accordance with the Surveillance Frequency Control Program
SR 3.9.4.2	<p>----- NOTE -----  Only required for an open equipment hatch.  -----</p> <p>Verify the capability to install the equipment hatch.</p>	In accordance with the Surveillance Frequency Control Program
SR 3.9.4.3	Verify each required containment purge isolation valve actuates to the isolation position on a manual actuation signal.	In accordance with the Surveillance Frequency Control Program



ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. RHR loop requirements not met. (continued)	A.3 Initiate action to satisfy RHR loop requirements.	Immediately
	<u>AND</u> A.4 Close all containment penetrations providing direct access from containment atmosphere to outside atmosphere.	4 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.9.5.1 Verify one RHR loop is in operation and circulating reactor coolant at a flow rate of $\geq 1000$ gpm.	In accordance with the Surveillance Frequency Control Program
SR 3.9.5.2 Verify required RHR loop locations susceptible to gas accumulation are sufficiently filled with water.	In accordance with the Surveillance Frequency Control Program

3.9 REFUELING OPERATIONS

3.9.6 Residual Heat Removal (RHR) and Coolant Circulation - Low Water Level

LCO 3.9.6 Two RHR loops shall be OPERABLE, and one RHR loop shall be in operation.

APPLICABILITY: MODE 6 with the water level < 23 ft above the top of reactor vessel flange.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. Less than the required number of RHR loops OPERABLE.	A.1 Initiate action to restore required RHR loops to OPERABLE status.	Immediately
	<u>OR</u> A.2 Initiate action to establish $\geq 23$ ft of water above the top of reactor vessel flange.	Immediately

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
B. No RHR loop in operation.	B.1 Suspend operations that would cause introduction into the RCS, coolant with boron concentration less than required to meet the boron concentration of <b>LCO 3.9.1.</b>	Immediately
	<u>AND</u> B.2 Initiate action to restore one RHR loop to operation.	Immediately
	<u>AND</u> B.3 Close all containment penetrations providing direct access from containment atmosphere to outside atmosphere.	4 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.9.6.1 Verify one RHR loop is in operation and circulating reactor coolant at a flow rate of $\geq 1000$ gpm.	In accordance with the Surveillance Frequency Control Program

(continued)

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE		FREQUENCY
SR 3.9.6.2	Verify correct breaker alignment and indicated power available to the required RHR pump that is not in operation.	In accordance with the Surveillance Frequency Control Program
SR 3.9.6.3	Verify RHR loop locations susceptible to gas accumulation are sufficiently filled with water.	In accordance with the Surveillance Frequency Control Program

3.9 REFUELING OPERATIONS

3.9.7 Refueling Pool Water Level

LCO 3.9.7 Refueling pool water level shall be maintained  $\geq 23$  ft above the top of reactor vessel flange.

APPLICABILITY: During movement of irradiated fuel assemblies within containment.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. Refueling pool water level not within limit.	A.1 Suspend movement of irradiated fuel assemblies within containment.	Immediately

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.9.7.1 Verify refueling pool water level is $\geq 23$ ft above the top of reactor vessel flange.	In accordance with the Surveillance Frequency Control Program