U.S. NUCLEAR REGULATORY COMMISSION

REGULATORY GUIDE RG 1.21



Issue Date: Month 2021 Technical Lead: Steven Garry

1	MEASURING, EVALUATING, AND REPORTING
2	RADIOACTIVE MATERIAL IN LIQUID AND GASEOUS
3	FFFI UENTS AND SOLID WASTE
4	
5	A. INTRODUCTION
6	
7	Purpose
8 9	This regulatory guide (RG) describes methods the staff of the U.S. Nuclear Regulatory
10	Commission (INCC) considers acceptable for the following uses:
12	(1) measuring, evaluating, and reporting licensed (plant-related) radioactivity in effluents and
13	solid radioactive waste shipments from nuclear power plants and spent fuel storage facilities,
14	and
15	
16	(2) assessing and reporting the public dose to demonstrate compliance with Title 10 of the <i>Code</i>
17/ 10	of Federal Regulations (10 CFR) Part 20, "Standards for Protection Against Radiation" (Def. 1) Title 40, (40 CEP) Part 100, "Equipropagated Dediction Protection Standards for
18 19	(Ref. 1), The 40, (40 CFR) Part 190, Environmental Radiation Protection Standards for Nuclear Power Operations" (Ref. 2) and nuclear power plant Technical Specifications
20	Nuclear Fower Operations (Ref. 2), and nuclear power plant reclinical Specifications.
21	This guide incorporates the risk-informed principles of the Reactor Oversight Process. A
22	risk-informed, performance-based approach to regulatory decision making combines the "risk-informed"
23	and "performance-based" elements discussed in the staff requirements memorandum to SECY-98-144,
24	"Staff Requirements—SECY-98-144—White Paper on Risk-Informed and Performance-Based
25	Regulation," dated February 24, 1999 (Ref. 3).
26	Applicability
27	Applicability
29	This RG is a Division 1, "Power Reactors" RG, which applies to nuclear power plant licensees
30	and applicants subject to Title 10 of the <i>Code of Federal Regulations</i> (10 CFR) Part 20, "Standards for
31	Protection Against Radiation," This RG is also applicable to specific and general licensees under 10 Part
32	72 for storage of spent fuel.
33	This includes licenses issued under the following regulations:
34	

Electronic copies of this RG, previous versions of RGs, and other recently issued guides are also available through the NRC's public Web site in the NRC Library at https://nrcweb.nrc.gov/reading-rm/doc-collections/reg-guides/, under Document Collections, in Regulatory Guides. This RG is also available through the NRC's Agencywide Documents Access and Management System (ADAMS) at http://www.nrc.gov/readingrm/adams.html, under ADAMS Accession Number (No.) ML21133A019. The regulatory analysis may be found in ADAMS under Accession No. ML20287A434. The associated draft guide DG-1377 may be found in ADAMS under Accession No. ML20287A423, and the staff responses to the public comments on DG-1377 may be found under ADAMS Accession No. ML21132A226.

Written suggestions regarding this guide or development of new guides may be submitted through the NRC's public Web site in the NRC Library at https://nrcweb.nrc.gov/reading-rm/doc-collections/reg-guides/,under Document Collections, in Regulatory Guides, at https://nrcweb.nrc.gov/reading-rm/doc-collections/reg-guides/, under Document Collections, in Regulatory Guides, at https://nrcweb.nrc.gov/reading-rm/doc-collections/reg-guides/contactus.html.

35 36 37	• 10 CFR Part 50, "Domestic Licensing of Production and Utilization Facilities" (Ref. 4), applies to the licensing of production and utilization facilities.				
38 39 40 41	• 10 CFR Part 52, "Licenses, Certifications, and Approvals for Nuclear Power Plants" (Ref. 5), applies to applicants and holders of combined licenses, standard design certifications, standard design approvals, and manufacturing licenses.				
42 43 44 45 46	• 10 CFR Part 72, "Licensing Requirements for the Independent Storage of Spent Nuclear Fuel, High-Level Radioactive Waste, and Reactor-Related Greater Than Class C Waste" (Ref. 6), applies to general licenses issued under Part 72 and to applicants for and holders of specific licenses under Part 72.				
47 48	Applic	able F	Regulations		
49 50 51	progra	The f m:	following regulations establish the regulatory basis for the radiological effluent control		
52 53	•	10 C	FR Part 20, "Standards for Protection Against Radiation"		
54 55 56		C	10 CFR 20.1003, "Definitions," defines terminology that is used in the regulations and in this regulatory guide.		
57 58 59		C	10 CFR 20.1301, "Dose limits for individual members of the public," establishes radiation dose limits for individual members of the public.		
60 61 62 63 64		c	10 CFR 20.1302, "Compliance with dose limits for individual members of the public," requires licensees to perform surveys of radiation levels in unrestricted and controlled areas and radioactive materials in effluents released to unrestricted and controlled areas to demonstrate compliance with the dose limits for individual members of the public.		
65 66 67 68		C	10 CFR 20.1402, "Radiological criteria for unrestricted use," establishes acceptance criteria for license termination to achieve the site's unrestricted use status after decommissioning.		
69 70 71		C	10 CFR 20.1501, "General," establishes requirements for performing radiological surveys.		
72 73 74		C	10 CFR 20.2001, "General requirements" (for waste disposal), establishes methods for disposing of licensed material.		
75 76 77		C	10 CFR 20.2103, "Records of surveys," requires licensees to maintain records of surveys and calibrations.		
78 79 80 81		C	10 CFR 20.2107, "Records of dose to individual members of the public," requires licensees to maintain records that demonstrate compliance with dose limits for members of the public.		
82 83 84		C	10 CFR 20.2108, "Records of waste disposal," requires licensees to maintain records of the disposal of licensed material.		

85 86 87 88 89	0	10 CFR Part 20, Appendix B, "Annual Limits on Intakes (ALIs) and Derived Air Concentrations (DACs) of Radionuclides for Occupational Exposure; Effluent Concentrations; Concentrations for Release to Sewage," establishes intake limits and airborne and liquid concentration limits for occupational exposure and member of the public exposure	
90		public exposure.	
91	• 10 CFF	R Part 50 "Domestic Licensing of Production and Utilization Facilities"	
92	10 011	er alt so, Donieske Dieensnig of Fredaetion and Canzadon Faeinaes	
93	0	10 CFR 50.34a, "Design objectives for equipment to control releases of radioactive	
94		material in effluents—nuclear power reactors," establishes numerical guides for design	
95		objectives and limiting conditions of operation to control radioactive effluents.	
96			
97	0	10 CFR 50.36a, "Technical specifications on effluents from nuclear power reactors,"	
98		requires licensees to establish technical specifications with operating procedures and	
99		controls be established and followed and that the radioactive waste system be maintained	
100		and used.	
101			
102	0	10 CFR 50.75, "Reporting and record keeping for decommissioning planning,"	
103		paragraph (g,) requires licensees to keep records of information important to	
104		decommissioning.	
105	0	10 CEP Part 50 Annendix A "General Decign Criteria for Nuclear Power Plante"	
100	0	General Design Criterion (GDC) 60 "Control of Releases of Radioactive Materials to the	
107		Environment "specifies that the nuclear power unit design shall include means to control	
109		suitably liquid and gaseous effluents and solid waste.	
110			
111	0	10 CFR Part 50, Appendix A, GDC 64, "Monitoring Radioactivity Releases," specifies	
112		that means shall be provided for monitoring the reactor containment atmosphere, spaces	
113		containing components for recirculation of loss-of-coolant fluids, effluent discharge paths	
114		and the plant environs for radioactivity that may be released from normal operations,	
115		anticipated operational occurrences, and from postulated accidents.	
116			
117	0	10 CFR Part 50, Appendix I, "Numerical Guides for Design Objectives and Limiting	
118		Conditions for Operation to Meet the Criterion 'As Low As Is Reasonably Achievable'	
119		(ALARA) for Radioactive Material in Light-Water-Cooled Nuclear Power Reactor	
120		Effluents," establishes design objectives for meeting the requirements of 10 CFR 50.34a.	
121	• 10 CEI	P Dort 52 "Liconses, Cortifications, and Approvals for Nuclear Dower Plants"	
122	• 10 CFI	x Part 52, Elcenses, Certifications, and Approvals for Nuclear Power Plants	
125		10 CEP 52.0 "Scope" requires Part 52 licensees to comply with all requirements in	
124	0	10 CFR Chapter I that are applicable, which includes, for example, 10 CFR Part 20 as	
125		discussed above	
127			
128	• 10 CFF	R Part 72, "Licensing Requirements for the Independent Storage of Spent Nuclear Fuel	
129	High L	evel Radioactive Waste, and Reactor-Related Greater Than Class C Waste"	
130	8		
131	0	10 CFR 72.44(d) requires that each specific license must include technical specifications	
132		that establishes limits on the release of radioactive materials and the ALARA objectives	
133		for effluents and that require establishment of an environmental monitoring program to	
134		ensure compliance with those limits	

135			
136		0	10 CEP 72 104 "Criteria for radioactive materials in effluents and direct radiation from
130		0	an ISESI or MPS " establishes dose limits to any real individual (excluding occupational
137			an ISFSF of MRS, establishes dose mints to any real individual (excluding occupational exposures) beyond the Part 72 controlled area (as defined in 10 CEP 72.3 and meeting
130			the minimum size requirements in 72 106(b))
139			the minimum size requirements in (2.100(0))
140		0	10 CER 72 126 "Criteria for radiological protection" requires radiation protection
141 142		0	systems be provided with effluent and direct radiation monitoring systems and controls to
142			limit releases to ALARA under normal conditions and control releases under accident
144			conditions and ensure limits relating to releases to the general environment will not be
145			exceeded
146			execute
147	•	40 CFR	R Part 190 "Environmental Radiation Protection Standards for Nuclear Power Operations"
148	-		
149		0	40 CFR 190 10. "Standards for normal operation" establishes standards for normal
150		Ũ	operations and annual dose equivalent standards and limits on the total quantity of
151			radioactive materials entering the environment from the entire uranium fuel cycle.
152			
153		0	40 CFR 190 11. "Variances for unusual operations" establishes variances (allowances)
154		Ũ	for unusual operations where the standards in 40 CFR 190 10 may be exceeded
155			for unusual operations where the standards in to erreform they be exceeded.
156	•	40 CFR	R Part 191 "Environmental Radiation Protection Standards for Management and Disposal
157		of Sper	It Nuclear Fuel and Transuranic Radioactive Wastes" (Ref. 7)
158		or open	
159		0	40 CFR 191.03(a), "Standards," establishes standards for the management and storage of
160			spent nuclear fuel or transuranic radioactive wastes.
161			
162			
163	Relate	d Guida	nce
164			
165	•	RG 1.2	3, "Meteorological Monitoring Programs for Nuclear Power Plants" (Ref. 8), provides
166		guidanc	ce for an onsite meteorological measurements program.
167			
168	•	RG 1.9	7, Revisions 0, 1, 2 and 3, "Instrumentation for Light-Water-Cooled Nuclear Power Plants
169		to Asse	ess Plant and Environs Conditions During and Following an Accident," issued
170		Decem	ber 1975, August 1977, and December 1980, and May 1983, respectively (Ref. 9),
171		provide	es guidance on instrumentation used to monitor plant variables and systems during and
172		followi	ng an accident.
173			
174	•	RG 1.9	7, Revision 4, "Criteria for Accident Monitoring Instrumentation for Nuclear Power
175		Plants,'	" issued June 2006 (Ref. 10), endorses (with certain clarifying regulatory positions) the
176		Institut	e of Electrical and Electronics Engineers (IEEE) Standard (Std.) 497-2002, "IEEE
177		Standar	rd Criteria for Accident Monitoring Instrumentation for Nuclear Power Generating
178		Station	s" (Ref. 11).
1/9		DC 1 0	
180	•	KG 1.9	7, Revision 5, "Criteria for Accident Monitoring Instrumentation for Nuclear Power
181		Plants,	issued April 2019 (Ker. 12), endorses, with exceptions and clarifications, IEEE 7 2016 "IEEE Standard Critoria for Assidant Monitoring Instrumentation for New Leaf
102 182		Bower	Generating Stations" (Pof. 13)
103 184		rower	Ochicialing Stations (Ref. 15).
104			

185 • 186 187 188 189	RG 1.109, "Calculation of Annual Doses to Man from Routine Releases of Reactor Effluents for the Purpose of Demonstrating Compliance with 10 CFR Part 50, Appendix I" (Ref. 14), describes basic features of calculational models and assumptions used for the estimation of doses to the public.		
190 • 191 192 193	RG 1.111, "Methods for Estimating Atmospheric Transport and Dispersion of Gaseous Effluents in Routine Releases from Light-Water-Cooled Reactors" (Ref. 15), describes models and assumptions for the estimation of atmospheric dispersion of gaseous effluent releases.		
194 • 195 • 196 • 197 • 198 • 199 • 200 •	RG 1.112, "Calculation of Releases of Radioactive Materials in Gaseous and Liquid Effluents from Light-Water-Cooled Power Reactors," (Ref. 16), provides acceptable methods for applicants to construct a nuclear power reactor to calculate realistic radioactive source terms for use in evaluating radioactive waste treatment systems to determine whether the design objectives of 10 CFR Part 50, Appendix I, are met, and to assess the environmental impact of radioactive effluents.		
201 • 202 203 204	RG 1.113, "Estimating Aquatic Dispersion of Effluents from Accidental and Routine Reactor Releases for the Purpose of Implementing Appendix I" (Ref. 17), describes general approaches for the analysis of releases of liquid effluents into surface water bodies.		
205 • 206 207 208	RG 1.184, "Decommissioning of Nuclear Power Reactors" (Ref. 18), provides guidance that during decommissioning, Technical Specifications require operational procedures for the control of effluent releases and submittal of annual effluent reports as specified by 10 CFR 50.36a.		
209 • 210 211 212	RG 1.185, "Standard Format and Content for Post-Shutdown Decommissioning Activities Report" (Ref. 19), identifies information licensees should provide to NRC and the public of the licensees expected decommissioning activities and schedule.		
213 • 214 215 216	RG 4.1, "Programs for Monitoring Radioactivity in the Environs of Nuclear Power Plants" (Ref. 20), describes acceptable programs for establishing and conducting an environmental monitoring program.		
217 • 218 219 220	RG 4.13, "Environmental Dosimetry—Performance Specifications, Testing, and Data Analysis" (Ref. 21), provides specifications for environmental dosimetry and methods of analyzing dosimetry to determine dose to members of the public.		
221 222 223 224 225 226	RG 4.15, "Quality Assurance for Radiological Monitoring Programs (Inception Through Normal Operations to License Termination)—Effluent Streams and the Environment" (Ref. 22), describes design and implementation programs to ensure the quality of the results of measurements of radioactive materials in the effluents from, and environment outside of, facilities that process, use, or store radioactive materials.		
227 • 228 229 230	RG 4.20, "Constraint on Releases of Airborne Radioactive Materials to the Environment for Licensees other than Power Reactors" (Ref. 23), provides guidance for meeting the constraint on airborne emissions of radioactive material as described in 10 CFR 20.1101(d).		
231 • 232 233 234	RG 4.25, "Assessment of Abnormal Radionuclide Discharges in Groundwater to the Unrestricted Area at Nuclear Power Plant Sites" (Ref. 24), describes an approach that is acceptable for use in assessing abnormal discharges of radionuclides in groundwater from the subsurface to the unrestricted area at nuclear power plant sites.		

235		
236	•	Generic Letter (GL) 89-01, "Guidance for the Implementation of Programmatic Controls for
237		Radiological Effluent Technical Specifications in the Administrative Controls Section of
238		Technical Specifications and the Relocation of Procedural Details to the Offsite Dose Calculation
239		Manual or Process Control Program " dated January 31, 1989 (Ref. 25), provides guidance for the
240		preparation of a license amendment request to relocate programmatic controls for radioactive
240		affluents and for radiological anvironmental monitoring from tachnical specifications to the
241		endents and for radiological environmental monitoring from technical specifications to the
242		licensee-controlled Offsite Dose Calculation Manual (ODCM) or equivalent document.
243		
244	•	NUREG-0133, "Preparation of Radiological Effluent Technical Specifications for Nuclear Power
245		Plants" issued October 1978 (Ref. 26), is one of the bases documents for the Radioactive Effluent
246		Controls Program in Standard Technical Specifications (section 5.5.4).
247		
248	•	NUREG-0016, Revision 1 and Revision 2, "Calculation of Releases of Radioactive Materials in
249		Gaseous and Liquid Effluents from Boiling-Water Reactors (GALE-BWR 3.2 Code)" issued
250		January 1979 and July 2020, respectively (Ref. 27) is a computerized mathematical model for
250		saleulating the release of redicactive materials in gaseous and liquid affluents from boiling water
251		calculating the release of radioactive materials in gaseous and inquid efficients from boining-water
252		reactors (Bwks).
253		
254	•	NUREG-0017, Revision 1 and Revision 2, "Calculation of Releases of Radioactive Materials in
255		Gaseous and Liquid Effluents from Pressurized-Water Reactors (GALE-PWR 3.2 Code)," issued
256		April 1985 and July 2020, respectively (Ref. 28), is a computerized mathematical model for
257		calculating the release of radioactive materials in gaseous and liquid effluents from
258		pressurized-water reactors (PWRs).
259		
260	•	NUREG-0543 "Methods for Demonstrating LWR Compliance with the EPA Uranium Fuel
261		Cycle Standard (CER Part 190) "1980 (Ref 29) explains the rationale for using Appendix I to
261		demonstrate compliance with 40 CEP 100 and methods for demonstrating compliance when
202		rediesetive offluents exceed Appendix Lynumerical guidenes
203		Tauloactive efficients exceed Appendix Thumerical guidance.
204		
265	•	NUREG-0/37, "Clarification of TMI Action Plan Requirements," issued November 1980
266		(Ref. 30), provides specific items that were approved by the NRC Commission following the
267		accident at Three Mile Island Nuclear Station (TMI) for implementation at reactors.
268		
269	•	NUREG-1301, "Offsite Dose Calculation Manual Guidance: Standard Radiological Effluent
270		Controls for Pressurized Water Reactors," issued April 1991 (Ref. 31), provides the PWR effluent
271		controls that may be removed from technical specifications and incorporated into the licensee's
272		ODCM (or equivalent).
273		
273		NUPEC 1302 "Offsite Dose Calculation Manual Guidance: Standard Padiological Effluent
274		NUKEO-1502, Offsite Dose Calculation Manual Outdance. Standard Radiological Efficient
213		Controls for Bonning water Reactors, issued April 1991 (Ref. 52), provides the BwR enfuent
276		controls that may be removed from technical specifications and incorporated into the licensee's
277		ODCM (or equivalent).
278		
279	٠	NUREG-1575, Rev. 1, "Multi-Agency Radiation Survey and Site Investigation Manual
280		(MARSSIM)" (Ref. 33), provides information on planning, conducting, evaluating, and
281		documenting building surface and surface soil final status radiological surveys for demonstrating
282		compliance with dose or risk-based regulations or standards.
283		r
200		

- 284 NUREG-1576, "Multi-Agency Radiological Laboratory Analytical Protocols Manual" (Ref. 34), • provides guidance for the planning, implementation, and assessment of projects that require the 285 286 laboratory analysis of radionuclides. 287 288 • NUREG-1757, Volume 2, Revision 1, "Consolidated Decommissioning Guidance: 289 Characterization, Survey, and Determination of Radiological Criteria" (Ref. 35), provides guidance on compliance with 10 CFR Part 20, Subpart E – "Radiological Criteria for License 290 291 Termination." 292 NUREG-1940, "RASCAL 4: Description of Models and Methods," issued December 2012 293 • 294 (Ref. 36), provides a description of an emergency response consequence assessment tool including models and methods for source term calculations, atmospheric dispersion and 295 296 deposition, and dose calculations. 297 298 NUREG-1940, Supplement 1, "RASCAL 4.3: Description of Models and Methods," issued • 299 May 2015 (Ref. 37), describes the Radiological Assessment System for Consequence Analysis 300 (RASCAL) models and methods for source term calculations, atmospheric dispersion and deposition, and dose calculations for accident analysis. 301 302 303 NUREG/CR-6948, "Integrated Ground-Water Monitoring Strategy for NRC-Licensed Facilities • 304 and Sites" issued November 2007 (Ref. 38), presents a framework for assessing what, where, 305 when, and how to monitor contamination in groundwater. 306 307 NUREG/CR-6805, "A Comprehensive Strategy of Hydrogeology Modeling and Uncertainty • 308 Analysis for Nuclear Facilities and Sites," issued July 2003 (Ref. 39), describes a strategy for a 309 systematic and comprehensive approach to hydrogeologic conceptualization, model development, and predictive uncertainty analysis. 310 311 312 **Purpose of Regulatory Guides** 313 314 The NRC issues RGs to describe methods that are acceptable to the staff for implementing 315 specific parts of the agency's regulations, to explain techniques that the staff uses in evaluating specific 316 issues or postulated events, and to describe information that the staff needs in its review of applications 317 for permits and licenses. RGs are not NRC regulations and compliance with them is not required. 318 Methods and solutions that differ from those set forth in RGs are acceptable if supported by a basis for the 319 issuance or continuance of a permit or license by the Commission. 320 321 **Paperwork Reduction Act** 322 323 This RG provides voluntary guidance for implementing the mandatory information collections in 10 CFR Parts 20, 50, 52, 72, that are subject to the Paperwork Reduction Act of 1995 (44 U.S.C. 3501 et. 324 325 seq.). These information collections were approved by the Office of Management and Budget (OMB), 326 approval numbers 3150-0014, 3150-0011, 3150-0151, and 3150-0132, respectively. Send comments 327 regarding this information collection to the FOIA, Library, and Information Collections Branch (T6-A10M), U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, or by e-mail to 328 329 Infocollects.Resource@nrc.gov, and to the OMB reviewer at: OMB Office of Information and
- 330 Regulatory Affairs (3150-0014, 3150-0011, 3150-0151, and 3150-0132), Attn: Desk Officer for the
- 331 Nuclear Regulatory Commission, 725 17th Street, NW Washington, DC20503; e- mail:
- 332 <u>oira_submission@omb.eop.gov</u>.
- 333

334 **Public Protection Notification**

335

The NRC may not conduct or sponsor, and a person is not required to respond to, a collection of information unless the document requesting or requiring the collection displays a currently valid OMB control number.

340		TABLE OF CONTENTS	
341 342	A INTR	PODICTION	1
343	B DISC	USSION	11
344	Reaso	n for Revision	11
345	Backo	round	11
346	Ohiect	tives of the Radiological Effluent Controls Program	12
347	C STAF	FEREGULATORY GUIDANCE	15
348	1.	Effluent Monitoring	.15
349	1.1	Effluent Monitoring Programs	.15
350	1.2	Release Points for Effluent Monitoring	.15
351	1.3	Monitoring a Significant Release Point	.16
352	1.4	Monitoring a Less-Significant Release Point	.16
353	1.5	Monitoring Leaks and Spills	.17
354	1.6	Monitoring Continuous Releases	.19
355	1.7	Monitoring Batch Releases	.20
356	1.8	Principal Radionuclides for Effluent Monitoring	. 20
357	1.9	Carbon-14	. 22
358	1.10	0 Return/Reuse of Previously Discharged Radioactive Effluents	
359	1.1	1 Abnormal Releases and Abnormal Discharges	.23
360	2.	Effluent Sampling	24
361	2.1	Representative Sampling.	
362	2.2	Sampling Liquid Radioactive Waste	
363	2.3	Sampling Gaseous Radioactive Waste	.25
364	2.4	Sampling Bias	.25
365	2.5	Composite Sampling	.26
366	2.6	Sample Preparation and Preservation.	.26
367	2.7	Short-Lived Radionuclides and Decay Corrections	.26
368	3.	Effluent Dispersion (Meteorology and Hydrology)	.26
369	3.1	Meteorological Data	.26
370	3.2	Atmospheric Dispersion (Transport and Diffusion)	.27
371	3.3	Release Height	.27
372	3.4	Aquatic Dispersion (Surface Waters)	.28
373	3.5	Spills and Leaks to the Ground Surface	.28
374	3.6	Spills and Leaks to Groundwater	. 28
375	4.	Quality Assurance	. 30
376	4.1	Quality Assurance Programs	. 30
377	4.2	Quality Control Checks	.31
378	4.3	Surveillance Frequencies	.31
379	4.4	Procedures	.31
380	4.5	Calibration of Laboratory Equipment and Routine Effluent Radiation Monitors	.31
381	4.6	Calibration of Measuring and Test Equipment	. 32
382	4.7	Calibration Frequency	.32
383	4.8	Measurement Uncertainty	. 32
384	4.9	Calibration of Accident-Range Radiation Monitors and Accident-Range Effluent Monitors	32
385	5.	Dose Assessments for Individual Members of the Public	.34
386	5.1	Bounding Assessments	.35
387	5.2	Individual Members of the Public	.36
388	5.3	Occupancy Factors	.36
389	5.4	10 CFR Part 50, Appendix I	.36

390	5.5	10 CFR 20.1301(a) through (c)	37
391	5.6	10 CFR 20.1301(e)	37
392	5.7	Dose Assessments for 10 CFR Part 50, Appendix I	38
393	5.8	Dose Assessments for 10 CFR 20.1301(e)	39
394	5.9	Dose Calculations	40
395	6. S	Solid Radioactive Waste Released from the Unit	40
396 ^{′′}	7. F	Reporting Errata in Effluent Release Reports	41
397	7.1	Examples of Small Errors	41
398	7.2	Reporting Small Errors	41
399	7.3	Examples of Large Errors	41
400	7.4	Reporting Large Errors	42
401	8. C	Changes to Effluent and Environmental Programs	43
402	9. For	mat and Content of the Annual Radioactive Effluent Release Report	43
403	9.1	Gaseous Effluents	44
404	9.2	Liquid Effluents	46
405	9.3	Solid Waste Shipments Released from the Unit (per Standard Technical Specifications)	47
406	9.4	Dose Assessments	48
407	9.5	Supplemental Information	48
408 D.	IMPLE	MENTATION	52
409 GL	OSSAR	Υ	53
410 RE	FEREN	CES	62
411 BI	BLIOGF	RAPHY	69
412 AP	PENDE	X A—TABLES	1
413 414			

415	B. DISCUSSION		
416	Dessen for Derivier		
417	Reason for Revision		
418	This revision of RG 1 21 (Revision 3):		
420	 Provides guidance and accentable methods for calibration of accident range radiation monitors 		
420	and accident range effluent monitors		
421	 Revises guidance on recommendations for reviewing and undating long-term annual average q/O 		
422	and D/O values		
423	 Clarifies reporting requirements for low level radioactive wests (LLW) shipmonts, specifically. 		
424	• Claimes reporting requirements for low rever radioactive waste (LLW) simplicity, specification		
425	does not need to be reported when shipped from the unit (plant site), and that waste classification		
420	Clarifies the existing guidenee in NUIDEG 1201 and NUIDEG 1202 that environmental monitoring		
427	• Claimes the existing guidance in NOREO 1501 and NOREO 1502 that environmental monitoring for joding (J) 121 in drinking water should be performed if a prospective dose evaluation of the		
420	annual there is a person in any age group from the drinking water route of		
420	annual triviolit dose from 1-151 to a person in any age group from the drinking water foure of		
430	 Clarifies the existing process as currently described in Technical Specifications for making 		
431	• Claimes the existing process as currently described in reclinical specifications for making changes to effluent and environmental programs, and		
432	 Incorporates the existing Degulatory Issue Summary 2008 03 "Deturn/Deuse of Previously 		
433	 Incorporates the existing Regulatory issue Summary 2008-05, Return/Reuse of Freviously Discharged Padioactive Effluents" (Ref. 40). 		
434	Discharged Radioactive Efficients (Ref. 40).		
435			
436	Background		
437			
438	In addition to this RG, five additional basic documents contain the primary regulatory guidance		
439	for implementing the 10 CFR Part 20 and 10 CFR Part 50 regulatory requirements and plant technical		
440	media, solid radioactive waste shipments, and the public dose that results from licensed operation of a		
442	nuclear power plant.		
443			
444	(1) RG 4.1		
445	(2) RG 4.15		
446	(3) RG 1.109		
447	(4) NUREG-1301		
448	(5) NUREG-1302		
449			
450	These documents, when used in an integrated manner, provide the basic guidance and		
451	at pupleer power plants. The four PCs (PC 1 21, PC 4 1, PC 4 15, and PC 1 100) specify the guidence		
452	for radiological monitoring and the assessment of dose and the two NUREGs (NUREG-1301 and		
454	NUREG-1302) provide specific implementation details for effluent and environmental monitoring		
455	programs		
456			
457	RG 1.21 addresses the measuring, evaluating, and reporting of effluent releases, solid radioactive		
458	waste shipments, and public dose from nuclear power plants. The guide describes the important concepts		
459	in planning and implementing an effluent and solid radioactive waste program. Concepts covered include		
460	meteorology, release points, monitoring methods, identification of principal radionuclides, unrestricted		

- area boundaries, continuous and batch release methods, representative sampling, composite sampling, radioactivity measurements, decay corrections, quality assurance (QA), solid radioactive waste shipments, 461
- 462

- and public dose assessments. The dose to occupational workers, including contributions from activities
 associated with effluent programs (such as LLW processing, storage, and shipping, as well as dose from
 handling resins and filters for gaseous and liquid radioactive waste), is occupational dose associated with
 the licensed operation and is not included in RG 1.21.
- 468 RG 4.1 addresses the environmental monitoring program. The guide discusses principles and 469 concepts important to environmental monitoring at nuclear power plants. The RG provides guidance on 470 both the preoperational and operational Radiological Environmental Monitoring Programs for the 471 routinely monitored exposure pathways (inhalation, ingestion, and direct radiation). The guide defines 472 the sampling media and sampling frequency, and the methods of comparing environmental measurements 473 to effluent releases in the Annual Radiological Environmental Operating Report (AREOR).
- RG 4.15 provides the basic principles of QA in all types of radiological monitoring programs for
 effluent streams and the environment. The guide provides principles for structuring organizational lines
 of communication and responsibility, using qualified personnel, implementing standard operating
 procedures, defining data quality objectives (DQOs), performing quality control (QC) checking for
 sampling and analysis, auditing the process, and taking corrective actions.
- RG 1.109 provides the detailed implementation guidance for demonstrating that radioactive
 effluents conform to ALARA design objectives of 10 CFR Part 50, Appendix I. The RG describes
 calculational models and parameters for estimating dose from effluent releases, including the dispersion
 of the effluent in the atmosphere and surface water bodies.
- NUREG-1301 and NUREG-1302 provide the detailed implementation guidance by describing
 effluent and environmental monitoring programs. These NUREGs provide guidance on meeting effluent
 monitoring and environmental sampling requirements, surveillance requirements for effluent monitors,
 types of monitors and samplers, sampling and analysis frequencies, types of analysis and radionuclides
 analyzed, lower limits of detection (LLDs), specific environmental media to be sampled, and reporting
 and program evaluation and revision.
- 493 **Objectives of the Radiological Effluent Controls Program**

474

507

494 495 The requirements for the radiological effluent control program are in 10 CFR Part 20 and the 496 technical specifications that are part of a license, including limitations on dose conforming to 497 10 CFR Part 50, Appendix I. In addition, a facility's technical specifications describe specific regulatory 498 requirements. Licensees can use these regulatory requirements and the RG 1.21 regulatory guidance as a basis for establishing the radiological effluent control program. The radiological effluent control program 499 500 for a nuclear power plant has the following six basic objectives, which are also reflected in 501 10 CFR 50.36a and in site-specific Technical Specifications: 502

- 503 (1) Ensure that effluent instrumentation has the functional capability to measure and analyze effluent discharges.
 505
- 506 (2) Ensure that effluent treatment systems are used to reduce effluent discharges to ALARA levels.
- 508 (3) Establish instantaneous release-rate limitations on the concentrations of radioactive material.
- 509
 510 (4) Limit the annual and quarterly doses or dose commitment to members of the public in liquid and gaseous effluents to unrestricted areas.
 512
- 513 (5) Measure, evaluate, and report the quantities of radioactivity in gaseous effluents, liquid effluents,

514 515		and solid radioactive waste shipments.
516 517	(6)	Evaluate the dose to members of the public.
518 519 520 521 522 523	Radioad (unless reports control	As required by technical specifications, Part 50 and Part 52 licensees must submit the Annual ctive Effluent Release Report (ARERR) before May 1 and the AREOR by May 15 of each year a licensing basis exists for a different submittal date for one or both reports). Licensees use these to demonstrate compliance with the facility's technical specifications for the radioactive effluent program. The reports demonstrate the following:
524 525 526	•	effectiveness of effluent controls and measurement of the environmental impact of radioactive materials
527 528 529	•	compliance with the design objectives and limiting conditions for operation required to meet the ALARA criteria in 10 CFR Part 50, Appendix I
530 531 532	•	relationship between quantities of radioactive material discharged in effluents and resultant radiation dose to individuals
533 534 535	•	compliance with the radiation dose limits to members of the public established by the NRC and the U.S. Environmental Protection Agency (EPA)
536 537	•	compliance with the effluent reporting requirements of 10 CFR 50.36a ¹
538 539	Consid	eration of International Standards ²
540 541 542 543 544 545 546 547 548 549 550 551 552 553 554	promot Require ionizing reflect a Regular relevan Interna The fol develop	The International Atomic Energy Agency (IAEA) works with member states and other partners to e the safe, secure, and peaceful use of nuclear technologies. The IAEA develops Safety ements and Safety Guides for protecting people and the environment from harmful effects of g radiation. These requirements and guides provide a system of Safety Standards Categories that an international perspective on what constitutes a high level of safety. In developing or updating tory Guides the NRC has considered IAEA Safety Requirements, Safety Guides ¹ and other t reports in order to benefit from the international perspectives, pursuant to the Commission's tional Policy Statement (Ref. 41) and NRC Management Directive and Handbook 6.6 (Ref. 42). lowing IAEA Safety Standards Series are consistent with the basic safety principles considered in bing this Regulatory Guide: IAEA General Safety Guide (GSG)-8, "Radiation Protection of the Public and the Environment," issued 2018 (Ref. 43)

¹ See Section C.9 of this regulatory guide for information regarding use of the ARERR or its format to also meet ISFSI effluent reporting requirements in 10 CFR 72.44(d) for specific licenses or imposed by certificate of compliance conditions for general licenses.

² IAEA Safety Requirements and Guides may be found at <u>https://www.iaea.org/</u> or by writing the International Atomic Energy Agency, P.O. Box 100 Wagramer Strasse 5, A-1400 Vienna, Austria; telephone (+431) 2600-0; fax (+431) 2600-7; or e-mail <u>Official.Mail@IAEA.Org.</u> It should be noted that some of the international recommendations do not correspond to the NRC requirements which take precedence over the international guidance.

555 556 557	•	IAEA Specific Safety Guide NS-G-3.2, "Dispersion of Radioactive Material in Air and Water and Consideration of Population Distribution in Site Evaluation for Nuclear Power Plants," issued 2002 (Ref. 44)
559 560 561	•	IAEA GSG-9, "Regulatory Control of Radioactive Discharges to the Environment," issued 2018 (Ref. 45)
562 563 564	•	IAEA GSG RS-G-1.8, "Environmental and Source Monitoring for Purposes of Radiation Protection," issued 2005 (Ref. 46)
565 566 567	•	IAEA Nuclear Energy Series NP-T-3.16, "Accident Monitoring Systems for Nuclear Power Plants," issued 2015 (Ref. 47)
568 569 570	•	IAEA-TECDOC-482, "Prevention and Mitigation of Groundwater Contamination from Radioactive Releases," Vienna, Austria, issued 1988 (Ref. 48)
571 572 573	•	IAEA Safety Guide No. WS-G-3.1, "Remediation Process for Areas Affected by Past Activities and Accidents," Vienna, Austria, issued 2007 (Ref. 49)
574 575 576	•	IAEA, "Management of Waste Containing Tritium and Carbon-14," Technical Report Series Number 421, Vienna, Austria, issued 2004 (Ref. 50)

577		C. STAFF REGULATORY GU	IDANCE	
578				
579	1.	Effluent Monitoring		
580				
581	1.1	Effluent Monitoring Programs		
582				
583		Monitoring programs shall be established to identify and qua	antify principal radionuclides in	
584	efflue	tts in accordance with 10 CFR 50.36a. NUREG-1301 (for PW	(Rs) and NUREG-1302 (for BWRs)	
585	provie	e guidance on acceptable methods of generic controls and surv	veillance requirements, including	
586	freque	ncy, duration, and methods of measurement. These NUREGs	provide acceptable LLDs, guidance	
587	on ba	ch releases and continuous releases, sampling frequencies, and	lysis frequencies and timelines, and	
588	comp	site sample guidance. Site-specific radiological effluent contr	ol programs that differ from the	
589	gener	c NUREG-1301 and NUREG-1302 guidance should be based	on a documented evaluation or	
590	justifi	ation for such deviations as part of an ODCM authorized char	nge, or, if submitted and approved as	
591	part o	the original ODCM, in accordance with GL 89-01.		
592	1			
593	1.2	Release Points for Effluent Monitoring		
594		e e e e e e e e e e e e e e e e e e e		
595		The ODCM (or equivalent), as required by technical specific	cations, should identify the facility's	
596	signif	cant release points (see definition in the glossary) used to quar	ntify liquid and gaseous effluents	
597	discharged to the unrestricted area. For those release points containing contributions from two or more			
598	inputs	inputs (or systems), it is preferable to monitor each major input (or system) individually to avoid dilution		
599	effect	effects, which may impede or prevent radionuclide identification NUREG-1301 and NUREG-1302		
600	conta	detailed guidance for the content and format of a licensee's (DDCM. For purposes of effluent and	
601	direct	radiation monitoring, the ODCM should list and describe the f	following:	
602			oo. ()	
603	1	significant release points (see definition in Section 1.3 and it	n the glossary) which include stacks	
604	1.	vents and liquid radioactive waste discharge points among	others.	
605		vonis, and require radioactive waste discharge points, among	official,	
606	2	less-significant release points (see definition in Section 1.4 a	nd in the glossary) that are not	
607	2.	normally classified as one of the significant release points by	it could become a significant release	
608		point based on expected operational occurrences (e.g. prima	ry to secondary leakage for PWRs or	
609		failed fuel) ³ .	ity to secondary leakage for 1 wiks of	
610		funder fuely,		
611	3	the site environs man, which should show each of the follow	ing:	
612	5.	the site environs map, which should show each of the follow	ing.	
612		significant urbana points		
613		a. significant release points,		
014		h have device of the restricted area and the second state	mod (in accordance with	
010		D. Downdaries of the restricted area and the controlled a 10 CED Dect 20 definitions)	trea (in accordance with	
010		10 CFK Part 20 definitions),		
617				

³ This list does not need to be exhaustive or all-inclusive but should demonstrate that the licensee has reasonably anticipated expected operational occurrences and their effects on radioactive discharges. Examples may include main steam line safety valves, steam-driven feedwater pumps, turbine building sumps, containment ice condensers, leachate seepage from unlined ponds, or evaporative releases from ponds in the restricted or controlled areas.

⁴ For ODCMs that also address Part 72 monitoring requirements, the boundaries of the Part 72 controlled area, as defined in 10 CFR 72.3 and meeting the minimum size requirements of 72.106 should be also be shown.

- boundary of the unrestricted area⁵ for liquid effluents (e.g., at the end of the pipe or 618 c. 619 entrance to a public waterway), and 620 621 d. boundary of the unrestricted area for gaseous effluents (e.g., the site boundary). 622 623 4. dose calculation methodologies for exposure pathways and routes of exposure that are identified 624 in RG 1.109, if applicable; and 625 5. dose calculation methodologies for direct radiation if necessary (e.g., when assessing direct 626 627 radiation from the facility)⁶. 628 629 1.3 Monitoring a Significant Release Point 630 A significant release point is any location from which radioactive material is released that 631 632 contributes greater than 1 percent of the activity discharged from all the release points for a particular 633 type of effluent considered. RG 1.109 lists the three types of effluent as (1) liquid effluents, (2) noble gases released to the atmosphere, and (3) all other radionuclides discharged to the atmosphere. 634 635 636 The ODCM should list significant release points. Significant release points should be monitored in accordance with the ODCM. If a new significant release point is identified and is not listed in the 637 638 ODCM, licensees should (1) establish an appropriate sampling interval (e.g., in site-specific procedures) and (2) update the ODCM within a reasonable timeframe (e.g., annually). Releases from a significant 639 640 release point should be assessed based on an appropriate combination of actual sample analysis results, 641 radiation monitor responses, flow rate indications, tank level indications, and system pressure indications as necessary to ensure that the amount of radioactive material released, and the corresponding doses, are 642 643 not substantially underestimated (see 10 CFR Part 50, Appendix I, Section III, "Implementation"). If 644 activity is detected when monitoring a significant release point, the radionuclides detected should be reported in the effluent totals (including those with half-lives less than 8 days) in the ARERR (i.e., in 645 Table A-1 or Table A-2), provided that the amount discharged is significant to the three-digit exponential 646 647 format required for the ARERR. 648
- 649 650

1.4

Monitoring a Less-Significant Release Point

NUREG-1301 and NUREG-1302 provide tables designating sampling and analysis frequencies 651 652 for release points. Historically, these tables, together with the guidance from RG 1.21, Revision 1, issued June 1974 (Ref. 51) or RG 1.21, Revision 2, issued June 2009 (Ref. 52) provide sampling and analysis 653 654 frequencies. Licensees may continue to use the guidance from NUREG-1301 or NUREG-1302 and/or Revision 1 or Revision 2 of RG 1.21 in accordance with their ODCMs. This method of assigning sample 655 656 frequencies is simple to implement but, in certain cases, may entail an inappropriately large number of 657 samples for less-significant release points with no-or extremely low-impact on the parameters reported in the ARERR. As a result, for less-significant release points, licensees may evaluate and assign more 658 659 appropriate sampling frequencies. If a licensee wishes to deviate from the NUREG-1301 and NUREG-660 1302 sampling frequencies, the licensee's evaluation must show that the changes (i.e., deviations from NUREG-1301 and NUREG-1302) maintain the levels of radioactive effluent control as stated in the 661 662 technical specifications required by 10 CFR 20.1302; 40 CFR Part 190; 10 CFR 50.36a; and

⁵ The boundaries of the unrestricted areas may be defined separately for liquid effluents, gaseous effluents, and if appropriate, for other radiological controls such as direct radiation.

⁶ The methodology should include background subtraction, and if appropriate, extrapolation of radiation measurements to points of interest (e.g., to the individual members of the public likely to receive the highest dose).

663 10 CFR Part 50, Appendix I, and do not adversely impact the accuracy or reliability of effluent, dose, or setpoint calculations, and should be maintained in site documentation. Regardless of the surveillance 664 frequencies, if activity is detected when monitoring a less-significant release point, the licensee must (in 665 666 accordance with 10 CFR 50.36a and 10 CFR Part 50, Appendix I, Section III.A.1) report the cumulative activity in the effluent totals (i.e., in Table A-1 or Table A-2) in the ARERR (provided that the amount 667 discharged is significant to the three-digit exponential format required for the ARERR). 668

669

670 Site documentation should identify less-significant release points, to the extent reasonable, but it 671 is not necessary to list all possible release points in site documentation. Releases from a less-significant release point may be assessed (see Section 5.1) to the extent reasonable using assumptions and bounding 672 calculations (in lieu of, or in addition to, sampling and analysis). When plant conditions change and such 673 674 changes may reasonably affect the status of a less-significant release point (e.g., significant change in 675 primary-to-secondary leakage in PWRs or substantial cross contamination between systems), the licensee should sample and analyze the affected less-significant release points. These sample results should be 676 evaluated to (1) confirm the continued validity of the bounding calculations (if used) with regard to 677 678 effluent accountability and (2) determine the impact (if any) on effluent accountability. The guidance in 679 this RG on monitoring less-significant release points for purposes of accountability (through the ARERR) 680 does not replace, supersede, or otherwise modify any responsibility for monitoring systems normally not contaminated, as outlined in NRC Inspection and Enforcement Bulletin 80-10, "Contamination of 681 682 Nonradioactive System and Resulting Potential for Unmonitored, Uncontrolled Release of Radioactivity 683 to Environment," issued May 1980 (Ref. 53). A thoroughly designed and documented evaluation of a less-significant release point could also assist in the evaluation and characterization of abnormal releases 684 685 and abnormal discharges (see Section 1.11 below).

686 687

1.5 Monitoring Leaks and Spills

688

689 An area where an unplanned release occurred in the onsite environs (e.g., a leak or spill) should 690 be identified as an "impacted area," as defined in 10 CFR 50.2, "Definitions," for decommissioning purposes, and in accordance with NUREG-1757. A leak or spill should be assessed to obtain the 691

necessary information for the ARERR, as specified in Section 8.5.1 of this RG (see glossary). 692 693

694 Leaks or spills to the ground and/or subsurface will be diluted on contact with soil and water in the environment; therefore, samples of the undiluted liquid (from the source of the leak or spill) and 695 samples of the affected soil (or surface water or subsurface groundwater) should be analyzed as soon as 696 practical. In some instances, sampling, particularly soil sampling, may not be practical if the leak 697 698 occurred in inaccessible areas or if there are extenuating considerations. In this respect, groundwater 699 monitoring may be used as a surrogate for soil sampling. If sampling is not practical, the 700 10 CFR 50.75(g) records should describe why sampling was not conducted (e.g., the area was 701 inaccessible or there were safety considerations). The licensee should ensure that the location and 702 estimated volume of the leak or spill are recorded to identify the extent of the impacted area and predicted 703 size or extent of the contaminant plume, both horizontally and vertically. If a spill is promptly and fully 704 remediated (e.g., within 48 hours) and if subsequent surveys of the remediated area indicate no detectable 705 residual radioactivity remaining in the soil or groundwater (see paragraph below), for purposes of 706 reporting discharges in the ARERR, there was no liquid discharge to the unrestricted area, and the spill 707 need not be reported in the ARERR. However, in accordance with 10 CFR 50.75(g), the 708 decommissioning file should be updated to include a description of the leak or spill event. Licensees 709 should review the decommissioning files before generating the ARERR to ensure that the ARERR 710 includes the necessary information on leaks and spills. 711

712 When evaluating areas that have been remediated, the licensee should survey for residual 713 radioactivity. There may be times when the licensee wants to verify that an area contains no residual

- radioactivity. There is existing regulatory guidance and information on analytical detection capabilities.
- Licensees should ensure that surveys are appropriate and reasonable, in accordance with 10 CFR 20.1501.
- T16 Licensees should generally ensure that surveys are conducted using the appropriate sensitivity
- 177 levels; e.g., refer to the environmental LLDs in NUREG-1301 and NUREG-1302, Table 4.12-1,
- ⁷¹⁸ "Detection Capabilities for Environmental Sample Analysis," or LLDs determined by using the
- methodology outlined in NUREG-1576. Additionally, licensees should apply plant-process-system
- knowledge when evaluating leaks and spills.

This RG provides guidance on information that licensees should provide in the ARERR. In that context, when leaks and spills of radioactive material are identified, prompt response and timely actions should be taken to the extent reasonable to (1) evaluate onsite radiological conditions and (2) ensure proper reporting of materials discharged off site. To realize these two goals, it may be necessary to isolate the leak or spill at the source, prevent the spread of the leak or spill, and remediate the affected area (if the licensee deems remediation to be reasonable and necessary).

For leaks and spills involving the discharge of radioactive material to an unrestricted area, licensees should follow RG 4.25 or equivalent methods to assess the amount of material discharged to the unrestricted area. The potential dose to members of the public from the leak or spill should be evaluated using realistic or bounding exposure scenarios. Attachment 6 to SECY-03-0069, "Results of the License Termination Rule Analysis," dated May 23, 2003 (Ref. 54), provides more information on the use of realistic scenarios.

736 For leaks and spills, licensees should perform surveys that are reasonable to evaluate the potential 737 radiological hazard (as described in 10 CFR 20.1501). As a result, for leaks and spills, licensees may choose to use bounding assessments to estimate the potential hazard. For example, if a leak occurs on site 738 739 and radioactive material is released at or below the ground surface, the licensee may choose to assess the 740 potential hazard by estimating a conservatively large (e.g., bounding) volume of water as part of an 741 assumed exposure pathway analysis (e.g., drinking water). Such assumptions would allow the licensee to 742 assess the potential hazard to a hypothetical individual member of the public. A hazard assessment of this 743 sort would be appropriate for inclusion in the supplemental information section of the ARERR. If there is 744 no real exposure pathway to a member of the public, the licensee should indicate that the hazard 745 assessment is a bounding estimate of the dose to a hypothetical individual member of the public, and no real individual member of the public received an actual exposure. 746 747

- 748 If licensees choose to notify local authorities of spills or leaks (e.g., because of local ordinances 749 or local and State government agreements), the licensee should review the reporting requirements of 10 CFR 50.72(b)(xi) and information in NUREG-1022, "Event Reporting Guidelines: 10 CFR 50.72 and 750 751 50.73," issued October 2000 (Ref. 55), for applicability. In such situations, licensees should ensure 752 effective communication, using NUREG/BR-0308, "Effective Risk Communication," issued June 2004 753 (Ref. 56), especially when ensuring that the risk is described in the appropriate context. In general, licensees should notify the NRC when significant public concern is raised, in accordance with 754 755 10 CFR 50.72(b)(xi). 756
- Although the licensee may choose to use its problem identification and resolution program
 (corrective action program) to document the evaluation of the spill or leak, appropriate documentation
 should be placed in, or cross referenced to, the decommissioning files, as required by 10 CFR 50.75(g).
- Although prompt remediation is not a requirement (Ref. 57), remediation should be evaluated and implemented, as appropriate, based on licensee evaluations and risk-informed decisionmaking. The Electric Power Research Institute (EPRI) Report 1021104 "Groundwater and Soil Remediation Guidelines for Nuclear Power Plants," proprietary report issued December 2010 (Ref. 58) and EPRI

765 Report 1023464, "Groundwater and Soil Remediation Guidelines for Nuclear Power Plants," (Public Edition) Final Report, July 2011 (Ref. 59) may be useful in performing remediation evaluations. 766 767 768 Evaluation factors should include (1) the location and accessibility, (2) the concentrations of 769 radionuclides and extent of the residual radioactivity, (3) the efficacy of monitored natural attenuation, 770 (4) the volume of the release, (5) the mobility of the radionuclides, (6) the depth of the water table, and 771 (7) whether "significant residual radioactivity" (see glossary) is expected at the time of 772 decommissioning. Since the contaminants, concentrations, and extent of contamination are expected to 773 vary over time or plant life (either increase based on anticipated future leaks and spills or decrease based 774 on remediation or monitored natural attenuation), no one set of numerical values defines significant 775 residual radioactivity. However, licensees may make remediation decisions based on their expectations 776 of their ability to meet the decommissioning criteria of 10 CFR 20.1402 at the anticipated time of 777 decommissioning. 778 779 Information that may be useful in this risk-informed decision making includes (1) NUREG-1757, 780 Volume 1, Appendix H, "EPA/NRC Memorandum of Understanding," (2) NUREG-1757, Volume 2, Table H.1, "Acceptable License Termination Screening Values of Common Radionuclides for 781 782 Building-Surface Contamination," and (3) the authorized derived concentration guideline levels for 783 decommissioned nuclear power plants. For a more detailed analysis, licensees may use the computer 784 codes described in NUREG/CR-6676, "Probabilistic Dose Analysis Parameter Distributions Developed for RESRAD and RESRAD-BUILD Codes," issued July 2000 (Ref. 60); NUREG/CR-6692, 785 "Probabilistic Modules for the RESRAD and RESRAD-BUILD Computer Codes," issued November 786 787 2000 (Ref. 61); NUREG/CR-6697, "Development of Probabilistic RESRAD 6.0 and RESRAD-BUILD 3.0 Computer Codes," issued December 2000 (Ref. 62); and NUREG/CR-7267, Default Parameter 788 Values and Distributions in RESRAD-ONSITE V7.2, RESRAD-BUILD V3.5 and RESRAD-OFFSITE 789 790 4.0 (Ref. 63). 791 792 1.6 Monitoring Continuous Releases 793 794 For continuous releases, gross radioactivity measurements are often the only practical means of 795 continuous monitoring. These gross radioactivity measurements are typically used to actuate alarms and 796 terminate (trip) effluent releases; by themselves, such measurements are generally not acceptable for 797 demonstrating compliance with effluent discharge limits. 798 799 The use of continuously indicating radiation monitoring system results may be combined with 800 sample analyses to more fully characterize and quantify a discharge. This technique may have particular 801 applicability when (1) a short-term, rapid upscale indication of a process radiation monitor occurs during 802 a release or (2) when there is a desire to verify whether a preliminary grab sample is representative. In 803 these instances, the licensee should ensure that the radiation monitor responses (i.e., the radiation monitor 804 efficiencies) for various radionuclides are well characterized. 805 806 Grab samples should be collected at scheduled frequencies in accordance with the ODCM (see 807 NUREG-1301 and NUREG-1302 or as approved in GL 89-01 submittals) to quantify specific radionuclide concentrations and release rates. The frequency of sample collection and radionuclide 808 809 analyses should be based on the degree of variance in (1) the magnitude of the discharge and (2) the 810 relative radionuclide composition from an established norm. If the magnitude of the discharge and the 811 relative nuclide composition of a continuous release vary significantly over the course of the discharge 812 period, a combination of grab samples and continuous monitor readings can assist in accurately 813 estimating the discharge. Continuous monitoring data (e.g., chart recorder data), as well as grab sample 814 data, should be reviewed periodically and used to identify this variance from the established norm.

815 Periodic evaluations should be made between gross radioactivity measurements and grab sample analyses

816 of specific radionuclides. These evaluations should be used to verify (or modify) the conversion factors 817 that correlate radiation monitor readings and concentrations of radionuclides in effluents. 818 819 NUREG-1301 and NUREG-1302 provide guidance on the Radiological Environmental 820 Monitoring Program. Table 3.12-1 therein provides guidance on implementing the environmental 821 monitoring program, including an I-131 sampling and analysis on each composite of drinking water. 822 823 If a drinking water exposure pathway exists, a prospective dose evaluation should be performed 824 based on I-131 in effluent discharges to determine the maximum likely annual I-131 thyroid dose to a 825 person in any age group. The purpose of the prospective dose evaluation is to determine the 826 environmental sampling and analysis requirements. Note: Freshwater fish ingestion is not included in 827 the prospective dose evaluation of I-131 from the drinking water route of exposure. 828 829 If the likely dose from I-131 is greater than 1 mrem per year, a composite drinking water sample 830 should be collected over a 2-week period and an I-131 analysis performed with an LLD of 1 pCi/liter. If 831 the likely dose from I-131 is less than or equal to 1 mrem per year, a monthly composite sample should be collected and an I-131 analysis performed with an LLD of 15 pCi/liter. 832 833 834 In addition, Standard Technical Specifications require determination of the projected dose 835 contributions from radioactive effluents at least every 31 days, and determination of the cumulative dose 836 contributions for the current calendar quarter and current calendar year. 837 838 1.7 Monitoring Batch Releases 839 For batch releases, measurements should be performed to identify principal radionuclides before 840 a release. If an analysis of specific "hard-to-detect" radionuclides (such as strontium-89/90, Ni-63 and 841 842 iron-55 in liquid releases) cannot be done before the batch release (see NUREG-1301 and NUREG-1302), 843 the licensee should have collected representative samples for the purpose of subsequent composite 844 analysis. The composite samples should be analyzed at the scheduled frequencies specified in NUREG-1301 and NUREG-1302 or at the revised frequencies specified by the licensee (with 845 846 documented justification in accordance with ODCM change process specified in the technical 847 specifications) (see Sections 1.3 and 1.4 of this RG). 848 849 Continuously indicating radiation monitoring system results may be combined with sample analyses to more fully characterize and quantify a discharge. This technique may have particular 850 851 applicability when (1) a short-term, rapid upscale indication of a process radiation monitor occurs during 852 a discharge or (2) when there is a desire to verify whether a preliminary grab sample is representative. In 853 these instances, the licensee should ensure that radiation monitor responses (i.e., the radiation monitor 854 efficiencies) for various radionuclides are well characterized. 855 856 1.8 Principal Radionuclides for Effluent Monitoring 857 This RG introduces the term "principal radionuclide" in a risk informed context. A licensee may 858 evaluate the list of principal radionuclides for use at a particular site. The principal radionuclides maybe 859 determined based on their relative contribution to either (1) the public dose compared to the 860 10 CFR Part 50, Appendix I, design objective doses, or (2) the amount of activity discharged compared to 861 862 other site radionuclides in the type of effluent being considered. Under this concept, radionuclides that 863 have either a significant activity or a significant dose contribution should be monitored in accordance with a predetermined and appropriate analytical sensitivity level (LLD) outlined in a licensee's ODCM. 864 865 This implementation of "principal radionuclides" ensures that the ARERR appropriately includes both the (1) radionuclides that are present in relatively large amounts but that contribute very little to dose and 866

867 (2) radionuclides that are present in very small amounts but that have a relatively high contribution to868 dose.

870 If a risk-informed approach is used, principal radionuclides should be determined based on an
871 evaluation over a time period that includes a refueling outage (e.g., one fuel cycle). A periodic
872 reevaluation should be performed to determine whether the radionuclide mix has changed and to identify
873 new principal radionuclides.

874

869

875 If a risk-informed approach is applied to the determination of principal radionuclides,⁷ the ODCM 876 becomes the controlling document and specifies the list of principal radionuclides. If adopting this 877 method, the licensee should update the ODCM with the list of principal radionuclides within 1 year of 878 their identification. Licensees are allowed to revise the ODCM in accordance with the ODCM change 879 process, as described in the plant's technical specifications (which includes documented evaluations of 880 such changes).

882 If adopting a risk-informed approach, a radionuclide is considered a principal radionuclide if it 883 contributes either (1) greater than 1 percent of the 10 CFR Part 50, Appendix I, design objective dose for 884 all radionuclides in the type of effluent being considered or (2) greater than 1 percent of the activity of all 885 radionuclides in the type of effluent being considered. RG 1.109 lists the three types of effluent as (1) liquid effluents, (2) noble gases released to the atmosphere, and (3) all other radionuclides released to 886 the atmosphere. In this context, the term "principal radionuclide" has special significance for the required 887 sensitivity levels (e.g., LLDs) for an analysis. The LLDs specified in NUREG-1301 and NUREG-1302 888 889 may be used, or LLDs may be determined based on the other methodologies (e.g., as outlined in 890 NUREG-1576). Once principal radionuclides are identified, they should be monitored in accordance with 891 the sensitivity levels (e.g., LLDs) listed in the ODCM.

892

893 During analysis of samples, licensees should apply the appropriate analytical sensitivities to 894 ensure adequate surveys are conducted. NUREG-1301 and NUREG-1302 provide a list of "principal 895 gamma emitters" for operating reactors for which an LLD control applies. Historically, this list and guidance from Revision 1 or Revision 2 provided the appropriate sensitivity levels for an analysis. 896 897 Licensees may continue to use this historical guidance, which essentially classifies all radionuclides as 898 principal radionuclides, and apply the analytical sensitivity levels (e.g., LLDs) directly from 899 NUREG-1301 and NUREG-1302 and Revision 1 or 2 of RG 1.21. This method is simple to implement 900 but, in certain cases, may entail inappropriately long count times or may involve alternate (or 901 unnecessary) methods of analysis for low-activity radionuclides with no-or extremely low-dose 902 significance. 903

904 Although the LLD list from NUREG-1301 and NUREG-1302 may be used to determine principal 905 radionuclides, in reality, the principal radionuclides at a site will depend on site-specific factors, such as 906 (1) the operating status of the facility (e.g., operating or in decommissioning), (2) the amount of failed fuel, (3) the extent of system leakage, (4) the sophistication of radioactive waste processing equipment, 907 908 and (5) the level of expertise in operating radioactive waste processing systems. Since the principal 909 radionuclides will vary from site to site, licensees that wish to deviate from the historical method of determining principal radionuclides (as described above) may adopt a risk-informed approach to identify 910 911 principal radionuclides (and the associated sensitivity levels) at a site.

912

For radionuclides that are not identified as principal radionuclides, licensees may use their discretion with the sensitivity of analysis, provided the licensees determine that the changes maintain the

⁷ With respect to principal radionuclides, "dose" is the measure of risk, whereas "activity" is not. For example, a relatively large amount of tritium released into a large body of water has little dose significance.

levels of radioactive effluent controls required by the regulations in 10 CFR 20.1302; 40 CFR Part 190;
10 CFR 50.36a; and 10 CFR Part 50, Appendix I, and do not adversely impact the accuracy or reliability
of effluent, dose, or setpoint calculations. If licensees change their analytical sensitivities from those in
their ODCM or equivalent, they must document the basis for the deviations. For example, DQOs and
other concepts from RG 4.15 may be useful for determining risk-informed sensitivity levels for an
analytical method.

The risk-informed concept of "principal radionuclides" does not reduce the requirement for reporting radionuclides detected in effluents. In addition to principal radionuclides, other radionuclides detected during routine monitoring of release points should be reported in the radioactive effluent release report and included in dose assessments to members of the public, consistent with site-specific technical specifications.

928 1.9 Carbon-14

927

Carbon (C)-14 is a naturally occurring isotope of carbon. Nuclear weapons testing in the 1950s
and 1960s significantly increased the amount of C-14 in the atmosphere. Commercial nuclear reactors
also produce C-14 but in much lower amounts than those produced naturally or from weapons testing.
IAEA Report Number 421 provides relevant information on C-14 releases. The C-14 releases in PWRs
occur primarily as a mix of organic carbon and carbon dioxide released from the waste gas system. In
BWRs, C-14 releases occur mainly as carbon dioxide in gaseous waste.

937 Regulations in 10 CFR 50.36a require that operating procedures be developed for the control of 938 effluents and that quantities of principal radionuclides be reported. The radioactive effluents from 939 commercial nuclear power plants overtime has decreased to the point that C-14 is likely to have become a 940 principal radionuclide (as defined in this document) in gaseous effluents. Therefore, licensees must 941 evaluate whether C-14 is a principal radionuclide for gaseous releases from their facility. Because the 942 dose contribution of C-14 from liquid radioactive waste is much less than that contributed by gaseous 943 radioactive waste, an evaluation of C-14 in liquid radioactive waste is not required.

The quantity of C-14 discharged can be estimated by use of a normalized C-14 source term and scaling factors based on power generation or estimated by use of the NUREG-0016 (GALE-BWR) and NUREG (GALE-PWR) computer codes. The National Council on Radiation Protection and Measurements Report No. 81, "Carbon-14 in the Environment," (Ref. 64) also provides information about the magnitude of C-14 in typical effluents from commercial nuclear power plants. These documents estimate that nominal annual releases of C-14 in gaseous effluents are approximately from 5 to 7.3 curies from PWRs and from 8 to 9.5 curies from BWRs.

The quantity of C-14 generated in BWR and PWR cores can also be estimated by a calculational method provided by the EPRI Report No. 1021106, "Estimation of Carbon-14 in Nuclear Power Plant Gaseous Effluents," issued December 2010 (Ref. 65) and EPRI Report No. 1024827 "Carbon-14 Dose Calculation Methods at Nuclear Power Plants," issued April 2012, (Ref. 66). If estimating C-14 based on scaling factors and fission rates, a precise and detailed evaluation of C-14 is not necessary. It is not necessary to calculate uncertainties for C-14 or to include C-14 uncertainty in any subsequent calculation of overall uncertainty.

960

952

Since the NRC published RG 1.21, Revision 1, in 1974, the analytical methods for determining C-14 have improved. Because the production of C-14 is expected to be relatively constant at a particular site, if sampling is performed for C-14 (instead of estimating C-14 discharges based on calculations), the sampling frequency may be adjusted to that interval that allows adequate measurement and reporting of effluents.

967 1.10 Return/Reuse of Previously Discharged Radioactive Effluents

969 Radioactive material properly released in gaseous or liquid effluents to the unrestricted area 970 (excluding solid materials or soil) is not considered licensed material when returned to the facility as long 971 as the concentration of radioactive material does not exceed 10 CFR Part 30, "Rules of General 972 Applicability to Domestic Licensing of Byproduct Material," exempt concentration limits (otherwise a 973 general or specific license is required). The water containing radioactive material returned from the 974 environment can be used by the licensee and returned to the unrestricted area without being considered a 975 new radioactive material effluent release. The basis for this determination is that the licensee has already 976 accounted for this radioactive material when the effluent was originally discharged, provided that the 977 subsequent use, possession, or release does not introduce a new significant dose pathway to a member of 978 the public, as explained below.

979

966

968

980 Licensees are responsible for evaluating any new significant exposure pathway and the resultant 981 radiological hazards associated with the return of radioactive material to the operating facility and its 982 subsequent discharge to the environment. For purposes of estimating dose during operations or 983 decommissioning, a new significant exposure pathway is any pathway that contributes dose that exceeds 984 10% of the dose criteria in 10 CFR 50 Appendix I, Section II (such that the dose from a new exposure 985 pathway is unlikely to be substantially underestimated). Bounding dose assessments as described in 986 Section 5.1 of this RG may be used in evaluating any new significant exposure pathway. Furthermore, 987 before returning radioactive materials to the environment, licensees must demonstrate that these 988 radioactive materials were previously disposed of in accordance with 10 CFR 20.2001(a)(3), or that the 989 material is naturally occurring background radiation. Radioactive material previously not accounted for as 990 an effluent that is entrained with returned/re-used water must be considered a new effluent disposal per 10 991 CFR 20.2001. See RIS 2008-03 for further details.

992 993

994

1.11 Abnormal Releases and Abnormal Discharges

995 In RG 1.21, Revision 1, the terms "release" and "discharge" were synonymous. In RG 1.21, 996 Revision 2 and 3, the term "release" describes an effluent from the plant (regardless of where the effluent 997 is located), and the term "discharge" describes an effluent that enters the unrestricted area. Although the term "release" includes effluents to either (1) the onsite environs or (2) the unrestricted area, this RG 998 999 generally reserves use of the term "release" for the release of an effluent from the power plant into the 1000 onsite environs. The onsite environs in this context encompass locations outside of nuclear power plant 1001 systems, structures, and components, as described in the final safety analysis report or ODCM. This is a 1002 change in terminology with respect to the definition of "abnormal release" in RG 1.21, Revision 1, which 1003 defined abnormal releases to be "from the site boundary."

1004

1005 An "abnormal release" (see glossary) is an unplanned or uncontrolled release of licensed radioactive material into the onsite environs. Abnormal releases may be categorized as either batch or 1006 continuous, depending on the circumstances. By contrast, an "abnormal discharge" (see glossary) is an 1007 1008 unplanned or uncontrolled discharge of licensed radioactive material to the unrestricted area. Abnormal discharges may also be categorized as either batch or continuous, depending on the circumstances. The 1009 distinction between the terms "abnormal release" and "abnormal discharge" is important for describing 1010 1011 the staff position for measuring, evaluating, and reporting releases and discharges, especially where leaks 1012 and spills are involved.

1013

1014 That portion of an abnormal release discharged to the unrestricted area is reported as an abnormal 1015 discharge in the year in which the discharge to the unrestricted area occurred. The portion of an abnormal release that remains onsite is considered residual radioactivity (see 10 CFR Part 20) and is documented in
accordance with 10 CFR 50.75(g).

1019 Low-level radioactive system leakage resulting from minor equipment failures and component 1020 aging (wear and tear) may be expected to occur as an anticipated part of the plant operation. If such 1021 leakage is captured by, or directed to, a system designed to accept and handle radioactive material, 1022 including the subsequent planned and controlled discharge of the radioactive material (e.g., as described 1023 in the final safety analysis report or ODCM), that evolution is not considered an abnormal release. Normal system leakage captured by effluent ventilation control systems or sumps is not an abnormal 1024 1025 release (provided that, before discharge of the radioactive material, the discharge is planned and controlled). (See also the definitions of "unplanned release" and "uncontrolled release" in the glossary.) 1026 1027

In certain circumstances, some subjectivity may be associated with the definitions of "unplanned release" and "uncontrolled release." In these situations, additional circumstances should be considered to determine whether an abnormal release occurred. A well-designed and documented evaluation of a release point can include an evaluation of the potential for an unplanned or uncontrolled release. The evaluation can establish bounding criteria that establish a threshold for an abnormal release based on planning and control. Generally, releases that may reasonably be categorized as both unplanned <u>and</u> uncontrolled should be considered abnormal releases.

1036 For example, consider an underground pipe that carries radioactive liquid to an outside storage 1037 tank. If this pipe develops a leak, and licensed radioactive material escapes into the surrounding soil, it is 1038 considered an abnormal release if some portion or all of the radioactive material remains onsite. This 1039 type of leak should be reported as an abnormal release in the next ARERR. If the licensee predicts (e.g., based on site conceptual model and subsequent groundwater monitoring results) that the radioactive 1040 material will enter the unrestricted area in 2 years, the resulting radioactive discharge (that would occur 1041 2 years hence) will be considered an abnormal discharge. Therefore, the resulting radioactive discharge 1042 1043 should be reported along with other data for the affected calendar year in a future ARERR (i.e., in this example, 3 years later). Both releases and discharges (either routine or abnormal) should be reported on a 1044 1045 calendar-year basis for the year in which the release or discharge occurred.

1046 1047 Consider another example involving a volume of radioactive gas from the containment 1048 atmosphere that escapes the equipment hatch during a refueling outage (especially during the time 1049 interval when the containment purge exhaust fans are off). This would generally not be considered an 1050 abnormal discharge if (1) the duration was preplanned (e.g., for a "short" duration such as 12 hours), 1051 (2) the containment activity (gas, particulate, tritium, and iodine) was preplanned, known, and very low (e.g., such that a bounding estimate of the radioactive material discharged indicated there would be no 1052 1053 measurable impact relative to typical discharges), (3) the containment activity was monitored (e.g., by 1054 sampling or radiation monitoring equipment), and (4) an evaluation was completed to identify a 1055 preplanned limiting (or "trigger") level of activity that would initiate remedial or mitigating action 1056 (e.g., close the equipment hatch to control gases escaping containment). In this example, the actions taken (i.e., preplanning and monitoring) before and during the evolution are sufficient to establish control 1057 1058 of this discharge. As a result, this type of evolution should not be categorized as an abnormal discharge. 1059

1060 **2. Effluent Sampling**

1061

1063

1062 2.1 Representative Sampling

1064NUREG-1301 and NUREG-1302 provide a typical schedule for radioactive effluent sample1065collection and analyses. Some licensees may have modified these sampling schedules (typically1066contained in the ODCM) as part of implementing GL 89-01, as approved by the NRC. Additional

1067 samples should be obtained as needed to characterize abnormal releases, abnormal discharges, or other 1068 significant operational evolutions. Samples should be representative of the overall effluent in the bulk 1069 stream, collection tank, or container. Licensees should ensure that representative samples were obtained 1070 from well-mixed streams or volumes of effluent at sampling points, using proper equipment and sampling 1071 procedures.

1072

1074

1073 2.2 Sampling Liquid Radioactive Waste

1075 Before sampling, large volumes of liquid waste should be mixed to ensure that sediments or 1076 particulate solids are distributed uniformly in the waste mixture. For example, a large tank may be mixed 1077 using a sparger system or recirculated three or more volumes to ensure that a representative sample can be 1078 obtained, as recommended by American Society for Testing and Materials (ASTM) D 3370 - 18, 1079 "Standard Practices for Sampling Water from Flowing Process Streams (Ref. 67). If tank-mixing practices deviate from industry standards (i.e., those for recirculation or otherwise), the licensee should 1080 1081 provide a technical evaluation or other justification. Sample points should be located where there is a 1082 minimum of disturbance of flow caused by fittings and other physical characteristics of the equipment and components. Sample nozzles should be inserted into the flow or liquid volume to ensure sampling of 1083 1084 the bulk volume of pipes and tanks. Sample lines should be flushed for a sufficient period of time before sample extraction to remove sediment deposits and air and gas pockets. Generally, three sample line 1085 1086 volumes should be purged as recommended by ASTM D3370 - 18, before withdrawing a sample, unless a technical evaluation or other justification is provided. A series of samples should be taken periodically 1087 1088 during the interval of discharge to determine whether any differences exist as a function of time and to 1089 ensure that individual samples are indeed representative of the effluent mixture. In some instances, this may be accomplished by collecting one or more samples (either by "grab" or composite sampler) during 1090 the discharge and comparing with one or more samples taken before the discharge. If a series of samples 1091 is collected, these samples can be used to assess the amount of measurement uncertainty in obtaining 1092 1093 representative samples.

1094

1096

1095 2.3 Sampling Gaseous Radioactive Waste

1097 Although all licensees may not be committed to RG 4.15, ANSI N42.18-2004, "Specification and Performance of On-Site Instrumentation for Continuously Monitoring Radioactivity in Effluents" 1098 1099 (Ref. 68), ANSI N42.54-2018, "Instrumentation and Systems for Monitoring Radioactivity" (Ref. 69), and ANSI/Health Physics Society (HPS) N13.1-2011, "Sampling and Monitoring Releases of Airborne 1100 1101 Radioactive Substances from the Stacks and Ducts of Nuclear Facilities" (Ref. 70), these documents 1102 provide general principles for designing and conducting monitoring programs for airborne effluents. The cited references also contain recommendations for obtaining valid samples of airborne radioactive 1103 1104 material in effluents and the guidelines for sampling from ducts and stacks. Licensees should use the 1105 appropriate licensing documents to evaluate the validity of representative samples (e.g., evaluate the potential for inaccurate sampling of gaseous effluents that may bypass a particulate filter and collect on an 1106 iodine collection cartridge) and to identify any inaccurate sample analyses configurations or counting 1107 geometries. 1108

- 1100
- 1110 2.4 Sampling Bias
- 1111

Sampling and storage techniques that could bias quantitative results for effluent measurements should be evaluated and corrections applied as necessary. These biases include inaccurate measurement of sample volumes resulting from pressure drops in long sample lines and loss of particulates or iodine in sample lines resulting from deposition or plate-out. Samplers for gaseous waste should be evaluated for particulate deposition using ANSI/HPS N13.1-1999 or equivalent.

1118 2.5 Composite Sampling

1120 Composite samples should be representative of the average quantities and concentrations of 1121 radioactive materials discharged in liquid and gaseous effluents. Composite samples should be collected 1122 in proportion to the effluent flow rate or in proportion to the volume of each batch of effluent discharges.

1123 1124 1125

1119

2.6 Sample Preparation and Preservation

Sample preparation and storage methods should minimize the potential for loss of radioactive material (i.e., deposition of analyte on walls of the sample container or volatilization of analyte).
Composite sample storage time should be as short as practical to preclude deposition on the storage container, or sample stabilization should be considered. Before quantitative radionuclide analyses for liquid effluent composites, licensees should ensure that samples are mixed thoroughly so that the sample is representative of the material discharged.

Procedures for handling, packaging, and storing samples should ensure that losses of radioactive
materials or other factors causing sample deterioration do not invalidate the analysis. For example, filters
should be stored carefully to prevent loss of radioactive material from the filter paper.

1136 1137

1138

1151

1156

1158

1160

2.7 Short-Lived Radionuclides and Decay Corrections

In the analysis of short-lived radionuclides (e.g., short-lived noble gases), measurements should generally be made as soon as practical after collection to minimize loss by radioactive decay. In other cases, when needed to improve the detection of the longer-lived radionuclides, time should be allowed for the decay of short-lived, interfering radionuclides.

Some special considerations may be applicable when measuring short-lived radionuclides. In general, sample collection (or analysis frequencies) should take into account the half-lives of the radionuclides being measured. This may have special applicability for continuous samples or composite samples. It is generally best to select a compositing interval (and analysis frequency) appropriate for the effluent (radionuclide) being analyzed. In cases where the compositing interval is selected appropriately, analytical bias is minimized. One way to avoid analytical bias is to decrease the composite sampling interval (and analysis frequency).

1152 To minimize bias in measurements, it may be necessary to decay correct analysis results for 1153 short-lived radionuclides. Licensees should be cognizant of those situations in which analytical bias may 1154 be introduced when analyzing short-lived radionuclides and should select appropriate methods to 1155 minimize such bias.

- 1157 **3.** Effluent Dispersion (Meteorology and Hydrology)
- 1159 3.1 Meteorological Data

1161 Gaseous effluents discharged into the atmosphere are transported and diffused (or, in combination dispersed and, therefore diluted) as a function of (1) the atmospheric conditions in the local environment 1162 (including ambient meteorology and structural wake effects), (2) the topography of the region, and (3) the 1163 1164 release characteristics of the effluents. In developing and implementing a monitoring program designed 1165 to collect site-specific meteorological data, licensees should, conform to the guidance consistent with their facility's current licensing basis but should also consider adopting the guidance in the current 1166 1167 version of RG 1.23. The meteorological data do not need to be reported in the ARERR, but the data 1168 should be summarized and maintained as documentation (records). Licensees should prepare and

maintain an annual meteorological summary report that provides the joint frequency distributions of wind
direction and wind speed by atmospheric stability class (see RG 1.23, or, if applicable, Safety Guide 23,
"Onsite Meteorological Programs," dated February 17, 1972 (Ref. 71)) on site for the life of the plant. In
addition, the licensee should record hourly meteorological data (or shorter-term averages compatible with
the appropriate dispersion models) and make the data available if needed for assessing abnormal gaseous
releases.

1176 1177

1185

1194

3.2

Atmospheric Dispersion (Transport and Diffusion)

1178 Site-specific meteorological data collected should be validated and used to generate gaseous 1179 effluent dispersion factors (χ/Q) and deposition factors (D/Q), in accordance with RG 1.111. The use of 1180 long-term annual-average meteorological conditions (based on 5 or more years of data) to determine χ/Q 1181 and D/Q is appropriate for continuous releases and for establishing instantaneous release rate set points. 1182 This practice may also be acceptable for calculating doses from intermittent releases if the releases occur 1183 randomly and with sufficient frequency to justify the use of annual-average meteorological conditions (see RG 1.111).

1186 Personnel familiar with the equipment and typical site meteorological conditions should review the meteorological data. Data losses can be minimized by incorporating redundant sensors and 1187 equipment, and by maintaining an adequate inventory of spares, as part of the monitoring program design. 1188 Periodic data evaluation may include, but is not be limited to, promptly identifying and inspecting 1189 1190 equipment failures and time to resolution, reviewing results of performance checks and calibrations, and 1191 confirming that measurements are within appropriate ranges (e.g., occurrence of excessive calm wind speeds, reasonable diurnal and seasonal variation of wind speed, wind direction, and temperature at each 1192 1193 level and with height).

1195 A change in χ/Q (and/or D/Q) may not be the only indicator that should be reviewed. A change 1196 in impact location should also be addressed (if not already the case). Such a change could be caused by 1197 (1) an actual change in the meteorological conditions, (2) a physical change in meteorological 1198 instrumentation (i.e., mechanical versus sonic anemometry), (3) a change in data averaging approach 1199 (e.g., scalar versus vector), or (4) any combination of the above.

1201 Invalid data should be removed from the meteorological data file prior to calculating long-term, 1202 annual-average χ/Q and D/Q values. Records of data invalidation (and if applicable, data substitution) 1203 should also be documented and retained. 1204

1205 The long-term, annual-average χ/Q and D/Q values should be reevaluated periodically (e.g., every 1206 3–5 years). If the periodic reevaluation indicates the controlling/limiting long-term, annual-average χ/Q 1207 and D/Q values are substantially nonconservative (e.g., higher by 20–30 percent or more with respect to 1208 historical data), the licensee should ensure that the χ/Q and D/Q values used in the dose assessment are 1209 revised or that the ARERR addresses why such changes are not deemed necessary. Acceptable reasoning 1210 includes evaluating data anomalies, identification of failures in meteorological sensors, and 1211 documentation that the locality experienced abnormal weather patterns.

- 1212
- 1213 3.3 Release Height

1214
1215 The release height affects the dispersion (transport and diffusion) of radioactive materials,
1216 especially for "downwash" and building wake effects. For facilities with ground-level, mixed-mode, and
1217 elevated releases, an evaluation should be made to determine the proper location of the maximum
1218 exposed individual member of the public. From a dispersion perspective, when determining the
1219 maximum exposure location (submersion and/or deposition), the evaluation should consider the

1220 magnitude of the release(s) originating as an elevated release and as a ground-level release. For example, 1221 a close-in, downwind location in one sector may have a higher χ/Q (i.e., less dispersion) for a 1222 ground-level release, whereas the majority of the source term may be originating as an elevated release, 1223 causing a higher concentration (χ) at a more distant location, possibly in a different sector. RG 1.111 1224 contains a more complete discussion of release height.

1225

1227

1243

1266

1226 3.4 Aquatic Dispersion (Surface Waters)

1228 Liquid radioactive effluents may be disposed in accordance with 10 CFR 20.2001 into a variety 1229 of receiving surface water bodies, including nontidal rivers, lakes, reservoirs, settling ponds, cooling 1230 ponds, estuaries, and open coastal waters. This effluent is dispersed by various mechanisms 1231 (i.e., turbulent mixing; stream flow in the water bodies; and internal circulation or flow-through in lakes, 1232 reservoirs, and cooling ponds). Parameters influencing the dispersion patterns and concentrations near a site include the direction and speed of flow of currents, both natural and plant induced, in the receiving 1233 1234 water; the intensity of turbulent mixing; the size, geometry, and bottom topography of the receiving 1235 water; the location of effluent discharge in relation to the receiving water surface and shoreline; the 1236 amount of recirculation of previously discharged effluent; the characteristics of suspended and bottom sediments; and sediment sorption properties. RG 1.113 describes calculational models for estimating 1237 1238 aquatic dispersion to surface water bodies. However, the dispersion characteristics may be highly site 1239 dependent, and local characteristics should be considered when performing dispersion modeling and dose 1240 assessments. 1241

1242 3.5 Spills and Leaks to the Ground Surface

Liquid releases onto the land surface are transported and diluted as a function of site-specific 1244 hydrologic features, events, and processes and properties of the effluent. The releases may temporarily 1245 1246 accumulate, pool, or run off to natural or engineered drainage systems. During this process, water may 1247 also be absorbed into the soil (see Section 3.6). RG 1.113 discusses the use of simple models to estimate 1248 transport through surface water bodies and considers water usage effects. Spills or leaks of radioactive 1249 material to the ground surface should initiate characterization of the runoff. At a minimum, the characterization activities should satisfy (1) the requirements of 10 CFR 50.75(g) and (2) the effluent 1250 reporting requirements of 10 CFR 50.36a, and the guidance described in NUREG-1301 and 1251 NUREG-1302 for planned effluents (e.g., sampling before discharge to unrestricted areas). 1252 Sections 8.5.1, 8.5.2, and 8.5.9 of this RG contain recommendations on the general format for reporting 1253 1254 abnormal releases to onsite areas and abnormal discharges to unrestricted areas. 1255

1256 3.6 Spills and Leaks to Groundwater1257

1258 Liquid radioactive leaks and spills are sometimes released to onsite groundwater or discharged to 1259 offsite groundwater. Leaks and spills onto the ground surface can be absorbed into the soil. Depending on the local soil properties and associated liquid flux of the release, some of the material in the leak or 1260 spill may eventually reach the local water table. The dispersion of this material depends on the local 1261 subsurface geology and hydrogeologic characteristics. Liquid releases into the subsurface will be 1262 1263 transported as a function of groundwater flow processes and conditions (e.g., hydraulic gradients, 1264 permeability, porosity, and geochemical processes) and will eventually be released to the unrestricted 1265 area.

A groundwater conceptual site model should be developed to predict the subsurface water flow
 parameters to include direction and rate and to be used as the basis for estimating the dispersion of
 abnormal releases of liquid effluents into groundwater (see RG 4.1 and RG 4.25). Section 1 of this RG
 lists references for use in developing an adequate groundwater conceptual site model.

Simple analytical models or more rigorous numerical codes (i.e., simulations) may be used to
evaluate subsurface transport following a release. Appropriate use of these models and codes will depend
on the release rate, depth of the release, depth to the local water table, groundwater flow directions,
groundwater flow rates, geochemical conditions, and other geochemical processes (e.g., geochemical
retardation). Additionally, water usage, such as groundwater pumping from wells, may create local
groundwater depression(s) that can alter the natural groundwater flow.

1279 Consistent with 10 CFR 20.1501, a basic site hydrogeological characterization, in advance of leaks or spills, is helpful for evaluating potential leaks and spills. Sites with significant residual 1280 1281 radioactivity that are likely to exceed the radiological criteria for unrestricted use at the time of 1282 decommissioning (e.g., as described in 10 CFR 20.1402) should perform more extensive evaluation. 1283 Initial assessments should be conducted with relatively simple conceptual site models using scoping surveys, bounding assumptions, or a combination of both (see RG 4.25 and American National Standards 1284 1285 Institute/American Nuclear Society (ANSI/ANS) 2.17-2009, "Evaluation of Subsurface Radionuclide 1286 Transport at Commercial Nuclear Power Production Facilities" (Ref. 72). The complexity of the models should increase as (1) more knowledge is obtained about the system under evaluation (e.g., source of leak, 1287 1288 plume size, concentrations, radionuclides, site characteristics, presence of preferential flow pathways) and 1289 (2) the dose estimates rise above significant residual radioactivity levels (see definition in the glossary). 1290 Industry documents (Refs. 38 and 72) contain details of various industry practices that may be used as 1291 part of a groundwater monitoring program. Sites with low-level spills or leaks generally do not require 1292 extensive site characterization and monitoring. 1293

1294 The following are basic steps in monitoring groundwater contamination:

1278

1295

1298

1300

1302

1304

1310

1312

- 12961.Use the conceptual site model (as necessary) to assist in monitoring, evaluating, and reporting
radioactive releases and radioactive discharges.
- 1299 2. Collect empirical data by one or more of the following (as necessary):
- 1301 a. Sample and analyze groundwater from existing monitoring wells.
- b. Conduct additional hydrogeologic testing using existing wells (or new wells) if required.
- Test the conceptual site model and radionuclide transport predictions using groundwater sample results and data collected during hydrogeologic testing.
- Modify conceptual site model and radionuclide transport parameters as necessary to predict discharges and assess doses to members of the public.
- 1311 5. Use an iterative process and revaluate as needed.

The groundwater monitoring results should be used in the development and testing of a conceptual site model to predict radionuclide transport in groundwater. The conceptual site model is generally considered adequate when it predicts the results of monitoring (sometimes called a calibrated model). Groundwater monitoring results evaluate the validity of the conceptual site model. Following a leak or spill of licensed (radioactive) material, the conceptual site model may be used in conjunction with radionuclide transport modeling and groundwater monitoring to comprise a basis for predicting future effluents from the site. Dispersion and dilution occur over time and in three dimensions.

1321 When used with a strategic and carefully planned monitoring program, the conceptual site model can ensure that necessary and reasonable surveys are performed (i.e., limited scoping surveys or more 1322 1323 extensive surveys). Limited scoping surveys can determine if significant residual radioactivity exists and if there is adequate protection of public health and safety. If the limited scoping surveys identify 1324 significant residual radioactivity, then the extent of the contamination should be further evaluated by 1325 1326 more extensive surveys (e.g., monitoring wells or other evaluations as appropriate). These survey 1327 activities may be direct (i.e., occurring at, or very near, the source of the leak) or indirect (i.e., occurring 1328 at some distance from the source of the leak) depending on the accessibility of the source of the spill or 1329 leak and the mobility of the radionuclides. 1330

1331 For spills or leaks occurring below the soil surface in inaccessible locations, direct scoping and 1332 characterization may not be feasible. In these cases, indirect monitoring techniques (e.g., groundwater 1333 monitoring wells in a down-gradient direction) will satisfy existing regulatory requirements. These survey activities should, at a minimum, satisfy (1) the requirements of 10 CFR 50.75(g) and (2) the 1334 1335 effluent reporting requirements of 10 CFR 50.36a for groundwater discharges to the unrestricted area. In general, licensees should describe (report) leaks and spills of radioactive material in the ARERR for the 1336 calendar year the spill or leak occurred. Additionally, licensees should report groundwater monitoring 1337 1338 data in the ARERR for the calendar year in which the data were collected. Sections 8.5.1, 8.5.2, and 8.5.9 1339 of this RG contain guidance on the general format for reporting abnormal releases to onsite areas and 1340 abnormal discharges to unrestricted areas.

Although licensees may conduct a groundwater monitoring effort for different reasons, for
 purposes of this RG, the surveys, characterization activities, conceptual site models, and other
 components of any groundwater monitoring effort should be sufficient to do the following:

- 1346 1. Appropriately report, for purposes of accountability, effluents discharged to unrestricted areas. 1347
- 1348 2. Document information in a format consistent with Table A-6 and Section 8.5 of this RG. 1349
- Provide advance indication of potential future discharges to unrestricted areas (to ensure releases are planned and monitored before discharge).
- 1353
 4. Demonstrate that significant residual radioactivity has not migrated off site to an unrestricted area in the annual reporting interval.
 1355
- 1356 5. Communicate relevant information as described in Section 9.5 of this guide.
- 1358 4. Quality Assurance

1341

1359

1360 4.1 Quality Assurance Programs

1361 1362 The analytical process should use a range of QA checks and tests. RG 4.15 describes the QA 1363 program activities for ensuring that radioactive effluent monitoring systems and operational programs meet their intended purpose. Each licensee's licensing basis determines the applicability of Revision 1 or 1364 Revision 2. However, RG 4.15, Revision 2 contains guidance on determining appropriate sensitivity 1365 1366 levels for analytical instrumentation based on DQOs. The use of DQOs may provide a better technical 1367 basis for determining sensitivity levels (e.g., LLDs) than the use of the default values in NUREG-1301 and NUREG-1302. A combination approach using both Revision 1 and Revision 2 of RG 4.15 may be 1368 used to determine appropriate sensitivity levels (e.g., LLDs) different (i.e., higher or numerically larger) 1369 1370 than those listed in NUREG-1301 and NUREG-1302. 1371

1372 4.2 Quality Control Checks

QC checks of laboratory instrumentation should be conducted daily or before use, and
background variations should be monitored at regular intervals to demonstrate that a given instrument is
in working condition and functioning properly. QC records should include results of routine tests and
checks, background data, calibrations, and all routine maintenance and service.

1379 4.3 Surveillance Frequencies

1381 Routine qualitative tests and checks (e.g., channel operational tests, channel checks, or source checks to demonstrate that a given instrument is in working condition and functioning properly) may be 1382 1383 performed using radioactive sources that are not traceable by the National Institute of Standards and 1384 Technology (NIST). The schedule for source checks, channel checks, channel calibrations, and channel operational tests should be in accordance with NUREG-1301 and NUREG-1302, unless otherwise 1385 modified after a technical evaluation demonstrates a justifiable change in frequency. A technical 1386 1387 evaluation that revises a surveillance frequency should include consideration of the instrument's function and the consequences of failure and not simply rely on the history of successful surveillances. 1388

1390 4.4 Procedures

1392 Individual written procedures should be used to establish specific methods of calibrating installed 1393 radiological monitoring systems and grab sampling equipment. Written procedures should document 1394 calibration practices used for ancillary equipment and systems (e.g., meteorological equipment, airflow measuring equipment, in-stack monitoring pitot tubes). Calibration procedures may be compilations of 1395 published standard practices or manufacturers' instructions that accompany purchased equipment, or they 1396 1397 may be written in house to include special methods or items of equipment not covered elsewhere. 1398 Calibration procedures should identify the specific equipment or group of instruments to which the 1399 procedures apply.

1400

1407

1373

1378

1380

1389

1391

Written procedures should be used for maintaining counting room instrument accuracy, including
maintenance, storage, and use of radioactive reference standards; instrumentation calibration methods;
and QC activities such as collection, reduction, evaluation, and reporting of QC data as required by the
technical specifications.

1405 1406 4.5

Calibration of Laboratory Equipment and Routine Effluent Radiation Monitors

1408 Calibrations (e.g., of laboratory equipment and continuous radiation monitoring systems used to 1409 quantify radioactive effluents) should be performed using the general principles for calibration of effluent 1410 monitoring instrumentation provided in ANSI N42.18-2004 and ANSI N323C-2009, "American National Standard for Radiation Protection Instrumentation Test and Calibration-Air Monitoring Instruments, 1411 American National Standards Institute" (Ref. 74), using radioactive calibration sources traceable to the 1412 1413 NIST. Calibration sources should have the necessary accuracy, stability, and radioactivity levels required 1414 for their intended use. The relationship between concentrations and monitor readings should be determined. Performance of the monitoring system should be judged on the basis of reproducibility, time 1415 1416 stability, and sensitivity. 1417

Periodic inservice correlations that relate monitor readings to the concentrations, release rates of radioactive material in the monitored release path, or a combination of both, should be performed when possible to validate the adequacy of the system. These correlations should be based on the results of analyses for specific radionuclides in grab samples from the release path.

- 1423 The use of NIST-traceable sources combined with mathematical efficiency calibrations may be 1424 applied to instrumentation used for radiochemical analysis (e.g., gamma spectroscopy systems) if 1425 employing a method provided by the instrument manufacturer.
- 1426 1427 1428

4.6 Calibration of Measuring and Test Equipment

Measuring and test equipment should be calibrated using NIST-traceable radioactive sources.
The source geometries should be representative of the sample types analyzed and have the necessary accuracy, stability, and activity concentrations for their intended use.

1433 4.7 Calibration Frequency 1434

1435 Calibrations should generally be performed at regular intervals in accordance with the frequencies established in NUREG-1301 and NUREG-1302. A change in calibration frequency (an increase or 1436 1437 decrease) should be based on the reproducibility and time stability characteristics of the system. For 1438 example, an instrument system that gives a relatively wide range of readings when calibrated against a 1439 given standard should be recalibrated at more frequent intervals than one that gives measurements within 1440 a more-narrow range. Any monitoring system or individual measuring equipment should be recalibrated 1441 or replaced whenever it is suspected of being out of adjustment, excessively worn, or otherwise damaged 1442 and not operating properly.

1444 4.8 Measurement Uncertainty 1445

1446 The measurement uncertainty (formerly called measurement error) associated with the measurement of radioactive materials in effluents should be estimated. Counting statistics can provide an 1447 estimate of the statistical counting uncertainty involved in radioactivity analyses. Because it may be 1448 1449 difficult to assign error terms for each parameter affecting the final measurement, detailed statistical 1450 evaluations of error are not required. Normally, the statistical counting uncertainty decreases as the amount (concentration) of radioactivity increases. Thus, for the radioactive effluent release report, the 1451 statistical counting uncertainty is typically a small component of the total uncertainty. The sampling 1452 1453 uncertainty is likely the largest component and includes uncertainties such as the uncertainty in volumetric and flow-rate measurements and laboratory processing uncertainties. 1454

1455

1443

1456 The total or expanded measurement uncertainty associated with the effluent measurement should 1457 ideally include the cumulative uncertainties resulting from the total operation of sampling and 1458 measurement. Expanded uncertainty should be reported with measurement results. The objective should be to evaluate only the important contributors and obtain a reasonable measure of the uncertainty 1459 1460 associated with reported results. Detailed statistical and experimental evaluations are not required. The 1461 overall objective should be to obtain an overall estimate of measurement uncertainty. The formula for 1462 calculating the total or expanded uncertainty classically includes the square root of the sum of squares of each important contributor to the measurement uncertainty. Licensees may obtain additional information 1463 from NUREG-1576 and ANSI/HPS N13.1-2011. 1464

- 1465
- 14664.9Calibration of Accident-Range Radiation Monitors and Accident-Range Effluent Monitors

GDC 64 requires means for monitoring radioactivity in the reactor containment atmosphere;
spaces containing components for recirculation of loss-of-coolant accident (LOCA) fluids; effluent
discharge paths; and the plant environs for radioactivity that may be released from normal operations,
including anticipated operational occurrences, and from postulated accidents. The regulation at
10 CFR 20.1501(c) requires periodic calibration of instruments and equipment used to perform
quantitative radiation measurements (e.g., dose rate and effluent monitoring).

1474			
1475	NUREG-0737, Item II.F.1, provides guidance for monitoring radiation levels and gaseous		
1476	effluent during postulated radiological emergencies. RG 1.97, Revisions 2 and 3, provide guidance on the		
1477	design and performance criteria of instrumentation used to assess plant and environ conditions during and		
1478	following an accident. This RG 1.21 provides further guidance on the calibration of such instrumentation		
1479	based on the NRC's "Proposed Guidance for Calibration and Surveillance Requirements to Meet Item		
1480	II.F.1 of NUREG-0737," issued August 1982 (Ref. 75), NUREG/CR-5569, "Health Physics Positions		
1481	Data Base "Health Physics Position (HPPOS)-001 "Proposed Guidance for Calibration and Surveillance		
1482	Requirements to Meet Item II F 1 of NUREG-0737, "issued February 1994 (Ref. 76), summarizes this		
1483	additional guidance.		
1484			
1485	Noble Gas Monitoring - NUREG-0737, Item II.F.1-1, describes accident-range noble gas effluent		
1486	monitors as monitors that are normally noble gas gross activity monitors sensitive to gamma emissions		
1487	beta emissions or a mix of gamma and beta emissions. These monitors normally indicate (read out) in		
1488	units of activity concentration a count rate or a dose rate (i.e. an indirect measurement of the noble gas		
1489	gross activity concentration). Therefore in order to determine the release rate of noble gas gross activity		
1407	a conversion factor (i.e. hereafter referred to as an instrument response factor) should be developed to		
1400	convert the instrument output into an activity concentration for use in determining a release rate		
1497	(e.g. curies per second of a mix of noble gases)		
1/03	(e.g., curres per second of a mix of noble gases).		
1493	The initial vendor calibration of emergency effluent monitoring instruments may be a one-time		
1405	prototype calibration based on the initial calibration of a single instrument of a certain model using		
1475	NIST traceable rediction sources. This initial prototype calibration of a single instrument model may		
1407	include a determination of its fundamental abarratorizing such as the following:		
1497	include a determination of its fundamental characteristics, such as the following.		
1490	1 a dose rate linearity check using a radioactive gas or solid source (e.g., casium (Cs) 137) to		
1499	1. a dose-fate finearity check using a fadioactive gas of solid source (e.g., cestuin (Cs)-157) to obtain three on scale values separated by two decades of scale:		
1500	obtain three on-scale values separated by two decades of scale,		
1502	2 a measurement of the instrument's regions a factor to a calibration gas (e.g. venon (Xe) 133 or		
1502	2. a measurement of the instrument s response factor to a canoration gas (e.g., xchoir (Xe)-155 of krypton (Kr) 85):		
1503	Krypton (Kr)-65),		
1505	2 a characterization of the instrument's energy demondency characteristics using solid sources		
1505	5. a characterization of the instrument's energy -dependency characteristics, using solid sources		
1500	ranging in gamma energy from low energy (e.g., 81 kiloelectron volts) to high energy		
1507	(e.g., 2 megaelectron volts); and		
1508			
1509	4. a determination, using a solid source, of a transfer factor that provides a dual purpose:		
1510			
1511	a. for use by vendors to validate that subsequent instruments produced for sale of the same		
1512	model have similar performance characteristics to the initial "type" instrument model's		
1513	characteristics; and		
1514			
1515	b. for use by end users (e.g., nuclear power plants) in performing post installation and		
1516	subsequent periodic calibration to verify that the instruments installed in the facility are		
1517	functioning consistently with respect to initial vendor calibration of that instrument		
1518	model.		
1519			
1520	Time-dependent (i.e., time since reactor shutdown) instrument response factors may be developed		
1521	for each major accident type (i.e., a small-break LOCA with normal reactor coolant system activity levels,		
1522	a large-break LOCA with gas gap activity levels, or a core-melt accident with noble gas activity levels		
1523	arising from the fuel pellets release of noble gas). Each accident type has a characteristic, time-dependent		

noble gas isotopic mix. In general terms, a small-break LOCA has a substantially decayed noble gas mix
from the reactor coolant system with predominantly low-energy gamma photons; a large-break LOCA has
a somewhat decayed noble gas mix from the gas gap of the fuel assemblies with predominately mediumenergy gamma photons; and a core -melt accident has a substantially undecayed mix of noble gas isotopes
in the fuel pellets with predominately high-energy gamma photons.

1530 The time-dependent instrument response factor accounts for the detector's energy efficiency at 1531 various gamma energies of the noble gas isotopic mix for that accident type. The instrument response 1532 factor normally has units of microcuries per cubic centimeter (μ Ci/cc) per count per minute or μ Ci/cc per 1533 milliroentgen per hour where the μ Ci/cc is the gross (total) summation of all the noble gas activities in the 1534 isotopic mix for each major type of accident listed above. It is also acceptable to use instrument response 1535 factors based on a single calibration gas with a low -energy gamma source (e.g., Xe-133) or beta 1536 emissions (e.g., Kr-85) for beta sensitive monitors.

The initial calibration process performed by the vendor does not need to be repeated at a nuclear power plant. Instead, a periodic single point source response check of the instrument's performance as compared to a transfer factor provided by the vendor using a solid source - see ANSI N320-1978, "Performance Specifications for Reactor Emergency Radiological Monitoring Instrumentation (Ref. 77).

1543 <u>Iodine and Particulate Monitoring</u> - NUREG-0737, Item II.F.1-2, provides guidance on iodine 1544 and particulate effluent monitoring by sampling and analysis. Real-time monitoring is not required or 1545 considered practical; however, the licensees should have established procedures for collection of iodine 1546 and particulate samples and subsequent analysis to determine the release rate. For emergency dose 1547 assessment purposes, RASCAL (NUREG-1940 Section 1.2.8) can also be used to assess a real-time 1548 iodine and particulate release rate based on partitioning (scaling) factors to noble gases.

1550 <u>Containment High Range Monitoring</u> - NUREG-0737, Item II.F.1-3, provides guidance on 1551 calibration of containment high-range monitors. An in-place calibration should be performed using a 1552 radioactive source at one point on the decade below 10 roentgens per hour (R/hr). Instrument scales in 1553 the range of 10 R/hr to 1E7 R/hr should be checked using electronic signal substitution with a calibrated 1554 current source to demonstrate that the system is functioning to higher radiation fields.

1556 Containment high-range monitors should be used to assess the amount of core damage and to 1557 assess the source terms for the containment leakage release pathway. NUREG-1940, Section 1.2.4, 1558 Figures 1-1 through 1-5, provide information for PWRs and BWRs at 1 hour and 24 hours after reactor 1559 shutdown that correlates the containment radiation monitor readings to the amount of reactor damage for 1560 normal coolant, spiked coolant, cladding failure, and core melt accident scenarios.

1561 1562 1563

5.

1537

1549

Dose Assessments for Individual Members of the Public

The regulation in 10 CFR 20.1301 establishes dose limits for individual members of the public⁸. The regulations referenced in Sections 5.4–5.6 of this RG contain both dose limits and design objectives that the licensee demonstrates compliance with through calculations. Table 1 summarizes the fundamental parameters associated with the dose calculations. RG Sections 5.7 and 5.8 present important concepts for these calculations. Because of differences between NRC and EPA regulations,

⁸ For ISFSIs, 10 CFR Part 72 specifies dose limits for any real individual beyond the Part 72 controlled area boundary (excluding occupational exposures). Thus, dose assessments performed to demonstrate compliance with the 10 CFR 72.104 must include the necessary components described in10 CFR 72.104.

- 1569 demonstrating compliance only with radiological effluent technical specifications (based on
- 1570 10 CFR Part 50, Appendix I) does not necessarily ensure compliance with the EPA's 40 CFR Part 190,
 1571 particularly if there is a direct radiation component (e.g., from BWR shine, ISFSI, or radioactive materials
 1572 storage).
- 1573
- 1574
- 1575

Table 1 - Parameters	Associated with	Dose Calculations
----------------------	-----------------	-------------------

	10 CFR PART 50, APPENDIX I	10 CFR 20.1301(e) (EPA 40 CFR PART 190)
Dose	whole body, max of any organ,	whole body, thyroid, and max of any organ
	gamma air, and beta air	
Basis	International Commission on	EPA 40 CFR Part 190
	Radiation Protection (ICRP)-2,	
	"Report of Committee II on	
	Permissible Dose for Internal	
	Radiation," issued 1959 (Ref. 78)	
Where	unrestricted area	unrestricted area
Individual	real person/exposure pathway	real person/exposure pathway (nearest real
Receptor	(nearest real residence, real garden,	(residence, real garden, real dairy/meat
	real dairy/meat animal)	animal)
Origin	liquid and gas radioactive waste	liquid and gas radioactive waste
		direct radiation
		(e.g., nitrogen-16 shine, ISFSI, radioactive
		materials storage, outside tanks)
		accumulated radioactive material
		(e.g., tritium in lake water) not already
		included in dose estimates
Radioactive	licensed only (per Appendix I,	licensed and unlicensed
Material	Section II radioactive materials – see	(see Section 5.6 below)
	Section 5.4 below)	
When	current year	current and prior years' operation

1576 1577

1578

5.1 Bounding Assessments

1579 Bounding assessments may be useful if compliance can be readily demonstrated using 1580 conservative assumptions. In this RG, the term "bounding assessment" means that the reported value is 1581 unlikely to be substantially underestimated (see 10 CFR Part 50, Appendix I, Section III). Bounding 1582 assessments for the current year do not imply the absolute bounds for future conditions.

For example, licensees may use conservative bounding dose assessments in lieu of site-specific dose assessments of the maximum dose to individual members of the public. Instead of assessing dose from ground-level effluent releases to a real individual member of the public located 3.2 km (2 miles) from the site boundary, a conservative bounding dose assessment can be performed for a hypothetical individual member of the public located at the site boundary.

1590 If bounding assumptions are made, the radioactive effluent release report should state such and 1591 should annotate the assumptions. Hypothetical exposure pathways (see definition in the glossary) and 1592 locations are sometimes used for bounding dose assessments (or hazard evaluations done in accordance 1593 with 10 CFR 20.1501).

1595 5.2 Individual Members of the Public

1597 Individual members of the public reside in the unrestricted area but at times may enter the 1598 controlled area of a commercial nuclear power plant. Each licensee is responsible for classifying individuals (by location) as either members of the public or as occupational workers (see the definition of 1599 "members of the public" in 10 CFR Part 20.) The NRC annual dose limits for members of the public are 1600 1601 100 mrem total effective dose equivalent in accordance with 10 CFR 20.1301(a) and (b). In addition, in 1602 accordance with 10 CFR 20.1301(e) for uranium fuel cycle licensees (including nuclear power plants), the annual dose limits to members of the public are the EPA 40 CFR Part 190 limits of 25 mrem whole body, 1603 1604 75 mrem to the thyroid, and 25 mrem to any other organ while in the unrestricted area. 1605

1606 If bounding assessments are not used, licensees should perform evaluations to determine the dose 1607 to a real, maximum exposed member of the public, regardless of whether the individual is in an unrestricted area or a controlled area. A member of the public is typically a real individual in a 1608 1609 designated location where there is a real exposure pathway (e.g., a real garden, real cow, real goat, or 1610 actual drinking water supply) and not a fictitious fencepost resident or an exposure pathway that includes a virtual goat or cow. Licensees are encouraged (but not required) to use real individual members of the 1611 public when performing dose assessments for radioactive discharges. Table 1 in RG 1.109 allows a dose 1612 evaluation to be performed at a location where an exposure pathway and dose receptor actually existed at 1613 1614 the time of licensing.

1616 5.3 Occupancy Factors

1618For members of the public in the unrestricted area, occupancy factors should be assumed to be1619100 percent at locations identified in the land use census, unless site -specific information indicates1620otherwise. Occupancy factors may be applied inside the controlled area based on estimated hours spent in1621the controlled area.

1622 1623 1624

1615

1617

1596

5.4 10 CFR Part 50, Appendix I, Design Objectives and Limiting Conditions for Operation

1625 Appendix I to 10 CFR Part 50 contains numerical guidance for design objectives and limiting 1626 conditions of operation for radioactive waste systems to ensure discharges of radioactive liquid and gaseous effluents to unrestricted areas are ALARA. This numerical guidance is listed in terms of annual 1627 1628 air doses (gamma and beta), annual total body doses, and annual organ doses (see below). Licensee technical specifications require that exposure to liquid and gaseous effluents conform to the numerical 1629 1630 guidance in 10 CFR Part 50, Appendix I. In accordance with 10 CFR 50.34a, these numerical guides for design objectives and limiting conditions of operation are not to be construed as radiation protection 1631 1632 standards. For these dose calculations, the following terms are generally used:

1634 1. air doses (gamma and beta), total body doses, and organ doses (based on ICRP-2),

- 1635 2. effluent discharges only (excludes direct radiation from the facility and ISFSIs),
- 1636 3. current annual period (excludes accumulated radioactivity from prior-year effluents), and
- 1637 4. unrestricted area (excludes individuals in the restricted areas and controlled areas).1638

When calculating air doses, licensees should assure that, for any location outside the site boundary, doses do not exceed the dose objectives in 10 CFR Part 50, Appendix I. Calculation of air dose at the site boundary would assure the most conservative calculation of air doses for ground-level releases. This may not be true for elevated releases. Licensees should select a location that assures the most conservative calculation of air dose.

1644
1645 5.5 10 CFR 20.1301(a) NRC dose limits for individual members of the public 1646 1647 This regulation specifies dose limits for members of the public from licensed operation of the 1648 facility. These limits apply to doses resulting from licensed and unlicensed radioactive material and from 1649 radiation sources other than background radiation (see 10 CFR 20.1001, "Purpose"). The dose limits include contributions to doses from (1) current-year effluents, (2) current-year direct radiation from the 1650 1651 facility, and (3) accumulated radioactivity from prior-year effluents. The Technical Specifications 1652 establish the Radioactive Effluent Controls Program and the Environmental Monitoring Program, which establish effluent control methods sufficient to demonstrate of compliance with the NRC public dose 1653 1654 limits in 10 CFR 20.1301(a). 1655 1656 5.6 10 CFR 20.1301(e) EPA Environmental Radiation Standards for the Uranium Fuel Cycle 1657 1658 For those facilities subject to the EPA's generally applicable environmental radiation standards in 40 CFR Part 190, licensees must assess the highest cumulative (whole body and organ) doses from the 1659 uranium fuel cycle to a real individual in the general environment (i.e., outside the site boundary). The 1660 dose limits include contributions to doses from (1) current-year effluents, (2) current-year direct radiation 1661 from the facility, and (3) accumulated radioactivity from prior-year effluents. The Technical 1662 Specifications establish the Radioactive Effluent Controls Program and the Environmental Monitoring 1663 1664 Program, which establish effluent control requirements sufficient to demonstrate compliance with the EPA public dose limits in 40 CFR Part 190 (see NUREG-0543). 1665 1666 1667 These requirements include the following considerations: 1668 1669 1. "Whole body and organ doses" come from ICRP-2 concepts. 1670 "Any member of the public" means any individual except when that individual is receiving an 1671 2. 1672 occupational dose. 1673 The "unrestricted area" means an area, access to which is neither limited nor controlled by the 1674 3. 1675 licensee. The boundaries of the unrestricted area are defined by the licensee. (See also the definition of "generally applicable environmental radiation standards" in 10 CFR 20.1003.) 1676 1677 1678 "Current-year effluents" includes both normal and abnormal discharges to the unrestricted area. 4. 1679 "Current-year direct radiation" includes all direct radiation from the facility (e.g., radioactive 1680 5. waste storage and ISFSIs) but excludes doses from radioactive waste shipments. 1681 1682 1683 6. "Cumulative" dose means the sum of (1) current-year effluent dose, (2) current-year direct radiation dose, and (3) dose from accumulated radioactivity if not already included in the first two 1684 1685 items. 1686 1687 "Accumulated radioactivity" includes radioactive material in the unrestricted area from prior-year 7. discharges that remains in the environment (e.g., tritium in lake water or radionuclides). 1688 1689 The "uranium fuel cycle" excludes uranium mining, radioactive waste shipping (in the 1690 8. 1691 unrestricted area), operations at waste disposal sites, and reuse of nonuranium special nuclear materials. (See the definition of "uranium fuel cycle" in 40 CFR Part 190 and in the glossary of 1692 1693 this document.) 1694

1695	5.7	Dose .	Assessments for 10 CFR Part 50, Appendix I			
1696						
1697		Dose	assessments to show compliance with technical specification requirements for meeting the			
1698	numerical values of 10 CFR Part 50, Appendix I, design objectives should include quarterly and annual					
1699	doses	doses using the considerations in Section 5.4 of this RG. The dose assessments should be reported in a				
1700	forma	at similar	to that shown in Table A-4 in Appendix A to this RG and include the items listed below:			
1701						
1702	1.	doses	from liquid effluents			
1703		a.	total body dose, quarterly and annually;			
1704		b.	organ dose, quarterly and annually (maximum, any organ); and			
1705		c.	percent of limits for each of the above.			
1706						
1707	2.	doses	from gaseous effluents			
1708		a.	beta and gamma air doses, quarterly and annually;			
1709		b.	organ dose commitment from iodine, tritium, and particulate releases with half-lives			
1710			greater than 8 days, quarterly and annually; and			
1711		с.	percent of limit for each of the above.			
1712						
1713		An ev	aluation of the local exposure pathways to determine the maximum exposed member of the			
1714	public	c should	be performed. However, maximum doses from various exposure pathways are not additive			
1715	from	different	locations. For example, dose from a downstream drinking water exposure pathway should			
1716	not be	e added t	o the dose to an upstream resident whose exposure is from gaseous effluents and direct			
1717	radiat	tion unles	ss that individual's drinking water is obtained from the downstream location.			
1718						
1719		"Maxi	imum" doses to real individuals should be assessed as described in RG 1.109. The locations			
1720	and e	xposure	pathways are those where real individuals are present and exposed. Maximum exposed			
1721	individuals are characterized as "maximum" with regard to food consumption, occupancy and other					
1722	usage in the vicinity of the plant site. For example, licensees should make "maximum" assumptions for					
1723	food consumption and occupancy factors at actual locations when assessing dose to the maximum					
1724	exposed individual, unless they have determined and applied site -specific (actual) data. In lieu of					
1725	assessing dose to real individuals, licensee may also use bounding dose assessments for compliance with					
1726	10 CFR Part 50, Appendix I (see the section titled "Bounding Assessments").					
1727						
1728		The o	bjective of 10 CFR Part 50, Appendix I, is to provide numerical guides for design objectives			
1729	and li	miting co	onditions for operation to ensure that radioactive effluent control equipment is effective in			
1730	reducing emissions to ALARA levels. The numerical guidance pertains to quarterly and annual dose					
1731	criter	ia at or b	eyond the unrestricted area from current-year effluent discharges. The calculations related			
1732	to Ap	pendix I	do not include dose from radioactivity in prior-year, accumulated, effluent discharges			
1733	(e.g.,	last year	's radioactivity remaining in lake water is excluded). However, the dose calculations for			
1734	demo	nstrating	compliance with the EPA limits do include accumulated radioactivity (see Section 5.8 of			
1735	this R	CG).				
1736						
1737		For pt	urposes of demonstrating compliance with dose criteria for limiting dose to a member of the			
1738	public	c in unres	stricted areas in accordance with Technical Specifications conforming to 10 CFR 50,			
1739	Appe	ndix I, th	he exposure pathways and routes of exposure identified in RG 1.109 should be considered.			
1740	Anev	aluation	of other exposure pathways (not included in dose assessments) should be performed and			
1741	maint	ained for	r purposes of demonstrating compliance with the staff position on significant exposure			
1742	pathw	vays. Ca	lculational procedures should be based on models and data such that the actual exposure of			
1743	an inc	lividual t	through appropriate pathways is unlikely to be substantially underestimated. A new			
1744	expos	sure path	way should be included in the demonstration of compliance if the calculated dose from that			
1745	new e	exposure	pathway exceeds 10 percent of the 10 CFR 50 Appendix I. Section II numerical guides on			
		1				

1746 1747	design evaluat	objectives. Bounding dose assessments as described in Section 5.1 of this RG may be used in ing the dose from any new significant exposure pathways.			
1748					
1749		Real exposure pathways are identified for routine discharges and direct radiation based on the			
1750	results	of the land use census. Dose calculations should typically be performed based on real exposure			
1751	pathwa	ys. Conversely, dose assessments (i.e., surveillances and dose calculations) are not needed for			
1752	exposu	re pathways that do not exist at a site. For example, if the land use census does not identify the			
1753	existen	ce of an ingestion exposure pathway involving a milk animal, the licensee is not required to assess			
1754	that rou	te of exposure for the ingestion exposure pathway. Similarly, if a licensee discharges liquid			
1755	radioac	tive waste to a body of water (either surface water or groundwater) and that body of water is not			
1756	used as	a source of drinking water (either private or public), a drinking water assessment is not required.			
1757	For put	poses of reporting information in the ARERR, there is a distinction between dose assessments for			
1758	10 CFF	R Part 50, Appendix I, and hazard assessments that may be conducted for onsite spills and leaks, as			
1759	outline	d in 10 CFR 20.1501 (where bounding estimates may be necessary). (See the discussion of			
1760	boundi	ng dose estimates in Section 5.1 of this RG.)			
1761					
1762	5.8	Dose Assessments for 10 CFR 20.1301(e)			
1763					
1764		To show compliance with 10 CFR 20.1301(e), dose assessments should be reported according to			
1765	the gen	erally applicable environmental radiation standards in 40 CFR Part 190, with consideration of			
1766	Section	5.6 of this RG, and in a format similar to Table A-5 of Appendix A to this RG.			
1767					
1768	5.8.1	The following should be reported:			
1769	0.011				
1770	•	whole body dose to the maximum individual member of the public			
1771		thyroid dose to the maximum individual member of the public			
1772		dose to any other organ to the maximum individual member of the public,			
1772	•	dose to any other organ to the maximum individual member of the public, and			
1//3	•	percent of the applicable limit.			
1//4	500	One means of demonstration controlion or with 40 CEP. Post 100 is listed in Mahuma 42 of the			
1776	3.8.2	Figure Desister, none 2850, which states the following:			
1//0		Federal Register, page 2859, which states the following:			
1///					
1//8		In the case of light water reactors, demonstrating conformance with			
1700		Appendix 1 of 10 CFR 50 are generally adequate for demonstrating compliance			
1780		with [EPA 40 CFR Part 190].			
1/81					
1782		As a result, a licensee that (1) can demonstrate that external sources of direct radiation are			
1783	indistinguishable from background and (2) demonstrates compliance with the numerical dose guidance of				
1784	10 CFF	R Part 50, Appendix I, may cite the above reference as the basis for demonstrating compliance with			
1785	40 CFF	R Part 190. The NRC provides additional guidance in NUREG-0543, "Methods for Demonstrating			
1786	Compl	iance with the EPA Uranium Fuel Cycle Standard (40 CFR Part 190).			
1787					
1788		However, licensees that (1) have external sources of direct radiation that are above background			
1789	and (2)	demonstrate compliance with the numerical dose guidance of 10 CFR Part 50, Appendix I, must			
1790	also in	clude sources of direct radiation from uranium fuel cycle operations (e.g., including direct radiation			
1791	from th	e licensed facility and co-located or nearby nuclear power facilities, as appropriate).			
1792					
1793	5.8.3	The dose contributions from direct radiation may be estimated based on either (1) direct radiation			
1794		measurements (e.g., thermoluminescent dosimeters, optically stimulated dosimeters, radiation			
1795		detection instruments), (2) calculations, or (3) a combination of measurements and calculations.			

When direct radiation dose is determined by measurement, RG 4.13 provides guidance on
determining the dose to members of the public. Several sources contain additional information
on background subtraction for environmental dosimeters (Refs. 29, 79, 80, and 81). Methods of
determining dose from direct radiation to the maximum exposed individual member of the public
may also include extrapolation methods.

Licensees must demonstrate compliance with 10 CFR 20.1301(e) for the generally applicable
environmental radiation standards in 40 CFR Part 190. These include the concept of a total dose (to the
whole body and to any organ) from all sources related to the uranium fuel cycle (such as adjacent or
nearby nuclear power plants).

1807 Contributions to the total dose from radioactive effluents (liquid and gaseous) and direct radiation 1808 should be included, if applicable. Other sources (e.g., accumulated radioactive materials in offsite ponds 1809 or lakes from previous years' discharges) should also be included, if applicable, when estimating the total 1810 dose. However, if the contributions from direct radiation or accumulated radioactivity are generally 1811 minor (as evaluated and documented in a licensee technical evaluation as not contributing to the total 1812 dose), these contributions need not be included in the total dose evaluation, but the basis for exclusion 1813 should be documented.

1814

1816

1826

1801

1815 5.9 Dose Calculations

Acceptable dose assessment models, such as those provided in RGs 1.109, 1.111, 1.112, and 1.113, should be used to make dose calculations. When calculating organ doses from airborne effluents for purposes of demonstrating compliance with Technical Specifications conforming to 10 CFR 50, Appendix I, contributions from I-131, I-133, tritium, and radionuclides in particulate form with half-lives greater than 8 days should be included in the assessment. For demonstrating compliance with EPA 40 CFR 190, in addition to the above radionuclides, doses from C-14 should be included in organ dose assessments.

1825 6. Solid Radioactive Waste Released from the Unit

1827 Section 5.6, "Reporting Requirements," in the Standard Technical Specifications normally
1828 requires reporting of "solid waste released from the unit" (see NUREG-1430, 1431, 1432, 1433, and 1434
1829 (Refs. 82 - 86)). The data reported should be for the LLW volumes shipped from the unit (plant site).

Solid radioactive waste shipments should be reported in a format similar to that of Table A-3 in
Appendix A to this RG. The total curie quantity and major radionuclides in the solid waste shipped off
site should be determined and reported.

1835 1836

1837

1838

1839 1840

1841

1842

1843

The data should be divided by the waste stream categories listed in Table A-3. The waste streams are:

- (1) wet radioactive waste (e.g., spent resin, filters, sludges, etc.),
- (2) dry radioactive waste (e.g., trash, paper, discarded protective clothing etc.),
- (3) activated or contaminated radioactive material (e.g., equipment or bulk radioactive material, etc.), and
 - (4) other radioactive waste (waste not included in the above categories and not excepted from reporting as described below).

1844 Shipments that do not need to be reported include shipments of metal melt, contaminated
1845 equipment for transfer between licensees or equipment for refurbishment, contaminated laundry (either
1846 launderable or dissolvable), or radioactive samples for analysis. Potentially contaminated dry active

1847	waste s	ent for resurvey and segregation (sometimes referred to as "green is clean") does not need to be				
1848	reported. Equipment shipped for decontamination and free release does not need to be reported.					
1849	However records of these types of shipments should be maintained on site					
1850		,				
1851		Note 1: Data on LLW disposed in licensed LLW disposal facilities is available using the Manifest				
1051	I. fame	Note 1. Data on ELW disposed in needsed ELW disposal facilities is available using the Maintest				
1852	Informa	ation Management System operated by the U.S. Department of Energy.				
1853						
1854		Note 2: There are no requirements for reporting storage of LLW at nuclear power plants.				
1855	Howev	er, LLW storage records should be established and maintained at nuclear plants and made				
1856	availab	le for NRC inspection during routine effluent inspections consistent with applicable NRC				
1857	require	ments.				
1858	•					
1859						
1860	7.	Reporting Errata in Effluent Release Reports				
1861		Reporting Errum in Errucite Release Reports				
1862		Errors in radioactive affluent release reports should be classified and reported as described below.				
1002		Errors in radioactive erruent release reports should be classified and reported as described below.				
1003	7 1					
1864	/.1	Examples of Small Errors				
1865						
1866		Small errors may be any of the following:				
1867						
1868	1.	inaccurate reporting of dose that equates to ≤ 10 percent of the applicable 10 CFR Part 50,				
1869		Appendix I, design objective or ≤ 10 percent of the EPA public dose criterion;				
1870						
1871	2.	inaccurate reporting of curies (or release rates, volumes, etc.) that equate to ≤ 10 percent of the				
1872		affected curie total (or release rate volume etc.) after correction:				
1873		anceled curie total (or release rate, volume, etc.) after correction,				
1874	2	omissions that do not impede the NPC's ability to adequately assess the information supplied by				
1074	5.	the licensees or				
18/5		the incensee; of				
18/6						
18//	4.	typographical errors or other errors that do not alter the intent of the report.				
1878						
1879	7.2	Reporting Small Errors				
1880						
1881		Licensees should correct small errors within 1 year of discovery and may submit the correction				
1882	with th	e next (normally scheduled) submittal of the ARERR, as follows. A brief narrative explanation of				
1883	the errors should be included in Section 8. "Errata/Corrections to Previous ARERRs," of Table A-6. The					
1884	narrative should state that the affected nages in their entirety are included as attachments to the ARER					
1885	Additionally the corrected pages in their entirety, should be submitted as an attachment (or addendum)					
1996	to the	NPEPD The corrected pages, in their chartery, should be submitted as an attachment (of addendum)				
1000		AKERK. The confected pages should reference the affected calendar year and should contain the significant of the second indicate the heating of the should be straight in the second straight in the second straight is the second				
1000	revision bars in the margins of the page to indicate the locations of the changes. If submitting corrections					
1888	to multiple ARERRs, a separate attachment (or addendum) should be made for each of the affected years.					
1889	Other methods of correcting previous ARERRs may be used, provided the corrections are clearly and					
1890	completely described.					
1891						
1892	7.3	Examples of Large Errors				
1893						
1894		Large errors may be any of the following:				
1895		6 · · · · · · · · · · · · · · · · · · ·				
1896	1.	inaccurate reporting of dose that equates to >10 percent of the 10 CFR Part 50 Appendix L or				
1897		FPA nublic dose criterion after correction:				
-0/1						

- 1898 1899 inaccurate reporting of curies (or release rate, volume, etc.) that equates to >10 percent of the 2. 1900 affected curie total (or release rate, volume, etc.) after correction; 1901 1902 3. omissions that may impede the NRC's ability to adequately assess the information supplied by 1903 the licensee; or 1904 1905 typographical errors or other errors that significantly alter the intent of the report. 4. 1906 1907 7.4 **Reporting Large Errors** 1908 Licensee should correct large errors within 90 days of discovery. The correction may be made by 1909 1910 special submittal or may be submitted with the next (normally scheduled) ARERR (if the next ARERR is to be submitted within 90 days of discovery of the error). If corrections are made by special submittal, 1911 the licensee should include a brief narrative explaining the errors. The narrative should state that the 1912 1913 affected pages, in their entirety, are included as an attachment. The corrected pages should be attached in their entirety. The corrected pages should reference the affected calendar year and should contain 1914 1915 revision bars in the margins of the page to indicate the locations of the changes. If submitting corrections 1916 to multiple ARERRs, separate attachment (or addendum) should be made for each of the affected years. 1917 If corrections are made coincident with the next (normally scheduled) submittal of the ARERR, the
- 1918 correction process should be used as specified in Section 7.2 (for small errors). Other methods of
- 1919 correcting previous ARERs may be used provided the corrections are clearly and completely described
- 1920 consistent with NRC requirements on the completeness and accuracy of information.

1922

1923 8. Changes to Effluent and Environmental Programs

1924 Standard Technical Specifications (e.g., Section 5.5, "Programs and Manuals") establishes 1925 1926 requirements for the radioactive effluent controls and radiological environmental monitoring activities. 1927 The Technical Specifications establish a specific review and approval process for making changes to the 1928 ODCM. Potential changes require licensee analyses or evaluations justifying the change and a 1929 determination that the changes maintain the levels of radioactive effluent control required 1930 by10 CFR 20.1302, 40 CFR 190, 10 CFR 50.36a, and 10 CFR 50, Appendix I. The evaluation of potential 1931 changes should also consider the need for monitoring in support of decommissioning planning during 1932 operations (see RG 4.22). 1933

1934 Effluent and environmental monitoring programs may need to be modified once power operations have permanently ceased and a written certification has been submitted to the NRC in accordance with 1935 1936 10 CFR 50.82, "Termination of License." The evaluation of potential changes should consider the need 1937 for effluent and environmental monitoring during active decommissioning which is likely to affect 1938 principal release points and principal radionuclides. For example, the removal of effluent ventilation 1939 systems will likely change principal release points and there may be new principal radionuclides 1940 identified (e.g., Kr-85), while radioactive decay may have eliminated former principal radionuclides (e.g., 1941 I-131) (see Section C.1). Potential changes must be reviewed and approved by the plant manager, station 1942 manager, or as described in plant-specific Technical Specifications, with submittal to the NRC as part of 1943 the next Annual Radioactive Effluent Release Report.

1944

If the plant has a 10 CFR Part 72 ISFSI, the licensee must maintain compliance with the requirements
in 10 CFR Part 72 regarding controls of effluent(s) and an environmental monitoring program. These
requirements include 10 CFR 72.44(d) for 10 CFR Part 72 specific license ISFSIs and, for
10 CFR Part 72 general license ISFSIs, any requirements specified in technical specifications of the
certificate(s) of compliance for the storage systems in use at the ISFSI (to comply with
10 CFR 72.212(b)(3) and (b)(5)).

1951

1952 The radiological criteria for license termination are addressed in 10 CFR 20 Subpart E. The 1953 radiological criteria for unrestricted use (10 CFR 20.1402) encompass contributions from residual 1954 radioactivity in soils and remnant site components and in groundwater. While some reductions in 1955 monitoring programs may be possible when operations cease, other aspects of monitoring such as 1956 groundwater monitoring may need to be increased to adequately characterize residual radioactivity and 1957 characterize dispersion pathways to support dose assessments and to estimate the decommissioning costs. Lessons learned documented in RG 1.185 and NUREG-1757 indicate that the monitoring data from the 1958 1959 period of operation tend to be insufficient to allow the staff to fully understand the types and the 1960 movement of radioactive material contamination in groundwater at the facility, as well as the extent of the 1961 residual radioactivity. Decommissioning reporting and recordkeeping requirements are addressed in 1962 10 CFR 50.75(g). 1963

Further general guidance to facilitate planning for decommissioning of power plants and
facilities during operations can be found in RG 4.22, in RG 1.185 for post-shutdown decommissioning
activities, in NUREG-1757 for consolidated decommissioning guidance, and in NUREG-1575, Rev. 1,
"Multi-Agency Radiation Survey and Site Investigation Manual."

1968 1969 1970

9. Format and Content of the Annual Radioactive Effluent Release Report

In accordance with 10 CFR 50.4, "Written communications," licensees should submit their 1973 annual report electronically or in a written communication. The report should consist of a summary of the 1974 1975 numerical data in a tabular format similar to Tables A-1–A-5 in Appendix A to this RG. Effluent data reported in Tables A-1, A-1A – A-1F, A-2, A-2A, A-2B, and A-4 should be summarized on a quarterly 1976 1977 and annual basis. Tables A-3 and A-5 should be summarized on an annual basis. In addition to 1978 numerical data, the report should include additional supplemental information containing all the 1979 information in (but not necessarily in the format of Table A-6). Additional detail for the information 1980 contained in each of these tables is listed below. To comply with 10 CFR 50.36a, licensee must submit 1981 their ARERR by May 1 (unless a licensing basis exists for a different submittal date) to report on 1982 effluents and solid waste from the previous calendar year. 1983

1984 Radionuclides that are not detected do not need to be listed in the tables (Tables A-1A-A-1F, A-1985 2A, and A-2B). Activity that is detected should be reported in the appropriate tables (i.e., Tables A-1, A-1986 2, A-1A – A-1F, A-2A, and A-2B) in the ARERR, provided that the amount discharged is numerically 1987 significant with respect to the three-digit exponential format recommended for the ARER. This should 1988 not be confused with three significant figures. Licensees may round numbers according to accepted 1989 practices (e.g., refer to ASTM E-29, "Standard Practice for Using Significant Digits in Test Data to 1990 Determine Conformance with Specifications" (Ref. 87)); however, after rounding has been completed, 1991 values should be reported in the ARERR in a three-digit exponential format. Measurements should be 1992 reported for positive values. Some radionuclides that are detected in a year may not be detected in all 1993 quarters. If results are determined to be below detectable levels for an entire quarter, the table entry 1994 should include a suitable designation (e.g., N/D (not detected) and an accompanying footnote) to denote 1995 that measurements were performed but activity was not detected. 1996

1997 The format specified in this RG revision differs slightly from the format specified in Revision 1 and Revision 2. The format and content specified in this Revision 3 of RG 1.21 is one acceptable method 1998 1999 of reporting the data. Other formats may be used (e.g., some tables may be combined) as long as the 2000 specified content is provided (e.g., quarterly totals and annual totals by each release category). However, licensees are encouraged to use the format listed below to maximize consistency in data reporting. This 2001 format is designed to be consistent with some commonly used electronic-data-reporting software 2002 2003 packages. Consistency in reporting format aids review by members of the public and allows easier 2004 industrywide comparisons of the data.

10 CFR 72 licensees may also, if they choose to do so, use the format specified in this RG for
independent spent fuel storage installation (ISFSI) effluent reports required by 10 CFR 72.44(d) (for
specific licenses) or the storage system(s) certificate(s) of compliance (for general licenses). However,
the ISFSI effluent reporting requirement is not normally satisfied by inclusion as part of the ARERR
since the reporting dates may conflict. If the dates are coincident, or can be met with a single report,
licensees may use the ARERR to fulfill the ISFSI reporting requirements, provided the licensee submits a
copy as specified in those requirements (e.g., 10 CFR 72.44(d)(3) for specific licenses).

2014 9.1 Gaseous Effluents

2005

2015

2016The quarterly and annual sums of all radionuclides discharged in gaseous effluents (i.e., routine2017and abnormal discharges, continuous, and batch) should be reported in a format similar to that of2018Tables A-1A – A-1F in Appendix A to this RG. The data should then be further summarized and2019reported in the format of Table A-1.20202020

2021Table A-1, "Gaseous Effluents—Summation of All Discharges," contains a summation of all2022gaseous effluent discharges from all release points and all modes of release. The data are subdivided by

2023	quarter and year for each radionuclide category: fission and activation gases, iodines/halogens,
2024	particulates, tritium, gross alpha and carbon-14.
2025	Table A-1A, "Gaseous Effluents—Ground-Level Release—Batch Mode," contains a summation
2026	of gaseous effluent releases from ground-level release points in the batch mode of release for six
2027	radionuclide categories: fission and activation gases, iodines/halogens, particulates, tritium, gross alpha
2028	and carbon-14. Licensees should report the following:
2029	
2030	1. curies of each radionuclide discharged by quarter and year, and
2031	
2032	2. total curies discharged in each radionuclide category by quarter and year.
2033	
2034	Some licensees may have surveillance requirements allowing the non-noble gas radionuclides
2035	(e.g., jodines and tritium) for some types of batch releases (e.g., containment purge) to be reported with
2036	continuous release results. In these instances, the table entries for the affected radionuclides for batch
2037	releases should include an appropriate designation (e.g. "*") and an accompanying footnote describing
2038	this situation
2039	
2032	Table A-1B "Gaseous Effluents—Ground-Level Release—Continuous Mode" contains a
2040	summation of gaseous effluent releases from ground-level release points in the continuous mode of
2041	release for six radionuclide categories: fission and activation gases iodines/halogens, particulates
2042	tritium gross alpha and carbon-14. Licensees should report the following:
2043	undun, gross alpha and carbon-14. Electisees should report the following.
2044	1 curies of each radionuclide discharged by quarter and year, and
2045	 curies of each radionuclide discharged by quarter and year, and total curies discharged in each radionuclide category by quarter and year.
2040	2. total curies discharged in each radionuclide category by quarter and year.
2047	Table A. 1C. "Casesus Effluents Elevated Balance Batch Made" contains a summation of
2048	Table A-TC, Gaseous Effluents—Elevated Release—Batch Mode, Contains a summation of
2049	gaseous enfuent releases from elevated release points in the batch mode of release for six radionuclide
2030	categories. Institution gases, routiles/natogens, particulates, trittuin, gross alpha, and carbon-
2051	14. Licensees should report the following:
2052	1 and a second second by success a second
2035	1. Curies of each radionuclide released by quarter and year, and
2054	2. total curies released in each radionuclide category by quarter and year.
2055	
2056	Some licensees may have surveillance requirements allowing the non-hoble gas radionuclides
2057	(e.g., iodines and tritium) for some types of batch releases (e.g., containment purge) to be reported with
2058	continuous release results. In these instances, the table entries for the affected radionuclides for batch
2059	releases should include an appropriate designation (e.g., "*") and an accompanying footnote describing
2060	this situation.
2061	
2062	Table A-1D, "Gaseous Effluents—Elevated Release—Continuous Mode," contains a summation
2063	of gaseous effluent releases from elevated release points in the continuous mode of release for six
2064	radionuclide categories: fission and activation gases, iodines/halogens, particulates, tritium, gross alpha
2065	and carbon-14. Licensees should report the following:
2066	
2067	1. curies of each radionuclide released by quarter and year, and
2068	
2069	2. total curies released in each radionuclide category by quarter and year.
2070	
2071	Table A-1E, "Gaseous Effluents—Mixed Mode Release—Batch Mode," contains a summation of
2072	gaseous effluent releases from mixed-mode release points in the continuous mode of release for six

radionuclide categories: fission and activation gases, iodines/halogens, particulates, tritium, gross alpha,
and carbon-14. Licensees should report the following:

- 2076 1. curies of each radionuclide released by quarter and year, and
- 2077 2078

2079

2085

2090

2092

2094

2096

2. total curies released in each radionuclide category by quarter and year.

2080 Some licensees may have surveillance requirements allowing the non-noble gas radionuclides 2081 (e.g., iodines and tritium) for some types of batch releases (e.g., containment purge) to be reported with 2082 continuous release results. In these instances, the table entries for the affected radionuclides for batch 2083 releases should include an appropriate designation (e.g., "*") and an accompanying footnote describing 2084 this situation.

2086Table A-1F, "Gaseous Effluents—Mixed Mode Release—Continuous Mode," contains a2087summation of gaseous effluent releases from mixed-modes release points in the continuous mode of2088release for six radionuclide categories: fission and activation gases, iodines/halogens, particulates,2089tritium, gross alpha, and carbon-14. Licensees should report the following:

2091 1. curies of each radionuclide released by quarter and year, and

2093 2. total curies released in each radionuclide category by quarter and year.

2095 9.2 Liquid Effluents

2097The quarterly and annual sums of all radionuclides discharged in liquid effluents (i.e., routine and2098abnormal discharges, continuous, and batch) should be reported in a format similar to that of Tables A-2A2099and A-2B. The data should then be further summarized and reported in the format of Appendix A,2100Table A-2.

2101

2106

Table A-2, "Liquid Effluents—Summation of All Releases," contains a summation of all liquid
radioactive discharges from all release points and all modes of release. The data are subdivided by
quarter and year for each of the radionuclide categories: fission and activation products, tritium,
dissolved and entrained noble gases, and gross alpha.

2107 The table also includes the total volume of "primary coolant waste" (typically batch mode 2108 releases) before dilution. In this context, "primary coolant waste" means the higher activity waste that generally is not discharged directly but is instead typically processed through the liquid radioactive waste 2109 treatment system before discharge. Various methods exist for calculating the dilution water flow rate. 2110 2111 HPPOS-099, "Attention to Liquid Dilution Volumes in Semiannual Radioactive Effluent Release 2112 Reports," issued November 1984 (Ref. 88), indicates that licensees should use the total volume of dilution flow, not just that flow during periods of liquid effluent releases. Licensees should include information 2113 describing how this value is calculated in either the ODCM or the ARERR. Because the primary coolant 2114 2115 waste typically accounts for the vast majority of the radioactivity in liquid waste discharges, the NRC recommends that the volume and dilution data be summarized separately from the low-activity waste 2116 2117 described in the following paragraph. 2118

The total measured volume or average flow rate of waste from secondary or balance-of-plant systems (e.g., steam generator blowdown, low-activity waste sumps, and auxiliary boilers) should be reported. In this context, secondary or balance-of-plant waste means the typically very low-activity waste that is generally not processed with the liquid radioactive waste treatment system and that collectively represents a very large volume of waste. Various methods exist for calculating the dilution water flow

2124	rate. H	PPOS-099 states that licensees should use the total volume of dilution flow, not just that volume				
2125	discharg	ged during periods of liquid effluent releases. Licensees should include information describing				
2126	how this value is calculated in either the ODCM or the ARERR. Because of the potentially high volume					
2127	and extremely low activity of this type of waste, the NRC recommends the volume and dilution data be					
2128	summar	rized separately from the higher activity waste described in the previous paragraph.				
2129						
2130		Licensees should report dilution flow rates during periods of release (before effluent is discharged				
2131	to the re	eceiving water body) as described above. If calculated differently than described above, the				
2131	licensee	e should describe the method of calculation. Licensees may choose to report near-field dilution if				
2132	they acc	count for dilution by the receiving water body. Licensees may enouse to report the average minimum neak				
2133	river a	ad stream flow rates as annlicable				
2134	iivei, ai	in stream now rates, as appreable.				
2135		Table A-2A "Liquid Effluents-Batch Mode" contains a summation of liquid effluent				
2130	dischar	rable A-2A, Elquid Efficients—Daten Wood, contains a summation of right efficient				
2137	and act	ges in the batch mode of release. The table is divided into four radionachide categories. Itssion				
2130	the foll	ivation products, trittum, dissorved and entrained gases, and gross alpha. Licensees should report				
2139	the follo	owing:				
2140	1					
2141	1.	curies of each radionuclide and gross alpha discharged by quarter and year, and				
2142	2					
2143	Ζ.	total curies in each radionuclide category by quarter and year.				
2144						
2145	1. 1	Table A-2B, "Liquid Effluents—Continuous Mode," contains a summation of liquid effluent				
2146	discharg	ges in the continuous mode of release. The table is divided into four radionuclide categories:				
2147	fission a	and activation products, tritium, dissolved and entrained gases, and gross alpha. Licensees should				
2148	report t	he following:				
2149						
2150	1.	curies of each radionuclide and gross alpha discharged by quarter and year, and				
2151						
2152	2.	total curies in each radionuclide category by quarter and year.				
2153						
2154	9.3	Solid Waste Shipments Released from the Unit (per Standard Technical Specifications)				
2155						
2156		Appendix A, Table A-3, provides an acceptable format for reporting the solid radioactive waste				
2157	released	d (shipped) from the unit (plant site) during the reporting period. The NRC intends that licensees				
2158	report t	he waste shipped from the site, regardless of whether the shipment is sent for waste processing or				
2159	direct d	isposal (i.e., with or without waste processing).				
2160						
2161		Licensee should report the volume and curies of solid waste shipped (see exceptions noted in				
2162	Section	6) for each of the following waste streams:				
2163						
2164	1.	wet radioactive waste (e.g., spent resins, filters, sludges, etc.),				
2165						
2166	2.	dry radioactive waste (e.g., trash, paper, discarded protective clothing, etc.),				
2167						
2168	3.	activated or contaminated radioactive material (e.g., equipment or bulk radioactive material, etc.).				
2169		and				
2170						
2171	4.	other radioactive waste (waste not included in the above categories and waste not excepted from				
2172		reporting requirements in Section 6).				
2173						

2174 9.4 Dose Assessments

2175

2182

2188

2192

2196

2205

2210

2212

Licensees should calculate the annual evaluations of dose to members of the public using
 RG 1.21, Section 5 and report the data in the format of Tables A-4 and A-5. Dose assessments should
 demonstrate compliance with the following⁹:

- 21801.Licensees should demonstrate compliance with 10 CFR Part 50, Appendix I (see Table A-4), by2181doing the following¹⁰:
- 2183a.Reporting the calculated dose from liquid effluents on a quarterly and annual basis to the2184total body and maximum organ and the percentage of the 10 CFR Part 50, Appendix I,2185design objectives for the maximum exposed individual. If a particular exposure pathway2186is not applicable (i.e., it does not exist at a site), do not calculate the dose for that2187exposure pathway.
- 2189b.Reporting the highest air dose from gaseous effluents on a quarterly and annual basis at
any location that could be occupied by individuals in the unrestricted area and the
percentage of the 10 CFR Part 50, Appendix I, design objectives.
- 2193c.Reporting the organ dose from iodine, tritium, and particulates with a half-life greater2194than 8 days to the maximum exposed individual in an unrestricted area from all pathways2195of exposure (e.g., submersion and ingestion).
- 2. Licensees must demonstrate compliance with 10 CFR 20.1301(e) and 40 CFR Part 190 (see Table A-5) as follows:
- 2200a.Reporting the whole body, thyroid, and highest dose to any other organ from licensed and2201unlicensed radioactive material in the uranium fuel cycle, excluding background, to the2202individual member of the public likely to receive the highest dose.2203

2204 9.5 Supplemental Information

Licensees should provide supplemental information in a descriptive, narrative form (see Table A-6 or in a similar format). Relevant information and a description of circumstances should be provided as appropriate for each the following categories, adding categories as appropriate. The annotation N/A should be used if a category is not applicable.

2211 9.5.1 Abnormal Releases or Abnormal Discharges

The reporting of abnormal releases to onsite areas and abnormal discharges to unrestricted areas
 should include the following:

Specific information should be reported concerning abnormal (airborne, liquid) releases on site
 and abnormal discharges to the unrestricted area. The report should describe each event in a way
 that would enable the NRC to adequately understand how the material was released and if there
 was a discharge to the unrestricted area. The report should describe the potential impact on the

⁹ As noted in Section C.5, dose assessments for 10 CFR 72.104 should include the components necessary to appropriately demonstrate compliance with those limits.

¹⁰ The type of individual or dose receptor should be identified as a real individual or as a hypothetical individual if using bounding dose assessments; the individual/ receptor is in the unrestricted area.

2220		ingestic	on exposure pathway involving surface water and groundwater, as applicable. The report
2221		should	also describe the impact (if any) on other affected exposure pathways (e.g., inhalation).
2222			
2223	2.	The fol	lowing are the thresholds for reporting abnormal releases and abnormal discharges in the
2224		supplen	nental information section:
2225			
2226		a.	abnormal releases or abnormal discharges that are voluntarily reported to local authorities
2227			under Nuclear Energy Institute 07-07. Revision 1. "Industry Groundwater Protection
2228			Initiative—Final Guidance Document," dated February 26, 2019 (Ref. 89);
2229			
2230		b.	abnormal releases or abnormal discharges estimated to exceed 300 liters (100 gallons) of
2231			radioactive liquid where the presence of licensed radioactive material is positively
2232			identified (in either the onsite environs or in the source of the leak or spill) as greater than
2233			the minimum detectable activity ¹¹ for the laboratory instrumentation:
2234			
2235		C	abnormal releases to onsite areas that result in detectable residual radioactivity after
2235		С.	remediation:
2230			Temediation,
2237		d	abnormal releases that result in a high effluent radiation alarm without an anticipated
2230		u.	system trip occurring: and
2237			system up occurring, and
2240		۵	abnormal discharges to an unrestricted area
2241 2242		с.	abiormal discharges to an unrestricted area.
2243	3.	Informa	ation on abnormal releases or abnormal discharges should include the following, as
2244	5.	applical	hle.
2245		appirea	
2246		a.	date and duration.
2247		b.	location.
2248		c.	volume.
2249		d.	estimated activity of each radionuclide,
2250		e.	effluent monitoring results (if any).
2251		f.	onsite monitoring results (if any).
2252		g.	depth to the local water table.
2253		h.	classification(s) of subsurface aguifer(s) (e.g., drinking water, unfit for drinking water.
2254			not used for drinking water).
2255		i	size and extent of any groundwater plume
2256		i	expected movement/mobility of any groundwater plume
2257		k.	land use characteristics (e.g., water used for irrigation).
2258		1	remedial actions considered or taken and results obtained
2259		m	calculated member of the public dose attributable to the release
2260		n.	calculated member of the public dose attributable to the discharge
2261		0	actions taken to prevent recurrence as applicable and
2262		n.	whether the NRC was notified the date(s) and the contact organization
2263		Ь.	mether the rate was notified, the date(s), and the contact organization.
2263	952	Nonrou	tine Planned Discharges
2265	1.5.2	1,0111,00	Ante Frantier Elisentie Bos

¹¹ The minimum detectable activity is a post-analysis calculation of sensitivity level based on the actual sample measurement.

2266		Dischar	rges resulting from remediation efforts that are not identified in the ODCM should be		
2267	reporte	reported. For example, the remediation effort may include pumping of contaminated groundwater in			
2268 2269	respons	se to leal	ks and spills.		
2270 2271	9.5.3	Radioa	ctive Waste Treatment System Changes		
2271		License	ees should report any changes or modifications affecting any portion of the gaseous		
2272	radioac	tive was	the treatment system, the ventilation exhaust treatment system, or the liquid radioactive		
2273	waste t	reatment	t		
2274	waste t	reatment			
2275	954	Annual	Land Use Census Changes		
2277	2.5.1	7 minuu	Lund Obe Centrus Chunges		
2278		License	ees should report any changes or modifications affecting significant aspects of the		
2279	enviror	mental	monitoring program such as receptors, receptor locations, sample media availability, or		
2280	new (or	r change	d) routes of exposure.		
2281					
2282	9.5.5	Effluen	t Monitoring System Inoperability		
2283	21010	2111001			
2284		License	ees should report information on inoperable effluent monitors as follow:		
2285					
2286		1.	If an effluent radiation monitor is not operable for the consecutive time period listed in		
2287			the licensee's ODCM or technical specifications (typically 30 days), then the ARERR		
2288			should include the radiation monitor's equipment designation, the common name of the		
2289			effluent radiation monitor, the time period of the inoperability, the reason why this		
2290			inoperability was not corrected in a timely manner, and any other information required by		
2291			the licensee's ODCM or technical specifications.		
2292					
2293		2.	In accordance with NUREG-1301 and NUREG-1302, Sections 3.3.3.10,b and 3.3.3.11,b.		
2294			Generic Letter 89-01, and licensee ODCMs, the information above is required only when		
2295			the minimum channels operability requirement is not achieved for the consecutive time		
2296			period listed in the ODCM (typically 30 days).		
2297			Fine mental in the end () Fine by the most of		
2298	9.5.6	Offsite	Dose Calculation Manual Changes		
2299			- sst timesining timeger		
2300		License	ees should report any changes or modifications affecting significant aspects of the ODCM.		
2301					
2302	9.5.7	Process	s Control Program Changes		
2303					
2304		License	ees should report any changes or modifications affecting significant aspects of the ODCM.		
2305					
2306	9.5.8	Correct	tions to Previous Reports		
2307					
2308		When s	submitting corrections to previous reports, licensees should do the following:		
2309					
2310		1.	Include a brief explanation of the error(s).		
2311			1		
2312		2.	State that the affected pages, in their entirety, are included as attachments to this ARERR.		
2313					
2314		3.	Ensure that a copy of the affected page(s), in their entirety, is included as an attachment		
2315			to the ARERR. The attached pages should reference the affected calendar year and		
2316			contain revision bars.		

2317
2318 9.5.9 Other (Narrative Descriptions of Other Information Related to Radioactive Effluents)
2319
2320 Licensees should report other supplemental information (as appropriate).

RG 1.21, Rev. 3, Page 51

D. IMPLEMENTATION

2323 The NRC staff may use this regulatory guide as a reference in its regulatory processes, such as 2324 licensing, inspection, or enforcement. However, the NRC staff does not intend to use the guidance in this 2325 regulatory guide to support NRC staff actions in a manner that would constitute backfitting as that term is defined in 10 CFR 50.109, "Backfitting," or in 10 CFR 72.62, "Backfitting," and as described in NRC 2326 2327 Management Directive 8.4, "Management of Backfitting, Forward Fitting, Issue Finality, and Information 2328 Requests," (Ref. 90), nor does the NRC staff intend to use the guidance to affect the issue finality of an 2329 approval under 10 CFR Part 52, "Licenses, Certifications, and Approvals for Nuclear Power Plants." The staff also does not intend to use the guidance to support NRC staff actions in a manner that constitutes 2330 2331 forward fitting as that term is defined and described in Management Directive 8.4. If a licensee believes 2332 that the NRC is using this regulatory guide in a manner inconsistent with the discussion in this 2333 Implementation section, then the licensee may file a backfitting or forward fitting appeal with the NRC in 2334 accordance with the process in Management Directive 8.4.

2335

- 2336
- 2337

2338	GLOSSARY
2339	
2340	a priori—Before-the-fact limit, representing the capability of a measurement system and not as an
2341	after-the-fact (a posteriori) limit for a particular measurement.
2342	
2343	abnormal discharge—The unplanned or uncontrolled emission of an effluent (i.e., containing
2344	plant-related. licensed radioactive material) into the unrestricted area.
2345	1,,
2346	abnormal release—The unplanned or uncontrolled emission of an effluent (i.e., containing plant-related,
2347	licensed radioactive material) into the onsite environs.
2348	
2349	accumulated radioactivity—Radioactivity from prior-year effluent releases that may still be present in
2350	the media of concern.
2351	
2352	background (radiation)—Means radiation from cosmic sources; naturally occurring radioactive
2353	material, including radon (except as a decay product of source or special nuclear material); and
2354	global fallout as it exists in the environment from the testing of nuclear explosive devices and
2355	from past nuclear accidents, such as Chernobyl, that contribute to background radiation and are
2356	not under the control of the licensee. Background radiation does not include radiation from
2357	source, byproduct, or special nuclear materials regulated by the Commission.
2358	
2359	batch release—The release of liquid (radioactive) wastes of a discrete volume or the release of a tank or
2360	purge of radioactive gases into the site environs.
2361	
2362	channel check—The qualitative assessment of channel behavior during operation by observation. This
2363	determination should include, where possible, comparison of the channel indication, status with
2364	other indications, and status derived from independent instrument channels measuring the same
2365	parameter.
2366	
2367	channel operational test—The injection of a simulated signal into the channel as close to the sensor as
2368	practicable to verify operability of alarm, interlock, and trip functions, as applicable. The channel
2369	operational test should include adjustments, as necessary, of the alarm, interlock, and trip
2370	setpoints, as applicable, such that the setpoints are within the required range and accuracy.
2371	
2372	continuous release—An essentially uninterrupted release of gaseous or liquid effluent for extended
2373	periods during normal operation of the facility where the volume of radioactive waste is
2374	non-discrete and there is input flow during the release.
2375	
2376	controlled area (10 CFR Part 20)—An area outside of a restricted area but inside the site boundary,
2377	access to which is limited by the licensee for any reason.
2378	
2379	controlled area (10 CFR Part 72)—The area immediately surrounding an ISFSI or a monitored
2380	retrievable storage installation (MRS) for which the licensee exercises authority over its use and
2381	within which ISFSI or MRS operations are performed.
2382	
2383	controlled discharge—A radioactive discharge is considered to be "controlled" if (1) the discharge was
2384	conducted in accordance with methods, and without exceeding any of the limits, outlined in the
2385	ODCM or (2) if one or more of the following three items are true:
2386	

2387	1.	The radioactive discharge had an associated, preplanned method of radioactivity
2388		monitoring that assured the discharge was properly accounted and was within the limits
2389		set by 10 CFR Part 20 and 10 CFR Part 50.
2390		
2391	2.	The radioactive discharge had an associated, preplanned method of termination (and
2392		associated termination criteria) that assured the discharge was properly accounted and
2393		was within the limits set by 10 CFR Part 20 and 10 CFR Part 50.
2394		·
2395	3.	The radioactive discharge had an associated, preplanned method of adjusting,
2396		modulating, or altering the flow rate (or the rate of release of radioactive material) that
2397		assured the discharge was properly accounted and was within the limits set by
2398		10 CFR Part 20 and 10 CFR Part 50.
2399		
2400	controlled rele	ease—A radioactive release is considered to be "controlled" if (1) the release was
2401	conduc	ted in accordance with methods, and without exceeding any of the limits, outlined in the
2402	ODCM	I or (2) if one or more of the following three items are true:
2403		
2404	1.	The radioactive release had an associated, preplanned method of radioactivity monitoring
2405		that assured the release was properly accounted and was within the limits set by
2406		10 CFR Part 20 and 10 CFR 50.
2407		
2408	2.	The radioactive release has an associated, preplanned method of termination
2409		(and associated termination criteria) that assured the release was properly accounted and
2410		was within the limits set by 10 CFR Part 20 and 10 CFR 50.
2411		
2412	3.	The radioactive release had an associated, preplanned method of adjusting, modulating,
2413		or altering the flow rate (or the rate of release of radioactive material) that assured the
2414		release was properly accounted and was within the limits set by 10 CFR Part 20 and
2415		10 CFR Part 50.
2416		
2417	conversion fac	tor —A factor (e.g., microcuries per cubic centimeter per counts per minute (μ Ci/cc/cpm)
2418	used to	estimate a radioactivity concentration in an effluent based on a gross radioactivity
2419	measur	rement (e.g., cpm).
2420		
2421	D/Q—A depos	ition value used for estimating the dose to an individual at a specified (e.g., controlling)
2422	locatio	n. D/Q may be described as the downwind surface or ground deposition (D) (e.g., in units
2423	of mici	rocuries per square meter $[\mu Ci/m^2]$) of radioactive material at a location, divided by the
2424	release	activity (Q) (e.g., in μ Ci). D/Q is thus a normalized downwind surface deposition value
2425	per uni	t release and can be used to determine the surface or ground radioactivity concentration
2426	during	a measured effluent release over a specific period of time. The units of D/Q are reciprocal
2427	square	meters.
2428		
2429	determination	—A quantitative evaluation of the release or presence of radioactive material under a
2430	specific	c set of conditions. A determination may be made by direct measurement or indirect
2431	measur	rements (e.g., with the use of scaling factors).
2452	19149 4	(for Reading the star and the December of the December of the star
2455	allution water	(IOF IIQUO FACIOACTIVE WASTE)—For purposes of this KG, any water other than the
2454	undilut	ed radioactive waste that is mixed with undiluted liquid radioactive waste before its
2455	ultimat	e discharge to the unrestricted area.
2436		

2437 **discharge point**—A location at which radioactive material enters the unrestricted area. This would be the point beyond the vertical plane of the unrestricted area (surface or subsurface). 2438 2439 2440 **drinking water**—Water that does not contain an objectionable pollutant, contamination, minerals, or infective agent and is considered satisfactory for domestic consumption. This is sometimes called 2441 2442 potable water. Potable water is water that is safe and satisfactory for drinking and cooking. 2443 Although EPA regulations only apply to public drinking water sources supplying 25 or more 2444 people (refer to the EPA for more information), for purposes of the effluent and environmental monitoring programs, the term drinking water includes water from single-use residential drinking 2445 water wells. 2446 2447 effluent—Liquid or gaseous waste containing plant-related, licensed radioactive material, emitted at the 2448 2449 boundary of the facility (e.g., buildings, end-of-pipe, stack, or container) as described in the final 2450 safety analysis report. 2451 2452 effluent discharge—The portion of an effluent release that reaches an unrestricted area. (See also the 2453 definition for radioactive discharge.) 2454 2455 effluent release—The emission of an effluent. (See also the definition for radioactive release.) 2456 2457 elevated release—A gaseous effluent release made from a height that is more than twice the height of adjacent solid structures, or releases made from heights sufficiently above adjacent solid 2458 2459 structures such that building wake effects are minimal or absent. 2460 2461 **exposure pathway**—A mechanism by which radioactive material is transferred from the (local) 2462 environment to humans. There are three commonly recognized exposure pathways: inhalation, 2463 ingestion, and direct radiation. For example, ingestion may include dose contributions from one 2464 or more routes of exposure. One route of exposure that may contribute to the ingestion exposure pathway is often referred to as grass-cow-milk-infant-thyroid route of exposure. 2465 2466 2467 general environment—An EPA 40 CFR 190.02 definition meaning the total terrestrial, atmospheric and aquatic environment outside sites upon which any (licensed) operation of a nuclear fuel cycle is 2468 2469 conducted. 2470 ground-level release—A gaseous effluent release made from a height that is at—or less than—the height 2471 2472 of adjacent solid structures, or where the degree of plume rise is unknown or is otherwise 2473 insufficient to avoid building wake effects. 2474 2475 groundwater—All water in the surface soil, the subsurface soil, or any other subsurface water. Groundwater is simply water in the ground regardless of its quality, including saline, brackish, or 2476 fresh water. Groundwater can be moisture in the ground that is above the regional water table in 2477 the unsaturated (or vadose) zone, or groundwater can be at and below the water table in the 2478 2479 saturated zone. 2480 2481 hypothetical exposure pathway—An exposure pathway in which one or more of the components 2482 involved in the transfer of a radionuclide from the environment to the human does not actually 2483 exist at the specified location, or if a real human does not consume, inhale, or otherwise become exposed to the radioactive material. For example, the grass-cow-milk-infant-thyroid route of 2484 exposure (associated with the ingestion exposure pathway) would be considered a hypothetical 2485 2486 exposure pathway if the grass, the cow, or the milk did not actually exist at a specified location or 2487 if an infant did not actually consume the milk.

2488 2489 impacted areas—The areas with some reasonable potential for residual radioactivity in excess of natural 2490 background or fallout levels. The NRC discusses impacted areas in 10 CFR 50.2 and 2491 NUREG-1757. For example, impacted areas include locations where radiological leaks or spills 2492 have occurred within the onsite environs (i.e., outside of the facility's systems, structures, and 2493 components). (See also the definition for significant contamination.) 2494 2495 leachate—Water containing contaminants that is percolating downward from a pond or lake into the 2496 subsurface. 2497 2498 less-significant release point—Any location from which radioactive material is released as a liquid or 2499 gaseous effluent contributing less than or equal to 1 percent of the activity discharged from all the 2500 release points for a particular type of effluent considered. RG 1.109 lists the three types of effluent as (1) liquid effluents. (2) noble gases discharged to the atmosphere in gaseous 2501 radioactive waste, and (3) all other nuclides discharged to the atmosphere in gaseous radioactive 2502 2503 waste. 2504 Example: If 1,000 curies (Ci) of tritium are released in all liquid effluents in a given period of 2505 time (e.g., a typical calendar year or fuel cycle) and 0.01 Ci of tritium is released in steam 2506 2507 generator blowdown, then the steam generator blowdown would be a less-significant release point. Similarly, for gaseous releases of radionuclides other than noble gases (i.e., iodine, 2508 particulates, and tritium), if the total effluents are 10 Ci (iodine, particulates, and tritium), and the 2509 2510 refueling water storage tank released 0.009 Ci of iodine, particulates, and tritium, then the refueling water storage tank would be a less-significant release point. In both examples, the 2511 sample frequency can be adjusted to an appropriate frequency for the less-significant release 2512 point. Samples collected from these systems for other programs (e.g., detection of 2513 primary-to-secondary leakage) must still be collected and analyzed at the frequencies specified by 2514 2515 the other programs. 2516 licensed material—Source material, special nuclear material, or byproduct material received, possessed, 2517 2518 used, transferred, or disposed under a general or specific license issued by the Commission. 2519 2520 lower limit of detection (LLD)—The a priori smallest concentration of radioactive material in a sample that will yield a net count, above system background, that will be detected with 95-percent 2521 probability with only a 5-percent probability of falsely concluding that a blank observation 2522 2523 represents a real signal (see NUREG-1301, NUREG-1302, and NUREG/CR-4007, "Lower Limit 2524 of Detection: Definition and Elaboration of a Proposed Position for Radiological Effluent and Environmental Measurements," issued September 1984 (Ref. 91)). 2525 2526 2527 maximum exposed individual—Individuals characterized as maximum exposed with regard to food consumption, occupancy, and other usage in the vicinity of the plant site. As such, the maximum 2528 2529 exposed individual represents individuals with habits that are considered to be maximum reasonable deviations from the average for the population in general. Additionally, in 2530 physiological or metabolic respects, the maximum exposed individual is assumed to have those 2531 characteristics that represent the averages for the corresponding age group in the general 2532 population. (This term typically refers to members of the public.) RG 1.109 contains additional 2533 2534 information. 2535 2536 member of the public (10 CFR Part 20)—Any individual except when that individual is receiving an 2537 occupational dose. 2538

member of the public (40 CFR Part 190)—Any individual that can receive a radiation dose in the 2539 general environment, whether the individual may or may not also be exposed to radiation in an 2540 occupation associated with a nuclear fuel cycle. However, an individual is not considered a 2541 member of the public during any period in which the individual is engaged in carrying out any 2542 2543 operation that is part of a nuclear fuel cycle. 2544 2545 minimum detectable concentration—The smallest activity concentration measurement that is 2546 practically achievable with a given instrument and type of measurement procedure. The 2547 minimum detectable concentration depends on factors involved in the survey measurement process (surface type, geometry, backscatter, and self-absorption) and is typically calculated 2548 following an actual sample analysis (a posteriori). (See NUREG-1507, "Minimum Detectable 2549 2550 Concentrations with Typical Radiation Survey Instruments for Various Contaminants and Field 2551 Conditions," issued June 1998 (Ref. 92)). 2552 mixed mode release—A gaseous effluent release made from a height higher than a ground-level release 2553 2554 but less than an elevated release where, sometimes, because of a lack of plume rise (e.g., buoyancy, momentum, wind speed), a proper estimate of radionuclide transport and 2555 diffusion requires mathematically splitting the plume into (1) an elevated component and (2) a 2556 ground-level component to properly account for building wake effects, release, or ambient 2557 2558 conditions (or a combination of all three). (RG 1.111 contains further guidance.) 2559 **monitoring**—With respect to radiation or radiation protection, the measurement of radiation levels, 2560 2561 concentrations, surface area concentrations, or quantities of radioactive material and the use of results of these measurements to evaluate potential exposures and doses. 2562 2563 2564 nonroutine, planned discharge—An effluent release from a release point not defined in the ODCM but 2565 that has been planned, monitored, and discharged in accordance with 10 CFR 20.2001 (e.g., the 2566 discharge of water recovered during a spill or leak from a temporary storage tank). 2567 nuclear fuel cycle—The operations defined to be associated with the production of electrical power for 2568 2569 public use by any fuel cycle through the use of nuclear energy (see 40 CFR 190.02). 2570 2571 onsite environs—Location within the site boundary but outside of the systems, structures, or components described in the final safety analysis report or the ODCM. 2572 2573 2574 operability (operable)—The ability of a system, subsystem, train, component, or device to perform its specified safety function(s) and the ability of all necessary attendant instrumentation, controls, 2575 normal or emergency electrical power, cooling and seal water, lubrication, and other auxiliary 2576 2577 equipment (required for the system, subsystem, train, component, or device to perform its specified safety function(s)) to perform their related support function(s). 2578 2579 2580 principal radionuclide—One of the principal gamma emitters listed in NUREG-1301 and NUREG-1302, Tables 4.11-1 and 4.11-2, or, from a risk-informed perspective, a radionuclide that 2581 contributes either (1) greater than 1 percent of the 10 CFR Part 50, Appendix I, design objective 2582 dose when all radionuclides in the type of effluent are considered, or (2) greater than 1 percent of 2583 the activity of all nuclides in the type of effluent being considered. RG 1.109 lists the three types 2584 2585 of effluents as (1) liquid effluents, (2) noble gases discharged to the atmosphere, and (3) all other nuclides discharged to the atmosphere. In this RG, the terms "principal radionuclide" and 2586 "principal nuclide" are synonymous since this document is only concerned with measuring, 2587 2588 evaluating, and reporting radioactive materials in effluents. 2589

2590	radioactive discharge—The emission of an effluent (i.e., containing plant-related, licensed radioactive
2591 2592	material) into the unrestricted area. (See also the definition for effluent discharge.)
2593	radioactive release—The emission of an effluent (i.e., containing plant-related, licensed radioactive
2594	material). (See also the definition for effluent release.)
2595	
2596	real exposure pathway—An exposure pathway in which plant-related radionuclides in the environment
2597	at (or from) a specified location cause exposure to an actual individual. For example, the
2598	grass-cow-milk-infant-thyroid exposure pathway would be considered a real exposure pathway if
2599	the grass, the cow, and the milk actually existed at a specified location and an infant actually
2600	consumed the milk. For purposes of compliance with 10 CFR Part 50, Appendix I, the individual
2601	must be a member of the public.
2602	
2603	real individual (10 CFR 72) - Any individual who lives, works, or engages in recreation or other
2604	activities close to the ISFS1/WIRS for a significant portion of the year.
2003	release source. A system structure or component (containing radioactive material under the licensee's
2607	control) where radioactive materials are contained before release
2608	control) where radioactive materials are contained before release.
2609	release point —A location from which radioactive materials are released from a system structure or
2610	component (including evaporative releases and leaching from ponds and lakes in the controlled or
2611	restricted area before release under 10 CFR 20.2001). For release points monitored by plant
2612	process radiation monitoring systems, the release point is associated with the piping immediately
2613	downstream of the radiation monitor. (See also the definition for significant release point.)
2614	Several release sources may contribute to a common release point.
2615	
2616	residual radioactivity—Radioactivity in structures, materials, soils, groundwater, and other media at a
2617	site resulting from activities under the licensee's control. This includes radioactivity from all
2618	licensed and unlicensed sources used by the licensee, but it excludes background radiation. It
2619	also includes radioactive materials remaining at the site as a result of routine or accidental
2620	releases of radioactive material at the site and previous burials at the site, even if those burials
2621	were made in accordance with 10 CFR Part 20.
2622	restricted area. An area, access to which is limited by the licensee for the nurpose of protecting
2623	individuals against undue risks from exposure to radiation and radioactive materials. Restricted
2624	area does not include areas used as residential quarters, but separate rooms in a residential
2626	building may be set apart as a restricted area.
2627	
2628	route of exposure—A specific path (or delivery mechanism) by which radioactive material can
2629	eventually cause a radiation dose to an individual. The path typically includes a type of
2630	environmental medium (e.g., air, grass, meat, or water) as the starting point and a recipient's
2631	organ or body as the end point. For example, the grass-cow-milk-infant-thyroid route of exposure
2632	may contribute to the ingestion exposure pathway. Additionally, several routes of exposure may
2633	contribute to a single exposure pathway.
2634	
2635	scaling factor—A factor used to estimate the unknown activity of a radionuclide based on its ratio to the
2636	activity of a readily measured radionuclide or other parameter (e.g., carbon-14 scaled to power
2637	generation).
2038 2630	significant contamination As used for 10 CED 50.75(a) record continue a quantity concentration or
2039 2640	both of residual radioactivity that would require remediation during decommissioning in order to
-010	sour, or residual radioactivity that would require remodulation during decommissioning in order to

2641 2642	terminate the license by meeting the unrestricted use criteria stated in 10 CFR 20.1402 (see NUREG-1757).
2643	A ANA . A
2644	significant release point—Any location from which radioactive material is released that contributes
2645	greater than I percent of the activity discharged from all the release points for a particular type of
2646	effluent considered. RG 1.109 lists the three types of effluent as (1) liquid effluents, (2) noble
2647	gases discharged to the atmosphere in gaseous radioactive waste, and (3) all other radionuclides
2648	discharged to the atmosphere in gaseous radioactive waste.
2649	
2650	significant residual radioactivity—See the definition for significant contamination.
2651	
2652	site boundary—The line beyond which the licensee owns, leases, or otherwise controls land or property.
2653	
2654	site environs—Locations outside of the nuclear power plant systems, structures, or components as
2655	described in the final safety analysis report or the ODCM.
2030	calid nadiografine maste (calid maste) calid metanial for which the lineness forecast of further use
2037	sond radioactive waste (sond waste)—sond material for which the ficensee foresees no further use.
2038	source check. A qualitative assessment of the channel response when the channel consor is exposed to a
2039	source of increased radioactivity
2000	source of increased radioactivity.
2662	standard (instrument or source) (see ANSI N323C-2009 and ANSI N42 22-2006 "Traceability of
2663	Radioactive Sources to the National Institute of Standards and Technology (NIST) and
2664	Associated Instrument Quality Control" (Ref. 93):
2665	Associated instrument Quanty Control (Ref. 95).
2665	• National standard—a standard determined by a nationally recognized competent
2667	authority to serve as the basis for assigning values to other standards of the quantity
2668	concerned. In the United States, this is an instrument, source, or other system or device
2669	maintained and promulgated by the NIST.
2670	
2671	• Primary standard—a standard that is designated or widely acknowledged as having the
2672	highest metrological qualities and whose value is accepted without reference to other
2673	standards of the same quantity.
2674	
2675	• Secondary standard—a standard whose value is assigned by comparison with a primary
2676	standard of the same quantity.
2677	
2678	• Reference standard—a standard, generally having the highest metrological quality
2679	available at a given location or in a given organization, from which measurements made
2680	there are derived.
2681	
2682	• Transfer standard—A standard used as an intermediary to compare standards. (If the
2683	intermediary is not a standard, the term <i>transfer device</i> should be used.)
2684	
2685	• Working standard—a standard that is used routinely to calibrate or check material
2686	measures measuring instruments or reference materials. A working standard is usually
2687	traceable to the NIST.
2688	
2689	survey—An evaluation of the radiological conditions and potential hazards incident to the production.
2690	use, transfer, release, disposal, or presence of radioactive material or other sources of radiation.

2691	When appropriate, such an evaluation includes a physical survey of the location of radioactive
2692	material and measurements or calculations of levels of radiation, or concentrations or quantities
2693	of radioactive material present.
2694	
2695	type of effluent—A grouping of radioactive releases into one of the three categories listed in
2696	10 CFR Part 50, Appendix I, paragraphs A–C. RG 1.109 classifies the three categories as
2697	(1) liquid effluents, (2) noble gases discharged to the atmosphere in gaseous radioactive waste,
2698	and (3) all other nuclides discharged to the atmosphere in gaseous radioactive waste.
2699	
2700	unlicensed material—Radioactive material discharged as licensed material in effluents and background
2701	radioactivity (including global fallout). Licensed radioactive material becomes unlicensed
2702	radioactive material upon discharge in effluents, in accordance with 10 CFR 20.2001.
2703	
2704	uncontrolled discharge—An effluent discharge that does not meet the definition of a controlled
2705	discharge. (See also the definition of controlled discharge.)
2706	
2707	uncontrolled release—An effluent release that does not meet the definition of a controlled release. (See
2708	also the definition of controlled release).
2709	
2710	unplanned discharge—The unintended or unexpected discharge of liquid or airborne radioactive
2711	material to the unrestricted area. Examples of an unplanned discharge include the following:
2712	
2713	• the unintentional discharge of a wrong waste gas decay tank (or bulk liquid radioactive
2714	waste tank) or
2715	
2716	• the failure of a radiation monitor to divert liquid to the radioactive waste system in the
2710	case where radioactivity is present and the automatic alarm/trin function fails to divert
2718	material to liquid radioactive waste and that material (or a portion of that material)
2710	instead discharges to the environment
2717	instead discharges to the environment.
2720	unplanned release. The unintended or unexpected release of liquid or airborne radioactive material to
2721	the onsite environment. An example of an unplanned release would include a plant occurrence
2722	that results in a leak or spill of radioactive material to onsite areas, requiring a report under
2723	10 CFR 50.72 "Immediate notification requirements for operating nuclear power reactors" or
2724	10 CFR 50.72, "License event report system" (See HDDOS 254 "Definition of Unplanned
2725	Release "issued February 1004 (Ref. 94))
2720	Release, issued reordary 1994 (Rel. 94)).
2727	For example, if a licensee has prepared documents describing an intended release (e.g., a
2720	preliminary radioactive waste release permit) in advance of the evolution, and the intended
2729	release occurs as planned, then the release is a planned release. If such documents (a.g., a
2730	proliminary release permit) are not prepared (or considered/avaluated) before the release, it is
2731	premimary release permit) are not prepared (or considered/evaluated) before the release, it is
2722	potentiarry an unpraimed release (and additional information may be required to determine if it is
2733	an unplanned release).
2734	unnecturisted anon An area for which the licenses notther limits nor controls access
2135	unrestricted area —An area for which the licensee neither limits for controls access.
2130	unanium fuel evels. The energy of milling of unanium and chemical conversion of unanium instance
2131 0720	uranium fuer cycle— The operations of mining of uranium ore, chemical conversion of uranium, isotopic
2130	light water pooled public power plant using warding field and approximation of electricity by a
2139	full to the extent that these directly support the production of electrical power for sublicities
274U 2741	using public operations with a value of the mining operations, operations of most disconstantiates
4/41	using nuclear energy, but excludes mining operations, operations at waste disposal sites,

- transportation of any radioactive material in support of these operations, and the reuse of recovered nonuranium special nuclear and byproduct materials from the cycle.
- 2744
- 2745 χ/Q —Referred to as "Chi over Q," the average atmospheric effluent concentration, χ , normalized by 2746 release rate, Q, at a distance (or location) in a given downwind direction. Expressed in another 2747 way, χ/Q is the concentration (χ) of airborne radioactive material (e.g., in units of μ Ci/m³) divided 2748 by the release rate (Q) (e.g., in units of μ Ci/s) at a specified distance and direction downwind of 2749 the release point.

2750		REFERENCES ¹²
2751 2752 2753 2754	1.	U.S. Code of Federal Regulations (CFR), "Standards for Protection Against Radiation," Part 20, Chapter 1, Title 10, "Energy."
2755 2756 2757	2.	CFR, "Environmental Radiation Protection Standards for Nuclear Power Operations," Part 190, Chapter 1, Title 40, "Protection of Environment."
2758 2759 2760	3.	U.S. Nuclear Regulatory Commission (NRC), "Staff Requirements—SECY-98-144—White Paper on Risk Informed and Performance-Based Regulation," SRM-SECY-98-144, February 24, 1999 ADAMS Accession No. ML003753593.
2761 2762 2763	4.	CFR, "Domestic Licensing of Production and Utilization Facilities," Part 50, Chapter 1, Title 10, "Energy."
2764 2765 2766	5.	CFR, "Licenses, Certifications, and Approvals for Nuclear Power Plants," Part 52, Chapter 1, Title 10, "Energy."
2768 2769 2770 2771	6.	CFR, "Licensing Requirements for the Independent Storage of Spent Nuclear Fuel, High-Level Radioactive Waste, and Reactor-Related Greater Than Class C Waste," Part 72, Chapter 1, Title 10, "Energy."
2772 2773 2774	7.	CFR, "Environmental Radiation Protection Standards for Management and Disposal of Spent Nuclear Fuel and Transuranic Radioactive Wastes," Part 191, Chapter 1, Title 40, "Standards."
2774 2775 2776 2777	8.	NRC, Regulatory Guide (RG) 1.23, "Meteorological Monitoring Programs for Nuclear Power Plants," Revision 1, March 2007.
2778 2779 2780 2781	9.	NRC, RG 1.97, "Instrumentation for Light-Water-Cooled Nuclear Power Plants to Assess Plant and Environs Conditions During and Following an Accident," Revision 0, December 1975; Revision 1, August 1977; Revision 2, December 1980; and Revision 3, May 1983.
2781 2782 2783 2784	10.	NRC, RG 1.97, "Criteria for Accident Monitoring Instrumentation for Nuclear Power Plants," Regulatory Guide 1.97, Revision 4, June 2006.
2784 2785 2786 2787	11.	IEEE, "Standard Criteria for Accident Monitoring Instrumentation for Nuclear Power Generating Stations," Std. 497-2002, New York, NY.
2787 2788 2789 2790	12.	NRC, RG 1.97, "Criteria for Accident Monitoring Instrumentation for Nuclear Power Plants," Regulatory Guide 1.97, Revision 5, April 2019.
2790 2791 2792 2793	13.	IEEE, "IEEE Standard Criteria for Accident Monitoring Instrumentation for Nuclear Power Generating Stations," Std. 497-2016, New York, NY.
2793	14.	NRC, RG 1.109, "Calculation of Annual Doses to Man from Routine Releases of Reactor

¹² Publicly available NRC published documents are available electronically through the NRC Library on the NRC's public Web site at <u>http://www.nrc.gov/reading-rm/doc-collections/index.html and</u> through the NRC's ADAMS at <u>http://www.nrc.gov/reading-rm/adams.html.</u> The documents can also be viewed online or printed for a fee in the NRC's Public Document Room (PDR) at 11555 Rockville Pike, Rockville, MD. For problems with ADAMS, contact the PDR staff at 301-415-4737 or (800) 397-4209; fax (301) 415-3548; or e-mail <u>pdr.resource@nrc.gov</u>.

2795 2796		Effluents for the Purpose of Evaluating Compliance with 10 CFR Part 50, Appendix I," Revision 1, October 1977.
2797 2798 2799 2800	15.	NRC, RG 1.111, "Methods for Estimating Atmospheric Transport and Dispersion of Gaseous Effluents in Routine Releases from Light-Water-Cooled Reactors," Revision 1, July 1977.
2800 2801 2802 2803	16.	NRC, RG 1.112, "Calculation of Releases of Radioactive Materials in Gaseous and Liquid Effluents from Light-Water-Cooled Power Reactors," Revision 1, March 2007.
2804 2805 2806	17.	NRC, RG 1.113, "Estimating Aquatic Dispersion of Effluents from Accidental and Routine Reactor Releases for the Purpose of Implementing Appendix I," Revision 1, April 1977.
2807 2808	18.	NRC, RG 1.184, "Decommissioning of Nuclear Power Reactors," Revision 1, October 2013.
2809 2810 2811	19.	NRC, RG 1.185, "Standard Format and Content for Post-Shutdown Decommissioning Activities Report," Revision 1, June 2013.
2812 2813 2814	20.	NRC, RG 4.1, "Radiological Environmental Monitoring for Nuclear Power Plants," Revision 2, June 2009.
2815 2816 2817	21.	NRC, RG 4.13, "Environmental Dosimetry—Performance Specifications, Testing, and Data Analysis," Revision 2, June 2019.
2817 2818 2819 2820 2821	22.	NRC, RG 4.15, "Quality Assurance for Radiological Monitoring Programs (Inception Through Normal Operations to License Termination)—Effluent Streams and the Environment," Revision 2, July 2007.
2822 2823 2824	23.	NRC, RG 4.20, "Constraint on Releases of Airborne Radioactive Materials to the Environment for Licensees other than Power Reactors," Revision 1, April 2012.
2825 2826 2827	24.	NRC, RG 4.25, "Assessment of Abnormal Radionuclide Discharges in Groundwater to the Unrestricted Area at Nuclear Power Plant Sites," Revision 0, March 2017.
2828 2828 2829 2830 2831	25.	NRC, Generic Letter 89-01, "Implementation of Programmatic and Procedural Controls for Radiological Effluent Technical Specifications," January 31, 1989, ADAMS Accession No. ML031140051.
2832 2833 2834	26.	NUREG-0133, "Preparation of Radiological Effluent Technical Specifications for Nuclear Power Plants" issued October 1978, ADAMS Accession No. ML091050057.
2835 2835 2836 2837 2838 2839	27.	NRC, NUREG-0016, "Calculation of Releases of Radioactive Materials in Gaseous and Liquid Effluents from Boiling-Water Reactors: GALE-BWR 3.2 Code," Revision 1, January 1979, ADAMS Accession No. ML091910213, and Revision 2, July 2020, ADAMS Accession No. ML20213C728.
2840 2841 2842 2843 2844	28.	NRC, NUREG-0017, "Calculation of Releases of Radioactive Materials in Gaseous and Liquid Effluents from Pressurized Water Reactors: GALE-PWR 3.2 Code," Revision 1, April 1985, ADAMS Accession No. ML112720A411, and Revision 2, July 2020, ADAMS Accession No. ML20213C729.

2845	29.	NRC, NUREG-0543, "Methods for Demonstrating LWR Compliance with the EPA Uranium
2846		Fuel Cycle Standard (CFR Part 190)," issued January 1980, ADAMS Accession
2847		No. MI 081360410
2047		110. 111001500410.
2040	20	
2849	30.	NRC, NUREG-0/37, "Clarification of TMI Action Plan Requirements," November 1980,
2850		ADAMS Accession No. ML051400209.
2851		
2852	31.	NRC, NUREG-1301, "Offsite Dose Calculation Manual Guidance: Standard Radiological
2853		Effluent Controls for Pressurized Water Reactors," April 1991, ADAMS Accession
2854		No. MI 091050061
2054		110.11120/1020001.
2055	20	NDC NUDEC 1202 "Offite Deer Calculation Manual Cuidence, Stondard Dadialagical
2850	32.	NRC, NUREG-1502, Offsite Dose Calculation Manual Guidance: Standard Radiological
2857		Effluent Controls for Boiling Water Reactors," April 1991, ADAMS Accession
2858		No. ML091050059.
2859		
2860	33.	NRC, NUREG-1575, "Multi-Agency Radiation Survey and Site Investigation Manual
2861		(MARSSIM)," Revision 1, August 2000.
2862		
2863	3/	NRC NUREG-1576 "Multi-Agency Radiological Laboratory Analytical Protocols Manual"
2005	54.	Luly 2004 ADAMS Accession No. MI 042210547 MI 042210728 MI 042220082
2004		July 2004, ADAMIS Accession No. MIL042510547, MIL042510756, MIL042520085.
2865	~-	
2866	35.	NRC, NUREG-1757, "Consolidated Decommissioning Guidance: Characterization, Survey, and
2867		Determination of Radiological Criteria," Volume 2, Revision 1, September 2006, ADAMS
2868		Accession No. ML063000243.
2869		
2870	36.	NRC, NUREG-1940, "RASCAL 4: Description of Models and Methods," December 2012,
2871		ADAMS Accession No. ML13031A448.
2872		
2072	27	NDC NUDEC 1040 (DACCAL 42) Description (N. 1.1, 10.1M.4, 1.2) Constant 1
2873	37.	NRC, NUREG-1940, "RASCAL 4.3: Description of Models and Methods," Supplement 1,
2874		May 2015, ADAMS Accession No. ML15132A119.
2875		
2876	38.	NRC, NUREG/CR-6948, "Integrated Ground-Water Monitoring Strategy for NRC-Licensed
2876 2877	38.	NRC, NUREG/CR-6948, "Integrated Ground-Water Monitoring Strategy for NRC-Licensed Facilities and Sites: Logic, Strategic Approach and Discussion," Volume 1, November 2007,
2876 2877 2878	38.	NRC, NUREG/CR-6948, "Integrated Ground-Water Monitoring Strategy for NRC-Licensed Facilities and Sites: Logic, Strategic Approach and Discussion," Volume 1, November 2007, ADAMS Accession No. ML073310297.
2876 2877 2878 2879	38.	NRC, NUREG/CR-6948, "Integrated Ground-Water Monitoring Strategy for NRC-Licensed Facilities and Sites: Logic, Strategic Approach and Discussion," Volume 1, November 2007, ADAMS Accession No. ML073310297.
2876 2877 2878 2879 2880	38.	NRC, NUREG/CR-6948, "Integrated Ground-Water Monitoring Strategy for NRC-Licensed Facilities and Sites: Logic, Strategic Approach and Discussion," Volume 1, November 2007, ADAMS Accession No. ML073310297.
2876 2877 2878 2879 2880 2881	38. 39.	NRC, NUREG/CR-6948, "Integrated Ground-Water Monitoring Strategy for NRC-Licensed Facilities and Sites: Logic, Strategic Approach and Discussion," Volume 1, November 2007, ADAMS Accession No. ML073310297. NRC, NUREG/CR-6805, "A Comprehensive Strategy of Hydrogeology Modeling and Uncertainty Anglusia for Nuclear Facilities and Sites." July 2002, ADAMS Accession
2876 2877 2878 2879 2880 2881	38. 39.	NRC, NUREG/CR-6948, "Integrated Ground-Water Monitoring Strategy for NRC-Licensed Facilities and Sites: Logic, Strategic Approach and Discussion," Volume 1, November 2007, ADAMS Accession No. ML073310297. NRC, NUREG/CR-6805, "A Comprehensive Strategy of Hydrogeology Modeling and Uncertainty Analysis for Nuclear Facilities and Sites," July 2003, ADAMS Accession
2876 2877 2878 2879 2880 2881 2882	38. 39.	NRC, NUREG/CR-6948, "Integrated Ground-Water Monitoring Strategy for NRC-Licensed Facilities and Sites: Logic, Strategic Approach and Discussion," Volume 1, November 2007, ADAMS Accession No. ML073310297. NRC, NUREG/CR-6805, "A Comprehensive Strategy of Hydrogeology Modeling and Uncertainty Analysis for Nuclear Facilities and Sites," July 2003, ADAMS Accession No. ML032470827.
2876 2877 2878 2879 2880 2881 2882 2883	38. 39.	 NRC, NUREG/CR-6948, "Integrated Ground-Water Monitoring Strategy for NRC-Licensed Facilities and Sites: Logic, Strategic Approach and Discussion," Volume 1, November 2007, ADAMS Accession No. ML073310297. NRC, NUREG/CR-6805, "A Comprehensive Strategy of Hydrogeology Modeling and Uncertainty Analysis for Nuclear Facilities and Sites," July 2003, ADAMS Accession No. ML032470827.
2876 2877 2878 2879 2880 2881 2882 2883 2883 2884	38.39.40.	 NRC, NUREG/CR-6948, "Integrated Ground-Water Monitoring Strategy for NRC-Licensed Facilities and Sites: Logic, Strategic Approach and Discussion," Volume 1, November 2007, ADAMS Accession No. ML073310297. NRC, NUREG/CR-6805, "A Comprehensive Strategy of Hydrogeology Modeling and Uncertainty Analysis for Nuclear Facilities and Sites," July 2003, ADAMS Accession No. ML032470827. NRC, Regulatory Issue Summary (RIS) 2008-03, "Return/Reuse of Previously Discharged
2876 2877 2878 2879 2880 2881 2882 2883 2883 2884 2885	38.39.40.	 NRC, NUREG/CR-6948, "Integrated Ground-Water Monitoring Strategy for NRC-Licensed Facilities and Sites: Logic, Strategic Approach and Discussion," Volume 1, November 2007, ADAMS Accession No. ML073310297. NRC, NUREG/CR-6805, "A Comprehensive Strategy of Hydrogeology Modeling and Uncertainty Analysis for Nuclear Facilities and Sites," July 2003, ADAMS Accession No. ML032470827. NRC, Regulatory Issue Summary (RIS) 2008-03, "Return/Reuse of Previously Discharged Radioactive Effluents" February 2008, ADAMS Accession No. ML072120368.
2876 2877 2878 2879 2880 2881 2882 2883 2884 2885 2886	38.39.40.	 NRC, NUREG/CR-6948, "Integrated Ground-Water Monitoring Strategy for NRC-Licensed Facilities and Sites: Logic, Strategic Approach and Discussion," Volume 1, November 2007, ADAMS Accession No. ML073310297. NRC, NUREG/CR-6805, "A Comprehensive Strategy of Hydrogeology Modeling and Uncertainty Analysis for Nuclear Facilities and Sites," July 2003, ADAMS Accession No. ML032470827. NRC, Regulatory Issue Summary (RIS) 2008-03, "Return/Reuse of Previously Discharged Radioactive Effluents" February 2008, ADAMS Accession No. ML072120368.
2876 2877 2878 2879 2880 2881 2882 2883 2884 2885 2886 2886 2887	38.39.40.	 NRC, NUREG/CR-6948, "Integrated Ground-Water Monitoring Strategy for NRC-Licensed Facilities and Sites: Logic, Strategic Approach and Discussion," Volume 1, November 2007, ADAMS Accession No. ML073310297. NRC, NUREG/CR-6805, "A Comprehensive Strategy of Hydrogeology Modeling and Uncertainty Analysis for Nuclear Facilities and Sites," July 2003, ADAMS Accession No. ML032470827. NRC, Regulatory Issue Summary (RIS) 2008-03, "Return/Reuse of Previously Discharged Radioactive Effluents" February 2008, ADAMS Accession No. ML072120368. NRC "International Policy Statement," ADAMS Accession No. ML 14132A317
2876 2877 2878 2879 2880 2881 2882 2883 2884 2885 2886 2887 2888	38.39.40.41.	 NRC, NUREG/CR-6948, "Integrated Ground-Water Monitoring Strategy for NRC-Licensed Facilities and Sites: Logic, Strategic Approach and Discussion," Volume 1, November 2007, ADAMS Accession No. ML073310297. NRC, NUREG/CR-6805, "A Comprehensive Strategy of Hydrogeology Modeling and Uncertainty Analysis for Nuclear Facilities and Sites," July 2003, ADAMS Accession No. ML032470827. NRC, Regulatory Issue Summary (RIS) 2008-03, "Return/Reuse of Previously Discharged Radioactive Effluents" February 2008, ADAMS Accession No. ML072120368. NRC "International Policy Statement," ADAMS Accession No. ML14132A317.
2876 2877 2878 2879 2880 2881 2882 2883 2884 2885 2886 2887 2888 2889	 38. 39. 40. 41. 42 	 NRC, NUREG/CR-6948, "Integrated Ground-Water Monitoring Strategy for NRC-Licensed Facilities and Sites: Logic, Strategic Approach and Discussion," Volume 1, November 2007, ADAMS Accession No. ML073310297. NRC, NUREG/CR-6805, "A Comprehensive Strategy of Hydrogeology Modeling and Uncertainty Analysis for Nuclear Facilities and Sites," July 2003, ADAMS Accession No. ML032470827. NRC, Regulatory Issue Summary (RIS) 2008-03, "Return/Reuse of Previously Discharged Radioactive Effluents" February 2008, ADAMS Accession No. ML072120368. NRC "International Policy Statement," ADAMS Accession No. ML14132A317. NRC Management Directive and Handbook 6.6. "Regulatory Guides" ADAMS Accession No.
2876 2877 2878 2879 2880 2881 2882 2883 2884 2885 2886 2887 2888 2889 2800	 38. 39. 40. 41. 42. 	 NRC, NUREG/CR-6948, "Integrated Ground-Water Monitoring Strategy for NRC-Licensed Facilities and Sites: Logic, Strategic Approach and Discussion," Volume 1, November 2007, ADAMS Accession No. ML073310297. NRC, NUREG/CR-6805, "A Comprehensive Strategy of Hydrogeology Modeling and Uncertainty Analysis for Nuclear Facilities and Sites," July 2003, ADAMS Accession No. ML032470827. NRC, Regulatory Issue Summary (RIS) 2008-03, "Return/Reuse of Previously Discharged Radioactive Effluents" February 2008, ADAMS Accession No. ML072120368. NRC "International Policy Statement," ADAMS Accession No. ML14132A317. NRC Management Directive and Handbook 6.6, "Regulatory Guides" ADAMS Accession No. ML 16083 A122
2876 2877 2878 2879 2880 2881 2882 2883 2884 2885 2886 2887 2888 2889 2890 2801	 38. 39. 40. 41. 42. 	 NRC, NUREG/CR-6948, "Integrated Ground-Water Monitoring Strategy for NRC-Licensed Facilities and Sites: Logic, Strategic Approach and Discussion," Volume 1, November 2007, ADAMS Accession No. ML073310297. NRC, NUREG/CR-6805, "A Comprehensive Strategy of Hydrogeology Modeling and Uncertainty Analysis for Nuclear Facilities and Sites," July 2003, ADAMS Accession No. ML032470827. NRC, Regulatory Issue Summary (RIS) 2008-03, "Return/Reuse of Previously Discharged Radioactive Effluents" February 2008, ADAMS Accession No. ML072120368. NRC "International Policy Statement," ADAMS Accession No. ML14132A317. NRC Management Directive and Handbook 6.6, "Regulatory Guides" ADAMS Accession No. ML16083A122.
2876 2877 2878 2879 2880 2881 2882 2883 2884 2885 2886 2887 2888 2889 2890 2891	 38. 39. 40. 41. 42. 42. 	 NRC, NUREG/CR-6948, "Integrated Ground-Water Monitoring Strategy for NRC-Licensed Facilities and Sites: Logic, Strategic Approach and Discussion," Volume 1, November 2007, ADAMS Accession No. ML073310297. NRC, NUREG/CR-6805, "A Comprehensive Strategy of Hydrogeology Modeling and Uncertainty Analysis for Nuclear Facilities and Sites," July 2003, ADAMS Accession No. ML032470827. NRC, Regulatory Issue Summary (RIS) 2008-03, "Return/Reuse of Previously Discharged Radioactive Effluents" February 2008, ADAMS Accession No. ML072120368. NRC "International Policy Statement," ADAMS Accession No. ML14132A317. NRC Management Directive and Handbook 6.6, "Regulatory Guides" ADAMS Accession No. ML16083A122.

2893		2018. ¹³
2894		
2895	44.	IAEA, "Dispersion of Radioactive Material in Air and Water and Consideration of Population
2896		Distribution in Site Evaluation for Nuclear Power Plants," Specific Safety Guide No. NS-G-3.2,
2897		Vienna, Austria, 2002.
2898		
2899	45	IAFA "Regulatory Control of Radioactive Discharges to the Environment" GSG 9 Vienna
2900	10.	Austria 2018
2900		
2901	16	IAEA "Environmental and Source Monitoring for Purposes of Radiation Protection"
2902	40.	GSG N RS-G-18 Vienna Austria 2005
2003		050 IV. K5-0-1.8, Vielina, Austria, 2005.
2904	17	IAEA "A eaident Monitoring Systems for Nuclear Power Dients" Nuclear Energy Series No. ND.
2905	47.	TALA, Accident Womtoring Systems for Nuclear Fower Flams, Nuclear Energy Series No. NF-
2900		1-5.10, vielilla, Austria, 2015.
2907	10	IAEA "Descention and Mitiantian of Course American Contamination from Dedication Deleases"
2908	48.	TECDOC 482 Visual Association in the second second matter Contamination from Radioactive Releases,
2909		TECDOC-482, Vienna, Austria, issued 1988.
2910	40	
2911	49.	IAEA, "Remediation Process for Areas Affected by Past Activities and Accidents," IAEA Safety
2912		Guide No. WS-G-3.1, Vienna, Austria, 2007.
2913	-	
2914	50.	IAEA, "Management of Waste Containing Tritium and Carbon-14," Technical Report Series
2915		Number 421, Vienna, Austria, 2004.
2916		
2917	51.	NRC, RG 1.21, "Measuring, Evaluating, and Reporting Radioactive Material in Liquid and
2918		Gaseous Effluents and Solid Waste," Revision 1, June 1974.
2919		
2920	52.	NRC, RG 1.21, "Measuring, Evaluating, and Reporting Radioactive Material in Liquid and
2921		Gaseous Effluents and Solid Waste," Revision 2, June 2009.
2922		
2923	53.	NRC, "Contamination of Nonradioactive System and Resulting Potential for Unmonitored,
2924		Uncontrolled Release of Radioactivity to Environment," Inspection and Enforcement Bulletin
2925		No. 80-10, May 1980.
2926		
2927	54.	NRC, "Results of the License Termination Rule Analysis," Commission Paper SECY-03-0069,
2928		May 23, 2003, ADAMS Accession No. ML030800158.
2929		
2930	55.	NRC, NUREG-1022, "Event Reporting Guidelines 10 CFR 50.72 and 50.73: Final Report,"
2931		January 2013, ADAMS Accession No. ML13032A220.
2932		
2933	56.	NRC, NUREG/BR-0308, "Effective Risk Communication," January 2004, ADAMS Accession
2934		No. ML040690412.
2935		
2936	57.	NRC. SRM-SECY-13-108. "Staff Requirements—SECY-13-108—Staff Recommendations for
2937	2	Addressing Remediation of Residual Radioactivity During Operations "December 20, 2013
2938		ADAMS Accession No. ML13354B759
_//0		

¹³ Copies of IAEA documents may be obtained through their Web site: <u>https://www.iaea.org/</u> or by writing the International Atomic Energy Agency, P.O. Box 100 Wagramer Strasse 5, A-1400 Vienna, Austria.

2939 2940 2041	58.	EPRI ¹⁴ Report 1021104 "Groundwater and Soil Remediation Guidelines for Nuclear Power Plants," (Proprietary report) issued December 2010.
2941 2942 2943	59.	EPRI Report 1023464, "Groundwater and Soil Remediation Guidelines for Nuclear Power Plants" (Public Edition") Final Report, July 2011.
2944 2945 2946 2947	60.	NRC, NUREG/CR-6676, "Probabilistic Dose Analysis Using Parameter Distributions Developed for RESRAD and RESRAD-BUILD Codes," July 2000, ADAMS Accession No. ML003741920.
2948 2949 2950	61.	NRC, NUREG/CR-6692, "Probabilistic Modules for the RESRAD and RESRAD-BUILD Computer Codes," November 2000, ADAMS Accession No. ML003774030.
2951 2952 2953	62.	NRC, NUREG/CR-6697, "Development of Probabilistic RESRAD 6.0 and RESRAD-BUILD 3.0 Computer Codes," December 2000, ADAMS Accession No. ML010090284.
2953 2954 2955 2956 2957	63.	NRC, NUREG/CR-7267, Default parameter Values and Distributions in RESRAD-ONSITE V7.2, RESRAD-BUILD V3.5 and RESRAD-OFFSITE 4.0, 2020, ADAMS Accession No. ML20279A652.
2958 2959 2960	64.	National Council on Radiation Protection and Measurements, "Carbon-14 in the Environment," Report No. 81, Bethesda, MD, January 1985.
2960 2961 2962 2963	65.	EPRI, "Estimation of Carbon-14 in Nuclear Power Plant Gaseous Effluents," Technical Report 1021106, Palo Alto, CA, December 2010.
2964 2965 2966	66.	EPRI, "Carbon-14 Dose Calculation Methods at Nuclear Power Plants," Technical Report No. 1024827, Palo Alto, CA, April 2012.
2967 2968 2969	67.	ASTM D 3370 - 18, "Standard Practices for Sampling Water from Flowing Process Streams ASTM D 3370 - 18, West Conshohocken, PA, 2007. ¹⁵
2970 2971 2972 2973	68.	American National Standards Institute (ANSI), "Specification and Performance of On-Site Instrumentation for Continuously Monitoring Radioactivity in Effluents," ANSI N42.18-2004, New York, NY.
2973 2974 2975 2976	69.	ANSI "Instrumentation and Systems for Monitoring Radioactivity," ANSI N42.54-2018, New York, NY
2977 2977 2978 2979 2980	70.	ANSI /Health Physics Society, "Sampling and Monitoring Releases of Airborne Radioactive Substances from the Stacks and Ducts of Nuclear Facilities," ANSI/HPS N13.1-2011, New York, NY.
2980 2981 2982	71.	NRC, "Onsite Meteorological Programs," Safety Guide 23, February 17, 1972, ADAMS Accession No. ML020360030.
	14	Copies of EPRI standards and reports may be obtained from EPRI, 3420 Hillview Ave., Palo Alto, CA 94304; telephone (800) 313-3774; https://www.epri.com

¹⁵ Copies of ASTM standards may be purchased from ASTM, 100 Barr Harbor Drive, P.O. Box C700, West Conshohocken, Pennsylvania 19428-2959; telephone (610) 832-9585. Purchase information is available through the ASTM Web site at <u>http://www.astm.org</u>.

2983		
2984	72.	ANSI /ANS, "Evaluation of Subsurface Radionuclide Transport at Commercial Nuclear Power
2985		Production Facilities," ANSI/ANS 2.17-2009, New York, NY.
2986		
2987	73.	EPRI Report No. 3002000546 "Groundwater Protection Guidelines for Nuclear Power Plants:
2988		Revision 1," Electric Power Research Institute, Palo Alto, CA., October 2013.
2989		
2990	74.	ANSI, "Radiation Protection Instrumentation Test and Calibration—Air Monitoring
2991		Instruments," ANSI N323C-2009, New York, NY.
2992		
2993	75.	D.G. Eisenhut, NRC, memorandum for Regional Administrators, "Proposed Guidance for
2994		Calibration and Surveillance Requirements for Equipment Provided to Meet Item II.F.1,
2995		Attachments 1, 2, and 3, NUREG-0737," August 16, 1982, ADAMS Accession
2996		No. ML103420044.
2997		
2998	76.	NRC, NUREG/CR-5569, "Proposed Guidance for Calibration and Surveillance Requirements to
2999		Meet Item II.F.1 of NUREG-0737," HPPOS-001 in "Health Physics Positions Data Base,"
3000		Revision 1, February 1994, ADAMS Accession No. ML093220108.
3001		
3002	77.	ANSI, "Performance Specifications for Reactor Emergency Radiological Monitoring
3003		Instrumentation," ANSI N320-1978, New York, NY.
3004		
3005	78.	ICRP Publication 2, "Report of Committee II on Permissible Dose for Internal Radiation,"
3006		International Commission on Radiation Protection, Pergamon Press, Oxford, 1959.
3007		
3008	79.	Maiello, M., "The Variations in Long Term TLD Measurements of Environmental Background
3009		Radiation at Locations in Southeastern New York State and Southern New Jersey," Health
3010		<i>Physics</i> , 72:915–922, June 1997.
3011		
3012	80.	ANSI /HPS, "American National Standard for Dosimetry Personnel Dosimetry Performance
3013		Criteria for Testing," ANSI/HPS N13.11-2009, New York NY, January 13, 2009.
3014		
3015	81.	ANSI/HPS, "Environmental Dosimetry—Criteria for System Design and Implementation,
3016		ANSI/HPS N13.37-2014, New York NY, April 8, 2014.
3017		
3018	82.	NRC, NUREG-1430, "Standard Technical Specifications, Babcock and Wilcox Plants," April
3019		2012, ADAMS Accession No. ML12100A177 and ML12100A178.
3020		
3021	83.	NRC, NUREG-1431, "Standard Technical Specifications, Westinghouse Plants," April 2012,
3022		ADAMS Accession No. ML12100A222 and ML12100AA288.
3023		
3024	84.	NRC, NUREG-1432, "Standard Technical Specifications, Combustion Engineering Plants,"
3025		April 2012, ADAMS Accession No. ML12102A165 and ML12102A169.
3026		
3027	85.	NRC, NUREG-1433, "Standard Technical Specifications, General Electric BWR/4 Plants,"
3028		April 2012, ADAMS Accession No. ML12024A192 and ML12104A193.
3029		•
3030	86.	NRC, NUREG-1434. "Standard Technical Specifications, General Electric BWR/6. April 2012."
3031		ADAMS Accession No. ML12104A195 and ML12104A196.
3032		

3033 87. ASTM, "Standard Practice for Using Significant Digits in Test Data to Determine Conformance 3034 with Specifications," ASTM E-29, West Conshohocken, PA. 3035 3036 88. NRC, NUREG/CR-5569, "Attention to Liquid Dilution Volumes in Semiannual Radioactive Effluent Release Reports," HPPOS-099, in "Health Physics Positions Data Base," 3037 November 1984, ADAMS Accession No. ML093220108. 3038 3039 3040 89. NEI, "Industry Groundwater Protection Initiative-Final Guidance Document," NEI 07-07, Revision 1, Washington, DC, February 26, 2019, ADAMS Accession No. ML20199M271. 3041 3042 3043 90. NRC, "Management of Backfitting, Forward Fitting, Issue Finality, and Information Requests," 3044 Management Directive 8.4, September 2019, ADAMS Accession No. ML18093B087. 3045 3046 91. NRC, NUREG/CR-4007, "Lower Limit of Detection: Definition and Elaboration of a Proposed 3047 Position for Radiological Effluent and Environmental Measurements," September 1984, ADAMS Accession No. ML16152A647. 3048 3049 NRC, NUREG-1507, "Minimum Detectable Concentrations with Typical Radiation Survey 3050 92. Instruments for Various Contaminants and Field Conditions," June 1998, ADAMS Accession 3051 3052 No. ML20233A507. 3053 3054 93. ANSI, "Traceability of Radioactive Sources to the National Institute of Standards and Technology (NIST) and Associated Instrument Quality Control," ANSI N42.22-2006, New York, 3055 NY. 3056 3057 3058 NRC, NUREG/CR-5569, "Definition of Unplanned Release," HPPOS-254, in "Health Physics 94. 3059 Positions Data Base," February 1994, ADAMS Accession No. ML093220108.

BIBLIOGRAPHY
U.S. Nuclear Regulatory Commission Documents
NUREG-Series Reports
U.S. Nuclear Regulatory Commission, "Standard Review Plan for the Review of Safety Analysis Reports for Nuclear Power Plants," NUREG-0800, Section 2.3.5, "Long-Term Atmosphere Dispersion Estimates for Routine Releases," Revision 3, Washington, DC, March 2007.
"XOQDOQ: Program for the Meteorological Evaluation of Routine Effluent Releases at Nuclear Power Stations," NUREG-0324, September 1977.
"XOQDOQ: Computer Program for the Meteorological Evaluation of Routine Effluent Releases at Nuclear Power Stations," NUREG/CR2919, September 1982.
Regulatory Guides
U.S. Nuclear Regulatory Commission, "Design Guidance for Radioactive Waste Management Systems, Structures, and Components Installed in Light-Water-Cooled Nuclear Power Plants," Regulatory Guide 1.143, Revision 2, November 2001.
U.S. Environmental Protection Agency Documents
U.S. Code of Federal Regulations, "National Primary Drinking Water Regulations," Part 141, Chapter 1, Title 40, "Protection of Environment."
National Standards and Industry Reports
ANSI, "Performance Criteria for Radiobioassay," ANSI N13.30-1996, New York, NY.
ANSI/ANS, "Determining Meteorological Information at Nuclear Facilities," ANSI/ANS 3.11-2005, New York, NY, January 2005.
ANSI, "Calibration and Use of Germanium Spectrometers for the Measurement of Gamma-Ray Emission Rates of Radionuclides," ANSI N42.14-1999, New York, NY.
ANSI/National Conference of State Legislatures (NCSL), "American National Standard for Expressing Uncertainty—U.S. Guide to the Expression of Uncertainty in Measurement," ANSI/NCSL Z540-2-1997 (reapproved 2002), New York, NY.
NIST, "Guidelines for Evaluating and Expressing the Uncertainty of NIST Measurement Results," Technical Note 1297, Gaithersburg, MD, September 1994.
EPRI, "Groundwater Monitoring Guidance for Nuclear Power Plants," Report No. 1011730, Palo Alto,
CA, September 2005.

APPENDIX A—TABLES

SUMMATION OF ALL RELEASES	UNITS	QUARTER 1	QUARTER 2	QUARTER 3	QUARTER 4	TOTAL	UNCERTAINTY
Fission and	Ci						
Activation Gases							
Iodines (Halogens)	Ci						
Particulates	Ci						
Tritium	Ci						
Gross Alpha	Ci						
C-14	Ci						

RG 1.21, Rev. 3, Appendix A, Page A-1

Fission and						
Activation	UNITS	QUARTER 1	QUARTER 2	QUARTER 3	QUARTER 4	TOTAL
Gases						
Ar-41	Ci					
Kr-85	Ci					
Kr-85m	Ci					
Kr-87	Ci					
Kr-88	Ci					
Xe-131m	Ci					
Xe-133	Ci					
Xe-133m	Ci					
Xe-135	Ci					
Xe-135m	Ci					
Xe-138	Ci					
(List Others)	Ci					
Total	Ci					
Iodines/	UNITS	OUARTER 1	OHARTER 2	OHARTER 3	OUARTER 4	TOTAL
Halogens	UNIIS	QUARTERT	QUARIER 2	QUARTER 5	QUARTER 4	IOTAL
I-131	Ci					
I-132	Ci					
I-133	Ci					
I-134	Ci					
I-135	Ci					
Total	Ci					
				Y	-	
Particulates	UNITS	QUARTER 1	QUARTER 2	QUARTER 3	QUARTER 4	TOTAL
Co-58	Ci					
Co-60	Ci					
Sr-89	Ci					
Sr-90	Ci					
Cs-134	Ci					
(List Others)	Ci					
Total	Ci					
Tritium	Ci					
	(7					
Gross Alpha	Ci					
C-14	Ci					
	/					

 Table A-1A - Gaseous Effluents—Ground-Level Release—Batch Mode

Fission and						
Activation	UNITS	QUARTER 1	QUARTER 2	QUARTER 3	QUARTER 4	TOTAL
Gases						
Ar-41	Ci					
Kr-85	Ci					
Kr-85m	Ci					
Kr-87	Ci					
Kr-88	Ci					
Xe-131m	Ci					
Xe-133	Ci					
Xe-133m	Ci					
Xe-135	Ci					
Xe-135m	Ci					
Xe-138	Ci					
(List Others)						
Total	Ci					
Iodines/	UNITS	OUARTER 1	OUARTER 2	OUARTER 3	OLIARTER 4	ΤΟΤΑΙ
Halogens	UNIIS	QUARIERI	QUARIER 2	QUARIER 5	QUARIER 4	IOIAL
I-131	Ci					
I-132	Ci					
I-133	Ci					
I-134	Ci					
I-135	Ci					
Total	Ci					
				*		
Particulates	UNITS	QUARTER 1	QUARTER 2	QUARTER 3	QUARTER 4	TOTAL
Co-58	Ci					
Co-60	Ci					
Sr-89	Ci					
Sr-90	Ci					
Cs-134	Ci					
(List Others)	Ci					
Total	Ci					
			•	•		
Tritium	Ci					
Gross Alpha	Ci					
C-14	Ci					

Table A-1B - Gaseous Effluents—Ground-Level Release—Continuous Mode
Fission and						
Activation	UNITS	QUARTER 1	QUARTER 2	QUARTER 3	QUARTER 4	TOTAL
Gases						
Ar-41	Ci					
Kr-85	Ci					
Kr-85m	Ci					
Kr-87	Ci					
Kr-88	Ci					
Xe-131m	Ci					
Xe-133	Ci					
Xe-133m	Ci					
Xe-135	Ci					
Xe-135m	Ci					
Xe-138	Ci					
(List Others)	Ci					
Total	Ci					
						•
Iodines/	UNITO	OUADTED 1	OLIADTED 2	OLIADTED 2	OUADTED 4	TOTAL
Halogens	UNITS	QUARTERT	QUARTER 2	QUARTER 5	QUARTER 4	IOTAL
I-131	Ci					
I-132	Ci					
I-133	Ci					
I-134	Ci					
I-135	Ci					
Total	Ci					
				7		
Particulates	UNITS	QUARTER 1	QUARTER 2	QUARTER 3	QUARTER 4	TOTAL
Co-58	Ci					
Co-60	Ci					
Sr-89	Ci					
Sr-90	Ci					
Cs-134	Ci					
(List Others)	Ci					
Total	Ci					
Tritium	Ci					
Gross Alpha	Ci					
		1				
C-14	Ci					
		1	1	1	1	
	7					

 Table A-1C - Gaseous Effluents—Elevated Release—Batch Mode

Fission and Activation Gases	UNITS	QUARTER 1	QUARTER 2	QUARTER 3	QUARTER 4	TOTAL
Ar-41	Ci					
Kr-85	Ci					
Kr-85m	Ci					
Kr-87	Ci					
Kr-88	Ci				A	
Xe-131m	Ci					
Xe-133	Ci					
Xe-133m	Ci					
Xe-135	Ci					
Xe-135m	Ci					
Xe-138	Ci					
(List Others)	Ci					
Total	Ci					

Table A-1D - Gaseous Effluents—Elevated Release—Continuous Mode

Iodines/ Halogens	UNITS	QUARTER 1	QUARTER 2	QUARTER 3	QUARTER 4	TOTAL
I-131	Ci					
I-132	Ci					
I-133	Ci					
I-134	Ci					
I-135	Ci					
Total	Ci					

Particulates	UNITS	QUARTER 1	QUARTER 2	QUARTER 3	QUARTER 4	TOTAL
Co-58	Ci					
Co-60	Ci					
Sr-89	Ci					
Sr-90	Ci					
Cs-134	Ci					
(List Others)	Ci					
Total	Ci					

Tritium	Ci			
Gross Alpha	Ci			
C-14	Ci			

Fission and						
Activation	UNITS	QUARTER 1	QUARTER 2	QUARTER 3	QUARTER 4	TOTAL
Gases						
Ar-41	Ci					
Kr-85	Ci					
Kr-85m	Ci					
Kr-87	Ci					
Kr-88	Ci					
Xe-131m	Ci					
Xe-133	Ci					
Xe-133m	Ci					
Xe-135	Ci					
Xe-135m	Ci					
Xe-138	Ci					
(List Others)	Ci					
Total	Ci					
	•					·
Iodines/						TOTAL
Halogens	UNITS	QUARTER I	QUARTER 2	QUARTER 3	QUARTER 4	TOTAL
I-131	Ci				1	
I-132	Ci					
I-133	Ci					
I-134	Ci					
I-135	Ci					
Total	Ci					
		I.			I.	1
Particulates	UNITS	OUARTER 1	OUARTER 2	OUARTER 3	OUARTER 4	TOTAL
Co-58	Ci			7	C	
Co-60	Ci					
Sr-89	Ci					
Sr-90	Ci					
Cs-134	Ci					
(List Others)	Ci					
Total	Ci					
Tritium	Ci					
	CI					
			1			
Gross Alpha	Ci					
		1				
C-14	Ci					
R						

 Table A-1E - Gaseous Effluents—Mixed Mode Release—Batch Mode

Fission and Activation Gases	UNITS	QUARTER 1	QUARTER 2	QUARTER 3	QUARTER 4	TOTAL
Ar-41	Ci					
Kr-85	Ci					
Kr-85m	Ci					
Kr-87	Ci					
Kr-88	Ci					
Xe-131m	Ci					
Xe-133	Ci					
Xe-133m	Ci					
Xe-135	Ci					
Xe-135m	Ci					
Xe-138	Ci					
(List Others)	Ci					
Total	Ci					

Table A-1F - Gaseous Effluents—Mixed Mode Release—Continuous Mode

Iodines/ Halogens	UNITS	QUARTER 1	QUARTER 2	QUARTER 3	QUARTER 4	TOTAL
I-131	Ci					
I-132	Ci					
I-133	Ci					
I-134	Ci					
I-135	Ci					
Total	Ci					

Particulates	UNITS	QUARTER 1	QUARTER 2	QUARTER 3	QUARTER 4	TOTAL
Co-58	Ci					
Co-60	Ci					
Sr-89	Ci					
Sr-90	Ci					
Cs-134	Ci					
(List Others)	Ci					
Total	Ci					

Tritium	Ci			
Gross Alpha	Ci			

C-14 Ci

SUMMATION OF							
ALL LIQUID	UNITS	QUARTER 1	QUARTER 2	QUARTER 3	QUARTER 4	TOTAL	UNCERTAINTY (%)
RELEASES							
Fission and Activation	Ci						
Products (excluding						6/	
tritium, noble gases,							
C-14 and gross alpha)							
Tritium	Ci						
Dissolved and Entrained	Ci						
Gases							
Gross Alpha	Ci						
Volume of Primary	Liters						
System Liquid Effluent							
(before dilution)							
Dilution Water Used for	Liters						
Above							
Volume of Secondary or	Liters						
Balance-of-Plant Liquid							
Effluent (e.g., low-							
activity or unprocessed)							
(before dilution)							
Quarterly Dilution	Liters						
Water Used for Above							
Average Stream Flow	m ³ /s						

Table A-2 - Liquid Effluents—Summation of All Releases

Fission and						
Activation	UNITS	QUARTER 1	QUARTER 2	QUARTER 3	QUARTER 4	TOTAL
Products						
Cr-51	Ci					
Mn-54	Ci					
Fe-55	Ci					
Fe-59	Ci					
Co-57	Ci					
Co-58	Ci					
Co-60	Ci					
Sr-89	Ci					
Sr-90	Ci					
Nb-95	Ci					
Ag-110m	Ci					
Sn-113	Ci					
Sb-124	Ci					
Sb-125	Ci					
I-131	Ci					
I-133	Ci					
I-135	Ci					
Cs-134	Ci					
Cs-137	Ci					
(List Others)	Ci					
Total	Ci					

Table A-2A - Liquid Effluents—Batch Mode

Dissolved and	UNITS	QUARTER 1	QUARTER 2	QUARTER 3	QUARTER 4	TOTAL
Kr 85	Ci					
Kr 85m	Ci					
Kr_88	Ci					
Xe-131m	Ci					
Xe-133	Ci					
Xe-133m	Ci					
Xe-135	Ci					
Xe-135m	Ci					
(List Others)	Ci					
Total	Ci					
	-			1		
Tritium	Ci					
Gross Alpha	Ci					

 Table A-2A - Liquid Effluents—Batch Mode (continued)

Fission and						
Activation	UNITS	QUARTER 1	QUARTER 2	QUARTER 3	QUARTER 4	TOTAL
Products	C:					
Cr-51	Ci					
Mn-54	Ci					
Fe-55	Ci					
Fe-59	Ci					
Co-57	Ci					
Co-58	Ci					
C0-00	Ci					
SI-09	Ci					
Nh 05	Ci					
N0-95	Ci					
Ag-11011 Sn-113	Ci					
Sh-124	Ci					
Sb-125	Ci					
I-131	Ci					
I-133	Ci					
I-135	Ci					
Cs-134	Ci					
Cs-137	Ci					
(List Others)	Ci					
Total	Ci					
/						

Table A-2B - Liquid Effluents—Continuous Mode

Dissolved and						
Entrained	UNITS	QUARTER 1	QUARTER 2	QUARTER 3	QUARTER 4	TOTAL
Gases						
Kr-85	Ci					
Kr-85m	Ci					
Kr-88	Ci					
Xe-131m	Ci					
Xe-133	Ci					
Xe-133m	Ci					
Xe-135	Ci					
Xe-135m	Ci					
(List Others)	Ci					
Total	Ci					
Tritium	Ci					
		1	1	ı		1
Gross Alpha	Ci					
				•	7	
		\				
	7					

 Table A-2B - Liquid Effluents—Continuous Mode (continued)

Table A-3 - Solid Waste and Irradiated Fuel Shipments

A. SOLID RADIOACTIVE WASTE SHIPPED FROM THE UNIT (not irradiated fuel)

TYPE OF WASTE	NUMBER OF SHIPMENTS	VOLUME (m ³)	ACTIVITY OF MAJOR NUCLIDES (Ci)
Wet radioactive waste			
(e.g., spent resins, filters,			
sludges, etc.)			
Dry radioactive waste			
(e.g., trash, paper, discarded			
protective clothing, etc.)			
Activated or contaminated			
radioactive material			
(e.g., equipment or bulk			
radioactive material)			
Other radioactive waste			7
(waste not included in the			
above categories and waste not			
excepted per Section 6 of this			
RG.)			

B. IRRADIATED FUEL SHIPMENTS (Disposition)

Number of Shipments

, ,

Mode of Transportation

Destination

Table A-4 - Dose Limits¹⁶, per Technical Specifications (based on fractions of 10 CFR Part 50, Appendix I)

QUARTER 1	QUARTER 2	QUARTER 3	QUARTER 4	YEARLY
1.5 mrem	1.5 mrem	1.5 mrem	1.5 mrem	3 mrem
5 mrem	5 mrem	5 mrem	5 mrem	10 mrem
5 mrad	5 mrad	5 mrad	5 mrad	10 mrad
10 mrad	10 mrad	10 mrad	10 mrad	20 mrad
7.5 mrem	7.5 mrem	7.5 mrem	7.5 mrem	15 mrem
	QUARTER 1 1.5 mrem 5 mrem 5 mrad 10 mrad 7.5 mrem	QUARTER 1QUARTER 21.5 mrem1.5 mrem5 mrem5 mrem5 mrad5 mrad5 mrad5 mrad10 mrad10 mrad7.5 mrem7.5 mrem	QUARTER 1QUARTER 2QUARTER 31.5 mrem1.5 mrem1.5 mrem5 mrem5 mrem5 mrem5 mrad5 mrad5 mrad5 mrad5 mrad5 mrad10 mrad10 mrad10 mrad7.5 mrem7.5 mrem7.5 mrem	QUARTER 1 QUARTER 2 QUARTER 3 QUARTER 4 1.5 mrem 1.5 mrem 1.5 mrem 1.5 mrem 5 mrem 5 mrem 5 mrem 5 mrem 5 mrem 5 mrem 5 mrem 5 mrem 5 mrad 5 mrad 5 mrad 5 mrad 5 mrad 5 mrad 5 mrad 5 mrad 10 mrad 10 mrad 10 mrad 10 mrad 7.5 mrem 7.5 mrem 7.5 mrem 7.5 mrem

¹⁶ Doses based on quarterly and annual limits

Table A-5 - EPA 40 CFR Part 190 Dose Limits to an Individual in the Unrestricted Area

	WHOLE BODY	THYROID	ANY OTHER ORGAN
Dose Limit	25 mrem	75 mrem	25 mrem
Dose ¹⁷			
% of Dose Limit			

3 4

Dose from current year effluent discharges.

5		Table A-6. Supplemental Information
6 7 8	1.	Abnormal Releases and Abnormal Discharges (e.g., leaks and spills)
9 10 11	2.	Nonroutine, Planned Discharges (e.g., pumping of leaks and spills for remediation, results of groundwater monitoring to quantify effluent releases to the offsite environment)
12 13	3.	Radioactive Waste Treatment System Changes
13 14 15	4.	Annual Land Use Census Changes
16 17	5.	Effluent Monitor Instrument Inoperability
18 19	6.	ODCM Changes
20 21	7.	Process Control Program Changes
22 22 23	8.	Errata/Corrections to Previous ARERRs
23 24 25	9.	Other (narrative description of other information that is provided to the NRC, such as in the ARERR or ISFSI reports).