

# Regulatory Commitment Update

(1 page)

## LIST OF COMMITMENTS

The following table identifies those actions committed to by Ameren Missouri in this document. Any other statements in this document are provided for information purposes and are not considered commitments. Please direct questions regarding these commitments to: Justin Hiller at 314-225-1141.

<b>Regulatory Commitment and Completion Schedule</b>			
<b>Commitment</b>	<b>Committed Completion Date</b>	<b>Commitment Tracking Number</b>	<b>Status</b>
<p>The resolution of Fire PRA Suggestion F&amp;O FSS-B1-03 was determined to be an upgrade during F&amp;O closure review. The upgrade was not reviewed at the time of identification and has not yet been reviewed by an independent peer review. To resolve FSS-B1-03 and also close NFPA-805 LAR Table S-3 Implementation item 13-805-001, the Fire PRA was updated to perform the Human Reliability Analysis (HRA) evaluations for MCR abandonment using detailed assessments within HRA Calculator rather than the screening values discussed in this F&amp;O. This change was determined by a recent independent peer review team to be an upgrade. PRA scope and technical adequacy guidance requires upgrades to be independently peer reviewed and Finding F&amp;Os to be closed, or dispositioned for a given application. Therefore, Ameren Missouri will conduct a focused scope peer review on this upgrade and close any new Finding F&amp;Os using an endorsed closure process.</p>	<p>Prior to using the Fire PRA to support implementation of any alternative treatments under the 10 CFR 50.69 application.</p>	50437	Complete