




Holtec International – HI-STORE RAIs – Chapter 5



Chapter 5 RAIs

■ RAI 5-3

- ✓ NRC requests details of the anchor rods of the HI-TRAC CS
- ✓ Holtec will update drawings to provide details of the anchor rods and the HI-TRAC CS restraints, and update seismic analysis to consider combined shear, bending and tension in the anchor rods

■ RAI 5-4

- ✓ NRC requests seismic evaluation of cask handling operations
- ✓ Holtec will provide seismic evaluations of all cask handling operations along with updated operational procedures

■ RAI 5-8

- ✓ NRC requests calculations for the VCT with specific details
- ✓ Holtec will provide details of the VCT and associated calculations under all applicable conditions, and will also provide details of other handling equipment

Chapter 5 RAIs

■ RAI 5-9

- ✓ NRC requests more details and analyses for the CTB
- ✓ Holtec will provide drawings, details, applicable design codes and all supporting analyses for CTB as requested

■ RAI 5-10

- ✓ NRC requests fatigue life of VCT, HI-TRAC CS and all associated equipment
- ✓ Holtec will perform the fatigue analyses (including low cyclic fatigue) and provide the number of allowable canister deployments associated with VCT, HI-TRAC and other handling equipment

■ RAI 5-11

- ✓ NRC requests details on groove weld options
- ✓ Holtec will update drawing to remove the groove or equivalent weld option

Chapter 5 RAIs

■ RAI 5-13

- ✓ NRC requests clarification on ITS welds and sizes
- ✓ Holtec will revise drawing to clearly identify ITS/NITS components and provide appropriate weld sizes for ITS welds

■ RAI 5-14

- ✓ NRC needs details on pedestal for the HI-STAR 190 in the CTF
- ✓ Holtec will provide drawing with pedestal design and appropriate supporting analyses

■ RAI 5-15

- ✓ NRC requests revision to the LS-DYNA model to address hour glassing energy
- ✓ Holtec will revise stack-up analysis accordingly

Chapter 5 RAIs

■ RAI 5-18-S-1

- ✓ NRC requests details on CLSM used for CTB slab
- ✓ Holtec will update CTB drawing to provide details (reinforced concrete slab supported by CLSM)

■ RAI 5-18-S-2

- ✓ NRC requests details and calculations for the CTB floor slab and CTF
- ✓ Holtec will provide updated drawing and analyses of the CTB floor slab and CTF for all applicable loadings

■ RAI 5-21

- ✓ NRC requests stress-strain curves based on material testing
- ✓ Holtec will use recent information from HI-STAR ATB-1T and HI-STAR 100MB

Chapter 5 RAIs

■ RAI 5-23

- ✔ NRC requests buckling analysis of horizontal lift beam along with CTB, crane and rigging details
- ✔ Holtec will provide buckling analysis of horizontal lift beam and seismic analyses of all lifting and handling equipment including slings

■ RAI 5-24

- ✔ NRC requests information on seismic loads on transportation cask lifting equipment
- ✔ Holtec will provide seismic analyses of the lifting/handling equipment for transportation cask