

APPENDIX A ABNORMAL OCCURRENCE CRITERIA

ABNORMAL OCCURRENCE GENERAL STATEMENT OF POLICY

The Commission will apply the following policy in determining whether an incident or event at a facility or involving an activity that is licensed or otherwise regulated by the Commission or an Agreement State is an abnormal occurrence (AO).¹

An incident or event is considered an AO if it involves a major reduction in the protection of public health or safety. The incident or event has a moderate or severe impact on public health or safety and could include, but need not be limited to, the following:

- (1) Moderate exposure to, or release of, radioactive material licensed by or otherwise regulated by the Commission or Agreement State;
- (2) Major degradation of essential safety-related equipment;
- (3) Major deficiencies in design, construction, use of, or management controls for, facilities or radioactive material licensed by or otherwise regulated by the Commission or Agreement State; or
- (4) Substantiated case of actual loss, theft, or diversion of risk-significant radioactive material licensed by or otherwise regulated by the Commission or Agreement State.

The NRC identified the following criteria for determining an AO and the guidelines for “other events of interest” in a policy statement published in the *Federal Register* on October 2, 2017 (82 FR 45907).

Abnormal Occurrence Criteria

The following presents the criteria, by types of events, used to determine which events will be considered for reporting as AOs.

- I. All Licensees²
 - A. Human Exposure to Radiation from Licensed Material

¹ Events reported to the NRC by Agreement States that reach the threshold for reporting as AOs will be reported as such by the Commission.

² Medical patients and human research subjects are excluded from consideration under these criteria, and these criteria do not apply to medical events defined in § 35.3045 of Title 10 of the Code of *Federal Regulations* (10 CFR), “Report and notification of a medical event,” which are considered in AO Criteria III.C.

1. Any unintended radiation exposure to an adult (any individual 18 years of age or older) resulting in:
 - a. An annual total effective dose equivalent (TEDE) of 250 millisieverts (mSv) (25 rem) or more;
 - b. An annual sum of the deep dose equivalent (external dose) and committed dose equivalent (intake of radioactive material) to any individual organ other than the lens of the eye, the bone marrow, and the gonads of 2,500 mSv (250 rem) or more;
 - c. An annual dose equivalent to the lens of the eye of 1 Sievert (Sv) (100 rem) or more;
 - d. An annual sum of the deep dose equivalent and committed dose equivalent to the bone marrow of 1 Sv (100 rem) or more;
 - e. A committed dose equivalent to the gonads of 2,500 mSv (250 rem) or more; or
 - f. An annual shallow-dose equivalent to the skin or extremities of 2,500 mSv (250 rem) or more.
2. Any unintended radiation exposure to any minor (an individual less than 18 years of age) resulting in an annual TEDE of 50 mSv (5 rem) or more, or to an embryo/fetus resulting in a dose equivalent of 50 mSv (5 rem) or more.
3. Any radiation exposure that has resulted in unintended permanent functional damage to an organ or a physiological system as determined by an independent physician³ deemed qualified by the NRC or Agreement State.

B. Discharge or Dispersal of Radioactive Material from Its Intended Place of Confinement

The release of radioactive material to an unrestricted area in concentrations that, if averaged over a period of 24 hours, exceed 5,000 times the values specified in Table 2 of Appendix B, "Annual Limits on Intake (ALIs) and Derived Air Concentrations (DACs) of Radionuclides for Occupational Exposure; Effluent Concentrations; Concentrations for Release to Sewerage," to 10 CFR part 20, "Standards for protection against radiation," unless the licensee has demonstrated compliance with § 20.1301, "Dose limits for individual members of the public," using § 20.1302(b)(1) or § 20.1302(b)(2)(ii). This criterion does not apply to transportation events.

³ "Independent physician" is defined as a physician not on the licensee's staff and who was not involved in the care of the patient involved.

- C. Theft, Diversion, or Loss of Licensed Material; Sabotage; or Security Breach^{4, 5, 6}
1. Any stolen, diverted, abandoned, or unrecovered lost radioactive material that meets or exceeds the thresholds listed in Appendix A, "Category 1 and Category 2 Radioactive Materials," to 10 CFR part 37, "Physical Protection of Category 1 and Category 2 Quantities of Radioactive Material." Excluded from reporting under this criterion are those events involving sources that are lost or abandoned under the following conditions: sources that have been lost and for which a reasonable attempt at recovery has been made without success, or irretrievable well logging sources as defined in § 39.2, "Definitions." These sources are only excluded if there is reasonable assurance that the doses from these sources have not exceeded, and will not exceed, the reporting thresholds specified in AO Criteria I.A.1 and I.A.2 and the agency has determined that the risk of theft or diversion is acceptably low.
 2. An act that results in radiological sabotage as defined in § 73.2.
 3. Any substantiated⁷ case of actual theft, diversion, or loss of a formula quantity of special nuclear material,⁸ or an inventory discrepancy of a formula quantity of special nuclear material that is judged to be caused by theft or diversion.

⁴ Information pertaining to certain incidents may either be classified or under consideration for classification because of national security implications. Classified information will be withheld when formally reporting these incidents in accordance with Executive Order 13526, "Classified National Security Information," as amended (75 FR 707; January 5, 2010), or any predecessor or successor order to require protection against unauthorized disclosures. Any classified details about these incidents would be available to Congress upon request, under appropriate security arrangements.

⁵ Information pertaining to certain incidents may be Safeguards Information as defined in § 73.2 because of safety and security implications. The AO report would withhold specific Safeguards Information in accordance with Section 147 of the Atomic Energy Act of 1954, as amended. Any safeguards details regarding these incidents would be available to Congress upon request, under appropriate security arrangements.

⁶ Reporting lost or stolen material is based on the activity of the source at the time the radioactive material was known to be lost or stolen. If, by the time the AO report is due to Congress, the radioactive material has decayed below the thresholds listed in Appendix A to 10 CFR part 37, the report will clarify that the radioactive material has decayed below the thresholds.

⁷ "Substantiated" means a situation in which there is an indication of loss, theft, or unlawful diversion, such as an allegation of diversion, report of lost or stolen material, or other indication of loss of material control or accountability that cannot be refuted following an investigation, and requires further action on the part of the agency or other proper authorities.

⁸ "Formula quantity of special nuclear material" is defined in § 70.4, "Definitions."

4. Any substantial breakdown⁹ of physical security, cyber security, or material control and accountability programs that significantly weakens the protection against loss, theft, diversion, or sabotage.
 5. Any significant unauthorized disclosures (loss, theft, and/or deliberate disclosure) of classified information that harms national security or of Safeguards Information that threatens public health or safety.
- D. Initiation of High-Level NRC Team Inspection.¹⁰
- II. Commercial Nuclear Power Plant Licensees
- A. Malfunction of Facility, Structures, or Equipment
1. Exceeding a safety limit of a license technical specification (TS) (§ § 50.36(c)).
 2. Serious degradation of fuel integrity, primary coolant pressure boundary, or primary containment boundary.
 3. Loss of plant capability to perform essential safety functions so that a release of radioactive materials that could result in exceeding the dose limits of 10 CFR part 100, "Reactor site criteria," or five times the dose limits of General Design Criteria (GDC) 19, "Control Room," in Appendix A, "General Design Criteria for Nuclear Power Plants," to 10 CFR part 50, "Domestic licensing of production and utilization facilities," could occur from a postulated transient or accident (e.g., loss of emergency core cooling system, loss of control rod system).
- B. Design or Safety Analysis Deficiency, Personnel Error, or Procedural or Administrative Inadequacy
1. Discovery of a major condition not specifically considered in the safety analysis report or TS that requires immediate remedial action.
 2. Personnel error or procedural deficiencies that result in the loss of plant capability to perform essential safety functions such that a release of radioactive materials exceeding the dose limits of 10 CFR part 100 or five times the dose limits of GDC 19 in Appendix A to 10 CFR part 50, could

⁹ A substantial breakdown is defined as a red finding under the Reactor Oversight Process (ROP) in the physical security inspection program or any plant or facility determined to have overall unacceptable performance.

¹⁰ This item addresses the initiation of any incident investigation teams, as described in NRC Management Directive (MD) 8.3, "NRC Incident Investigation Program" (ADAMS Accession No. ML13175A294), or initiation of any accident review groups, as described in MD 8.9, "Accident Investigation" (ADAMS Accession No. ML13319A133).

occur from a postulated transient or accident (e.g., loss of emergency core cooling system, loss of control rod drive mechanism).

- C. Any operating reactor events or conditions evaluated by the NRC ROP to be the result of or associated with licensee performance issues of high safety significance.¹¹
 - D. Any operating reactor events or conditions evaluated by the NRC Accident Sequence Precursor (ASP) program to have a conditional core damage probability (CCDP) or change in core damage probability (Δ CDP) of greater than or equal to 1×10^{-3} .¹²
 - E. Any operating reactor plants that are determined to have overall unacceptable performance or are in a shutdown condition as a result of significant performance problems and/or operational event(s).¹³
- III. Events at Facilities Other Than Nuclear Power Plants and All Transportation Events
- A. Events Involving Design, Analysis, Construction, Testing, Operation, Transport, Use, or Disposal
 - 1. An accidental criticality.
 - 2. A major deficiency in design, construction, control, or operation having significant safety implications that require immediate remedial action.
 - 3. A serious safety-significant deficiency in management or procedural controls.

¹¹ The NRC ROP uses four colors to describe the safety significance of licensee performance. As defined in NRC MD 8.13, "Reactor Oversight Process" (ADAMS Accession No. ML17347B670), green is used for very low safety significance, white is used for low to moderate safety significance, yellow is used for substantial safety significance, and red is used for high safety significance. Reactor conditions or performance indicators evaluated to be red are considered AOs.

¹² Results from the NRC ASP program are used to monitor agency performance against the agency's strategic safety goal (e.g., ensure the safe use of radioactive materials) and objectives (e.g., prevent and mitigate accidents and ensure radiation safety). A precursor event with a CCDP or Δ CDP of greater than or equal to 1×10^{-3} is used as a performance indicator for the strategic safety goal by determining that there have been no significant precursors of a nuclear reactor accident and that there have been no more than one significant adverse trend in industry safety performance.

¹³ Any plants assessed by the ROP to be in the unacceptable performance column, as described in NRC Inspection Manual Chapter (IMC) 0305, "Operating Reactor Assessment Program" (ADAMS Accession No. ML19256A191), or under NRC IMC 0350, "Oversight of Reactor Facilities in a Shutdown Condition Due to Significant Performance and/or Operational Concerns" (ADAMS Accession No. ML17116A273). This assessment of safety performance is based on the number and significance of NRC inspection findings and licensee performance indicators.

4. A series of events (in which the individual events are not of major importance), recurring incidents, or incidents with implications for similar facilities (generic incidents) that raise a major safety concern.
- B. Fuel Cycle Facilities¹⁴
1. Absence or failure of all safety controls (engineered and human) such that conditions were present for the occurrence of a high-consequence event involving an NRC-regulated hazard (radiological or chemical).¹⁵
 2. An NRC-ordered safety-related or security-related immediate remedial action.
- C. Events Involving the Medical Use of Radioactive Materials in Patients or Human Research Subjects¹⁶
1. A medical event, as defined in § 35.3045, which results in a dose that:
 - a. Is equal to or greater than 1 gray (Gy) (100 rad) to a major portion of the bone marrow or to the lens of the eye; or equal to or greater than 2.5 Gy (250 rad) to the gonads; or
 - b. Exceeds, by 10 Gy (1,000 rad), the expected dose to any other organ or tissue from the administration defined in the written directive; and

¹⁴ Criterion III.A also applies to fuel cycle facilities.

¹⁵ High-consequence events for facilities licensed under 10 CFR part 70, “Domestic licensing of special nuclear material,” are those that could seriously harm the worker or a member of the public in accordance with § 70.61, “Performance requirements.” The integrated safety analysis conducted and maintained by the licensee or applicant of 10 CFR part 70 fuel cycle facilities identifies such hazards and the safety controls (§ 70.62(c)) applied to meet the performance requirements in accordance with § 70.61(b) through (d).

Fuel cycle facilities licensed under 10 CFR part 40, “Domestic licensing of source material,” or certified under 10 CFR part 76, “Certification of gaseous diffusion plants,” have licensing basis documents that describe facility specific hazards, consequences, and those controls used to prevent or mitigate the consequences of such accidents. For these facilities, a high-consequence event would be a release that has the potential to cause acute radiological or chemical exposures to a worker or a member of the public similar to that defined in Appendix A to Chapter 3, Section A.2, of NUREG 1520, Revision 2, “Standard Review Plan for Fuel Cycle Facilities License Applications—Final Report,” issued June 2015, under “Consequence Category 3 (High Consequences)” (ADAMS Accession No. ML15176A258).

¹⁶ Criteria III.A.2, III.A.3, and III.A.4 also apply to medical licensees.

2. A medical event, as defined in § 35.3045, which involves:
 - a. A dose or dosage that is at least 50 percent greater than that prescribed, or
 - b. A prescribed dose or dosage that:
 - (i) Uses the wrong radiopharmaceutical or unsealed byproduct material; or
 - (ii) Is delivered by the wrong route of administration; or
 - (iii) Is delivered to the wrong treatment site; or
 - (iv) Is delivered by the wrong treatment mode; or
 - (v) Is from a leaking source or sources; or
 - (vi) Is delivered to the wrong individual or human research subject.