

**Official Transcript of Proceedings**  
**NUCLEAR REGULATORY COMMISSION**

Title: Advisory Committee on Reactor Safeguards  
Radiation Protection & Nuclear Materials

Docket Number: (n/a)

Location: teleconference

Date: Friday, July 23, 2021

Work Order No.: NRC-1599

Pages 1-111

**NEAL R. GROSS AND CO., INC.**  
**Court Reporters and Transcribers**  
**1323 Rhode Island Avenue, N.W.**  
**Washington, D.C. 20005**  
**(202) 234-4433**

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S  
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, as reported herein, is a record of the discussions recorded at the meeting.

This transcript has not been reviewed, corrected, and edited, and it may contain inaccuracies.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

UNITED STATES OF AMERICA

NUCLEAR REGULATORY COMMISSION

+ + + + +

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

(ACRS)

+ + + + +

RADIATION PROTECTION & NUCLEAR MATERIALS

SUBCOMMITTEE

+ + + + +

FRIDAY

JULY 23, 2021

+ + + + +

The Subcommittee met via Video  
Teleconference, at 9:30 a.m. EDT, David Petti,  
Chairman, presiding.

COMMITTEE MEMBERS:

DAVID A. PETTI, Chairman

RONALD G. BALLINGER, Member

DENNIS BLEY, Member

CHARLES H. BROWN, JR. Member

VESNA B. DIMITRIJEVIC, Member

GREG HALNON, Member

WALTER L. KIRCHNER, Member

JOSE MARCH-LEUBA, Member

JOY L. REMPE, Member

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

MATTHEW W. SUNSERI, Member

ACRS CONSULTANT:

MIKE CORRADINI

STEVE SCHULTZ

DESIGNATED FEDERAL OFFICIAL:

MICHAEL SNODDERLY

ALSO PRESENT:

GREG BROADBENT, Entergy

JERRY DOZIER, NRR

MIKE FRANOVICH, NRR

KEVIN HSUEH, NRR

STEVE JONES, NRR

SCOTT MOORE, Executive Director, ACRS

JOHN PARILLO, NRR

FRANCES PIMENTEL, NEI

SHILP VASAVADA, NRR

CONTENTS

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

Opening Remarks . . . . . 4

Discussion of Draft Final Interim Staff Guidance 6

Comments on Draft Final Guidance . . . . . 98

Opportunity for Public Comment . . . . . 107

Adjourn . . . . . 111

## P R O C E E D I N G S

9:30 a.m.

CHAIR PETTI: Okay, so I have 30 minutes after the hour so let's have the meeting come to order.

This is a meeting of the Advisory Committee on Reactor Safeguards, Radiation Protection and Nuclear Materials Subcommittee. I'm Dave Petti, chairman of today's subcommittee meeting.

Members with us today are Charlie Brown, Dennis Bley, Greg Halnon, Jose March-Leuba, Walt Kirchner, Consultant Mike Corradini.

MEMBER REMPE: Dave, this is Joy. I'm also here.

CHAIR PETTI: Yes, Member Joy Rempe, Consultant Steve Schultz, Member Ron Ballinger, Member Vesna Dimitrijevic, and Member Matt Sunseri.

Mike Snodderly is the Designated Federal Official for this meeting. The subcommittee will review the staff's draft interim staff guidance entitled Supplemental Source Guidance for Radiological Consequence Analysis Using Alternative Source Term. We also have members of the NRC staff and NEI to brief the subcommittee.

The ACRS was established by statute and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 it's governed by the Federal Advisory Committee Act,  
2 FACA. The NRC implements FACA in accordance with its  
3 regulations found in Title 10 of the Code of Federal  
4 Regulations, Part 7. The committee can only speak to  
5 its published letter reports. We hold meetings to  
6 gather information, perform preparatory work to  
7 support our full deliberations at a full committee  
8 meeting.

9 The rules for participation in all ACRS  
10 meetings were announced in the Federal Register on  
11 June 13, 2019. The ACRS section of the U.S. NRC  
12 public website provides our charter, bylaws, agendas,  
13 letters, of course, and full transcripts of all full  
14 subcommittee meetings including slides presented  
15 there. The agenda for this meeting was also posted  
16 there.

17 As stated in the Federal Register notice  
18 and in the public meeting notice posted to the  
19 website, members of the public who desire to provide  
20 written or oral input to the subcommittee may do so.  
21 You should contact the Designated Federal Official  
22 five days prior to the meeting as practicable.

23 We've set aside 15 minutes for comments  
24 from members of the public, attending or listening to  
25 our meetings. We have not received written comments

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 or requests for time to make oral statements for  
2 members of the public regarding today's meeting.

3 A transcript of the meeting is being kept  
4 and will be made available on the ACRS section of the  
5 NRC public website.

6 It is requested that speakers identify  
7 themselves and speak with sufficient clarity and  
8 volume so they can be readily heard. Additionally,  
9 participants should mute themselves when not speaking.  
10 A telephone bridge line has been established for the  
11 public to listen to the meeting. To minimize  
12 disturbance, the public line will be kept in a listen  
13 in only mode.

14 With that, we will now proceed with the  
15 meeting. I call upon Mike Franovich, Director of the  
16 Division of Risk Assessment in NRR to begin today's  
17 presentations. Mike?

18 MR. FRANOVICH: Good morning, Chairman  
19 Petti. If we could have Slide 2, please.

20 Good morning, Chairman Petti and good  
21 morning, ACRS Subcommittee members. I am Mike  
22 Franovich and I serve as the Director of the Division  
23 of Risk Assessment in NRR. Thank you for the  
24 opportunity today for the staff to share advances in  
25 our regulatory reviews of radiological consequence

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 analysis using the alternate source term.

2 To set the stage, let me highlight a few  
3 of the more recent regulatory transformations and the  
4 performance shaping factors improving our efficiency  
5 and reliability as regulators.

6 A key theme is that our licensing, other  
7 regulatory decisions, and backfit/forward fit actions  
8 must be risk informed and there are two particular  
9 staff requirement memoranda that have been directing  
10 those items here noted on the slide.

11 The Commission's recent direction reminded  
12 the staff that we are enabled to use risk-informed,  
13 performance-based approaches in our work. This  
14 direction in 2019 also serves as an accelerant for  
15 transformation become a more modern risk-informed  
16 regulator.

17 The SRM, commonly referred to as the  
18 NuScale Block Valve SRM, draws upon long standing  
19 practices and in particular, a 1999 Commission paper  
20 that states succinctly a risk-informed, performance-  
21 based approach is one of risk insights, engineering  
22 analysis, and judgment including the principle of  
23 defense in depth and the incorporation of safety  
24 margins including performance history are used in  
25 decisions.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1           In 2018, we also received additional  
2 clarifications from the Commission regarding  
3 regulatory backfits and proper treatment of forward  
4 fits. This Commission direction serves as a regulatory  
5 stabilizing applying the reliability principles of  
6 good regulations in our license amendment reviews.

7           Secondly, improved realism evaluation  
8 techniques and additional information are applied to  
9 improve risk-informed decision making.

10           As noted in a 2019 memo to the Executive  
11 Director for Operations on applying risk-informed  
12 principles, the NRC's application of risk-informed  
13 decision making continues to evolve, as improved  
14 realism, evaluation techniques, and additional  
15 information are applied to improve our decisions.  
16 What that means to the staff when it comes to review  
17 of applications to allow for possible increases in  
18 leakage from BWR main steam isolation valves is that  
19 there are tremendous opportunities to apply  
20 engineering and risk insights. This mosaic of  
21 information includes plant operating experience, as  
22 well as our experiences from post-Fukushima activities  
23 to make more realistic and ultimately better decisions  
24 while abiding by the Commission's backfit and forward  
25 fit expectations.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1           And third, cultural realignment is needed  
2           to ensure that we identify and resolve challenges and  
3           roadblocks for the appropriate and consistent  
4           integration of risk insights. Two important agency  
5           activities address NRC internal cultural realignment  
6           needs that are detailed in the previously mentioned  
7           memo to the EDO. Most recently, the Be riskSMART  
8           Initiative is driving agency-wide practices for a  
9           uniform risk and reward mindset and use of graded  
10          approaches in our safety, security, corporate support  
11          and other agency business.

12           This concept is also applicable as we  
13          assess licensees' request to allow for increased  
14          leakage while satisfying overall plant performance  
15          objectives, limiting potential consequences during  
16          hypothetical accidents. For BWR MSIV leakage, here is  
17          once again an opportunity to be mindful of radiation  
18          dose ALARA objectives for workers who maintain these  
19          MSIVs in terms of their performance.

20           Lastly, NRR continues to implement the  
21          after actions of our 2018 risk-informed decision  
22          making action plan and a key insight out of that plan  
23          is promoting greater use of integrated review teams.

24           Today, you will hear from a diverse team  
25          consisting of management, systems and component

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 experts, risk analysts, seismic experts, and accident  
2 dose analysts supporting this Draft ISG.

3 And with that said, I will turn it over to  
4 Kevin.

5 MR. HSUEH: Thanks, Mike. Good morning,  
6 everyone. I am Kevin Hsueh, Branch Chief, Radiation  
7 Protection and Consequence Branch in NRR, Division of  
8 Risk Assessment.

9 I'll cover Slides 3 and 4 and we are  
10 currently on Slide 3. In 2019, we received four  
11 license amendment requests to increase MSIV leakage  
12 allowed by tech specs for BWR. Traditionally, this  
13 type of amendment requests were reviewed using  
14 deterministic review methods.

15 In the SRM that might mention the NuScale  
16 Block Valve SRM, the Commission directed the staff to  
17 apply risk-informed principles in any licensing review  
18 or other regulatory decision when strict, prescriptive  
19 application of deterministic criteria is unnecessary  
20 to provide for reasonable assurance of adequate  
21 protection of public health and safety.

22 In response to this and other previous  
23 risk-informed related SRMs and soon after we received  
24 this amendment request, we started to look for ways  
25 where we can increase use of risk insights to perform

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 this review.

2 After several months of efforts and a  
3 number of meetings among NRR staff for more support  
4 (phonetic) the regions staff developed a technical  
5 assessment and followed NRR office instructions LIC-  
6 206 process to integrate this insight with these types  
7 of traditional decommissioning reviews.

8 CHAIR PETTI: It looks like Member Rempe  
9 has her hand up. She has a question, I think.

10 MR. HSUEH: Oh, okay. All right. Go  
11 ahead.

12 MEMBER REMPE: Sorry, Kevin. I have a  
13 question that is a bit off topic and it's probably due  
14 to me not being fully informed on what the staff did  
15 with these reviews, but again, we only saw the  
16 Fitzpatrick and the ISG, but if the staff is going to  
17 be using risk insights for design basis actions source  
18 terms, I'm wondering if other risk insights were also  
19 considered such as the impact on operator actions if  
20 they allow increased leakage from the MSIVs.

21 As I think about how the operators would  
22 know if the MSIV closed, there is probably differences  
23 in temperature or radiation, monitor readings or  
24 something like that, but again, they're used to seeing  
25 increased leakage. And so I'm wondering if their

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 ability to detect that it really closed or if it  
2 failed to close would be impacted.

3 Did the staff consider that as they risk  
4 informed this process? Because I didn't see anything  
5 about operator actions in what the staff sent back on  
6 the Fitzpatrick request.

7 MR. HSUEH: Thank you for the question and  
8 please hold that thought and maybe later on we can  
9 touch base on that and we have the staff can answer  
10 that question if it's okay with you.

11 MEMBER REMPE: Sure. It was something  
12 that crossed my mind when I was reading this and  
13 again, perhaps the staff did something and it just  
14 wasn't in the documentation you were given. But I am  
15 curious about that. To meet holistically, consider  
16 risk insights, not just pick and choose things that  
17 are going to address the consequences is what my  
18 thought was.

19 MR. HSUEH: Okay. Thank you. So we will  
20 answer -- respond to that at the staff's presentation  
21 and I think that the staff is prepared to respond to  
22 that question.

23 MEMBER REMPE: Great.

24 MR. HSUEH: All right, so I continue the  
25 Slide 3. So during our review, we overcame many

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 changes and completed all four safety evaluations with  
2 risk and engineering insights to support our  
3 reasonable assurance finding. And to document our  
4 reasonable assurance finding each of the four safety  
5 evaluations includes new risk and engineering insight  
6 section summarizing the finding and conclusion of a  
7 technical assessment.

8 All four safety evaluations received OGC's  
9 no legal decision (phonetic) individually prior to  
10 staff approval of this amendment request.

11 Mike mentioned the November 2019 NRC memo,  
12 agency's efforts in implementing the NuScale Block  
13 Valve SRM. The memo highlights the staff's efforts  
14 and staff's challenges and continuous efforts in  
15 applying risk-informed principles in our decision  
16 making and making the progress one decision at a time.

17 Consistent with the implementation of that  
18 SRM and to memorialize our practice and experiences,  
19 we developed this interim staff guidance or ISG. This  
20 ISG serves as an example of our continuous effort in  
21 working toward being a more modern and risk-informed  
22 regulators.

23 Next slide.

24 We are now on Slide 4. In addition to the  
25 ISG developments, there has been a separate on-going

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 effort to revise Reg Guide 1.183 in parallel.  
2 Specifically, staff has restarted its efforts to  
3 revise Reg Guide 1.183 since late last year to update  
4 the current Rev. 0 which was issued in 2000.

5 A working group and a steering committee  
6 were established with a step-by-step project plan to  
7 keep the project moving efficiently and effectively.  
8 So far, we have held three public meetings to seek  
9 stakeholders' input and feedback on a variety of  
10 proposed changes to Rev. 0 and completed a threat  
11 revision.

12 The threat revision is currently being  
13 processed by the Office of Research and the  
14 subcommittee meeting on the threat revision is  
15 scheduled in fall of this year.

16 So for today's meeting, we're trying to  
17 focus our discussion on the threat ISG and how we use  
18 the recent engineering insight to support our  
19 reasonable assurance findings. With that, I'll turn  
20 it over to Jerry to start that presentation.

21 MR. DOZIER: Hello. My name is Jerry  
22 Dozier. I'm a Senior Risk and Reliability Analyst  
23 from the Radiation Protection and Consequences Branch  
24 in the Division of Risk Assessment.

25 In this presentation today that we'll

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 have, as Mike said, diverse skilled members of staff  
2 will provide a presentation which will basically give  
3 a background of the ISG, the basis for the ISG. We  
4 were requested to provide about the difference between  
5 this ISG and the Reg Guide as Kevin just mentioned,  
6 and also how we use this ISG in the LARs. And then  
7 we'll finish with a few takeaways.

8 MEMBER KIRCHNER: Jerry, this is Walt  
9 Kirchner. May I just ask you for a little background  
10 or context from you and your team about the BWR LARs?  
11 The way the viewgraphs are written might lead the  
12 public to -- might mislead the public into thinking  
13 there's an issue with the performance of the main  
14 steam isolation valves.

15 So could you just give us some context for  
16 the record as to what the issues are? Again, the way  
17 the viewgraphs actually read, kind of just on the  
18 surface, is that you're allowing increased leakage  
19 from valves. And it suggests that that might be  
20 actually a problem. And of course, you've used your  
21 risk-informed approach to determine that it is not.

22 But could you just provide a little more  
23 context about the LARs and the issues with the main  
24 steam isolation valves in BWR?

25 MR. DOZIER: Sure. Sure, I can. And also

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 basically for -- we have one of the reviewers of the  
2 LARs toward the end of the presentation actually  
3 talking about some of the challenges that were in the  
4 LARs, how this was used to resolve that. However,  
5 that will come a little bit later.

6 MEMBER KIRCHNER: Okay, I'll wait until  
7 then. I just thought up front it might provide more  
8 context for the public.

9 MR. DOZIER: Okay, and what I would like  
10 to say that as far as the leakage, what the theme of  
11 these LARs were, was basically it was the licensees  
12 asking for an increase in allowed leakage in their  
13 technical specifications. So it was -- that was the  
14 whole purpose of the LAR was to ask for this increase  
15 in the leakage. And of course, the reviewer has to  
16 use our guidance to review this. And there was some  
17 challenges even within our guidance that we resolved.  
18 We'll talk about it in detail, talk about the slides,  
19 if that's okay.

20 MEMBER BROWN: Did we lose the presenter?

21 MR. DOZIER: I'm still here. I was just  
22 saying if that's okay with you.

23 MEMBER KIRCHNER: I'll wait.

24 MR. DOZIER: Okay.

25 MR. FRANOVICH: Thank you. This is Mike

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 Franovich, Director of Risk Assessment, NRR. I think  
2 it's important to note here, as the staff will explain  
3 further in the presentation. I'm sorry, I hear a  
4 little bit of feedback on the line. I'm not sure all  
5 the lines are muted.

6 The proposed amendments that came in  
7 doesn't suggest or at least we're not aware of any  
8 suggestion that they are some type of industry trend  
9 issue with the performance of MSIVs. We've had other  
10 plants that have requested increased allowables for  
11 leakage. And so this is not necessarily a reflection  
12 of issue with the components as an industry wide type  
13 of issue in terms of trends. I just want to set that  
14 out there for members of the public.

15 MEMBER KIRCHNER: That's what I was  
16 thinking, Mike. You know, because just like I said,  
17 a superficial reading of the viewgraphs would suggest  
18 there's problems with the valves and now they want to  
19 have a more allowance for leakage, et cetera, so thank  
20 you.

21 MR. FRANOVICH: And if I can also add --  
22 no, that's very fair. I appreciate you giving us the  
23 opportunity to explain that because the other  
24 tempering factor that the licensees are challenged  
25 with is managing ALARA. And these are not small, low-

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 dose type of activities to overhaul our maintenance on  
2 these types of valves. So there is a balancing there  
3 between that of the needs for radiation protection for  
4 the rad workers versus what would be an acceptable  
5 increase in allowables for these hypothetical type  
6 scenarios that we look at for consequence analysis.

7 MEMBER KIRCHNER: So just thank you. Just  
8 one recommendation, when this comes before the full  
9 committee, I think it would be important for that --  
10 that context and background to be up front in the  
11 presentation. Thank you.

12 MR. DOZIER: Slide 6. So for the overview  
13 of the ISG, basically, this ISG was published in the  
14 Federal Register on June 21, 2021. We did get  
15 comments from NEI, as well as also some anonymous  
16 comments. There was 13 from NEI, 20 anonymous  
17 comments.

18 We'll have an ACRS full committee briefing  
19 that's scheduled for November 2021. OMB approval  
20 would be after that and we expect final FRN for this  
21 to be February of 2021.

22 Slide 7.

23 MEMBER REMPE: I think you meant 2022,  
24 right?

25 MR. DOZIER: Yes, as the slide --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1                   MEMBER REMPE:  It's what's on the slide,  
2                   but, yeah, I can't do it in --

3                   (Simultaneous speaking.)

4                   MR. DOZIER:  Thank you.  Slide 7.

5                   This ISG is expected to be transitioning  
6                   into SRP Section 15.0.1.  Section 15.0.1 will include  
7                   a reference to the revised Reg Guide 1.183 that we are  
8                   working on as a separate project as was explained  
9                   earlier.  Then the ISG will be closed after transition  
10                  to this section.

11                  So this is kind of the high level primary  
12                  insights.  We had many insights, but this is really  
13                  the primary insight that we're taking from this look  
14                  and that is that there's a high probability that doses  
15                  will be lower than those estimated strictly using  
16                  traditional deterministic methods and by using this  
17                  we're using all of the accepted assumptions that's  
18                  already in the guidelines.  We're not changing those.  
19                  And what we're saying is that do not credit hold-up  
20                  and retention of the Main Steam Isolation Valve  
21                  leakage within the power conversation system.

22                  So big picture.  Piping and components  
23                  downstream of the MSIVs sees significant pressure,  
24                  temperatures, and vibrations 7 days a week, 24 hours  
25                  a day while the reactor is operating.  If the plant

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 does not ask for formal credit for hold-up in the  
2 condenser, Reg Guide 1.183 assumes that the piping and  
3 components disappear with a safe shutdown earthquake  
4 and the MSIV leakage goes directly to the environment.  
5 This is all that stuff after the second MSIV.

6 For plants requesting an increase in the  
7 tech spec allowable MSIV leakage and they do not  
8 credit the condenser, the staff may recognize that  
9 there's a high likelihood that this robust, high  
10 pressure pipe, and components is available for hold-up  
11 instead of it being rubble on the floor to support the  
12 staff's reasonable assurance.

13 And that was kind of the simple way of  
14 maybe I could say these formal words.

15 MEMBER HALNON: So Jerry, this is Greg  
16 Halnon. When you credit and make that assumption,  
17 what is the condition of the piping downstream of the  
18 second MSIV to a condenser that you're assuming that  
19 it's all intact and then there's no additional leakage  
20 or that there's a -- so that's one thing we don't do  
21 in BWRs. We don't necessarily measure the leakage,  
22 but we do have leakage.

23 You can just look at the amount of leak  
24 repairs that are done on line through the power  
25 conversion systems, MSRs, and other extraction, steam,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 steam trap and other things that are releasing it, not  
2 realizing BWRs that's a lot more evident because  
3 you'll have the radiological measurement of those  
4 types of things, but there are quite a lot of leaks  
5 that the industry deals with as they operate these  
6 plants in those U.S. conditions.

7 So how did you assume that piping was  
8 intact enough even in normal operation to get that  
9 leakage to the condenser to have that hold up?

10 MR. DOZIER: Well, actually, you know, if  
11 those valves -- okay, so those valves are the money  
12 makers for the utility, okay? You know, so they're  
13 very important valves for the plant.

14 We're going to go into detail on this  
15 later in the presentation, but even if there is no  
16 hold up, I mean especially if those valves close, you  
17 know, there's really, as far as leakage to the control  
18 room, you know, it's not any leakage, because  
19 everything held up in that large PCF volume that we'll  
20 get into.

21 MEMBER HALNON: Okay, well, if you're  
22 going to get into more detail, we can hold the  
23 question.

24 MR. DOZIER: Yes, I'll let the expert on  
25 that one answer it.

1                   MEMBER HALNON:   Okay.   I can hold the  
2 question, so we'd be -- start looking at full diagrams  
3 and what not.

4                   MR. DOZIER:   Now I'm on Slide 9.   In this,  
5 as I said, this ISG is to make a formal footprint.  
6 That's really what the objective is.   The staff will  
7 use this to offset uncertainties and input parameters  
8 for deterministic calculations and supports -- and the  
9 main thing is it supports the staff's reasonable  
10 assurance finding during reviews and it will be  
11 transitioned.

12                   Now the most -- a very important caveat to  
13 this is it does not change the licensee's  
14 responsibility to demonstrate compliance within 10 CFR  
15 50.67.

16                   It also -- since we're using something  
17 that probably 50 percent of the plants formally  
18 credited earlier, and now we're doing for these LARs  
19 that did not ask for this credit, we are not changing  
20 acceptable methods for demonstrating compliance with  
21 10 CFR 5067.   So we're not changing things upstream  
22 from these MSIVs or any of those assumptions.

23                   As even in the opening remarks, now I'm on  
24 Slide 10, given in the opening remarks, we're  
25 basically trying to be a modern, risk-informed

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 regulator as we're directed. And the documents we  
2 spoke about before, we had those four license  
3 amendments submitted to us and they were asking for  
4 increased MSIV leakage in 2019. We had some challenge  
5 that we'll talk about later and since we had those  
6 challenges, we invoked LIC-206 which is basically for  
7 risk informed decision making that we do in reviews.  
8 So this was a new process that we would follow.

9 We got an integrated review team --

10 MR. CORRADINI: Excuse me. This is  
11 Corradini. Can you just remind people of what LIC-206  
12 is? Maybe I'm the only one that doesn't remember.

13 MR. DOZIER: It's risk-informed decision  
14 making and reviews, license amendment reviews.

15 MR. CORRADINI: Thank you.

16 MR. DOZIER: So it's specific to license  
17 amendment reviews.

18 MEMBER BLEY: This is Dennis Bley. For  
19 everybody else, maybe who hasn't been around a long  
20 time on this, LIC-206 is worth reading. It's really  
21 good background and you understand how people are  
22 implementing some of the risk-informed activities.

23 MR. DOZIER: Dr. Vasavada, who will be  
24 speaking later, was one of the contributors,  
25 significant contributors to that document.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1           Okay, it identified that risk insights  
2 support consideration of holdup into PCS and ability  
3 to -- okay, so we had that group and we looked at many  
4 risk insights. There was many things we looked at. We  
5 focused on just the condenser because we wouldn't have  
6 to change up a lot of the very conservative  
7 assumptions that was in Reg Guide 1.183. So we  
8 focused on this holdup, okay? And we (unintelligible)  
9 those insights and that technical assessment which you  
10 basically see in the basis portion of the ISG. It was  
11 talked about internally, multi-division, multi-people.  
12 It was a team approach. It was lots of insight.

13           So we --

14           MEMBER REMPE: LIC-206 does say you need  
15 to have a holistic approach, so are you the right  
16 person to ask my question about did you consider the  
17 impact on what the operators would see and if there's  
18 some penalties associated with allowing increased  
19 leakage. And I'll mention that at TMI, they changed  
20 the tech spec for the core and they did see increased  
21 leakage and that may be one of the reasons the  
22 operators didn't detect that they had a small break  
23 LOCA. So my question -- are you the right person or  
24 is that going to come up later?

25           MR. DOZIER: I'm kind of waiting for the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 team to see if someone in the team wants to jump in on  
2 that.

3 MR. JONES: This is Steve Jones. I'll be  
4 speaking next and I can try to address that issue with  
5 how testing and tech spec limits on the testing relate  
6 to what operators would see and conditions that they  
7 would respond to.

8 MEMBER REMPE: Great. Thank you. Again,  
9 sorry, to keep bringing it up, but I am curious about  
10 it.

11 MR. DOZIER: Okay, with that, we'll get  
12 right into Steve's presentation to hopefully address  
13 those, Dr. Rempe.

14 MR. JONES: Good morning. I'm Steve  
15 Jones, a Senior Plant and Safety Systems Engineer from  
16 the Containment and Plant Systems Branch in the NRR  
17 Division of Safety Systems.

18 As Jerry went over the current guidance in  
19 Reg Guide 1.183, specified the assumption of a direct  
20 ground level release at the downstream MSIV when no  
21 seismically qualified main steam piping downstream of  
22 that MSIV is present.

23 In part, to address those issues, the BWR  
24 owner's group developed a topical report and the staff  
25 approved that in 1999 to allow computational credit to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 consider holdup and deposition within the main steam  
2 piping and the main condenser as kind of indicated by  
3 the dash line in the diagram to the right.

4           Roughly half of the operating boiling  
5 water reactors have adopted this methodology which  
6 significantly reduces the effect of mainstream  
7 isolation valve leakage on the calculated dose  
8 consequences as evaluated for the control room and the  
9 site boundaries.

10           However, again, as Jerry mentioned, even  
11 without a thorough evaluation of the seismic  
12 robustness of the main steam lines and the remainder  
13 of the power conversion system, the staff determined  
14 that there's significant evidence supporting the main  
15 steam system and other parts of the power conversion  
16 system would contribute to holdup and potential  
17 deposition of fission products when not formally  
18 credited in the dose calculation.

19           Slide 13, please.

20           Okay, this diagram shows the configuration  
21 of the main steam system in a typical boiling water  
22 reactor. The curved gray wall represents the dry well  
23 or primary containment and the second straight gray  
24 wall represents secondary containment boundary.

25           So the downstream main steam isolation

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 valves are the ones to the -- between the two gray  
2 barriers, the air operated valves with the mushroom-  
3 shaped actuator depicted in this diagram. And then  
4 this diagram indicates that there are several paths  
5 once there's flow beyond the main steam isolation  
6 valves and these paths include main steam piping  
7 drains and turbine bypass valves that lead directly --  
8 both of which lead directly to the main condenser.

9 In addition, there are other flow paths  
10 through the main turbines, potentially steam driven  
11 main feedwater turbines that could provide additional  
12 holdup volumes for any main steam isolation valve  
13 leakage.

14 Slide 14, please.

15 Going into just a little bit more detail  
16 on our approach, the staff developed this overall  
17 assessment considering the risk triplet for releases  
18 beyond the main steam isolation valves. We considered  
19 operating experience related to the ruggedness of  
20 piping systems and other components and that operating  
21 experience included the events at Fukushima, North  
22 Anna earthquakes, and other events that demonstrated  
23 the robustness of secondary plant system components  
24 through earthquakes.

25 We also considered the pathways available

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 to the leakage without operator efforts or operator  
2 actions to redirect flow to any specific location and  
3 assessments of seismic capacity that Dr. Vasavada will  
4 address in the later slides.

5 MR. DOZIER: Dr. Rempe had a question.

6 MEMBER REMPE: It's a different question  
7 this time.

8 MR. JONES: Okay.

9 MEMBER REMPE: I'm curious about anchorage  
10 of the piping and the condenser. And again, the  
11 documentation we were given was very limited in that  
12 area. But what assurance do you have that the  
13 anchorage is similar, because that was one question  
14 that I've seen raised in other forums about what can  
15 we learn from the events at Daiichi and if the way  
16 that the components were anchored were similar. And  
17 did you investigate that?

18 And then I noticed you mentioned Onagawa  
19 in your documentation. But you didn't mention what  
20 you saw at Daiichi or Daini. And was there a reason  
21 for that?

22 MR. JONES: No. I'm sorry. We were just  
23 generally considering the operating experience  
24 developed from the Great Tohoku Earthquake. And we  
25 did consider the experience at some of the other sites

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 where we found documented information about, for  
2 instance, the seismic damage that resulted from plants  
3 that did not experience core damage events to the --

4 MEMBER REMPE: But --

5 MR. JONES: -- secondary system.

6 MEMBER REMPE: But Daini had no core  
7 damage and yet it might've had a more -- did you see  
8 any damage where the earthquake occurred too in the  
9 condenser? Why just Onagawa?

10 MR. JONES: I guess I did not note any  
11 documentation of specific damage states at that site.

12 MEMBER REMPE: Okay. And then also, do we  
13 know at Anchorage at all of the plants for the  
14 condensers and the piping is similar, not only in  
15 Japan versus a U.S. plant but also even at North Anna  
16 versus other U.S. plants?

17 MR. JONES: I guess from my perspective,  
18 we're not really worried about quantitative credit.  
19 We're just looking at, is there a volume for this to  
20 go to and will there be some level of delay in the  
21 release of the radioactive material that may propagate  
22 through the system? Looking at these assessments, the  
23 design-basis leakage rate would be on the order of a  
24 couple -- a few hundred standard cubic feet per hour  
25 or just a few cubic feet per minute. And even if the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 condenser loses structural integrity, it would still  
2 provide an area or a volume that would retain the  
3 fission products for a while until they find whatever  
4 openings may have developed as a result of loss of  
5 integrity. And Shilp -- Dr. Vasavada will be going  
6 over a little bit more about the fragilities and how  
7 a generic determination of structural stability was  
8 established for the condensers in the next part of the  
9 presentation.

10 MEMBER REMPE: Okay, thanks.

11 MR. HSUEH: Dr. Vasavada raised his hand.  
12 I just wonder if you want to respond at this time.

13 MR. VASAVADA: Thanks, Kevin. This is  
14 Shilp. I think Steve covered it, and I'll go in more  
15 detail. And I can answer additional questions.

16 Steve's overarching point that you're not  
17 giving quantitative credit and you're not trying to  
18 draw exact comparisons but get just insights from  
19 earthquake experience where plants have exceeded their  
20 safe shutdown earthquakes and what that means for the  
21 seismic capacity of the ECS components. That's what  
22 we are trying to draw other than exact comparisons or  
23 numerical credit. And I can talk in further detail or  
24 answer any further questions when I go over that.

25 MR. HSUEH: Thank you.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 MR. JONES: Okay. Slide 15, please.  
2 Okay. This slide gets into a little bit more detail  
3 of the technical assessment. And it primarily looks  
4 at the undesirable outcomes considered in the staff's  
5 evaluation which reflect the default assumption of a  
6 direct ground level release at the downstream main  
7 steam isolation valve. Absent these undesirable  
8 outcomes, the release would be maintained within the  
9 main steam system and other attached piping systems  
10 and components.

11 And these systems and components establish  
12 a boundary for fission product holdup under conditions  
13 where there's a very low differential pressure to  
14 drive any release out. So just having the volume  
15 present certainly delays the release and provides the  
16 opportunity for additional deposition. Sorry. Slide  
17 16, please. From the operational insights, the staff  
18 determined that the typical steam system design used  
19 the Power Piping standard and would be designed and  
20 fabricated to augmented quality standards which  
21 include consideration of a seismic load, design  
22 verification, and establish our use of volumetric non-  
23 destructive examination techniques to verify the  
24 fabrication and construction of the system.

25 The latest boiling water reactors have

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 fully safety-related main steam systems designed to  
2 withstand the safe shutdown earthquake and design to  
3 the ASME boiler and pressure vessel code out to the  
4 turbine stop valves or, in some plants, the  
5 intermediate stop valves which are located within the  
6 turbine building. The main steam isolation valves  
7 themselves are angled globe valves that are designed  
8 to seat more firmly with pressure from the reactor  
9 side. The inboard valve may be tested in the opposite  
10 direction of its normal seating design.

11 That is pressure could be applied between  
12 the two MSIVs. And therefore, you might see higher  
13 than actual leakage during the test. But you still  
14 need to maintain test values within the technical  
15 specifications.

16 Another testing methodology may rely on  
17 steam line plugs where you test the inboard valves and  
18 the outboard valves separately. But again, you're  
19 subject to increased leakage because the plugs  
20 themselves may be the source of leakage. So I just  
21 wanted to address that from the standpoint of  
22 conservatism with respect to the overall testing  
23 program relative to the technical specification  
24 leakage limits.

25 We also considered the potential -- sorry,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 I'm still on Slide 16 -- the potential for stem  
2 leakage. But that is considered small and believe  
3 would be addressed promptly by operators. Again,  
4 we're not looking at specific credit for this  
5 particular control, but we don't believe that would be  
6 a significant contribution to offsite dose as it would  
7 be a release to the steam tunnel in the boiling water  
8 reactor. The main steam -- therefore, we concluded  
9 the --

10 (Simultaneous speaking.)

11 MR. JONES: Yes.

12 MR. VASAVADA: So this is Shilp again. I  
13 think what Steve provided for the ACRS members is  
14 considered an answer to the question by Member Hanlon  
15 about -- sorry, Halnon, about the leak tightness.  
16 Essentially, the ISG, and as Steve pointed out, there  
17 is no assumption that it is being bottled up.

18 We are considering the fact that there can  
19 be leakage. It's a comparison against the situation  
20 where the downstream piping and the PCS is not  
21 considered at all and how that factors into the staff  
22 decision. Just wanted to make that point. Thanks.

23 MR. JONES: Right. And I was going to  
24 continue that the main steam and attached systems are  
25 there, therefore available to collect this leakage.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 There would be leakage potentially directly to the  
2 main condenser through the turbine bypass, active  
3 drain lines through an orifice, or drain lines where  
4 the isolation valves leak. In addition, there's  
5 potential for leakage through other paths to the  
6 remainder of the power conversion system.

7 (Simultaneous speaking.)

8 MR. JONES: But I'll touch on that the  
9 next slide.

10 MEMBER HALNON: Yeah, this is Greg Halnon.  
11 Just so I understand, you're saying that the -- it was  
12 assumed that the -- any rate of leakage that's  
13 typically not measured which is other valves, other  
14 steam traps, other areas in this main steam system  
15 that maybe have leaked by that that is going to be a  
16 small contribution and it was negligible to the  
17 overall calcs. Is that essentially what you're  
18 saying?

19 MR. JONES: I guess what I'm saying is  
20 that we're only looking for maybe a reduction by a  
21 factor of two or three of the release of the full  
22 volume of the tech spec limit of leakage from these  
23 values to be held up or delayed in such -- well, what  
24 I should say, it's not a fraction of the amount. But  
25 the effect of a delay, the holdup in these volumes,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 and potential for some deposition -- some limited  
2 deposition on some surfaces, particularly if it gets  
3 to the main condenser, would result in maybe a factor  
4 of two or three reduction in what is actually  
5 represented in the calculations. And that is  
6 intended. One of the other presenters, John Parillo,  
7 will be getting into exactly how that was used and  
8 what specific assumptions and uncertainties he was  
9 trying to address in his evaluation of those  
10 consequences.

11 MEMBER HALNON: Okay. I'll take it all  
12 in. And if I don't understand it at the end, I'll ask  
13 the question again. But I think I'm getting it. So  
14 continue on. Thank you.

15 MEMBER KIRCHNER: Greg, this is Walt. It  
16 seems to me, Steve, with the cubic feet per minute  
17 leakage assumption, what effectively is the pressure  
18 in the power conversion system? With a condenser, is  
19 the condenser just -- is it slightly above  
20 atmospheric? In the case where the MSIVs shut, you  
21 have some leakage as the tech spec's amount of  
22 leakage. Then the pressure in the power conversion  
23 system is what, pretty low, isn't it? I mean, so --

24 MR. JONES: Right, yes.

25 MEMBER KIRCHNER: -- where I'm going with

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 this, Greg, is that the leakage compared to normal  
2 leakage at operating conditions would be much less if  
3 the pressure of the system is significantly reduced  
4 which I expect.

5 MR. JONES: Right. I should probably get  
6 into that. The whole dose evaluation process occurs  
7 at a delayed time and not at the instant of the  
8 accident. But Reg Guide 1.183, I don't have the exact  
9 timing in my mind. I believe it's two hours.

10 But the -- so there's a delayed release.  
11 By that time, the containment is at accident pressure.  
12 And that's what's acting against the MSIVs. You have  
13 an assumption of one failed open MSIV. So the  
14 remaining valve is leaking at its tech spec limit for  
15 that steam line --

16 MEMBER KIRCHNER: Okay.

17 MR. JONES: -- which is on the order of a  
18 few cubic feet per minute in these cases. And then  
19 the other MSIV lines are also leaking at some reduced  
20 rate.

21 MEMBER KIRCHNER: Okay.

22 MR. JONES: So that rate does not maintain  
23 the main steam system or anything at any significant  
24 pressure. It's very close to atmospheric --

25 MEMBER KIRCHNER: Okay.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. JONES: -- by that time because you've  
2 had the condensation cool down.

3 MEMBER HALNON: That helps. Thanks, Walt.  
4 I guess my background is biasing me thinking, how do  
5 I maintain a tech spec value given a leakage in one  
6 cart given the fact I know I got leakage throughout in  
7 the system that I'm crediting for some kind of holdup?  
8 So I understand now that they're apples and oranges at  
9 this point. So you can continue on. Appreciate it.

10 MR. DOZIER: This is Jerry Dozier. On  
11 that -- and I'm only talking from an operations  
12 standpoint. But you was asking about the pressure  
13 downstream of the second MSIV.

14 If you look at what the leakage is and  
15 compare the leakage as being requested, as one of the  
16 team members indicated, that leakage is about what a  
17 kitchen fan -- that the flow rate, which is in a cubic  
18 feet per hour standpoint, is about the level of a  
19 bathroom fan. So picture that bathroom fan kind of  
20 going into that downstream piping. And so that's why  
21 you would see such a low leakage. So it's low  
22 pressure down there that's beyond a second MSIV.

23 MR. PARILLO: Jerry, this is John Parillo.  
24 I just want to mention that a bathroom fan is usually  
25 about one to two hundred cubic feet per minute, the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 allowable. It may seem an isolation valve limits that  
2 we're talking about here are on the order of 200  
3 standard cubic feet per hour, per hour. So I just  
4 wanted to make that clarification.

5 MR. DOZIER: Thank you for that.

6 MR. VASAVADA: This is Shilp Vasavada from  
7 the staff. I just wanted to also, I don't know,  
8 clarify one item. I think we have been talking about  
9 calcs and credit. And I think Steve mentioned factors  
10 of two and four. So I just wanted to make it very  
11 clear that as you will see later on, especially in  
12 John's presentation, what this ISG and the work that  
13 was done that I think was -- that was used by the  
14 staff simply as a decision making input to achieve  
15 confidence to reach a reasonable assurance finding.

16 It did not, in any way, shape, or form,  
17 change the licensee's calculation. So no factor was  
18 applied. No calculations were changed. No number was  
19 put into a calculation, no quantitative credit was  
20 taken. So I just wanted to make that fact clear.  
21 Thanks.

22 MEMBER MARCH-LEUBA: Sorry. This is Jose.  
23 You just confused me. Were calculations performed on  
24 the holdup on what pressure? Or are you saying there  
25 was no calculation, no deterministic number

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1       calculated?

2                   MR. VASAVADA:  So -- go ahead, Steve.

3                   MR. JONES:  Okay.  Yes, that's correct.

4       There is no deterministic evaluation of this holdup or  
5       deposition.  It's just considered as a factor in  
6       addressing uncertainties with respect to other inputs  
7       to those calculations.  There are several points where  
8       removal of the fission products is modeled by  
9       different physical mechanisms at different points in  
10      the system.  And this is just a consideration in  
11      resolving uncertainties with those values.  And again,  
12      John Parillo will be getting to that later in the  
13      presentation.  I did want to --

14                   MEMBER MARCH-LEUBA:  I would have --  
15      sorry.  Keep going.

16                   (Simultaneous speaking.)

17                   MR. JONES:  So --

18                   MEMBER MARCH-LEUBA:  So this is Jose.  I  
19      honestly would have liked to see a deterministic  
20      calculation because you get surprises when you start  
21      modeling things.  Clearly if this PCS piping is not on  
22      the floor and is still intact, it's good for leakage.  
23      I mean, I can't deny that.

24                   But what the pressure is doing there as  
25      you're losing cooling in the condenser and everything

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 is -- whatever atmosphere you had in the PCS before  
2 the leak started is going to heat up as you lose  
3 condenser cooling. And then you're adding this cubic  
4 feet per hour, however much, you get surprises.  
5 That's why we do the calculations with good codes and  
6 figure out what the output is. I would have liked to  
7 see the calculations. Thank you.

8 MR. JONES: I see. Okay. I did want to  
9 touch back on issues that Dr. Rempe raised and Mike  
10 Franovich discussed, I guess, with respect to the  
11 testing and indication of the main steam isolation  
12 valves and the issue with, I guess, balancing their  
13 safety performance post-accident with the maintenance  
14 and operational dose consequence issues with  
15 maintaining these valves that are very high leak type  
16 condition at low pressure. So as I mentioned that the  
17 valves are intended for -- to seat with pressure at  
18 very high normal operating pressure for the boiling  
19 water reactors, near 1,000 psi.

20 During the accident, we're addressing  
21 conditions closer to 40 to 60 psi inside the main  
22 containment. And evaluating leakage, I guess the  
23 operators can -- or the operating companies that  
24 maintain these valves have provided a suitable basis  
25 to demonstrate that leakage on the order of a few

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 hundred cubic feet per hour is commensurate with very  
2 good operation of these valves. So we have very  
3 little concern with the valves not operating properly  
4 or not seating.

5 And we expect that this does not impact  
6 the operation of the valves with respect to their  
7 performance as a primary reactor coolant pressure  
8 boundary valve or a containment isolation valve. And  
9 again, we were not really modifying any operating  
10 procedures or any inputs to the dose analysis with  
11 this evaluation, just considering what the real world  
12 impacts of the downstream power conversion system  
13 would be on the dose consequences and how that could  
14 be used to address uncertainty. All right. Our last  
15 slide is Slide -- the last slide I'm discussing --

16 MEMBER REMPE: This is Joy. Then if  
17 that's the answer to my question, maybe I didn't make  
18 my question clear enough. And again, I'm not an  
19 expert on operator response during a BWR event. But  
20 if the -- again, valves sometimes just fail to close.  
21 That's why they have reliability numbers.

22 And if the valve failed to close, how  
23 would the operators detect the leakage that's  
24 occurring versus the higher leakage rate allowed by  
25 the revised tech spec? And are there any actions that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 they have to take? And if there's no actions they  
2 take, then the answer to my question is it doesn't  
3 matter. But typically, you detect whether a valve is  
4 open or closed by temperature or radiation readings  
5 usually is my understanding.

6 And are there any actions that suddenly  
7 they don't detect that the thing failed to close  
8 because it leaks more is my point. And are there any  
9 actions that should be considered, because we're going  
10 to use some more realistic risk-informed insights to  
11 have a lower release to the environment. And I'm  
12 wondering if there's other concurrent risk insights  
13 that we're forgetting about. Does that make sense  
14 what I'm trying to get to?

15 MR. JONES: Yes, but I'd just point out,  
16 I guess, the MSIV leakage detection -- I mean, the  
17 leakage detection systems and things in a boiling  
18 water reactor are designed to detect ruptures in the  
19 main steam system so that the high temperature would  
20 be outside in the steam tunnel. And we wouldn't  
21 expect any of that to result when these are operating  
22 per the assumptions. I mean, this is a very stylistic  
23 calculation design to test primary containment  
24 performance. It's not really reflective of the most  
25 likely outcome of -- or likely configuration that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 would exist following a core damage event. So I mean  
2 --

3 MEMBER REMPE: But I mean, if it fails to  
4 close, don't you really have a containment bypass?  
5 It's open, right? And --

6 (Simultaneous speaking.)

7 MR. JONES: You would. And for that  
8 reason, I mean, these valves are designed to be  
9 redundant and very reliability in their closing. And  
10 there is an assumption that one of them does not  
11 close. In fact, does not close --

12 (Simultaneous speaking.)

13 CHAIR PETTI: Right. Isn't that part of  
14 the calculation is to assume that one does not --

15 MEMBER KIRCHNER: Yeah, single failure.

16 CHAIR PETTI: And so I think I'm still  
17 struggling understanding. There's leakage from all  
18 the others. But then there's one that didn't close.  
19 It seems like the one that didn't close is going to  
20 dominate what's going on.

21 MR. JONES: Well, there's --

22 (Simultaneous speaking.)

23 MR. JONES: -- because there's two valves  
24 in a series, the overall leakage is still limited.  
25 It's just that line would have maybe higher pressure

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 acting on the one remaining valve. So you would see  
2 -- there's an assumption that there's higher leakage  
3 down one particular steam line than the other three.  
4 But the other three still contribute some factor to  
5 the dose consequence. And again, I think John Parillo  
6 is the best one to address that when he gets --

7 MR. DOZIER: Dr. Vasavada wanted to  
8 contribute, I think.

9 MR. JONES: Okay.

10 MR. VASAVADA: No, I think -- this is  
11 Shilp from the staff -- Steve covered it. But I think  
12 the point I was going to make is as Steve said. This  
13 is a postulated scenario with certain stylized -- in  
14 some cases in my personal opinion -- unphysical  
15 assumptions about, like, for example, how long you  
16 have choke flow, et cetera.

17 And those inputs remain unchanged by all  
18 the work for the ISG. So the fact -- I mean, it's  
19 already assumed that multiple redundant protection  
20 systems have failed and you have achieved core damage.  
21 And then there is a single failure of one of the MSIVs  
22 that's already part of the analysis.

23 And then the other one leaks at a  
24 particular rate which is being requested. And the  
25 dose consequence analysis is considered in that rate.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 So just wanted to give that background. Nothing about  
2 that is being changed by the ISG. Those postulated  
3 assumptions remain as they are.

4 MEMBER KIRCHNER: Thank you. I think also  
5 I would've answered Joy -- Joy, this is Walt. On the  
6 highly low -- I'm not saying correctly. In the very  
7 low probability of two isolation valves on the same  
8 steam line failing to close, you would see pressure on  
9 the secondary system. So I think the answer to your  
10 question, how would you know that the valves didn't  
11 seat, it would be a high pressure would build up in  
12 the -- to whatever the containment pressure is in the  
13 secondary system. So indirectly, you could check on  
14 how well the valves seated by monitoring the pressure  
15 in the power conversion system.

16 MEMBER REMPE: Okay. You're getting to my  
17 point that, yes, there are ways they could detect  
18 this. And again, there's this unusual situation  
19 because we did design-basis calculations with a  
20 stylized calculation. But then there are the real  
21 world.

22 And in the real world, you're going to  
23 allow higher leakage. The tech spec is going to be  
24 changed. And so my point is, is that when you allow  
25 that, it seems like somebody ought to be thinking

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 about the real world and a scenario that's not just a  
2 design-basis calculation. But should you be  
3 considering about the instrumentation?

4 Now again, Vesna has been sending me  
5 emails and she said, I don't think there's anything  
6 the operators. There's no actions. And that would've  
7 been also a good response to my question. But I'm not  
8 hearing that anybody has thought about, is there  
9 something that should be done or not?

10 And again, I'm just curious because I  
11 think if we're going to do risk-informed stuff, we  
12 ought to -- and a make a change with the tech spec, we  
13 ought to think about what the operator should or  
14 should not do. And there's no actions they take, oh,  
15 well, I guess that's it. But if there are other  
16 instrumentations that should be giving them insights,  
17 then we ought to think about the difference between a  
18 leaky valve versus an open valve. Maybe that ought to  
19 be done. Does that kind of explain where I'm coming  
20 from a bit more?

21 MR. JONES: Yes, I think I understand.  
22 We're getting a lot more into the detail of how the  
23 MSIVs operate. They are spring powered to close, and  
24 they do have a pilot system that increases the  
25 pressure to close the valves once they're actuated.



1           And there would be an indication that the  
2 valve is fully closed. So the operators would be  
3 looking for that. If they did not fully close, they  
4 could verify that the air was released or maybe taken  
5 action to release air.

6           But other than the actual -- I'm sorry, an  
7 indication of the valve position, there wouldn't be  
8 anything for the operators to indicate that there's a  
9 problem with the valve because, I mean, under normal  
10 operating conditions, you have obviously full steam  
11 flow going through these valves and it's very high  
12 temperature. So where we're seeing the temperature  
13 just gradually falling off in the system and as one of  
14 the other members mentioned, there would be  
15 potentially secondary system pressures holding up at  
16 higher than expected values. But other than that, I  
17 wouldn't expect to see anything from excessive leakage  
18 beyond the --

19           MEMBER REMPE: Is there an operator action  
20 that would be done? Or would they just say, hey, the  
21 thing didn't close? And they'd see it more slowly  
22 because they have to figure out whether there's  
23 pressure, there's increased leakage that they're  
24 allowing because it -- from a much lower leakage. And  
25 I just am curious about it. And did somebody think

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 about this when they were saying, yeah, we're going to  
2 let them increase the tech spec?

3 MR. DOZIER: Dr. Rempe, what I could  
4 propose, okay, I was an STA at Grand Gulf, okay? And  
5 if you visualize this stylized accident that is done  
6 basically for calculation purposes, you would have --  
7 you basically have core damage here -- I mean, an  
8 assumed core damage. You have an assumed drywell  
9 pressure at that maximum level.

10 I mean, at the point of especially the  
11 initial leakage or whatever, the operator is focused  
12 on getting water in the core. They're focused on  
13 protecting other containment, things like that. So  
14 it's hard. It's very difficult to put this into a  
15 realistic situation. But we have done that with some  
16 of our risk studies, with SOARCA, and also the  
17 original report that was one on this to talk about the  
18 releases to the environment.

19 MR. JONES: I guess what I can say is that  
20 we've considered the effect of the increased allowable  
21 leakage on valve operation and we see no effect. With  
22 respect to operator action, it would be driven again  
23 by position indication on these valves. And that  
24 would be unaffected by this action as well. If the  
25 valve does not close, I'm certain there are actions in

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 the EOPs, although I can't confirm right now, to  
2 address that condition.

3 MEMBER REMPE: Yeah, if the EOPs take care  
4 of it, those are the kind of things I wanted to hear.  
5 Yeah, we thought about it and the increased leakage.  
6 And it doesn't matter or something, that it's been  
7 taken care of in the EOPs. And I just didn't see it.  
8 But I may not have seen all the information that's  
9 available. I only saw one document from FitzPatrick.

10 MR. JONES: Right. Okay.

11 MR. VASAVADA: This is Shilp from the  
12 staff. I just also wanted to point out that all of  
13 what Steve said and the EOPs, et cetera, that is true  
14 for MSIV leakage, increased LARs and reviews and  
15 decisions whether the ISG exists or not. So the  
16 question about valve closure and indications, the ISG  
17 doesn't either change it, improve it, or reduce it.  
18 It's the same. It does not change anything from  
19 whether the ISG is used or not.

20 MEMBER REMPE: That's also true. I was  
21 more concerned when I was seeing tech specs change for  
22 the actual plants. And I only, again, saw one of  
23 them. But it's a related topic, and that's why I  
24 wanted to bring it up because maybe Daiichi should  
25 mention that you are changing a tech spec.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 I don't know. Maybe it's a separate  
2 topic. And I did start off my discussion that this is  
3 a bit off topic. But I was curious about what was  
4 going on.

5 MR. JONES: Okay. I guess we can move on  
6 to Slide 17, just again discussing a realistic  
7 transport pathway. I did want to clarify a  
8 distinction from the BWR topical report. In this --  
9 for this ISG, the staff does not assume any operator  
10 action to align a specific path to direct main steam  
11 isolation valve leakage to a particular location like  
12 the main condenser.

13 Drain lines and turbine bypass lines lead  
14 directly to the main condenser. And if they leak,  
15 that would be one way that any leakage release would  
16 get to the main condenser. Other leakage paths  
17 primarily through the stop and governor valves on the  
18 high pressure turbine would go to the high pressure  
19 turbine area.

20 There is definitely less holdup and  
21 deposition in the main condenser. But there's still  
22 a volume there. And the additional -- those valves  
23 are designed again to be fairly reliable and leak  
24 tight.

25 We do not expect with a high likelihood

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 there would be an easy flow path even to the steam  
2 chest and the -- of the main turbine. But if they did  
3 get there, then there would be a release path via the  
4 high resistance path through the shaft seals -- the  
5 main turbine shaft seals since there would not be  
6 steam pressure to provide the ceiling steam. There  
7 would still be kind of a torturous path for the  
8 release to follow to get to the turbine building at  
9 that point.

10 But I just want to point out that we're  
11 not necessarily considering complete holdup or that  
12 all the flow gets to the main condenser. But there  
13 are places that would delay and otherwise reduce the  
14 dose consequences from the event when realistically  
15 considering the transport pathways through the power  
16 converting system. That's all I have.

17 (Simultaneous speaking.)

18 MR. VASAVADA: Yeah, this is Shilp. I  
19 just wanted to also point out to what Steve said and  
20 support that. They're not considering, like, bottling  
21 up that if you are to compare that -- again, this is  
22 no credit was given. This is a decision making input.

23 If we are to compare that with the actual  
24 quantitative credit for the condenser in Reg Guide,  
25 the disparity there because the quantitative credit in

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 the condenser does not mean that the holdup -- I mean,  
2 the deficient part of the water in the condenser.  
3 There is a defined, you can say, leakage rate from the  
4 condenser. So the condenser is considered, quote,  
5 open, end quote. So the disparity there to restart as  
6 if the condenser is leak tight if quantitative credit  
7 using Reg Guide is used.

8 MR. JONES: Okay. And with that, that was  
9 the end of my section with this presentation. And I'd  
10 like to hand it over to Dr. Vasavada to go over the  
11 seismic considerations.

12 CHAIR PETTI: Yeah, so maybe this is a  
13 good point. We usually take a break around 9:00  
14 o'clock before we get into the seismic stuff. Is that  
15 okay with you guys?

16 And we take about a 15-minute break and  
17 then reconvene at the top of the hour to start the  
18 seismic.

19 (Whereupon, the above-entitled matter went  
20 off the record at 10:46 a.m. and resumed at 11:00  
21 a.m.)

22 CHAIR PETTI: Okay. I have top of the  
23 hour, so let's reconvene and start with the seismic  
24 slides. Thank you.

25 MR. VASAVADA: Okay. Thank you. This is

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 Shilp Vasavada. I hope you can hear me.

2 CHAIR PETTI: Yes, we can.

3 MR. VASAVADA: I'll start. Good morning  
4 to everyone. As I said, my name is Shilp Vasavada.  
5 I'm in the Division of Risk Assessment in NRR, and  
6 I'll be discussing the seismic capacity evaluation for  
7 the SSCs in the power conversion system or PCS that is  
8 documented in the technical assessment for the ISG.

9 As many of you may know, the SSCs in the  
10 PCS do not need to be seismically qualified primarily  
11 because they are not safety related. Therefore, the  
12 context for the seismic capacity evaluation, if you  
13 think about the risk triplet for the ISG is to  
14 understand the risk of gross failure of the SSCs in  
15 the PCS, especially the safe shutdown earthquake of  
16 the plants. The intent is not to, again, provide a  
17 factor for reduction of the dose.

18 It is to see whether the SSCs in the PCS  
19 have a high confidence of surviving the safe shutdown  
20 earthquake in a realistic scenario or considering  
21 realism, provide holdup volume that the staff can use  
22 that's realism in its decision making. It will --  
23 overcoming any challenges with uncertainties in other  
24 parameters. Before I provide an overview of the  
25 evaluation, I'll just go over a primer on some seismic

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 capacity-related terms that you will be hearing.

2 They may be new to you. But they are  
3 meant to help with common understanding and the  
4 communication. I'm on Slide 18, and the terms over  
5 here, I'll give a caveat. They're not textbook  
6 definitions, please don't hold me to that.

7 Firstly, fragility, it's the conditional  
8 probability of failure of an SSC as a function of  
9 seismic acceleration. And one of the common ways of  
10 expressing fragility is what's known as median  
11 fragility, also known as  $A_{sub m}$ . This is a seismic  
12 acceleration at which there is a 50 percent  
13 probability of failure.

14 And along with  $A_{sub m}$ , there are two  
15 uncertainty parameters,  $\beta_r$  and  $\beta_u$  as they are  
16 called, to which together define the median fragility  
17 of an SSC. These uncertainty parameters characterize  
18 the, again, uncertainty in the median fragility or the  
19 fragility of an SSC. The seismic acceleration is the  
20 measure of the strength of an earthquake.

21 It is usually expressed in terms of  
22 multiples of the gravitational acceleration. So  
23 you'll hear terms like 0.1g, 0.2g where g is the  
24 gravitational acceleration. And peak ground  
25 acceleration is a commonly used term -- or commonly

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 used acceleration level for seismic analysis.

2 It corresponds to the acceleration of a  
3 100 Hertz oscillator. A lot of times, a lot of  
4 analyses are so to say anchored to the peak ground  
5 acceleration to provide a common language for  
6 comparison and use. Next slide, please. So I'm on  
7 Slide 19.

8 And this slide, basically, the figure over  
9 here brings all the terms that we discussed in the  
10 previous slide together and pictorially. You can see  
11 the curves which are the cumulative fragility curves,  
12 the 95th percentile, the 50th percentile, and the 5th  
13 percentile. As previously explained, the fragility is  
14 a function of the seismic acceleration and peak ground  
15 acceleration in this case which is the commonly used  
16 acceleration value.

17 In this example, so the median fragility  
18 is 0.8g -- 0.87g. So you have a 50 percent  
19 probability of failure of this example, SSC at that  
20 particular acceleration. One concept that I wanted to  
21 also share is that a higher median fragility value  
22 implies a more robust or a higher seismic capacity  
23 SSC.

24 The reason being that a higher median  
25 fragility value shifts all those curves to the right.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 So you have -- for the same seismic acceleration,  
2 you'll have a lower failure probability. Next slide,  
3 please. So I'm on Slide 20.

4 To evaluate the seismic capacity of the  
5 PCS components, we looked at several diverse sources  
6 of information that compiled fragility data to get an  
7 idea of where the fragility is of different components  
8 that may exist in the PCS line. We also looked at  
9 insights from both earthquake walkdowns. And we  
10 performed representative risk calculations to estimate  
11 the risk of gross failure of the SSCs in the PCS.

12 For the fragility data, we looked at the  
13 various NUREGs and industry reports, including EPRI  
14 reports as well as information we recently submitted,  
15 a seismic probabilistic risk assessments or PRAs, that  
16 were submitted in response to the Agency's post-  
17 Fukushima's actions. As many of you may know, seismic  
18 PRAs usually don't model PCS components or balance of  
19 plants components as they are called. However, the  
20 seismic PRAs do carry information related to the  
21 fragility of several other components which exist in  
22 the PCS like welded and bolted piping, valves.

23 And they also provide information about  
24 the extent of seismic risk accelerations up to the  
25 plant safe shutdown earthquake. All of that is

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 relevant to this evaluation. In terms -- Jerry, can  
2 you go to the next? I'm still on Slide 19.

3 We also reviewed the post-earthquake  
4 walkdown experience for North Anna in the U.S. and  
5 Kashiwazaki-Kariwa in Japan and Onagawa also in Japan  
6 following the Great Tohoku Earthquake of 2011. All  
7 these plants experienced earthquakes that exceeded  
8 their respective safe shutdown earthquakes and  
9 equivalent in Japan. And we focused our observations  
10 over there for the PCS components and the impacts --  
11 post-earthquake impacts that were observed or not on  
12 those components.

13 As I think in response to a question, I'll  
14 just mention it over here. And I can additional  
15 detail if that's necessary. The ISG nearly mentions  
16 that the purpose of the reviewing the walkdowns was  
17 not to draw one is to one comparisons.

18 We recognize it's plant-specific, it's  
19 design-specific, and location-specific and also maybe  
20 operating practices-specific. The reason for doing  
21 the evaluation of the post-earthquake walkdowns was to  
22 identify insights related to the behavior of PCS  
23 components in general: were there any gross failures  
24 that were observed, were there any issues that we need  
25 to consider in our evaluation, and to take it in

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 conjunction with the data as a body of evidence which  
2 then was used to determine and lower bound median  
3 fragility value which we believe encompasses the  
4 seismic failure modes for the SSCs in the PCS and then  
5 use the representative risk to determine what would be  
6 the representative risk of gross failure of the SSCs  
7 in the PCS. Next slide, please. I'm on Slide 21.

8           So the insights that we gathered from all  
9 of that evaluation was that welded piping, bolted  
10 piping, as well as valves have high median fragility  
11 values which as we talked about implies that they have  
12 high seismic capacity. In addition, the main  
13 condenser is usually -- I mean, as all of you may know  
14 -- a huge structure which is bolted to the floor of  
15 the turbine building. It's usually a seismic Category  
16 II structure, so the anchorage is designed to avoid  
17 failure at design-basis loads to prevent what's called  
18 a Seismic II or I interaction.

19           In addition, all the post-earthquake  
20 walkdowns of plants in the U.S. and Japan demonstrated  
21 that the PCS components have high seismic capacity.  
22 No gross failures or major issues were identified for  
23 even the nonsafety-related PCS components at any of  
24 those post-earthquake walkdowns. And finally, the  
25 seismic PRAs demonstrated that the seismic risk from

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 acceleration at accelerations below -- at and below  
2 plant safe shutdown earthquake is small.

3 The contribution to the overall plant risk  
4 -- seismic risk from those acceleration levels is a  
5 very small fraction. Next slide, please. So based on  
6 all of that, the information, we determined a lower  
7 bound median fragility parameters for the use in our  
8 evaluation. These parameters as displayed over here  
9 are the median fragility value of 0.4g and the beta r  
10 and beta u of 0.22.

11 They are based on the fragility of an  
12 expansion joint connecting the circulating water  
13 piping to the condenser. And based on, again, the  
14 evaluation and the survey of data and the walkdown  
15 information, we believe that it encompasses all the  
16 failure modes for the relevant SSCs in the PCS piping,  
17 et cetera, and valves. And it supports the low  
18 likelihood that the gross failure of the SSCs in the  
19 PCS would not occur.

20 For context, as I mentioned, the --- but  
21 for parity, when the actual quantitative credit for  
22 holdup in the condenser is taken, the condenser is  
23 considered code open with a specified leakage rate  
24 from the condenser. So using this lower bound is also  
25 actually conservative because it is essentially

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 treating the entirety of the PCS at a very lower  
2 fragility to see what would be the failure and release  
3 if this fragility were to be exceeded as compared to  
4 just considering a small level of leakage which is  
5 anyways allowed or considered when the credit is taken  
6 -- quantitative credit is taken. Next slide, please.  
7 So I'm on Slide 23.

8 Using that lower bound fragility value,  
9 what we did was we, it was called a range of seismic  
10 hazard curves with that condition failure probability  
11 from the median fragility values to determine what is  
12 the -- you can say frequency of release due to the  
13 gross failure of the SSCs in the PCS. And we used a  
14 range of recently developed seismic hazard curves  
15 which are developed in response to the Agency's post-  
16 Fukushima actions. And our results -- estimates  
17 showed that the risk is low from -- the risk of  
18 release from a gross failure of the SSCs in the PCS is  
19 low.

20 And even if you consider the entire  
21 seismic hazard curve, if you were to consider only up  
22 to the safe shutdown earthquake as is necessary for  
23 the purposes of this -- I mean, this entire MSIV dose  
24 calculation, the risk would be even lower. So next  
25 slide, please. So Slide 24 talks about the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 uncertainty, how we considered the uncertainty for the  
2 seismic capacity evaluation. In terms of the  
3 uncertainty, the --- in the selected parameter, that,  
4 I mentioned, is already included explicitly to the  
5 beta r and beta u parameters and used in the  
6 calculation of the representative risk estimates. In  
7 order to address the conservatism in the selection of  
8 the median fragility parameter, that is, is 0.4  
9 sufficiently lower bound? Or it should be 0.3 or  
10 should be 0.5?

11 We looked at the conservatisms that  
12 already exist brought in our evaluation as well as in  
13 the overall MSIV calculation to address that  
14 uncertainty. So we are using a lower bound region  
15 fragility as we mentioned to kind of encompass all  
16 potential failure modes in spite of the fact that  
17 several of the SSCs show much, much higher median  
18 fragility values. And it is not necessary to have a  
19 leak tight approach for the decision making that the  
20 ISG provides.

21 As we have noted, there'll be low pressure  
22 conditions because of the postulated scenario. So the  
23 piping and the SSC in the PCS are designed for high  
24 pressure and high temperature. So the margin that is  
25 in that design is not explicitly being accounted for,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 especially with the choice of the lower bound  
2 fragility parameters.

3 We are considering the safe shutdown  
4 earthquake occurring concurrent with a postulated  
5 accident that results in complete core damage. So  
6 that's an additional level of conservatism. And as we  
7 have said multiple times, the important assumptions,  
8 parameters, guidance, boundary conditions that go into  
9 the actual dose calculation remain unchanged by this  
10 ISG. So that's additional conservatisms in there  
11 which we have not changed or taken advantage of.

12 MEMBER KIRCHNER: Shilp, this is Walt  
13 Kirchner. On a previous slide, you identified the  
14 weak link in your analyses -- seismic analyses as the  
15 expansion joint for circulating water to the main  
16 condenser. But that's not a leak path unless you have  
17 massive tube rupture in the condenser. So was there  
18 -- what was the second most fragile component in the  
19 PCS systems that actually are forming the holdup  
20 volume?

21 MR. VASAVADA: All right. So we didn't --  
22 or at least I didn't go line by line through all that  
23 exists in the PCS in order to determine the next --  
24 sorry, Steve, did you want to say something?

25 MR. JONES: Yes, sorry to interrupt. But

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 I mean, just to clarify, the expansion joint is the  
2 boot between the bottom of the low pressure turbine  
3 and the condenser, not -- I mean --

4 MEMBER KIRCHNER: And it wasn't explained

5 --

6 MR. JONES: -- there's still an expansion

7 --

8 MEMBER KIRCHNER: And it wasn't explained

9 --

10 MR. JONES: -- joint there.

11 MEMBER KIRCHNER: -- correctly in the  
12 viewgraph.

13 MR. JONES: Okay.

14 MR. VASAVADA: Sorry about that, yeah.  
15 And again, to --

16 (Simultaneous speaking.)

17 MEMBER KIRCHNER: Okay.

18 MR. VASAVADA: -- that question, if --

19 MEMBER KIRCHNER: That's part of a leak  
20 path then? Okay. Thank you. That answers my  
21 question.

22 MR. VASAVADA: Okay. Thank you. All  
23 right. So that was basically an overview -- I'm still  
24 on Slide 24 just closing up -- overview of the seismic  
25 capacity evaluation that is included in the technical

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 assessment. And in summary, in the context of the  
2 ISG, the seismic capacity evaluation supported the  
3 case that the SSCs in the PCS have a high seismic  
4 capacity. And the risk of release, because of the  
5 gross failure, especially at the safe shutdown  
6 earthquake level, is low.

7 And taken together with the other elements  
8 of the assessment that were described by Steve and  
9 Jerry, it supports the insights and the recommendation  
10 that the ISG provides to the staff to consider this  
11 realism in their decision making if they are  
12 challenged because of any uncertainty in input  
13 parameters in the rest of the dose calculation.  
14 Again, I'd like to reiterate the seismic capacity  
15 evaluation or the ISG evaluation does not change the  
16 dose calculations. They remain the same.

17 As submitted by the licensee, the margin  
18 to the acceptance guidelines remains the same. It's  
19 just a decision making input to provide staff the  
20 confidence to reach reasonable assurance if there are  
21 challenges with uncertainty in a parameter or the  
22 other. Next slide, please. I'm on Slide 25.

23 And I wanted to, again, put this ISG in  
24 the context -- a different holistic context of the  
25 entirety of the MSIV evaluation to kind of represent

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 the fact that it's a small sliver in the entirety if  
2 you consider the whole dose calculation approach. So  
3 first of all, the licensee's calculations will start  
4 with the assumption of core damage arising from a  
5 postulated scenario with failure of multiple redundant  
6 protection systems. In addition to that, there is a  
7 single failure of the inboard MSIV which is assumed.

8 In addition to that, there are  
9 conservatisms in the analysis -- in the guidance which  
10 include acceptable assumptions and parameters. I'll  
11 give an example that, for example, choked flow is  
12 assumed for 24 hours so that the leakage flow can be  
13 at the tech spec limit for 24 hours as part of the  
14 analysis. That conservatism remains in the guidance.  
15 It remains unchanged.

16 As I mentioned, we assume that a safe  
17 shutdown earthquake concurrent with this postulated  
18 scenario. And we use a lower bound median fragility  
19 value to kind of see what is the risk of gross  
20 failure. So in the context of the entirety of the  
21 evaluation, this ISG forms what I would call a small  
22 sliver of realism in a universe of conservatism.

23 And again, the purpose was not to change  
24 the dose calculations. The purpose was to provide the  
25 staff with additional confidence to reach the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 reasonable assurance if there was talk about whether  
2 X acceptable value is okay for a particular parameter  
3 or Y is okay. Next slide, please. I'm on Slide 26  
4 now.

5 So before I pass it on to John for more  
6 details, I wanted to provide a kind of comparison  
7 between what the ISG intends to do and what the  
8 proposed or planned revision to Reg Guide 1.183 is  
9 intended to achieve. And this slide attempts to  
10 clearly differentiate between the two. The ISG  
11 obviously is directed to the staff to support their  
12 decision making whereas the Reg Guide will be directed  
13 to the licensees and provides acceptable means of  
14 showing compliance with regulations.

15 The ISG, again, as I've been repeating it  
16 again and again, provides staff additional confidence  
17 to reach its reasonable assurance finding. It is not  
18 the only reason that the staff would reach the  
19 finding. It is providing additional confidence.

20 The Reg Guide provides acceptable methods,  
21 including it would provide the method and the guidance  
22 for getting quantitative credit for holdup in the main  
23 condenser which the ISG does not provide any  
24 quantitative credit. So the ISG, because of that  
25 reason, does not change the dose calculations of the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 analysis of record that the licensee has submitted and  
2 that the staff uses for its reasonable assurance  
3 finding. The Reg Guide revision, if the licensee were  
4 to take -- follow that guidance for quantitative  
5 credit, does change the dose calculations.

6 It does introduce if -- I believe the term  
7 is decontamination factor which does reduce the dose.  
8 The ISG does not do that. So for that purpose, the  
9 ISG does not need information from the licensee. It's  
10 a decision making tool for the staff. It is expected  
11 that the revision to Reg Guide 1.183 for quantitative  
12 credit in the condenser would be requesting docketed  
13 information from the licensee for that purpose. I see  
14 Member Corradini's hand up for a question.

15 MR. CORRADINI: Just for clarification, so  
16 the licensing basis calculation -- dose calculation  
17 would not be -- would be changed. But this is an  
18 internal document the staff would use for any  
19 subsequent LAR or similar LARs? Am I -- I'm still not  
20 clear about the use of the ISG. That's where my  
21 question is coming from.

22 MR. VASAVADA: Sure. So I'll give, you  
23 can say, an answer. And it will be maybe fleshed out  
24 in more detail by John as he goes through the details.  
25 I'll give -- let's start with an example.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. DOZIER: Mike Franovich has his hand  
2 up.

3 MR. VASAVADA: Okay.

4 MR. FRANOVICH: I don't think I did,  
5 Jerry, but --

6 MR. DOZIER: Oh, I'm sorry. Another  
7 Michael, I think, had their hand up. I'm sorry. Or  
8 Dr. Kirchner?

9 MEMBER KIRCHNER: Yes, thank you. Just to  
10 be precise here, I'm presume that the using in the  
11 spirit a holistic approach provides guidance for  
12 quantitative credit for holdup in the power conversion  
13 system, not just the main condenser, albeit the main  
14 condenser is probably the largest volume. The turbine  
15 is probably the second largest volume. The piping, I  
16 don't know where that all -- how much volume that adds  
17 up to. But it would be for the full PCS, right?

18 MR. VASAVADA: So I'll address that one  
19 first and then go back to Member Corradini's question.  
20 In that context of Reg Guide 1.183 for quantitative  
21 credit, it is the condenser. It is not the PCS  
22 because over there, the way it works is that a pathway  
23 to the condenser has to be opened up.

24 And that pathway is given credit with, you  
25 can say, numerical decontamination factor which

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 decreases the dose because of the decay in the  
2 condenser. So it was just the condenser. And  
3 obviously, yeah, the lines that need to be opened up  
4 to -- for example, the drain lines that need to be  
5 opened up to get to the condenser. Does that help?

6 MEMBER KIRCHNER: Yeah. Well, unless the  
7 -- well, I'm trying to think through a BWR response to  
8 an accident. I guess the main turbine stop valve  
9 probably closes so that -- and doesn't have -- usually  
10 have a direct path into the turbine itself which is a  
11 significant volume, although the leakage paths from  
12 turbine are minimal. But okay.

13 MR. VASAVADA: So that is the --

14 MEMBER KIRCHNER: I assume you would just  
15 let the applicant assess his or her particular design  
16 and the line -- what would be the configuration of the  
17 PCS under the accident condition that's assumed?

18 MR. VASAVADA: That's correct. And what  
19 you just said about the configuration you're thinking  
20 about is the thought process we used for the ISG. But  
21 it does not provide quantitative credit. It is a  
22 realistic kind of decision making input using  
23 insights, operation and seismic insights, to support  
24 the staff that in reality this is what will happen.

25 So if you are challenged with some input

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 assumptions, you use this to get confidence in your  
2 decision that using accepted assumptions that doses  
3 are just calculated by the licensee would likely be  
4 lower if you were to think about it realistically.  
5 And you can still go out and make your conclusions.  
6 For the context of taking quantitative credit by the  
7 licensee to actually make a numerical change in their  
8 dose calculations, the guidance would be in 1.183.

9 And that just talks about opening a path  
10 to the condenser and credit for the condenser. And  
11 that would be a licensee's decision if they want to  
12 take credit or not. So I'll go back to Member  
13 Corradini's question.

14 MR. CORRADINI: You know what? I don't  
15 think you have to. The way you answered Walt helped  
16 me out. So I'm fine. Thank you.

17 MR. VASAVADA: Okay, thanks. And I'll  
18 continue on this slide. Again, to repeat, the ISG  
19 does not change the licensee's responsibilities to  
20 show compliance or to -- it does not change the  
21 acceptable methods to demonstrate compliance for the  
22 guidance. I think that ends my portion of the  
23 presentation. I'll turn it over to John Parillo to  
24 discuss how the content of the ISG was actually used  
25 to support the staff's reviews of recent LARs. John?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 MR. PARILLO: Thank you, Shilp. This is  
2 John Parillo speaking. I am a member of the Radiation  
3 Protection and Consequence Branch in the Division of  
4 Risk Assessment. I was a contributor to the review of  
5 the James A. FitzPatrick license amendment requesting  
6 an increase in their allowable main steam isolation  
7 valve leakage limits.

8 The FitzPatrick plan had the lowest MSIV  
9 leakage limits in the USBWR fleet and requested  
10 leakage limits more in line with the rest of the  
11 operating fleet. Slide 27 includes excerpts from  
12 Section 50.67, accident source term, and highlights  
13 that the rule states, the NRC may issue the amendment  
14 only if the applicant's analysis demonstrates with  
15 reasonable assurance that specific dose acceptance  
16 criteria will be met. Slide 28. Slide 28 contains  
17 information pertaining to challenges that the NRC  
18 staff has encountered when reviewing applications,  
19 requesting increases in main steam isolation valve  
20 leakage limits.

21 Regulatory Guide 1.183 does not contain an  
22 aerosol deposition model suitable for the evaluation  
23 of the dose consequences from main steam isolation  
24 valve leakage. In addition, the staff has concerns  
25 with the settling velocities used and researches

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 accident evaluation branch AEB-98-03. Due to the lack  
2 of a main steam line aerosol deposition model in Reg  
3 Guide 1.183 and issues with some of the assumptions in  
4 AEB-98-03, the NRC staff has issued many requests for  
5 additional information, questioning the aerosol  
6 deposition models submitted for NRC review.

7 Many licensees have incorporated concepts  
8 from AEB-98-03 with additional conservatisms in their  
9 licensing basis. Slide 29. The 2006 regulatory  
10 information summary included general concepts that  
11 licensees should consider when modeling main steam  
12 line deposition. However, the RIS did not provide an  
13 acceptable model or a reference to one that licensees  
14 could follow to provide some level of confidence in  
15 gaining staff acceptable of their license amendment  
16 requests. Slide 30.

17 Shortly after publishing of AEB-98-03, the  
18 staff identified concerns with the methodology used in  
19 this document. In spite of these concerns, the RIS  
20 stated that it is acceptable for licensees to continue  
21 to reference AEB-98-03 but that their deposition model  
22 needs to reflect individual plant characteristics. As  
23 evidenced by the continuing numerous requests for  
24 additional information pertaining to main steam line  
25 deposition modeling, the RIS did not resolve the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 ongoing issues encountered when licensees submitted  
2 license amendment requests for increasing MSIV leakage  
3 limits. In 2009, the --

4 CHAIR PETTI: This is Dave. I have a  
5 question, just a clarification. As I recall reading  
6 in FitzPatrick, is it the aerosol modeling in the  
7 steam line or in the drywell or both that have been  
8 the concern?

9 MR. PARILLO: Well, primarily in the main  
10 steam line. And specifically, we will discuss the --  
11 there's a particular uncertainty we had in trying to  
12 evaluate the combination of the aerosol deposition in  
13 the drywell due to drywell sprays and then that  
14 subsequent deposition in the main steam line which was  
15 the primary uncertainty in this review. And in fact,  
16 it was the primary uncertainty in all of the four  
17 recent MSIV leakage license amendment requests.

18 CHAIR PETTI: Okay. Thank you.

19 MR. PARILLO: Thank you. Let's see.  
20 Where was I? In 2009, the NRC published Draft Guide  
21 DG-1199 for public comment as a proposed revision to  
22 Reg Guide 1.183. Draft Guide 1199 provided a model  
23 for assessing MSIV leakage. However, the approach  
24 described in this Draft Guide provided very  
25 challenging for licensees and has never been

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 implemented in a license amendment request.

2 The proposed model in DG-1199 did not  
3 credit safety-related equipment to distribute the  
4 deterministic source term for the first two hours of  
5 the evaluation. This assumption has been determined  
6 to be inappropriate for design-basis assessments as  
7 described in the case file for differing professional  
8 opinion, DPO 2020-2, and is being eliminated in the  
9 proposed revision to Reg Guide 1.183. Slide 31.  
10 Slide 31 summarizes a significant uncertainty  
11 encountered in the review of the recent MSIV leakage  
12 license amendment request.

13 The interaction between aerosol removal by  
14 drywell sprays and the subsequent aerosol removal due  
15 to main steam line deposition as modeled by the  
16 licensees was questioned. Sensitive analyses were  
17 submitted that indicated that if the power conversion  
18 system is assumed to be intact providing a pathway to  
19 the condenser, the dose reduction would be  
20 substantial. The effectiveness of an intact power  
21 conversion system providing a pathway to the condenser  
22 is acknowledged by the NRC staff as evidenced by  
23 assumptions in Appendix C to Reg Guide 1.183 for the  
24 evaluation of the boiling water reactor rod drop  
25 accident.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1           Due to model limitations and for  
2 additional conservatism, licensees only credit a  
3 deposition in two of the four main steam lines. This  
4 conservatism alone accounted for an approximate 30  
5 percent increase in the calculated dose consequences.  
6 And in addition, licensees did not credit mixing  
7 between the drywell and the wetwell air space for the  
8 first two hours of the accident. This assumption has  
9 also been determined to be inappropriate for design-  
10 basis assessments as described in the previously  
11 mentioned DPO case file. Slide 32.

12           Slide 32 describes the licensees' accident  
13 analyses of record and how the NRC staff use the  
14 insights described in the ISG to reach its conclusion  
15 of reasonable assurance. As stated, the key points  
16 are that, one, the licensees' sensitivity analyses are  
17 not part of their licensing basis, two, a pathway to  
18 the condenser was not credited in the analyses of  
19 record, three, the licensees provided analyses which  
20 met the acceptance criteria in 10 CFR 50.67, and most  
21 important for this discussion is that the staff's  
22 determination of reasonable assurance was supported by  
23 the recognition that there is a high probability that  
24 doses will be significantly lower than those estimated  
25 by the licensees using deterministic methods that do

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 not credit holdup and retention of the main steam  
2 isolation valve leakage within the power conversion  
3 system.

4 This essential concept explains the  
5 relationship between the review of the four license  
6 amendment requests and the concepts presented in the  
7 ISG. I'm looking to see if there are any questions.  
8 Oh, well. No hands raised. So now Jerry will review  
9 the key takeaways from today's presentation.

10 MR. DOZIER: Okay. So as we've  
11 demonstrated today, the ISG will result in  
12 consideration of large holdup volume in future MSIV  
13 leakage LARs. It offset some of the certainty and  
14 input parameters for deterministic calculations,  
15 supports the reasonable assurance findings during  
16 reviews, and is only applicable if quantitative credit  
17 is not included in the licensee's calculations. As  
18 we've emphasized, the ISG does not change the  
19 licensee's responsibility to demonstrate compliance  
20 with 2 CFR 50.67.

21 Acceptable methods for demonstrating  
22 compliance remain unchanged. ISG is expected to be  
23 transitioned to the standard review plan. And we've  
24 got more work to do because formal condenser holdup  
25 credit for licensees is being considered in the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 revision to Reg Guide 1.183. That concludes our  
2 presentation.

3 CHAIR PETTI: So question, it's being  
4 considered or it will be incorporated?

5 MR. VASAVADA: This is Shilp. If I can  
6 answer, I think -- this is Shilp Vasavada from the  
7 staff. First of all, I mean, being considered may not  
8 be the right words because it's already there in  
9 Revision 0 of Reg Guide 1.183. What I think we are  
10 trying to say over here is the insights that we gained  
11 from the development of the technical assessment for  
12 the ISG will be leveraged to see how we can streamline  
13 the credit -- getting the credit in the revision to  
14 1.183.

15 CHAIR PETTI: Okay. Thank you.

16 MR. DOZIER: And in other words, it might  
17 change it because realize that if you look at that old  
18 topical report, it actually goes to looking at fossil  
19 plans. With this new approach that we're looking at,  
20 we're looking at a wide range of more modern  
21 information, for example, the Fukushima operating  
22 experience, all these lessons learned that we've  
23 gotten from Fukushima. So we're looking at in the  
24 update, maybe we could use these insights to change,  
25 I want to say, our archaic way that we had done

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 before.

2 CHAIR PETTI: Okay. Thank you.

3 MEMBER REMPE: Dave, this is Joy. Can I  
4 ask a question again?

5 (Simultaneous speaking.)

6 MEMBER REMPE: I just want to confirm what  
7 I heard from Shilp earlier. Shilp, did you tell me  
8 that all the BWRs do have positive indication of  
9 closure for the MSIVs?

10 MR. VASAVADA: I think -- I believe it was  
11 maybe Steve. But Steve, can you --

12 MR. JONES: Yes, this is Steve. The  
13 indication would be from the stem position of MSIVs.  
14 But in that sense, there's indication of closure.

15 MEMBER REMPE: So my question is  
16 irrelevant because it would not -- you can immediately  
17 detect closure. So the fact that you have higher  
18 leakage does not matter. Is that the answer to my  
19 question then?

20 MR. JONES: Well, I think the higher  
21 leakage is really independent. We're talking about  
22 very small leakage still. And the indication of valve  
23 closure is really just greater than 90 percent closed.  
24 And you have the valve being spring actuated would  
25 drive it to full closure. So --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 MEMBER REMPE: Okay.

2 MR. JONES: -- in that sense, I don't see  
3 a lot of follow-up. If you get the indication of  
4 closure, there would not be a need for operator  
5 action.

6 MEMBER REMPE: So there would not be any  
7 change? Okay. I just wanted to make sure I fully  
8 understood it because it is just something that was  
9 concerning me. So thank you.

10 MR. JONES: Okay. Thank you.

11 MEMBER HALNON: This is Greg. I get a  
12 little bit confused. First of all, Joy, there's other  
13 indications, steam tunnel temperatures and other  
14 things that the operators would expect to see upon  
15 closure versus not. So it's not just based on  
16 indication. But back on Slide 26, we talk about that  
17 the licensee from Reg Guide 1.183 provides guidance  
18 for quantitative credit for holdup in main condenser.  
19 And then this last slide was that there's no credit  
20 for holdup and condenser.

21 And I guess I lost the bubble here  
22 somewhere. What are licensees taking credit for in  
23 their deterministic calculation, just the general PCS  
24 deposition rates? Or was it always predetermined that  
25 they could just redo their -- take out some

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 conservativisms or add some depositions such that they  
2 could get a higher leakage rate anyway without any  
3 other conservativisms being taken off?

4 I kind of just lost that last statement  
5 that said you don't take credit for the holdup. I  
6 think I lost the overall concept. So help me with  
7 that. Just reconcile the two statements, the one on  
8 the last slide and the one on Slide 26.

9 MR. VASAVADA: John, do you want to take  
10 that? Or do you want me to start?

11 MR. PARILLO: Yeah. If I understood your  
12 question, we have a bit of a discontinuity in the  
13 existing Reg Guide. Appendix C which is for the  
14 control rod drop accident for boiling water reactors,  
15 that provides assumptions that licensees use which  
16 implicitly assumes that a pathway to the condenser and  
17 that allows for a certain deposition in the condenser.  
18 But more importantly, it allows you to release the  
19 effluent one percent per day.

20 Now that accident is only evaluated for 24  
21 hours. But that, for a long-term release, would be  
22 very, very significant reduction. But for Appendix A  
23 which deals with -- well, currently, it's referred to  
24 as the loss of coolant accident. But we prefer to use  
25 the term, the maximum hypothetical accident, or, the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 accident that's described in the regulation in a  
2 footnote.

3 And for that evaluation, Reg Guide 1.183  
4 allows you to credit systems downstream of the second  
5 MSIV leakage -- MSIV valve, excuse me, main steam  
6 valve -- isolation valve, providing that they -- words  
7 to the effect that they could survive a safe shutdown  
8 earthquake. So there's a difference in the guide.  
9 We're applying a more strict interpretation for the  
10 MHA than is applied for whatever you wanted to call  
11 lesser accidents.

12 So the credit now does exist for a pathway  
13 to the condenser in the current guide. What we're  
14 anticipating -- and of course, this is all pre-  
15 decisional. But what we're working on is to provide  
16 some guidance that could be followed for the maximum  
17 hypothetical accident which could -- we would have  
18 reasonable assurance of a pathway to the condenser.  
19 And we will also provide certain removal coefficients  
20 that could be used for that particular evaluation.

21 MEMBER HALNON: Okay. That reconnected  
22 the dots. Thank you. I appreciate it.

23 MR. PARILLO: Thank you.

24 MEMBER REMPE: So Greg, now you're getting  
25 back into the, oh, well, yeah, but then they also

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 confirm it. Well, will the confirmatory information  
2 be less distinct is what I'm trying to say. And  
3 again, is the flow rate so big that there are no  
4 needed changes in the EOPs, because there's no mention  
5 of this at all in the FitzPatrick response from the  
6 staff.

7 And so again, were there -- and I heard  
8 earlier, well, I think there might've been some  
9 changes in the EOPs, I believe from Steve. Were there  
10 some changes in the EOPs? And is that something  
11 that's always done? Or it's just, no, this does not  
12 matter?

13 MR. PARILLO: Well, maybe I should take  
14 it. This is John Parillo again. I think a key to  
15 understanding what went on with FitzPatrick, I mean,  
16 they -- like I said before, they -- prior to this  
17 recent amendment which was granted, FitzPatrick had  
18 the lowest MSIV leakage limit in the fleet, 46  
19 standard cubic feet per hour.

20 Now they -- by virtue of this amendment,  
21 now they will have a leakage limit, total leakage of  
22 200 standard cubic feet per hour. Now I'm not an  
23 operator. But if you think -- I think what you're  
24 asking is what does that change -- what does the  
25 impact of that change and is that going to have a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 significant impact on operator actions?

2 And I would say that you're going from an  
3 incredibly --- to a very low leakage. And I don't  
4 think offhand that there would be any perceptible  
5 difference downstream. But I would defer to an  
6 operator to verify that. But my gut feeling is that  
7 it's not something that would require any kind of a  
8 change in an emergency operating procedure. But  
9 that's --

10 MEMBER REMPE: And this was a plant that  
11 had very low leakage valves. And again, this is going  
12 on with the operating -- some of the operating fleet.

13 MR. PARILLO: Yeah, well --

14 MEMBER REMPE: I'm just curious. Would it  
15 be too much to ask if you could pull the string and  
16 say, yeah, it was considered even if the staff didn't  
17 do it in their review of the LAR by the actual plants  
18 and they did not need to make any changes to EOPs or  
19 they did but they thought about it? That's what I'm  
20 trying to ask today.

21 And it's not -- again, maybe I'm slow.  
22 I'm also not an operator. But I just am curious  
23 because it's of interest. It could be a safety issue.  
24 I just am curious.

25 MR. DOZIER: For that particular

1 consideration, of course the things that the licensee  
2 would need to do is being considered in the Reg Guide  
3 update. So certainly, I think we could -- we would be  
4 asking those questions, what would need to be done?  
5 So I think the answer to your question, Dr. Rempe, is  
6 yes.

7 MEMBER REMPE: Yes, you are asking that  
8 question and so it is being done. That's what I  
9 wanted to hear today.

10 MR. JONES: This is Steve Jones. I think  
11 just to clarify, there is an evaluation that's  
12 included in the BWR topical report dealing with credit  
13 for this type of main steam isolation valve, leakage,  
14 holdup, and deposition. And one of the main concepts  
15 is that these higher level leakages do not represent  
16 any condition that's outside what you would expect  
17 from a good or a very well performing main steam  
18 isolation valve.

19 In other words, as John said, we're just  
20 going from extremely low leakage to very low leakage  
21 to get these type of leakage limits. Three cubic feet  
22 per minute at 45 psig is still a very tight valve for  
23 this size. We're talking about nearly a foot diameter  
24 of the seat. So it's just, again, balancing how  
25 frequently these valves are reworked and the operator

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 dose associated with that versus how well they perform  
2 in the absolute containment of fission products post-  
3 accident.

4 MEMBER REMPE: So I'll try and paraphrase  
5 again. You're saying that there is some sort of BWR  
6 topical report where the staff does -- or a Reg Guide  
7 that would guide the staff to ask that question. Are  
8 there any changes that need to be made to the EOPs if  
9 there were a need to verify that the MSIV has closed  
10 in light of the increased leakage?

11 MR. JONES: Well, what there is, is  
12 there's a statement from industry. And the staff has  
13 accepted that the -- that in the leakage -- in the  
14 range of leakage limits we're discussing here, there's  
15 very high confidence that the valve would continue to  
16 perform as designed. There's no degradation or any  
17 change in response that's expected from this change.

18 MEMBER HALNON: So Joy, this is Greg. I  
19 have never put my eyes on it, but I am pretty sure  
20 that there's, in EOP, the symptom-based EOPs were  
21 increasing, radiation increasing heat in the steam  
22 tunnel, other things that would drive you back to  
23 verify that the MSIVs are closed.

24 MEMBER REMPE: I would think so too. And  
25 then the question is with the increased leakage, is it

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 harder for them to detect it, is what I'm kind of  
2 asking. And again, I'm kind of -- I'm not getting a  
3 real strong answer that I expected to get when I  
4 raised the issue. Maybe it's because I don't  
5 communication very well.

6 MR. JONES: The steam tunnel temperature  
7 monitoring and things like that is outside the -- I  
8 mean, it's in the steam tunnel. But it's not touching  
9 the piping or anything like that. So you're not going  
10 to see that response at the type of leakage limits  
11 we're referring to here. Again, it's very low. And  
12 in terms of mass, a very, very low leakage rate.

13 MEMBER HALNON: Yeah, the point is --

14 MR. JONES: And they can't transfer much  
15 energy.

16 MEMBER HALNON: The point is the operators  
17 are trained on scenarios that MSIVs have either failed  
18 to close or have increased leakage through. And I  
19 think what Joy is looking for is some validation, one,  
20 was that already there, and two, was there any  
21 additional actions they may need to take based on the  
22 fact that we're increasing the leakage limit? So  
23 that's the --

24 MEMBER REMPE: And actually, it's only the  
25 latter point. I'm pretty confident too it's there.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 But the question is does it need to change? And  
2 that's what I am trying to get to. And --

3 (Simultaneous speaking.)

4 MR. JONES: Yeah, the value was just too  
5 low to be significant with respect to the valve  
6 performance or the effect it would have on the  
7 downstream --

8 (Simultaneous speaking.)

9 MEMBER REMPE: And I would buy that. If  
10 that's the answer, that makes sense to me and so I'd  
11 buy that. What I -- I guess I didn't hear that till  
12 this last time, and I know I kept berating it. But  
13 again, if that's the case and you're confident that  
14 that is the case, it's just too low, it would not  
15 matter, that would be fine. I just was curious when  
16 I saw that.

17 MEMBER KIRCHNER: Yeah, Joy, this is Walt.  
18 I would second Steve's answer. Basically, the  
19 inventory of the PCS, for these low leakage rates,  
20 you're not going to pressurize the power conversion  
21 system with these low rates of leakage. There's so  
22 much -- there's so many thermal -- there's so much  
23 thermal loss in the system that with this low leakage,  
24 it's unlikely you can pressurize the volume that the  
25 PCS occupies. So you're not going to see a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 significant difference within the bands that the staff  
2 has been talking about in terms of increased leakage  
3 from a shut main steam isolation valve.

4 MEMBER REMPE: Again, that answer makes  
5 sense, but it took a while to get to that answer. And  
6 that's what I -- again, I just wanted to make sure  
7 that either it was thought out or it was thought about  
8 and dismissed. But I didn't hear that as clearly  
9 until this last time. So thank you for your tolerance  
10 of me bringing it up.

11 MEMBER KIRCHNER: I have a question to the  
12 staff. On the viewgraph in front of us, you talk  
13 about holdup. Does holdup include deposition? Does  
14 this allow -- if the licensee, the applicant can  
15 demonstrate a credible deposition model, does -- is he  
16 or she allowed to take credit for that as well? You  
17 seem to use the term, sometimes, interchangeably. But  
18 I think holdup means something different to me than  
19 deposition.

20 MR. PARILLO: This is John Parillo again.  
21 I could refer you to Appendix C of Reg Guide 1.183.  
22 I believe it provides a deposition of -- I believe  
23 it's 10 percent for iodine. And then the holdup is  
24 addressed by a leakage of one percent per day.

25 (Simultaneous speaking.)

1                   MEMBER KIRCHNER: And that was my second  
2 question, John. That leakage is based on one percent  
3 per day. Is that the venting of the air ejector  
4 condenser? Or is that just a cumulative estimate of  
5 what a PCS would --

6                   (Simultaneous speaking.)

7                   MR. PARILLO: It's just applied to  
8 whatever the source term is that reaches the condenser  
9 in that particular accident.

10                  MEMBER KIRCHNER: But where did you come  
11 up with the number?

12                  MR. PARILLO: The volume -- the leakage  
13 goes into the condenser volume, and then it leaks out  
14 of that volume at one percent per day.

15                  MEMBER KIRCHNER: And that's based on the  
16 venting of the air ejector condenser or just leakage  
17 --

18                  MR. PARILLO: No.

19                  MEMBER KIRCHNER: -- in the system?

20                  MR. PARILLO: No, no. I'll let --

21                  MR. JONES: This is Steve Jones. I guess  
22 I can address some of the systems aspects of this.

23                  MEMBER KIRCHNER: Yeah, please, Steve.

24                  MR. JONES: I mean, we're talking about a  
25 rod drop accident. So you'd have as the source a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 localized high power within several rods -- maybe more  
2 than several -- but anyway, a high power condition  
3 that results in cladding rupture. And then that's  
4 diluted throughout the rest of the RCS and comes out  
5 in the steam system. The -- so it would be  
6 transported through the turbine to the condenser  
7 pretty rapidly. Once it's in the condenser, there are  
8 high radiation monitors that would close and isolate  
9 the vacuum pumps that are connected to the main  
10 condenser. So --

11 MEMBER KIRCHNER: Okay. So then it's just  
12 --

13 (Simultaneous speaking.)

14 MR. JONES: -- we'd just be talking about  
15 leakage.

16 MEMBER KIRCHNER: Okay. Does that take on  
17 then -- do you then require additional quality  
18 assurance requirements on that function of isolating  
19 the air ejector condenser?

20 MR. JONES: We --

21 (Simultaneous speaking.)

22 MR. JONES: I mean, that is a safety-  
23 related instrumentation function to isolate. But the  
24 pressure boundary itself is not.

25 (Simultaneous speaking.)

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. JONES: I mean, there's a -- there is  
2 also a high radiation trip, primary containment  
3 isolation that goes with that. So I mean, all these  
4 things are happening at once. So you're going to get  
5 just a part of that source term is going to get into  
6 the power --

7 MEMBER KIRCHNER: Right.

8 MR. JONES: -- conversion system. And  
9 then it's going to leak out over a period of time.  
10 That's really what you're modeling. And so the  
11 distinction between holdup and deposition is holdup is  
12 there's just a volume there that --

13 MEMBER KIRCHNER: No, I understand that.

14 MR. JONES: -- retains --

15 (Simultaneous speaking.)

16 MEMBER KIRCHNER: I just wanted to  
17 distinguish whether you also allowed credit for  
18 deposition because your viewgraph just talks about  
19 holdup. Okay. I get it. Thank you.

20 MEMBER BROWN: Dave, this is Charlie. Can  
21 I ask a question?

22 CHAIR PETTI: Sure.

23 MEMBER BROWN: This is definitely not my  
24 bailiwick, okay, BWRs in particular since I was a PWR  
25 person. But correct me if I'm wrong. But it sounds

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 like the whole reason for this, the ability to get to  
2 this alternate source term, is the deposition and the  
3 holdup in the condenser.

4 And all I heard was model, model, model  
5 all the way through the presentation. So I'm not  
6 objecting to that. But has there ever been any  
7 experimental basis for what expected deposition rates  
8 would be in these materials or holdup in the condenser  
9 based on the conditions that are there? Or is it just  
10 analytically developed based on analysis?

11 CHAIR PETTI: This is Dave. My view is  
12 there's tons of data. Billion dollars was spent in  
13 severe accident research --

14 MEMBER BROWN: Okay. I didn't hear that.  
15 I'm sorry.

16 CHAIR PETTI: -- looking at deposition in  
17 different systems, the effect of water as a way to  
18 wash out aerosols.

19 MEMBER BROWN: Okay. All right. I'm good  
20 with that. I just didn't hear anybody refer to that  
21 --

22 CHAIR PETTI: Yeah.

23 MEMBER BROWN: -- for the modeling  
24 calculations. Okay. Thank you very much. This has  
25 been enlightening, for me anyway.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 CHAIR PETTI: Any other comments from  
2 members? If not, we'll move on to the NEI. I see  
3 Steve Schultz had a question. Steve?

4 MR. SCHULTZ: Yes, this is a question for  
5 Mike and then also probably for John Parillo as well  
6 because it looks at it from two different ways. The  
7 discussions we've had today talks about the  
8 opportunity to use a risk-informed approach with the  
9 first stab to look at this particular set of license  
10 amendment requests and help with the decision making  
11 associated with it. And then at the end, John and  
12 others have talked about making an application of this  
13 or expanding the thinking associated with Reg Guide  
14 1.183 modifications, moving from just to consideration  
15 in control rod drop to the design-basis event  
16 evaluation. And my question is, is this type of  
17 evaluation, the diverse approach, risk-informed  
18 approach, can we expect to see this in other areas in  
19 the revisions that are being proposed and evaluated  
20 for the Reg Guide 1.183? Is the staff adopting this  
21 type of an approach for that Reg Guide modification  
22 evaluation?

23 MR. FRANOVICH: This is Mike Franovich.  
24 I think Shilp actually might be in a better position  
25 to address that. But the extent of the proposal here,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 there is a symmetry of sorts between the ISG which is  
2 focused on the staff's evaluation, particularly when  
3 the licensee has results that may be close to a limit  
4 and where you start grading your level of effort,  
5 versus the Reg Guide revision which is, again, focused  
6 on what the licensee might be taking credit for and  
7 perhaps more modernized approaches than relying on  
8 trying to use the -- what's been referenced already as  
9 the BWR Owners Group topical report that's been -- was  
10 reviewed now over 20 years ago. And so that sort of  
11 modernization is the extent of the -- the risk-  
12 informing part, it's the primary part. But maybe  
13 Shilp or John can amplify further.

14 MR. SCHULTZ: Thank you, Mike. Yeah, for  
15 Shilp, one of the things that certainly has been  
16 evaluated here which wasn't done 20 years ago was the  
17 association of the conservatisms that are in other  
18 pieces of the evaluation and analysis. And in other  
19 words, the focus was on the dose evaluation and that  
20 particular evaluation and not conservatisms that play  
21 into that from other areas, like seismic, for example.

22 MR. VASAVADA: Yeah, so this is Shilp.  
23 That's correct. In this case, the -- as I mentioned  
24 in one of my slides, we just looked at a sliver of the  
25 entirety of the dose calculations in the context of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 the challenges that we were facing because of  
2 uncertainty in a parameter in the licensee's dose  
3 calculations. And what Mike mentioned had more  
4 granularity to that. Using what we've done in the  
5 technical assessment for the ISG, what we are planning  
6 to do or we're trying to do is see if we can  
7 streamline some of the information that the licensees  
8 have to provide to take formal quantitative credit to  
9 approaching the Reg Guide for the condenser.

10 In the previous case that the BWR topical  
11 from 20 years ago, the topical is from '93, I believe,  
12 or safety evaluation is from '99 that has nine  
13 limitations and conditions which the licensees have to  
14 meet to take credit using the latest and greatest  
15 information that we have in 20-plus years of operating  
16 an earthquake experience. We are looking to see how  
17 we can streamline those information needs and kind of  
18 order the amount of information that the licensee has  
19 to offer, maybe on a tiered approach based on how  
20 significant their seismic hazard is at a particular  
21 site. So those are some of the thoughts how we are  
22 trying to use what we developed for the ISG into the  
23 Reg Guide development.

24 MR. SCHULTZ: Thank you very much.  
25 Appreciate that.

1 MR. VASAVADA: So this is Shilp Vasavada  
2 again. If Kevin Petti can allow me, I just wanted to  
3 go back to one of the items I had a note from Member  
4 March-Leuba's comments. If I can just speak to that.

5 CHAIR PETTI: Sure.

6 MR. VASAVADA: All right. So Member  
7 March-Leuba mentioned something about needed a  
8 calculation or would like to see a calculation. I  
9 just wanted to, again, put it in the context of the  
10 purpose of the ISG. The purpose was not, again, to  
11 give or for the staff to introduce which we cannot,  
12 quantitative credit in a licensee's calculation.

13 The point was to see, okay, if we were to  
14 think about this realism in our decision making, can  
15 we overcome challenges in the uncertainties and some  
16 parameters in the licensee's calculations? So it was  
17 hard to come up with a factor. And yes, you're right.  
18 Things can heat up and there can be revolatilization  
19 of aerosols.

20 But again, the comparison is against a  
21 case where the PCS is not even considered. There's a  
22 direct release as Steve pointed out, the ground cover  
23 release and then it goes to the control room.  
24 Compared to that, if one were to realistically think  
25 about the PCS, even with revolatilization -- I can't

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 ever say that -- there would be in reality holdup  
2 volumes which would lead to a decay of even those  
3 aerosols and a reduced dose compared to the  
4 calculation of the licensee.

5 And this is on record that the licensee  
6 has provided which does not consider any of that. So  
7 that was the context and that's the reason why we did  
8 not see the need to have a factor developed. So I  
9 just wanted to go back to that. Thank you for the  
10 time.

11 CHAIR PETTI: Okay. Unless I hear other  
12 questions from members, I think we should turn to NEI  
13 at this point.

14 MR. BROADBENT: So this is Greg. Frankie,  
15 did you want to say anything to begin with?

16 MS. PIMENTEL: No, I mean, other than we  
17 appreciate the opportunity to provide industry  
18 feedback during this discussion of the ISG. Other  
19 than that, we can get started with our presentation.

20 MR. BROADBENT: All right. Let me go to  
21 the start. So can everybody see the presentation?

22 CHAIR PETTI: Yes.

23 MR. BROADBENT: All right. I'm Greg  
24 Broadbent. I work for Entergy. I'm a senior staff  
25 engineer in the corporate office. And we have Frankie

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 on the call as well from NEI.

2 I've been working for most of my career at  
3 Grand Gulf. So I'm familiar with BWRs a lot more than  
4 PWRs. And so this is a radiological analysis as well.  
5 So this is a topic that I think I'm prepared to  
6 discuss. Go to the next slide.

7 Talking about in general starting with  
8 risk-informed regulation, we certainly support the  
9 NRC's efforts to risk inform all regulatory  
10 approaches. With regard to this, I'll mention -- with  
11 regard to the MSIVs, going off script a little bit  
12 here, the MSIVs are some of the biggest valves that we  
13 have in our plant. The ones at Grand Gulf, I think  
14 the steam lines are, like, 28 inches.

15 And we've got eight MSIVs that need to  
16 close very quickly. And they have some of the lowest  
17 leakage requirements of all the valves in the plants.  
18 So this is -- you need to take that in context that  
19 these are very, very low leakage to begin with and  
20 very big valves and that there are ALARA issues  
21 associated with this.

22 Going in and having to rework those valve  
23 seats does incur a lot of dose. And that's described  
24 in the BWR Owners Group report. And I think they may  
25 actually have some numbers in there.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1           It's also an outage length issue. We  
2 could -- we'd have to extend the outage because these  
3 valves can't be worked online. So we have to be shut  
4 down before we can actually do anything with regard to  
5 these valves.

6           We're only talking about small increases  
7 in this already small leakage rate allowance that we  
8 have in our tech specs. And by risk informing this,  
9 it allows us to spend our resources in areas that are  
10 most important to safety. So if it's not important  
11 that we incur personnel doses, real doses to people by  
12 allowing a little higher leakage rate on these valves,  
13 then we feel that's a good allowance to -- a good  
14 balance to allow us to increase these leakage rates.

15           And we've also seen some recent successes  
16 with GSI-191 resolution with a risk-informed approach.  
17 And 50.46 has recently taken some statistical  
18 approaches as well. So we feel like this ISG is the  
19 first step in risk informing the radiological  
20 analyses.

21           We feel that there may be other areas.  
22 And we'd certainly like to discuss that with the  
23 staff. But we're really just talking about the ISG  
24 here.

25           I'll quote Shilp from just about 30

1 minutes ago where he talked about this ISG is just a  
2 small sliver of realism in a universe of conservatism.  
3 And I think we would agree with that certainly. And  
4 the industry supports including these approaches in  
5 Revision 1 of the Reg Guide, and we know that the  
6 staff intends to do that.

7 We also recognize that the power  
8 conversion system is likely to remain intact post-  
9 accident. It is built to very high standards. And we  
10 do have confidence that the SSCs in the power  
11 conversion system will provide sufficient volume for  
12 holdup and retention of the fission products like the  
13 ISG concluded and also recognize that the power  
14 conversion system is an important system for plant  
15 operation, not just post-accident.

16 But that is really where we make our  
17 money. And we have to keep that system operational  
18 and generally leak free in order to get steam to the  
19 turbine and turn the generator so that we can stay in  
20 operation. Within Entergy, we've had some plants that  
21 weren't able to stay in operation because they weren't  
22 able to make the financial numbers we needed.

23 So it is a system that we keep in  
24 operation. And we can -- in the event that there are  
25 issues with it or any sort of failures, they're

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 clearly evident in a BWR plant. Steam plumes, high  
2 radiation in certain areas would alert us to any  
3 leaks, maybe some drain flows, also even things like  
4 trouble with people exiting the radiologically  
5 controlled area due to contamination of some noble gas  
6 isotopes that stick to people's clothes.

7 So as we mentioned, approximately half the  
8 plants have already demonstrated that the structural  
9 integrity would be maintained using the BWR Owners  
10 Group report that's currently out there. And we feel  
11 that this ISG also validates the current regulatory  
12 credit that we take for the power conversion system  
13 and other accident analyses like the control rod drop.  
14 I think that was previously discussed. Going to the  
15 next slide.

16 And we feel that the ISG does incorporate  
17 a good amount of operating experience, certainly the  
18 post-Fukushima seismic risk insights. The Owners  
19 Group report done back in the 1990s used earthquake  
20 experience data. Obviously, there's more now than  
21 there used to be. So that's incorporated in here.

22 And we do like the fact that the NRC is  
23 including explicit credit for at least these  
24 conclusions in the upcoming Reg Guide. And we also  
25 recognize that the LARs that were previously approved

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 really didn't use Rev. 1. They used Rev. 0 of the Reg  
2 Guide. So we've also like to have credit for plants  
3 that are applying Rev. 0 to be able to use the  
4 conclusions in this ISG.

5 And with regard to steam line deposition  
6 credit, there is some parts of the steam line that are  
7 credited in the analysis, even if we're not crediting  
8 the power conversion system, for example, the volumes  
9 between the MSIVs where they're isolated. And we want  
10 to make sure that there's realistic modeling  
11 associated with a deposition in the steam line. And  
12 that's important to us.

13 That's a release pathway that's directly  
14 coupled to the reactor vessel currently modeled to be  
15 released directly to the environment. So it can be a  
16 very significant release pathway and a contributor to  
17 doses due to some of the conservative assumptions that  
18 are in that analysis. And I think it was previously  
19 discussed from the staff's side that there were --  
20 that there's been a lot of history associated with  
21 this.

22 There was an Owners Group report back in  
23 the 1990s. AEB-9803 came out for the Perry Plant.  
24 And then there's been some concerns about using AEB-  
25 9803 and the applicability to other plants. So from

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 our perspective, there's been a lot of significant  
2 regulatory uncertainty regarding what models are  
3 acceptable for steam line deposition.

4 And as the staff pointed out that there is  
5 no specific discussion in Revision 0 of the Reg Guide.  
6 And we do like the fact and want to work with the  
7 staff to provide an approved model for deposition in  
8 Revision 1. And I'm sure that it's flexible enough to  
9 apply to all BWRs and even the advanced plants. And  
10 I think that was it for our presentation, yes.

11 MEMBER HALNON: Greg, this is Greg Halnon.  
12 Just a quick question. Since we're talking about  
13 higher depositions in the secondary side of the plan,  
14 is there any impact on control room dose or any other  
15 impact with time operator studies as you have to  
16 respond to other things in the turbine buildings and  
17 areas that the doses may be higher?

18 MR. BROADBENT: Well, and the answer to  
19 that is there's really nothing that we respond to in  
20 the turbine building. The turbine building is not a  
21 safety-related building. So we can't put anything  
22 important in there. So the fact that maybe with these  
23 increase the leakage allowances that the doses may  
24 increase a little bit on that side of the building.  
25 If it's not an area where we have an safety-related

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 equipment, if it's not an area where the operators  
2 have to transit through to get to some safety-related  
3 equipment or some action they need to take post-  
4 accident, then it's really not an issue for us.

5 MEMBER HALNON: How about actually  
6 changing a shift of operators? I know that some of  
7 the plants, you don't go through their turbine  
8 buildings or near. But I don't know all the designs.

9 MR. BROADBENT: Yeah, I'm not changing a  
10 shift early, or --

11 MEMBER HALNON: Yeah, this could go on for  
12 a while, though. So anyway, I guess you answered the  
13 question. There's no required actions that could be  
14 affected by dose.

15 I'm assuming that the control room doses  
16 have been checked and no issue on that. So everything  
17 else would be a site-specific issue that might have  
18 people transit through an area of higher dose. But I  
19 think you answered my question. That's fine.

20 MR. BROADBENT: Yeah, that's right. And  
21 any impact on control room dose, if there's any sort  
22 of shine or anything from the turbine would be  
23 included in a control room dose if that was really a  
24 significant pathway for dose to the operators.

25 MEMBER HALNON: Okay. Thank you.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. BROADBENT: Any more questions for me?

2 MEMBER MARCH-LEUBA: Yes, this is Jose.

3 I just wanted to make a comment that you triggered my  
4 thought process. I found argument on ALARA very  
5 convincing. It really makes sense. Unless I'm  
6 mistaken, during risk-informed evaluations, we don't  
7 consider that.

8 I'm thinking -- I'm just putting it out on  
9 the record -- that maybe we're using the wrong cost  
10 functions, thinking like a mathematician, that the  
11 reason that we need to minimize is not only the risk  
12 to the public but also the risk of the facility  
13 workers. It's a combination of the two with proper  
14 waiting. Just put it out there that you make a good  
15 argument that why am I going to give 10 drams for a  
16 couple of operators for something that doesn't really  
17 produce a significant benefit.

18 MR. BROADBENT: And that argument was the  
19 Owners Group report back in the 1990s came up with.  
20 And that's right. Why take dose that is specifically  
21 from -- or 100 percent certain we're going to get  
22 because we're going to go out and work those valves  
23 and compared to an accident dose that we would receive  
24 or the operators would receive and maybe some offsite  
25 would receive for a very, very low probability

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 accident. So that was the Owners Group approach.

2 CHAIR PETTI: And frankly, Jose, it's one  
3 of the reasons I thought we should hear this in  
4 subcommittee. This is a very subtle but interesting  
5 result. And I just thought that all the members, as  
6 we think about risk-informed regulation, would like to  
7 understand this tradeoff that we've heard today.

8 (Simultaneous speaking.)

9 MEMBER REMPE: -- we've got this other  
10 situation where we have some design developers who do  
11 not want to consider ALARA in Part 53, but just  
12 throwing it out there, right?

13 CHAIR PETTI: But it's required in Part  
14 20. And they have to live to Part 20.

15 MEMBER REMPE: Yeah, I know. It's just  
16 something to think about where it goes, but anyway.

17 CHAIR PETTI: Okay.

18 MEMBER MARCH-LEUBA: And then with respect  
19 to -- to comment about control room dose, I missed the  
20 plans where you have to run by the feedwater pump to  
21 get into the control room. And the path to control  
22 room goes by the turbine and all the secondary. So I  
23 assume those plants would consider increased leakage  
24 to -- we did consider the dose to the control room  
25 operators.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1           But if you have to get there, you have to  
2 walk by a contaminated area. It should incorporate  
3 analysis. That was just a rhetorical comment.

4           CHAIR PETTI: Any other comments from  
5 members?

6           Okay. So at this point, Scott and Thomas  
7 are going to try to fix the public line. So Scott,  
8 before we take public comment, he's going to --

9           (Simultaneous speaking.)

10          MR. MOORE: Yes, thank you, Chairman. So  
11 for all the members on the phone, we're going to reset  
12 the phone line now. And so you're going to drop off  
13 as we reset, and you need to call back in immediately.

14          And this will take just a couple minutes,  
15 and then we'll go to public comments. Thanks,  
16 everyone. Thomas, you can reset the public line at  
17 this point. Thank you.

18          MR. SNODDERLY: Excuse me, Chairman Petti.  
19 This is Mike Snodderly. While we have some time, I  
20 just wanted to make one comment.

21          CHAIR PETTI: Go ahead.

22          MR. SNODDERLY: So I just wanted to remind  
23 the members and the staff that as was mentioned in the  
24 slides, the staff has received public comments on the  
25 ISG. And the staff is currently -- or has resolved

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 those comments. But we did not hear about them today  
2 because of the very full agenda and making sure that  
3 everyone clearly understood the precedent that had  
4 been set through the LARs. But the staff does plan to  
5 address the resolution of those public comments when  
6 we have the full committee meeting right now currently  
7 scheduled for November. So I just wanted to remind  
8 the staff and the members and also get on the record  
9 that we will go over the final resolution of the  
10 public comments received in November.

11 CHAIR PETTI: Thank you, Mike.

12 MR. MOORE: Thomas or Makeeka, are either  
13 of you on?

14 (Pause.)

15 MR. DASHIELL: Public bridgeline has been  
16 reestablished.

17 MR. MOORE: Thomas, you said it has been  
18 reestablished?

19 MR. DASHIELL: That is correct, Scott.

20 MR. MOORE: Okay. Thank you.

21 CHAIR PETTI: And I assume all those beeps  
22 are people calling back in, right?

23 MR. MOORE: Yes, sir.

24 CHAIR PETTI: Okay. Let's give them  
25 another minute, and then we'll ask for if there's any

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 public comments.

2 (Pause.)

3 CHAIR PETTI: Okay. I'm not hearing any  
4 more beeps. So hopefully, everybody is back on. Are  
5 there any comments from members of the public? If so,  
6 please state your name and your comment.

7 Again, any comments from the public?

8 Okay. Not hearing any, we're going to  
9 turn to the staff -- I mean to the members. Any other  
10 comments on presentations today and the topic at hand?

11 MEMBER KIRCHNER: Dave, this is Walt. I  
12 have one general comment going back to the questions  
13 I asked of the staff. When this is presented at full  
14 committee, I really strongly feel that more context is  
15 needed up front because on the surface, it could be  
16 misinterpreted by the public that we're using these  
17 risk-informed measures to relax requirements. And  
18 that's not really the case.

19 But it sounds like it on the surface  
20 because we're talking about increasing leakage of  
21 valves. So that sounds like a problem. And as the  
22 NEI presentation made clear, we're not necessarily  
23 relaxing protection of the public. We're actually  
24 doing a more physically accurate representation of  
25 what happens and demonstrating that the public is

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 probably more protected when you analyze the problem  
2 in that manner.

3 And then obviously, LARs cost money. So  
4 the industry does an LAR often because there's an  
5 economic gain that offsets the cost of the LAR in  
6 terms of the operation of the plant and the safety of  
7 the plant. So I just think more context would be  
8 useful up front in an abbreviated presentation to the  
9 full committee, especially if the NEI doesn't  
10 participate in that presentation. Thank you.

11 CHAIR PETTI: That's a good point, Walt.  
12 I'm sure NRR is listening. Thanks.

13 MEMBER BALLINGER: This is Ron. We often  
14 -- we always make a distinction between members of the  
15 public and workers at the plant. But as soon as the  
16 worker goes home for supper, he or she becomes a  
17 member of the public. And so radiation dose is  
18 radiation dose. And it's useful to save it, period.

19 CHAIR PETTI: Anyone else?

20 Okay. Well, I want to thank the staff and  
21 NEI. Very informative presentations today. Members,  
22 of course I have a draft letter. I will place it on  
23 your NRC emails. And you can hack it at will and add  
24 any comments that you feel need to be there.

25 We've got a little bit of time since full

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 committee won't be now till November. If I recall,  
2 this was going to be an October thing, but things are  
3 moving around. But I'll at least get it out there for  
4 you to think about it before you forget your thoughts  
5 before the November full committee.

6 And with that, we'll adjourn the meeting.  
7 And I guess we come back at 2:00 o'clock Eastern for  
8 the afternoon session. Thank you, all.

9 (Whereupon, the above-entitled matter went  
10 off the record at 12:34 p.m.)  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25



# **Presentation to ACRS Subcommittee on Draft Interim Staff Guidance for Radiological Consequence Analyses Using Alternate Source Terms**

**Mike Franovich, Director, NRR/DRA**


**Kevin Hsueh, Branch Chief, NRR/DRA**

**Jerry Dozier, Senior Reliability and Risk Analyst, NRR/DRA**

**Steve Jones, Senior Safety and Plant Systems Engineer, NRR/DSS**

**Shilp Vasavada, Branch Chief (Acting), NRR/DRA**

**John Parillo, Senior Reactor Engineer, NRR/DRA**



# Introductory Remarks

A changing regulatory environment:

- Licensing, other regulatory decisions, and backfit/forward fit actions must be risk-informed. (SRM-SECY-19-0036, SRM-SECY-18-0049)
- Improved realism, evaluation techniques, and additional information are applied to improve risk-informed regulatory decision making (ML19319C832)
- Culture re-alignment is needed to ensure that we identify and resolve challenges and roadblocks for the appropriate and consistent integration of risk insights.

# Introductory Remarks (Cont'd)

- Integrated Review Team process (LIC-206) was used in the staff's approval for BWR LARs to allow for increased MSIV leakage.
  - All four MSIV reviews were completed using a team approach.
  - Each SE includes a section on risk and engineering insights to support staff's reasonable assurance finding.
- ISG is being developed to memorialize staff's practice.

# Introductory Remarks (Cont'd)

- Draft RG 1.183 Rev. 1 (DG-1389)
  - Staff efforts have restarted using an integrated team to revise RG 1.183, “Alternative Radiological Source Terms for Evaluating DBAs at Nuclear Power Reactors.”
  - An ACRS meeting is being planned for Fall 2021, prior to issuance of DG-1389 for public comment.

# Outline

- Overview of the Interim Staff Guidance (ISG)
- Background of ISG
- Basis for ISG – Technical Assessment
  - Overview
  - Details
- Difference between ISG and Regulatory Guide 1.183 Revision
- Use of ISG approach in LARs
- Takeaways

# Overview of ISG - Timeline

- Published in *Federal Register* for public comment
  - 30-day comment period closed on June 21, 2021
- 13 comments received from NEI, 20 anonymous comments
- ACRS full committee briefing scheduled for November 2021 (tentative)
- OMB approval - January 2022 (tentative)
- Final FRN - February 2022 (tentative)

# Overview of ISG (Cont'd)

- The ISG is expected to be transitioned into SRP Section 15.0.1 (Radiological Consequence Analyses using AST) in conjunction with the separate RG 1.183 revision effort.
- Section 15.0.1 will include a reference to the revised RG 1.183.
- ISG will be closed after transition to Section 15.0.1.



# Overview of ISG – Primary Insight

- **High probability** that doses will be **lower** than those estimated strictly using traditional deterministic methods, which **include accepted assumptions**, that **do not credit** hold-up and retention of the Main Steam Isolation Valve (MSIV) leakage within the power conversion system (PCS)

# Overview of ISG – Objective and Expectation

- **Objective:** Near-term formal regulatory footprint for staff's use of risk insight
- **Expectations:**
  - Used by staff to offset uncertainty in input parameter(s) for deterministic calculations
  - Supports staff's reasonable assurance finding during reviews
  - Transitioned to Standard Review Plan Section 15.0.1
- **Caveat:**
  - **Does not change the licensee's responsibility** to demonstrate compliance with 10 CFR 50.67
  - **Does not change acceptable methods** for demonstrating compliance with 10 CFR 50.67

# Background of ISG - Genesis


- Commission direction to become a modern, risk-informed regulator (e.g., SRM-SECY-19-0036; ML19183A408)
- Four license amendments were submitted to allow for increased MSIV leakage in 2019
  - Challenges due to uncertainty in input parameter values in dose calculations
  - LIC-206 (ML19031C861) invoked for multi-disciplinary risk insights

# Background of ISG – Genesis (Cont'd)


- Integrated review team approach following LIC-206 guidance
- Identified that risk insights support consideration of holdup in PCS
  - Ability to offset challenges without changing calculation methods and assumptions
- Documented insights in technical assessment
  - Internal reviews and deliberations
- Implementation of LIC-206 in deterministic LARs
  - Included in all four safety evaluations for the LARs to allow for increased MSIV leakage (ML20140A070; ML20150A328; ML20241A190; ML20265A240)

# Basis for ISG – Technical Assessment

- Dose calculations often do not credit any SSCs beyond outboard MSIVs
- “Formal” credit for condenser through safety evaluation on BWROG Topical Report – approximately half of BWRs have adopted this method.
- Large holdup volume exists in PCS beyond second MSIV




# Large Holdup Volume in PCS




<b>HPIC &amp; RCIC MSL SUCTION</b> U-1, A MSL RCIC Steam Supply U-2, D MSL RCIC Steam Supply U-1, B MSL HPIC Steam Supply U-2, C MSL HPIC Steam Supply			<b>SYSTEM INITIATION SIGNALS</b> <b>Leak Inside Containment</b> AOS will initiate FAIL the following signals are received/worst -59" Reactor Water Level +2.5 psig Drywell Pressure Any low pressure ECCS pump discharge > 100 psig 113 second timer timed out <b>Leak Outside Containment</b> AOS will initiate FAIL the following signals are received/worst -59" Reactor Water Level Any low pressure ECCS pump discharge > 100 psig 5.5 minute timer timed out <b>Pressure Relief Setpoints (ERVs)</b> B & C 1115 psig 1070 reset A, D & E 1135 psig 1090 reset			<b>VALVE CLOSURES ON GROUP 1</b> All Inboard & outboard MSIVs MSL Drain Valves (220-1 and 220-2) Reactor System Sample Valves (220-44 and 220-45)														
<b>SAFETY VALVE SETPOINTS</b> 2 LR @ 1240 psig 2 LR @ 1250 psig 4 LR @ 1260 psig			<b>SYSTEM ISOLATION SIGNALS</b> Group 1 Isolation -59" Low Low Reactor Water Level 200° F Steam Turbine Hi Temperature 140% High Steam Flow in 50XX MSL +785 psig MSL Low Pressure (ONLY if the Reactor mode switch is in "RUN")			<b>0250-01</b> <b>Main Steam System</b> Date: 02/25/05    Revision: 2 PRCY: MTS, MESS, MFD, MAB														
<b>SYSTEM DESIGN PARAMETERS</b> <table border="1"> <thead> <tr> <th>Valve</th> <th>Discharge Floor plate</th> <th>Pressure Relief Values</th> </tr> </thead> <tbody> <tr> <td>Safety</td> <td>545.00061491</td> <td>-100# below setpoint</td> </tr> <tr> <td>Target Rock</td> <td>595.00061491</td> <td>-45# below setpoint</td> </tr> <tr> <td>ERV5</td> <td>592.00061491</td> <td>-45# below setpoint</td> </tr> </tbody> </table>			Valve	Discharge Floor plate	Pressure Relief Values	Safety	545.00061491	-100# below setpoint	Target Rock	595.00061491	-45# below setpoint	ERV5	592.00061491	-45# below setpoint						
Valve	Discharge Floor plate	Pressure Relief Values																		
Safety	545.00061491	-100# below setpoint																		
Target Rock	595.00061491	-45# below setpoint																		
ERV5	592.00061491	-45# below setpoint																		

# Technical Assessment - Overview



# Technical Assessment – Risk Triplet Formulation

Risk = What Can Go Wrong x How Likely Is It x What are the Consequences  
= (Likelihood x Impact) of Undesirable Outcome  
= (Likelihood x Impact) of Fission Products Not Retained in Power Conversion System





# Operational Insights

- Main Steam System Piping:
  - Large internal volume
  - Typically designed to B31.1.0, "Power Piping"
  - Constructed with augmented quality
  - BWR 5 and BWR 6 designed to B&PV Code – safety-related
- Main Steam Isolation Valves:
  - Typically, large globe valves that seat with pressure
  - Stem leakage from outboard valve considered a small fraction of measured seat leakage
- Passive features provide hold-up volume for MSIV seat leakage


# Realistic Transport Pathway

- Consideration of piping attached to steam lines
  - No alignment of specific leakage path
  - Reliability of complete isolation; larger valves leak more
- Functional drain lines flow to main condenser
- Turbine bypass valves also flow to main condenser
- Other leakage, primarily through stop and governor valves to high pressure turbine, provide for less holdup and deposition than main condenser

# Seismic Capacity: A Primer

- **Fragility:** Conditional failure probability as a function of seismic acceleration; Analytically determined; Lognormally distributed
- **Median fragility ( $A_m$ ):** Seismic acceleration at which there is 50% probability of failure
- **Lognormal uncertainty parameters** ( $\beta_r$  for randomness;  $\beta_u$  for uncertainty): Parameters characterizing the uncertainty in the fragility
- **Seismic acceleration:** Measure of strength of earthquake in terms of multiples of gravitational acceleration (e.g., 0.1g, 1g)
- **Peak ground acceleration:** Commonly used acceleration level for seismic analysis; corresponds to acceleration of 100 Hz oscillator

# Seismic Capacity: A Primer



Source: Electric Power Research Institute Report  
1025287 (also known as SPID; ML123330282)


# Approach for Seismic Capacity Evaluation in Assessment

## Fragility Data

- Multiple and diverse sources
- Recent seismic probabilistic risk assessments (PRAs)

## Operating Experience - Walkdowns

- North Anna
- Kashiwazaki-Kariwa
- The Great Tohoku Earthquake of 2011



Lower Bound Median  
Fragility to  
Encompass Seismic  
Failure Modes



Representative Risk  
Estimation

# Seismic Capacity Insights

- Welded piping, bolted piping, and valves have high median fragilities
- Main condenser is usually a seismic Category II structure
  - Anchorage designed to avoid failure at design-basis seismic loads
- Post-earthquake walkdowns of plants demonstrate high seismic capacity of SSCs in PCS
- Seismic risk from accelerations at and below plant's safe shutdown earthquake (SSE) is small

# Seismic Capacity Insights

- Lower bound median fragility parameters
  - $A_m = 0.4g$ ;  $\beta_r = 0.22$ ;  $\beta_u = 0.22$
  - Based on fragility of expansion joint connecting circulating water piping to condenser
  - Encompasses failure modes of relevant SSCs
  - Supports low likelihood of gross failure of SSCs in PCS

# Representative Risk Estimation

- Convolution of range of hazards with lower bound median fragility parameters
  - Provides estimate of risk of gross failure of SSCs in PCS
  - Uses latest seismic hazard curves
- Estimates demonstrate low risk of gross failure
  - Even lower if contribution only until SSE is considered



# Uncertainty Consideration for Seismic Capacity Evaluation

- Uncertainty in median fragility is explicitly included
- Conservatisms exist that address uncertainty in selected median fragility
  - Use of lower bound median fragility
  - Low pressure conditions for high pressure piping
  - Consideration of SSE concurrent with the accident postulated for dose calculations
  - Conservatisms in remainder of dose calculation guidance are unchanged

# Holistic Context for ISG

- Requirements in 10 CFR 50.67
  - Initial condition assumes failure of multiple redundant engineered protection systems and core damage
- Single-failure of inboard MSIV
- Conservatism in analysis
  - Use of acceptable assumptions and parameters
- Concurrent SSE
- Lower bound median fragility parameters

# Difference between ISG and RG 1.183 Revision

ISG	RG 1.183 Revision
Directed at NRC staff	Directed at licensees
Provides additional support for the staff's reasonable assurance determination	Provides guidance for quantitative credit for holdup in main condenser
<b>Does not change the licensing basis dose calculation</b>	<b>Quantitative credit changes the licensing basis dose calculation</b>
Information needs from licensees are not required	Identifies docketed information needs for quantitative credit

**Licensee's responsibility to demonstrate compliance unchanged**  
**Acceptable methods for demonstrating compliance unchanged**

## § 50.67 Accident source term.

- “b) *Requirements.* (1) A licensee who seeks to revise its current accident source term in design basis radiological consequence analyses shall apply for a license amendment under § 50.90. The application shall contain an evaluation of the consequences of applicable design basis accidents previously analyzed in the safety analysis report.”
- “(2) The NRC may issue the amendment only if the applicant's analysis demonstrates with **reasonable assurance** that.....”

# RG 1.183 Rev 0 MSL Pathway Challenges

- RG 1.183 Rev 0 does not contain an aerosol deposition model for the main steam lines (MSL).
- Instead, many licensees have utilized the leakage pathway model described in the staff assessment entitled, *Assessment of Radiological Consequences for the Perry Pilot Plant Application using the Revised (NUREG-1465) Source Term, (AEB-98-03)*.
- Following multiple BWR license amendment requests to revise their source term to implement an AST under 50.67, the NRC staff published, *Regulatory Issues Summary 2006-04, NRC Regulatory Issue Summary 2006-04, Experience with Implementation of Alternate Source Terms*.

# RG 1.183 Rev 0 MSL Pathway Challenges (Cont'd)

- The purpose of RIS 2006-04 was to discuss the more frequent and significant issues encountered by the NRC staff during its review of AST submittals and to provide information for licensees to consider when developing submittals for implementation of an AST.
- A frequent point of contention between licensees and the NRC staff was the deposition of gaseous iodine in the main steam lines.

# RG 1.183 Rev 0 MSL Pathway Challenges (Cont'd)

- For calculation of aerosol settling velocity in the main steam line piping of boiling water reactors, the staff reaffirmed the modeling approach in AEB 98-03 [*emphasis added*] but emphasized the report was written based on the parameters of a particular plant and, therefore, the removal rate constant is specific to that plant.
- Any licensee who chooses to reference these AEB 98-03 assumptions would need to provide appropriate justification that the assumptions are applicable to their particular design.
- AEB-98-03 has been utilized for more than 20 years when implementing 10 CFR 50.67.

# MSIV Leakage LARs Submitted Using RG 1.183 Rev. 0

- LARs included drywell spray removal and main steam line (MSL) deposition in their MSIV leakage models consistent with RIS 2006-04 and past precedent.
  - Staff questioned how the drywell sprays would impact subsequent MSL aerosol deposition.
  - Licensees provided a sensitivity analysis examining the impact of several parameters.
  - Of the parameters evaluated, a pathway to the condenser provided a substantial dose reduction.



# MSIV Leakage LARs Submitted Using RG 1.183 Rev. 0 (Cont'd)

- The licensees' sensitivity analyses are not part of their licensing basis.
- A pathway to the condenser was not credited in the analyses of record (AOR).
- The licensee provided an analysis (the AOR), which met the acceptance criteria in 10 CFR 50.67.
- The staff's determination of reasonable assurance was supported by the recognition that there is a high probability that doses will be significantly lower than those estimated by the licensee using deterministic methods (the AOR) that do not credit holdup and retention of the MSIV leakage within the PCS.

# Takeaways

- ISG will result in consideration of large holdup volume in future MSIV leakage LARs
  - Offsets uncertainty in input parameter(s) for deterministic calculations
  - Supports reasonable assurance finding during reviews
  - Applicable if quantitative credit is not included in licensee's calculations
- ISG does not change licensee's responsibility to demonstrate compliance with 10 CFR 50.67
  - Acceptable methods for demonstrating compliance remain unchanged
- ISG is expected to be transitioned to SRP Section 15.0.1
- Formal condenser holdup credit for licensees is being considered in revision to RG 1.183

# Backup Slides

# Risk Insight References

- U.S. Nuclear Regulatory Commission, NUREG/CR-7110, Volume 1, Peach Bottom SOARCA, May 2013, ML13150A053
- U.S. Nuclear Regulatory Commission, PRAB-02-01, “Assessment of BWR Main Steam Line Release Consequences,” October 2002, ML062920249
- General BWR plant design regarding Defense-in-Depth to deter the release of iodine

# Iodine Pathway in SOARCA




Figure 5-12 LTSBO iodine fission product distribution

# Cesium Pathway in SOARCA




Figure 5-13 LTSBO cesium fission product distribution

# RG 1.183 Source Term (Rev. 0)

**Table 1**  
**BWR Core Inventory Fraction**  
**Released Into Containment**

<b>Group</b>	<b>Gap Release Phase</b>	<b>Early In-vessel Phase</b>	<b>Total</b>
--------------	--------------------------	------------------------------	--------------

Noble Gases	0.05	0.95	1.0
Halogens	0.05	0.25	0.3
Alkali Metals	0.05	0.20	0.25
Tellurium Metals	0.00	0.05	0.05
Ba, Sr	0.00	0.02	0.02
Noble Metals	0.00	0.0025	0.0025
Cerium Group	0.00	0.0005	0.0005
Lanthanides	0.00	0.0002	0.0002

# Increased Containment Leakage has Small Impact (SOARCA)





Figure 5-61 Effect of increased containment leakage on the release of iodine to the environment



# Realistic SOARCA releases much less than earlier studies

1982 Siting Study SST1 case calculated an iodine release of 45 percent and a cesium release of 67 percent of the core inventory.



**Figure ES-1 Iodine release to the environment for SOARCA unmitigated scenarios and the 1982 Siting Study SST1 case**



# ACRS Meeting on DRA-ISG-2021-XX

**Greg Broadbent, Entergy**

**Frankie Pimentel, Sr. Project Manager - Engineering and Risk**

**July 23, 2021**

# Risk-Informed Regulation

- Industry supports NRC efforts to risk-inform regulatory approaches
  - Risk-informing allows licensees to spend resources in areas that are most important to safety
  - Recent successes include GSI-191 resolution and 50.46 using risk-informed or statistical approaches
  
- This ISG is the first step to risk-informing deterministic radiological analyses
  
- Industry supports including these approaches in Reg Guide 1.183, Rev. 1

# ISG Conclusions

- Power Conversion Systems (PCS) highly likely to remain intact post-accident
  - PCS is built to high standards
  - High confidence in the SSCs in the PCS to provide sufficient volume for holdup and retention of fission products
  - Important system for plant operation
  
- Approximately half of plants have already demonstrated structural integrity with rigorous analyses
  - Validates current regulatory PCS credit for other accident analyses
    - ◆ Control Rod Drop Accident

# ISG Conclusions

- ISG incorporates relevant operating experience as well as recent post-Fukushima seismic risk insights and walkdowns
  - NEDC-31858P used earthquake experience data, primarily from nonnuclear facilities
  - Include explicit credit for the conclusions of this ISG approach in Reg Guide 1.183, Rev. 1
    - ◆ Allow credit for plants applying Rev. 0

# Steamline Deposition Credit

- Realistic modeling of the deposition in the steamline is important for BWRs
  - Directly coupled to the reactor vessel
  - Calculated dose for MSL is significant due to very conservative assumptions
  
- Significant regulatory uncertainty regarding acceptable models in RG 1.183 Revision 0
  - Revision 0 of RG 1.183 does not contain an aerosol deposition model for the main steam lines
  - Revision 1 should provide an approved model of deposition that is flexible enough to apply to all BWRs including advanced plants

Full Name	User Action	Timestamp
Snodderly, Michael	Joined	7/23/2021, 9:01:24 AM
Dickson, Elijah	Joined before	7/23/2021, 9:01:24 AM
Govan, Tekia	Joined before	7/23/2021, 9:01:24 AM
Burkhart, Larry	Joined before	7/23/2021, 9:01:24 AM
Dashiell, Thomas	Joined before	7/23/2021, 9:01:24 AM
Dozier, Jerry	Joined before	7/23/2021, 9:01:24 AM
Skov, Tammy	Joined	7/23/2021, 9:03:04 AM
Michael Corradini	Joined	7/23/2021, 9:03:31 AM
Franovich, Mike	Joined	7/23/2021, 9:05:49 AM
Jones, Steve	Joined	7/23/2021, 9:06:06 AM
Hsueh, Kevin	Joined	7/23/2021, 9:06:07 AM
Vasavada, Shilp	Joined	7/23/2021, 9:07:51 AM
Dave Petti (Guest)	Joined	7/23/2021, 9:09:02 AM
Court Reporter3	Joined	7/23/2021, 9:10:28 AM
Ron Ballinger (Guest)	Joined	7/23/2021, 9:13:44 AM
Jose March-Leuba (ACRS) (Guest)	Joined	7/23/2021, 9:14:59 AM
Whitman, Jennifer	Joined	7/23/2021, 9:16:34 AM
Meighan, Sean	Joined	7/23/2021, 9:17:46 AM
Rempe, Joy	Joined	7/23/2021, 9:20:06 AM
Hickey, Jim	Joined	7/23/2021, 9:20:12 AM
Sunseri, Matthew	Joined	7/23/2021, 9:20:22 AM
Dennis Bley (Guest)	Joined	7/23/2021, 9:20:31 AM
Schultz, Stephen	Joined	7/23/2021, 9:21:19 AM
Moore, Scott	Joined	7/23/2021, 9:21:28 AM
Kirchner, Walter	Joined	7/23/2021, 9:21:54 AM
Halnon, Gregory	Joined	7/23/2021, 9:22:07 AM
Greg Broadbent (Entergy) (Guest)	Joined	7/23/2021, 9:22:11 AM
PIMENTEL, Frances	Joined	7/23/2021, 9:22:37 AM
Parillo, John	Joined	7/23/2021, 9:23:44 AM
Clement, Richard	Joined	7/23/2021, 9:24:23 AM
Smith, Micheal	Joined	7/23/2021, 9:27:34 AM
Unknown User	Joined	7/23/2021, 9:27:57 AM
Unknown User	Left	7/23/2021, 9:28:17 AM
Vesna Dimitrijevic (Guest)	Joined	7/23/2021, 9:29:01 AM
Masters, Anthony	Joined	7/23/2021, 9:29:08 AM
Gamin, Kayla	Joined	7/23/2021, 9:29:39 AM
Brown, Charles	Joined	7/23/2021, 9:30:15 AM
Compton, Makeeka	Joined	7/23/2021, 9:30:16 AM
Lee, Samson	Joined	7/23/2021, 9:30:58 AM
Tilton, Caroline	Joined	7/23/2021, 9:31:25 AM
Krsek, Robert	Joined	7/23/2021, 9:32:17 AM
Markley, Michael	Joined	7/23/2021, 9:32:34 AM
Garry, Steven	Joined	7/23/2021, 9:33:13 AM
Clifford, Paul	Joined	7/23/2021, 9:33:19 AM
Kock, Andrea	Joined	7/23/2021, 9:34:29 AM
Marshall, Michael	Joined	7/23/2021, 9:36:22 AM
Dudek, Michael	Joined	7/23/2021, 9:44:20 AM