



International Agreement Report

TRACE VVER-1000/V-320 Model Cross-Code Validation

Prepared by:

S. Iegan*, Y. Vorobyov**, O. Zhabin**, S. Yanovskiy**

*State Nuclear Regulatory Inspectorate of Ukraine
9/11 Arsenalna Str.
Kyiv, 01011 Ukraine

**State Scientific and Technical Center for Nuclear and Radiation Safety of Ukraine
35-37 V. Stusa Str.
Kyiv, 03142 Ukraine

K. Tien, NRC Project Manager

**Division of Systems Analysis
Office of Nuclear Regulatory Research
U.S. Nuclear Regulatory Commission
Washington, DC 20555-0001**

Manuscript Completed: July 2020

Date Published: August 2021

Prepared as part of
The Agreement on Research Participation and Technical Exchange
Under the Thermal-Hydraulic Code Applications and Maintenance Program (CAMP)

**Published by
U.S. Nuclear Regulatory Commission**

AVAILABILITY OF REFERENCE MATERIALS IN NRC PUBLICATIONS

NRC Reference Material

As of November 1999, you may electronically access NUREG-series publications and other NRC records at NRC's Library at www.nrc.gov/reading-rm.html. Publicly released records include, to name a few, NUREG-series publications; *Federal Register* notices; applicant, licensee, and vendor documents and correspondence; NRC correspondence and internal memoranda; bulletins and information notices; inspection and investigative reports; licensee event reports; and Commission papers and their attachments.

NRC publications in the NUREG series, NRC regulations, and Title 10, "Energy," in the *Code of Federal Regulations* may also be purchased from one of these two sources.

1. The Superintendent of Documents

U.S. Government Publishing Office
Washington, DC 20402-0001
Internet: bookstore.gpo.gov
Telephone: (202) 512-1800
Fax: (202) 512-2104

2. The National Technical Information Service

5301 Shawnee Road
Alexandria, VA 22312-0002
Internet: www.ntis.gov
1-800-553-6847 or, locally, (703) 605-6000

A single copy of each NRC draft report for comment is available free, to the extent of supply, upon written request as follows:

Address: **U.S. Nuclear Regulatory Commission**
Office of Administration
Division of Resource Management & Analysis
Washington, DC 20555-0001
E-mail: distribution.resource@nrc.gov
Facsimile: (301) 415-2289

Some publications in the NUREG series that are posted at NRC's Web site address www.nrc.gov/reading-rm/doc-collections/nuregs are updated periodically and may differ from the last printed version. Although references to material found on a Web site bear the date the material was accessed, the material available on the date cited may subsequently be removed from the site.

Non-NRC Reference Material

Documents available from public and special technical libraries include all open literature items, such as books, journal articles, transactions, *Federal Register* notices, Federal and State legislation, and congressional reports. Such documents as theses, dissertations, foreign reports and translations, and non-NRC conference proceedings may be purchased from their sponsoring organization.

Copies of industry codes and standards used in a substantive manner in the NRC regulatory process are maintained at—

The NRC Technical Library

Two White Flint North
11545 Rockville Pike
Rockville, MD 20852-2738

These standards are available in the library for reference use by the public. Codes and standards are usually copyrighted and may be purchased from the originating organization or, if they are American National Standards, from—

American National Standards Institute

11 West 42nd Street
New York, NY 10036-8002
Internet: www.ansi.org
(212) 642-4900

Legally binding regulatory requirements are stated only in laws; NRC regulations; licenses, including technical specifications; or orders, not in NUREG-series publications. The views expressed in contractor prepared publications in this series are not necessarily those of the NRC.

The NUREG series comprises (1) technical and administrative reports and books prepared by the staff (NUREG-XXXX) or agency contractors (NUREG/CR-XXXX), (2) proceedings of conferences (NUREG/CP-XXXX), (3) reports resulting from international agreements (NUREG/IA-XXXX), (4) brochures (NUREG/BR-XXXX), and (5) compilations of legal decisions and orders of the Commission and Atomic and Safety Licensing Boards and of Directors' decisions under Section 2.206 of NRC's regulations (NUREG-0750).

DISCLAIMER: This report was prepared under an international cooperative agreement for the exchange of technical information. Neither the U.S. Government nor any agency thereof, nor any employee, makes any warranty, expressed or implied, or assumes any legal liability or responsibility for any third party's use, or the results of such use, of any information, apparatus, product or process disclosed in this publication, or represents that its use by such third party would not infringe privately owned rights.



International Agreement Report

TRACE VVER-1000/V-320 Model Cross-Code Validation

Prepared by:

S. Iegan*, Y. Vorobyov**, O. Zhabin**, S. Yanovskiy**

*State Nuclear Regulatory Inspectorate of Ukraine
9/11 Arsenalna Str.
Kyiv, 01011 Ukraine

**State Scientific and Technical Center for Nuclear and Radiation Safety of Ukraine
35-37 V. Stusa Str.
Kyiv, 03142 Ukraine

K. Tien, NRC Project Manager

**Division of Systems Analysis
Office of Nuclear Regulatory Research
U.S. Nuclear Regulatory Commission
Washington, DC 20555-0001**

Manuscript Completed: July 2020

Date Published: August 2021

Prepared as part of
The Agreement on Research Participation and Technical Exchange
Under the Thermal-Hydraulic Code Applications and Maintenance Program (CAMP)

**Published by
U.S. Nuclear Regulatory Commission**

ABSTRACT

This report is developed by the State Nuclear Regulatory Inspectorate of Ukraine (SNRIU) and its technical support organization, the State Scientific and Technical Center for Nuclear and Radiation Safety of Ukraine (SSTC NRS), under Implementing Agreement On Thermal-Hydraulic Code Applications And Maintenance Between The United States Nuclear Regulatory Commission and State Nuclear Regulatory Inspectorate of Ukraine (signed in 2014) in accordance with Article III, Section C, of the Agreement.

The report provides results of the comparison calculations conducted with application of SSTC NRS model of VVER-1000/V-320 for TRACE and RELAP5 computer codes. The calculation scenarios analyzed include design basis accidents and transients from several initiating event groups usually evaluated in safety analysis reports. Additionally, the plant incident with inadvertent opening of steam generator safety relief valve in hot shutdown is simulated.

TABLE OF CONTENTS

| | |
|--|-------------|
| ABSTRACT | iii |
| TABLE OF CONTENTS | v |
| LIST OF FIGURES | vii |
| LIST OF TABLES | xv |
| EXECUTIVE SUMMARY | xvii |
| ABBREVIATIONS | xix |
| 1 INTRODUCTION | 1 |
| 2 BRIEF DESCRIPTION OF MODEL VALIDATION PROCESS | 3 |
| 3 RESULTS OF COMPARATIVE CALCULATIONS | 5 |
| 3.1 MSH Break | 5 |
| 3.1.1 Brief Description of Initiating Event | 5 |
| 3.1.2 Initial Conditions | 5 |
| 3.1.3 Boundary Conditions | 6 |
| 3.1.4 Calculation Results | 6 |
| 3.2 Loss of Turbine Condenser Vacuum | 28 |
| 3.2.1 Brief Description of Initiating Event | 28 |
| 3.2.2 Initial Conditions | 28 |
| 3.2.3 Boundary Conditions | 28 |
| 3.2.4 Calculation Results | 28 |
| 3.3 Trip of One RCP | 49 |
| 3.3.1 Brief Description of Initiating Event | 49 |
| 3.3.2 Initial Conditions | 49 |
| 3.3.3 Boundary Conditions | 49 |
| 3.3.4 Calculation Results | 49 |
| 3.4 Uncontrolled Withdrawal of Control Rods Group | 69 |
| 3.4.1 Brief Description of Initiating Event | 69 |
| 3.4.2 Initial Conditions | 69 |
| 3.4.3 Boundary Conditions | 69 |
| 3.4.4 Calculation Results | 69 |
| 3.5 PRZ Surge Line Break | 88 |
| 3.5.1 Brief Description of Initiating Event | 88 |
| 3.5.2 Initial Conditions | 88 |
| 3.5.3 Boundary Conditions | 88 |
| 3.5.4 Calculation Results | 88 |
| 3.6 Inadvertent Opening of SG SRV in Hot Shutdown | 112 |
| 3.6.1 Brief Description of Incident | 112 |
| 3.6.2 Initial Conditions | 112 |
| 3.6.3 Boundary Conditions | 113 |
| 3.6.4 Calculation Results | 113 |
| 4 CONCLUSIONS | 125 |
| 5 REFERENCES | 127 |

LIST OF FIGURES

| | | |
|-------------|---|----|
| Figure 3-1 | MSH Break. Core Thermal Power | 9 |
| Figure 3-2 | MSH Break. RCS Pressure | 9 |
| Figure 3-3 | MSH Break. Pressurizer Level | 10 |
| Figure 3-4 | MSH Break. Coolant Temperature in Hot Leg, Loop 1 | 10 |
| Figure 3-5 | MSH Break. Coolant Temperature in Hot Leg, Loop 2 | 11 |
| Figure 3-6 | MSH Break. Coolant Temperature in Hot Leg, Loop 3 | 11 |
| Figure 3-7 | MSH Break. Coolant Temperature in Hot Leg, Loop 4 | 12 |
| Figure 3-8 | MSH Break. Coolant Temperature in Cold Leg, Loop 1..... | 12 |
| Figure 3-9 | MSH Break. Coolant Temperature in Cold Leg, Loop 2..... | 13 |
| Figure 3-10 | MSH Break. Coolant Temperature in Cold Leg, Loop 3..... | 13 |
| Figure 3-11 | MSH Break. Coolant Temperature in Cold Leg, Loop 4..... | 14 |
| Figure 3-12 | MSH Break. RCS Loop 1 Mass Flow Rate | 14 |
| Figure 3-13 | MSH Break. RCS Loop 2 Mass Flow Rate | 15 |
| Figure 3-14 | MSH Break. RCS Loop 3 Mass Flow Rate | 15 |
| Figure 3-15 | MSH Break. RCS Loop 4 Mass Flow Rate | 16 |
| Figure 3-16 | MSH Break. Make-Up and Let-Down Mass Flow Rate | 16 |
| Figure 3-17 | MSH Break. PRZ Spray Mass Flow Rate | 17 |
| Figure 3-18 | MSH Break. Core Reactivity | 17 |
| Figure 3-19 | MSH Break. SG-1 Pressure | 18 |
| Figure 3-20 | MSH Break. SG-2 Pressure | 18 |
| Figure 3-21 | MSH Break. SG-3 Pressure | 19 |
| Figure 3-22 | MSH Break. SG-4 Pressure | 19 |
| Figure 3-23 | MSH Break. SG-1 Level (Wide Range) | 20 |
| Figure 3-24 | MSH Break. SG-2 Level (Wide Range) | 20 |
| Figure 3-25 | MSH Break. SG-3 Level (Wide Range) | 21 |
| Figure 3-26 | MSH Break. SG-4 Level (Wide Range) | 21 |
| Figure 3-27 | MSH Break. Turbine Mass Flow Rate | 22 |
| Figure 3-28 | MSH Break. Mass Flow through MSIV | 22 |
| Figure 3-29 | MSH Break. MFW Pumps Mass Flow Rate | 23 |
| Figure 3-30 | MSH Break. AFW Pumps Mass Flow Rate | 23 |
| Figure 3-31 | MSH Break. EFW Pumps Mass Flow Rate | 24 |
| Figure 3-32 | MSH Break. HPIS-1 Mass Flow Rate..... | 24 |

| | | |
|-------------|---|----|
| Figure 3-33 | MSH Break. HPIS-2 Mass Flow Rate..... | 25 |
| Figure 3-34 | MSH Break. HPIS-3 Mass Flow Rate..... | 25 |
| Figure 3-35 | MSH Break. Break Mass Flow Rate..... | 26 |
| Figure 3-36 | MSH Break. Maximal Cladding Temperature | 26 |
| Figure 3-37 | MSH Break. Boric Acid Concentration in the Core | 27 |
| Figure 3-38 | Loss of Turbine Condenser Vacuum. Core Thermal Power | 31 |
| Figure 3-39 | Loss of Turbine Condenser Vacuum. RCS Pressure | 31 |
| Figure 3-40 | Loss of Turbine Condenser Vacuum. Pressurizer Level..... | 32 |
| Figure 3-41 | Loss of Turbine Condenser Vacuum. Coolant Temperature in Hot Leg, Loop 1..... | 32 |
| Figure 3-42 | Loss of Turbine Condenser Vacuum. Coolant Temperature in Hot Leg, Loop 2..... | 33 |
| Figure 3-43 | Loss of Turbine Condenser Vacuum. Coolant Temperature in Hot Leg, Loop 3..... | 34 |
| Figure 3-44 | Loss of Turbine Condenser Vacuum. Coolant Temperature in Hot Leg, Loop 4..... | 34 |
| Figure 3-45 | Loss of Turbine Condenser Vacuum. Coolant Temperature in Cold Leg, Loop 1..... | 35 |
| Figure 3-46 | Loss of Turbine Condenser Vacuum. Coolant Temperature in Cold Leg, Loop 2..... | 35 |
| Figure 3-47 | Loss of Turbine Condenser Vacuum. Coolant Temperature in Cold Leg, Loop 3..... | 36 |
| Figure 3-48 | Loss of Turbine Condenser Vacuum. Coolant Temperature in Cold Leg, Loop 4..... | 36 |
| Figure 3-49 | Loss of Turbine Condenser Vacuum. RCS Loop 1 Mass Flow Rate..... | 37 |
| Figure 3-50 | Loss of Turbine Condenser Vacuum. RCS Loop 2 Mass Flow Rate..... | 37 |
| Figure 3-51 | Loss of Turbine Condenser Vacuum. RCS Loop 3 Mass Flow Rate..... | 38 |
| Figure 3-52 | Loss of Turbine Condenser Vacuum. RCS Loop 4 Mass Flow Rate..... | 38 |
| Figure 3-53 | Loss of Turbine Condenser Vacuum. Make-Up and Let-Down Mass Flow | 39 |
| Figure 3-54 | Loss of Turbine Condenser Vacuum. PRZ Heaters Power..... | 39 |
| Figure 3-55 | Loss of Turbine Condenser Vacuum. PRZ Spray Mass Flow Rate | 40 |
| Figure 3-56 | Loss of Turbine Condenser Vacuum. Core Reactivity | 40 |
| Figure 3-57 | Loss of Turbine Condenser Vacuum. SG-1 Pressure..... | 41 |
| Figure 3-58 | Loss of Turbine Condenser Vacuum. SG-2 Pressure..... | 41 |
| Figure 3-59 | Loss of Turbine Condenser Vacuum. SG-3 Pressure..... | 42 |
| Figure 3-60 | Loss of Turbine Condenser Vacuum. SG-4 Pressure..... | 42 |
| Figure 3-61 | Loss of Turbine Condenser Vacuum. SG-1 Level (Wide Range)..... | 43 |

| | | |
|-------------|---|----|
| Figure 3-62 | Loss of Turbine Condenser Vacuum. SG-2 Level (Wide Range)..... | 43 |
| Figure 3-63 | Loss of Turbine Condenser Vacuum. SG-3 Level (Wide Range)..... | 44 |
| Figure 3-64 | Loss of Turbine Condenser Vacuum. SG-4 Level (Wide Range)..... | 44 |
| Figure 3-65 | Loss of Turbine Condenser Vacuum. Mass Flow through MSIV..... | 45 |
| Figure 3-66 | Loss of Turbine Condenser Vacuum. Turbine Mass Flow Rate..... | 45 |
| Figure 3-67 | Loss of Turbine Condenser Vacuum. BRU-K Steam Mass Flow Rate..... | 46 |
| Figure 3-68 | Loss of Turbine Condenser Vacuum. BRU-A Steam Mass Flow Rate..... | 46 |
| Figure 3-69 | Loss of Turbine Condenser Vacuum. SG SRV Steam Mass Flow Rate | 47 |
| Figure 3-70 | Loss of Turbine Condenser Vacuum. MFW Mass Flow Rate | 47 |
| Figure 3-71 | Loss of Turbine Condenser Vacuum. AFW Mass Flow Rate | 48 |
| Figure 3-72 | Loss of Turbine Condenser Vacuum. EFW Pumps Mass Flow Rate | 48 |
| Figure 3-73 | Loss of Turbine Condenser Vacuum. Maximal Cladding Temperature..... | 49 |
| Figure 3-74 | Trip of One RCP. Core Thermal Power..... | 51 |
| Figure 3-75 | Trip of One RCP. RCS Pressure..... | 51 |
| Figure 3-76 | Trip of One RCP. Pressurizer Level | 52 |
| Figure 3-77 | Trip of One RCP. Coolant Temperature in Hot Leg, Loop 1 | 52 |
| Figure 3-78 | Trip of One RCP. Coolant Temperature in Hot Leg, Loop 2 | 53 |
| Figure 3-79 | Trip of One RCP. Coolant Temperature in Hot Leg, Loop 3 | 53 |
| Figure 3-80 | Trip of One RCP. Coolant Temperature in Hot Leg, Loop 4 | 54 |
| Figure 3-81 | Trip of One RCP. Coolant Temperature in Cold Leg, Loop 1 | 54 |
| Figure 3-82 | Trip of One RCP. Coolant Temperature in Cold Leg, Loop 2 | 55 |
| Figure 3-83 | Trip of One RCP. Coolant Temperature in Cold Leg, Loop 3 | 55 |
| Figure 3-84 | Trip of One RCP. Coolant Temperature in Cold Leg, Loop 4 | 56 |
| Figure 3-85 | Trip of One RCP. RCS Loop 1 Mass Flow Rate..... | 56 |
| Figure 3-86 | Trip of One RCP. RCS Loop 2 Mass Flow Rate..... | 57 |
| Figure 3-87 | Trip of One RCP. RCS Loop 3 Mass Flow Rate..... | 57 |
| Figure 3-88 | Trip of One RCP. RCS Loop 4 Mass Flow Rate..... | 58 |
| Figure 3-89 | Trip of One RCP. Make-Up and Let-Down Mass Flow | 58 |
| Figure 3-90 | Trip of One RCP. PRZ Heaters Power..... | 59 |
| Figure 3-91 | Trip of One RCP. PRZ Spray Mass Flow Rate..... | 59 |
| Figure 3-92 | Trip of One RCP. Core Reactivity | 60 |
| Figure 3-93 | Trip of One RCP. SG-1 Pressure | 60 |
| Figure 3-94 | Trip of One RCP. SG-2 Pressure | 61 |
| Figure 3-95 | Trip of One RCP. SG-3 Pressure | 61 |
| Figure 3-96 | Trip of One RCP. SG-4 Pressure | 62 |

| | | |
|--------------|--|----|
| Figure 3-97 | Trip of One RCP. SG-1 Level (Wide Range)..... | 62 |
| Figure 3-98 | Trip of One RCP. SG-2 Level (Wide Range)..... | 63 |
| Figure 3-99 | Trip of One RCP. SG-3 Level (Wide Range)..... | 63 |
| Figure 3-100 | Trip of One RCP. SG-4 Level (Wide Range)..... | 64 |
| Figure 3-101 | Trip of One RCP. SG-1 Level (Narrow Range)..... | 64 |
| Figure 3-102 | Trip of One RCP. SG-2 Level (Narrow Range)..... | 65 |
| Figure 3-103 | Trip of One RCP. SG-3 Level (Narrow Range)..... | 65 |
| Figure 3-104 | Trip of One RCP. SG-4 Level (Narrow Range)..... | 66 |
| Figure 3-105 | Trip of One RCP. Mass Flow through MSIV..... | 66 |
| Figure 3-106 | Trip of One RCP. Turbine Mass Flow Rate..... | 67 |
| Figure 3-107 | Trip of One RCP. MFW Pumps Mass Flow Rate..... | 67 |
| Figure 3-108 | Trip of One RCP. AFW Mass Flow Rate..... | 68 |
| Figure 3-109 | Trip of One RCP. Maximal Cladding Temperature..... | 68 |
| Figure 3-110 | Uncontrolled Withdrawal of CR Group. Core Thermal Power..... | 72 |
| Figure 3-111 | Uncontrolled Withdrawal of CR Group. RCS Pressure..... | 72 |
| Figure 3-112 | Uncontrolled Withdrawal of CR Group. Pressurizer Level..... | 73 |
| Figure 3-113 | Uncontrolled Withdrawal of CR Group. Coolant Temperature in Hot Leg, Loop 1..... | 73 |
| Figure 3-114 | Uncontrolled Withdrawal of CR Group. Coolant Temperature in Hot Leg, Loop 2..... | 74 |
| Figure 3-115 | Uncontrolled Withdrawal of CR Group. Coolant Temperature in Hot Leg, Loop 3..... | 74 |
| Figure 3-116 | Uncontrolled Withdrawal of CR Group. Coolant Temperature in Hot Leg, Loop 4..... | 75 |
| Figure 3-117 | Uncontrolled Withdrawal of CR Group. Coolant Temperature in Cold Leg, Loop 1..... | 75 |
| Figure 3-118 | Uncontrolled Withdrawal of CR Group. Coolant Temperature in Cold Leg, Loop 2..... | 76 |
| Figure 3-119 | Uncontrolled Withdrawal of CR Group. Coolant Temperature in Cold Leg, Loop 3..... | 76 |
| Figure 3-120 | Uncontrolled Withdrawal of CR Group. Coolant Temperature in Cold Leg, Loop 4..... | 77 |
| Figure 3-121 | Uncontrolled Withdrawal of CR Group. RCS Loop 1 Mass Flow Rate..... | 77 |
| Figure 3-122 | Uncontrolled Withdrawal of CR Group. RCS Loop 2 Mass Flow Rate..... | 78 |
| Figure 3-123 | Uncontrolled Withdrawal of CR Group. RCS Loop 3 Mass Flow Rate..... | 78 |
| Figure 3-124 | Uncontrolled Withdrawal of CR Group. RCS Loop 4 Mass Flow Rate..... | 79 |

| | | |
|--------------|---|----|
| Figure 3-125 | Uncontrolled Withdrawal of CR Group. Make-Up and Let-Down Mass Flow | 79 |
| Figure 3-126 | Uncontrolled Withdrawal of CR Group. PRZ Heaters Power | 80 |
| Figure 3-127 | Uncontrolled Withdrawal of CR Group. PRZ Spray Mass Flow Rate | 80 |
| Figure 3-128 | Uncontrolled Withdrawal of CR Group. SG-1 Pressure | 81 |
| Figure 3-129 | Uncontrolled Withdrawal of CR Group. SG-2 Pressure | 81 |
| Figure 3-130 | Uncontrolled Withdrawal of CR Group. SG-3 Pressure | 82 |
| Figure 3-131 | Uncontrolled Withdrawal of CR Group. SG-4 Pressure | 82 |
| Figure 3-132 | Uncontrolled Withdrawal of CR Group. SG-1 Level (Wide Range) | 83 |
| Figure 3-133 | Uncontrolled Withdrawal of CR Group. SG-2 Level (Wide Range) | 83 |
| Figure 3-134 | Uncontrolled Withdrawal of CR Group. SG-3 Level (Wide Range) | 84 |
| Figure 3-135 | Uncontrolled Withdrawal of CR Group. SG-4 Level (Wide Range) | 84 |
| Figure 3-136 | Uncontrolled Withdrawal of CR Group. Mass Flow through MSIV | 85 |
| Figure 3-137 | Uncontrolled Withdrawal of CR Group. Turbines Mass Flow Rate | 85 |
| Figure 3-138 | Uncontrolled Withdrawal of CR Group. BRU-A Steam Mass Flow Rate | 86 |
| Figure 3-139 | Uncontrolled Withdrawal of CR Group. MFW Pumps Mass Flow Rate | 86 |
| Figure 3-140 | Uncontrolled Withdrawal of CR Group. AFW Mass Flow Rate | 87 |
| Figure 3-141 | Uncontrolled Withdrawal of CR Group. Maximal Cladding Temperature | 87 |
| Figure 3-142 | PRZ Surge Line Break. Core Thermal Power | 91 |
| Figure 3-143 | PRZ Surge Line Break. RCS Pressure | 91 |
| Figure 3-144 | PRZ Surge Line Break. Pressurizer Level | 92 |
| Figure 3-145 | PRZ Surge Line Break. Coolant Temperature in Hot Leg, Loop 1 | 92 |
| Figure 3-146 | PRZ Surge Line Break. Coolant Temperature in Hot Leg, Loop 2 | 93 |
| Figure 3-147 | PRZ Surge Line Break. Coolant Temperature in Hot Leg, Loop 3 | 93 |
| Figure 3-148 | PRZ Surge Line Break. Coolant Temperature in Hot Leg, Loop 4 | 94 |
| Figure 3-149 | PRZ Surge Line Break. Coolant Temperature in Cold Leg, Loop 1 | 94 |
| Figure 3-150 | PRZ Surge Line Break. Coolant Temperature in Cold Leg, Loop 2 | 95 |
| Figure 3-151 | PRZ Surge Line Break. Coolant Temperature in Cold Leg, Loop 3 | 95 |
| Figure 3-152 | PRZ Surge Line Break. Coolant Temperature in Cold Leg, Loop 4 | 96 |
| Figure 3-153 | PRZ Surge Line Break. RCS Loop 1 Mass Flow Rate | 96 |
| Figure 3-154 | PRZ Surge Line Break. RCS Loop 2 Mass Flow Rate | 97 |
| Figure 3-155 | PRZ Surge Line Break. RCS Loop 3 Mass Flow Rate | 97 |
| Figure 3-156 | PRZ Surge Line Break. RCS Loop 4 Mass Flow Rate | 98 |
| Figure 3-157 | PRZ Surge Line Break. Make-Up and Let-Down Mass Flow | 98 |
| Figure 3-158 | PRZ Surge Line Break. PRZ Heaters Power | 99 |

| | | |
|--------------|---|-----|
| Figure 3-159 | PRZ Surge Line Break. Core Reactivity | 99 |
| Figure 3-160 | PRZ Surge Line Break. SG-1 Pressure..... | 100 |
| Figure 3-161 | PRZ Surge Line Break. SG-2 Pressure..... | 100 |
| Figure 3-162 | PRZ Surge Line Break. SG-3 Pressure..... | 101 |
| Figure 3-163 | PRZ Surge Line Break. SG-4 Pressure..... | 101 |
| Figure 3-164 | PRZ Surge Line Break. SG-1 Level (Wide Range)..... | 102 |
| Figure 3-165 | PRZ Surge Line Break. SG-2 Level (Wide Range)..... | 102 |
| Figure 3-166 | PRZ Surge Line Break. SG-3 Level (Wide Range)..... | 103 |
| Figure 3-167 | PRZ Surge Line Break. SG-4 Level (Wide Range)..... | 103 |
| Figure 3-168 | PRZ Surge Line Break. Turbines Mass Flow Rate | 104 |
| Figure 3-169 | PRZ Surge Line Break. BRU-A Steam Mass Flow Rate..... | 104 |
| Figure 3-170 | PRZ Surge Line Break. MFW Pumps Mass Flow Rate | 105 |
| Figure 3-171 | PRZ Surge Line Break. HPIS-1 Mass Flow Rate..... | 105 |
| Figure 3-172 | PRZ Surge Line Break. HPIS-2 Mass Flow Rate..... | 106 |
| Figure 3-173 | PRZ Surge Line Break. HPIS-3 Mass Flow Rate..... | 106 |
| Figure 3-174 | PRZ Surge Line Break. LPIS-1 Mass Flow Rate | 107 |
| Figure 3-175 | PRZ Surge Line Break. LPIS-2 Mass Flow Rate | 107 |
| Figure 3-176 | PRZ Surge Line Break. LPIS-3 Mass Flow Rate | 108 |
| Figure 3-177 | PRZ Surge Line Break. HA-1 Mass Flow Rate | 108 |
| Figure 3-178 | PRZ Surge Line Break. HA-2 Mass Flow Rate | 109 |
| Figure 3-179 | PRZ Surge Line Break. HA-3 Mass Flow Rate | 109 |
| Figure 3-180 | PRZ Surge Line Break. HA-4 Mass Flow Rate..... | 110 |
| Figure 3-181 | PRZ Surge Line Break. Maximal Cladding Temperature | 110 |
| Figure 3-182 | PRZ Surge Line Break. Break Mass Flow Rate..... | 111 |
| Figure 3-183 | PRZ Surge Line Break. Boric Acid Concentration in the Core | 111 |
| Figure 3-184 | Inadvertent Opening of SG SRV in Hot Shutdown. Core Thermal Power..... | 116 |
| Figure 3-185 | Inadvertent Opening of SG SRV in Hot Shutdown. RCS Pressure..... | 116 |
| Figure 3-186 | Inadvertent Opening of SG SRV in Hot Shutdown. Pressurizer Level | 117 |
| Figure 3-187 | Inadvertent Opening of SG SRV in Hot Shutdown. Coolant Temperature in Hot Legs..... | 117 |
| Figure 3-188 | Inadvertent Opening of SG SRV in Hot Shutdown. Coolant Temperature in Cold Legs..... | 118 |
| Figure 3-189 | Inadvertent Opening of SG SRV in Hot Shutdown. RCS Loops Mass Flow Rate..... | 118 |
| Figure 3-190 | Inadvertent Opening of SG SRV in Hot Shutdown. Make-Up and Let- Down Mass Flow..... | 119 |

| | | |
|--------------|--|-----|
| Figure 3-191 | Inadvertent Opening of SG SRV in Hot Shutdown. PRZ Heaters Power | 119 |
| Figure 3-192 | Inadvertent Opening of SG SRV in Hot Shutdown. SG-1 Pressure | 120 |
| Figure 3-193 | Inadvertent Opening of SG SRV in Hot Shutdown. SG-2 Pressure | 120 |
| Figure 3-194 | Inadvertent Opening of SG SRV in Hot Shutdown. SG-3 Pressure | 121 |
| Figure 3-195 | Inadvertent Opening of SG SRV in Hot Shutdown. SG-4 Pressure | 121 |
| Figure 3-196 | Inadvertent Opening of SG SRV in Hot Shutdown. SG-1 Level (Wide Range)..... | 122 |
| Figure 3-197 | Inadvertent Opening of SG SRV in Hot Shutdown. SG-2 Level (Wide Range)..... | 122 |
| Figure 3-198 | Inadvertent Opening of SG SRV in Hot Shutdown. SG-3 Level (Wide Range)..... | 123 |
| Figure 3-199 | Inadvertent Opening of SG SRV in Hot Shutdown. SG-4 Level (Wide Range)..... | 123 |
| Figure 3-200 | Inadvertent Opening of SG SRV in Hot Shutdown. AFW Mass Flow Rate | 124 |

LIST OF TABLES

| | | |
|-----------|--|-----|
| Table 3-1 | Results of Steady State Calculation | 5 |
| Table 3-2 | Sequence of Events for MSH Break Accident | 7 |
| Table 3-3 | Sequence of Events for Loss of Turbine Condenser Vacuum Transient..... | 29 |
| Table 3-4 | Sequence of Events for "Trip of One RCP" Transient..... | 50 |
| Table 3-5 | Sequence of Events for "Uncontrolled Withdrawal of Control Rods Group" Transient..... | 70 |
| Table 3-6 | Sequence of Events for PRZ Surge Line Break Accident..... | 89 |
| Table 3-7 | Initial Conditions for Calculation of "Inadvertent Opening of SG SRV in Hot Shutdown" Incident..... | 112 |
| Table 3-8 | Sequence of Events for "Inadvertent Opening of SG SRV in Hot Shutdown" Incident..... | 114 |

EXECUTIVE SUMMARY

This report is developed in the framework of the Implementing Agreement on Thermal-Hydraulic Code Applications and Maintenance between United States Nuclear Regulatory Commission and the State Nuclear Regulatory Inspectorate of Ukraine.

At the previous stages of these activities existing RELAP5 model for VVER-1000 was converted to TRACE code format and set of validation calculations based on actual incidents were performed.

This work is aimed at the comparative TRACE and RELAP calculations for selected design basis accident scenarios. Thus, this report contains numeric analyses results of the following initiating events:

- guillotine break of the main steam header;
- loss of vacuum in the condenser of the turbine;
- trip of 1 out of 4 operating reactor coolant pumps;
- uncontrolled withdrawal of control rods group;
- break of the pressurizer surge line.

Additionally, the plant incident with inadvertent opening of steam generator safety relief valve in hot shutdown was simulated.

Comparison of the results obtained with TRACE and RELAP5 models indicates some differences in calculated parameters. Nevertheless, these differences do not affect significantly the overall behavior of the main parameters of the primary and secondary circuit and the sequence of events in the analyzed scenarios, and quantitatively the values are in a good agreement.

The results of cross-code validation calculations and simulation of plant incidents demonstrate that developed VVER-1000/V-320 thermal-hydraulic model for TRACE code is able to reproduce adequately the plant response to transients and accidents without core melt. For the majority of plant parameters good correspondence between TRACE and RELAP5 results or plant incident data is obtained.

ABBREVIATIONS AND ACRONYMS

| | |
|----------|--|
| AFW | Auxiliary Feedwater System |
| ARM | Reactor Power Controller, Russian designation |
| BRU-A | Steam Dump Valve to Atmosphere |
| BRU-K | Turbine Bypass to Condenser |
| CAMP | Code Maintenance and Assessment Program |
| CR | Control Rod |
| DBA | Design Basis Accident |
| DG | Emergency Power Supply Diesel-Generator |
| ECCS | Emergency Core Cooling System |
| EFW | Emergency Feedwater System |
| HA | Hydroaccumulators |
| HPIS | High Pressure Injection System |
| IE | Initiating Event |
| LOCA | Loss of Coolant Accident |
| LPIS | Low Pressure Injection System |
| MFW | Main Feedwater System |
| MSH | Main Steam Header |
| MSIV | Main Steam Isolation Valve |
| MSL | Main Steam Line |
| NPP | Nuclear Power Plant |
| PORV | Pilot-operated Relief Valve |
| PZ | Preventive Reactor Protection |
| PRZ | Pressurizer |
| RCP | Reactor Coolant Pump |
| RCS | Reactor Coolant System |
| RPL | Reactor Power Limiter |
| SG | Steam Generator |
| SLP | Sequential DG Loading Program |
| SNRIU | State Nuclear Regulatory Inspectorate of Ukraine |
| SRV | Safety Relief Valve |
| SSTC NRS | State Scientific and Technical Center for Nuclear and Radiation Safety |
| UPZ | Fast Power Reduction |
| USNRC | United States Nuclear Regulatory Commission |
| VVER | Pressurized Water Reactor, Russian design |
| ZNPP | Zaporizhzhya Nuclear Power Plant |

1 INTRODUCTION

At the end of 2014 the United States Nuclear Regulatory Commission (USNRC) and the State Nuclear Regulatory Inspectorate of Ukraine (SNRIU) signed Implementing Agreement on Thermal-Hydraulic Code Applications And Maintenance (CAMP). In accordance with Article III, Section C, of the Agreement, SNRIU shall submit to the USNRC the in-kind contribution reports providing the code assessment results or other activities results of equivalent value.

In the framework of the Agreement SNRIU and SSTC NRS obtained the state-of the-art TRACE code [1], [2] which provides advanced capabilities for modeling thermal-hydraulic processes and components, control systems and allows coupling with PARCS neutron kinetics code. In 2015 SSTC NRS initiated activities on TRACE code application for evaluation of the results of safety assessments performed for Ukrainian NPPs.

As the first step of these activities, the existing SNRIU/SSTC NRS RELAP5 model for VVER-1000 was converted to TRACE code format.

In order to justify capabilities of VVER-1000 model for TRACE code to simulate adequately the plant response during transients, calculations of several events that had actually occurred at Ukrainian NPPs were conducted. Results of TRACE simulations (validation) of these events in comparison to the plant measured data are provided in NUREG/IA-0490 [3]. Since these events do not cover all the phenomena expected to occur during accidents, the VVER-1000 input model validation activities were extended by performing the comparative calculations of selected design basis transient and accident scenarios with RELAP5 and TRACE model. This report provides the results of comparative calculations.

Section 2 of the report briefly describes the validation process and refers to the description of the main primary and secondary systems of VVER-1000/V-320 design which are important for development of thermal-hydraulic model, as well as to a description of TRACE model for this type of NPP unit.

The results of comparative TRACE and RELAP calculations for selected design basis accident (DBA) scenarios are provided in Section 3 of the report.

For each scenario the following information is provided:

- brief description of the scenario;
- initial and boundary conditions selected for calculation;
- sequence of events;
- description of calculation results;
- plots of the main primary and secondary circuit parameters.

2 BRIEF DESCRIPTION OF MODEL VALIDATION PROCESS

After preparation of VVER-1000/V-320 model for TRACE code and adjustment of steady state calculation several transient calculations were performed simulating the actual incidents that had actually occurred at NPPs in Ukraine and the results of calculations were compared with the plant measurement data. In particular the following incidents were simulated:

- main feedwater pump trip at Zaporizhzhya NPP (ZNPP) Unit 5;
- inadvertent closure of main steam isolation valve (MSIV) at ZNPP Unit 6;
- pressurizer (PRZ) pilot-operated relief valve (PORV) stuck open during testing at Rivne NPP Unit 3.

The results of these validation calculations, as well as a brief description of the model and of the main VVER-1000/V-320 design features are presented in NUREG/IA-0490 report [3]. In general, the results demonstrate that calculated behavior of the main primary and secondary circuit parameters is in good agreement with the plant measured data.

However, since simulated incidents do not cover all phenomena that are important for accident analysis and allow to check correctness of modelling for the limited number of plant systems only it was decided to extend TRACE model validation by performing comparative calculations of several scenarios with TRACE and RELAP codes. For this purpose the following DBA scenarios at full power operation are simulated:

- main steam header (MSH) break;
- loss of turbine condenser vacuum;
- trip of one reactor coolant pump (RCP);
- uncontrolled withdrawal of control rods (CR) group;
- PRZ surge line break.

These scenarios cover the majority of DBA initiating events groups, including loss of coolant accidents and secondary circuit breaks that can not be evaluated otherwise due to lack of correspondent plant incidents or reliable measured data.

For each scenario the identical initial and boundary conditions were specified for TRACE and RELAP calculations, and the results obtained with these models were compared.

Additionally, the plant incident with inadvertent opening of steam generator (SG) safety relief valve (SRV) in hot shutdown was simulated.

3 RESULTS OF COMPARATIVE CALCULATIONS

3.1 MSH Break

3.1.1 Brief Description of Initiating Event

This initiating event (IE) assumes postulated guillotine break of the main steam header with a diameter of 530×28 mm, that leads to a loss of secondary circuit coolant from all SG, decrease of SG pressure and increase of heat removal by the secondary circuit. According to the expected frequency of occurrence the IE is categorized as a design basis accident.

3.1.2 Initial Conditions

The initial conditions selected for calculation correspond to normal full power plant operation (taking into account allowances due to plant control systems operation) and are presented in Table 3-1.

Table 3-1 Results of Steady State Calculation

| Parameter | Units | Design value | Calculated value |
|---|---------------------|---|------------------|
| Core thermal power | MWt | 3000±60 | 3104 |
| Reactor outlet pressure | kgf/cm ² | 158...162 | 159.8 |
| Reactor inlet temperature | °C | 289 | 289.6 |
| Coolant temperature at reactor outlet | °C | 320 | 320 |
| Reactor coolant flow rate | m ³ /h | 84800 ⁺⁴⁰⁰⁰ ₋₄₈₀₀ | 84350 |
| PRZ level | m | 8.77±0.150 | 8.82 |
| SG pressure | kgf/cm ² | 60...64 | 60.8 |
| SG level (narrow range gauge) | m | 0.270±0.05 | 0.305...0.315 |
| SG steam production | t/h | 1470±103 | 1394.1 |
| SG feedwater temperature | °C | 220±5 | 220 |
| Water temperature in emergency core cooling system (ECCS) tanks | °C | 20...60 | 60.0 |
| Water temperature in ECCS hydroaccumulators (HA) | °C | 55±5 | 60.0 |

3.1.3 Boundary Conditions

The following assumptions on systems availability and configuration are selected in the analysis.

As an initiating event the guillotine break of MSH with a diameter of 530×28 mm with double-ended discharge of steam is modeled.

No operator actions are taken into account.

Operation of reactor power controller (ARM), reactor power limiter (RPL), preventive reactor protection (PZ) and fast power reduction (UPZ) to decrease power is not considered. Reactor scram operates according to the design with a delay of 1.0 s from formation of actuation signal to a start of control rods drop. Maximal allowed time of control rods drop to the core (4 s) is assumed.

As a single failure a failure to close of MSIV at the main steam line (MSL) from SG-1 is postulated.

Main feedwater (MFW) pumps trip is modelled at the time of turbine stop valves closure. It is postulated that MFW control valve to SG-1 remains in the same position as at the beginning of accident, and correspondent cut-off valve is failed to close (i.e., passive feedwater flow from MFW pipelines to SG-1 is possible). Cut-off valves to other SGs are closed after formation of signal "Pressure decrease in correspondent MSL below 45 kgf/cm² at increase of difference between saturation temperatures of primary and secondary circuit over 75°C and temperature in correspondent hot leg >200°C". Auxiliary feedwater (AFW) pumps start after SG level decrease below 0.22 m by narrow range level meter.

RCP at the loop no.1 remains in operation that increases primary circuit cooling by SG-1 with a potential to reach core recriticality temperature.

Operation of PRZ heaters and PRZ spray is not taken into account.

3.1.4 Calculation Results

Sequence of events for this accident is presented in Table 3-2.

Table 3-2 Sequence of Events for MSH Break Accident

| TRACE Time, s | RELAP5 Time, s | Event | Description |
|----------------------|-----------------------|--|---|
| 0.0 | 0.0 | MSH break | Start of double-ended steam discharge from MSH |
| 0.4 | 0.3 | Closure of turbine stop valves | MSH pressure decrease below 52 kgf/cm ² |
| 0.4 | 0.3 | Trip of MFW pumps | Postulated after closure of turbine stop valves |
| 8.0 | 10.2 | Scram signal | Pressure decrease in any MSL below 50 kgf/cm ² at increase of difference between saturation temperatures of primary and secondary circuit over 75°C |
| 8.0 | 10.2 | Formation of ECCS safeguard | Pressure decrease in MSL-1 below 50 kgf/cm ² at increase of difference between saturation temperatures of primary and secondary circuit over 75°C and temperature in hot leg >200°C |
| 8.0–15.0 | 10.2–27.0 | Closure of MSIV at MSL-2, 3, 4 | Pressure decrease in MSL below 50 kgf/cm ² at increase of difference between saturation temperatures of primary and secondary circuit over 75°C and temperature in correspondent hot leg >200°C. Failure of MSIV at MSL-1 is postulated |
| 10.0–16.0 | 12.0–28.0 | RCP-2, 3, 4 trip | Pressure decrease in MSL below 45 kgf/cm ² at increase of difference between saturation temperatures of primary and secondary circuit over 75°C and temperature in correspondent hot leg >200°C. Continuous operation of RCP-1 is postulated |
| 35.0 | 23.0 | Start of AFW pump | Due to SG level decrease below 0.22 m (by narrow range level meter) |
| 220.0 | 290.0 | Start of injection to the primary circuit from high pressure injection system (HPIS) pumps | Decrease of RCS pressure below HPIS pump shut-off head |
| 520 | 575 | Termination of HPIS injection | Increase of RCS pressure above HPIS pump shut-off head |
| 3600.0 | 3600.0 | End of calculation | Stabilization of parameters |

MSH break with double-ended discharge of steam causes rapid decrease of SG pressure (Figure 3-19 – Figure 3-22). Due to decrease of MSH pressure below 52 kgf/cm² the turbine stop valves are closed (Figure 3-27) at 0.3/0.4 s of the accident (in RELAP and TRACE calculations, respectively). At the same time the MFW pumps trip is assumed due to closure of turbine stop valves and low MSH pressure.

At 8.0/10.2 s after IE occurrence the scram signal "Pressure decrease in any MSL below 50 kgf/cm² at increase of difference between saturation temperatures of primary and secondary circuit over 75°C" is formed. With 1 s delay the control rods drop to the reactor core starts and the reactor power decreases to the decay heat (Figure 3-1).

Actuation of ECCS "MSL break" safeguards "Pressure decrease in MSL below 50 kgf/cm² at increase of difference between saturation temperatures of primary and secondary circuit over 75°C and temperature in correspondent hot leg >200°C" (within 10.2–27 s in RELAP calculation and 8–15 s in TRACE calculation) results in formation of signals to close MSIV at all main steam lines and steam loss from SG-2, 3, 4 is terminated. This causes temporary restoration of pressure in these SGs (Figure 3-20 – Figure 3-22), however before MSIVs are fully closed the steam lines pressure decreases below 45 kgf/cm² that corresponds to the setpoints for trip of RCPs at the affected loops (Figure 3-13 – Figure 3-15).

Steam loss from SG-1 continues since failure of MSIV at MSL-1 to close is postulated (Figure 3-28). RCP of correspondent loop also remains in operation as postulated (Figure 3-12).

Upon ECCS safeguard actuation all HPIS, low pressure injection system (LPIS) and containment spray pumps start operation through correspondent minimal bypass flow (recirculation) lines. Increased (compared to a decay power) heat removal from the primary circuit by SG-1 causes decrease of primary coolant temperature (Figure 3-4 – Figure 3-11), shrinkage of coolant volume and decrease of PRZ level (Figure 3-3) and RCS pressure (Figure 3-2). As RCS pressure decreases below HPIS pump shut-off head (~110 kgf/cm²) boric acid injection to the primary circuit begins at 290/220 s of accident (Figure 3-32 – Figure 3-34) and continues till RCS pressure increases at ~575/520 s.

Continuous operation of AFW (Figure 3-30) and decrease of steam loss through a break (Figure 3-35) cause gradual restoration of SG-1 level (Figure 3-23) starting from ~1200 s.

At ~1700/1400 s PRZ level starts to recover gradually (Figure 3-3) due to operation of make-up pump (Figure 3-16).

The calculation is ended at 3600 s of accident close to the stabilization of main primary and secondary circuit parameters. Core recriticality conditions are not reached (Figure 3-18) due to timely injection by HPIS. Cladding temperature (Figure 3-36) decreases the whole duration of accident and does not exceed the initial full power operation values.

The plots of the main parameters of calculation are presented below on Figure 3-1 – Figure 3-37.




Figure 3-1 MSH Break. Core Thermal Power




Figure 3-2 MSH Break. RCS Pressure




Figure 3-3 MSH Break. Pressurizer Level




Figure 3-4 MSH Break. Coolant Temperature in Hot Leg, Loop 1




Figure 3-5 MSH Break. Coolant Temperature in Hot Leg, Loop 2




Figure 3-6 MSH Break. Coolant Temperature in Hot Leg, Loop 3




Figure 3-7 MSH Break. Coolant Temperature in Hot Leg, Loop 4




Figure 3-8 MSH Break. Coolant Temperature in Cold Leg, Loop 1




Figure 3-9 MSH Break. Coolant Temperature in Cold Leg, Loop 2




Figure 3-10 MSH Break. Coolant Temperature in Cold Leg, Loop 3




Figure 3-11 MSH Break. Coolant Temperature in Cold Leg, Loop 4




Figure 3-12 MSH Break. RCS Loop 1 Mass Flow Rate




Figure 3-13 MSH Break. RCS Loop 2 Mass Flow Rate




Figure 3-14 MSH Break. RCS Loop 3 Mass Flow Rate




Figure 3-15 MSH Break. RCS Loop 4 Mass Flow Rate




Figure 3-16 MSH Break. Make-Up and Let-Down Mass Flow Rate




Figure 3-17 MSH Break. PRZ Spray Mass Flow Rate




Figure 3-18 MSH Break. Core Reactivity




Figure 3-19 MSH Break. SG-1 Pressure




Figure 3-20 MSH Break. SG-2 Pressure




Figure 3-21 MSH Break. SG-3 Pressure




Figure 3-22 MSH Break. SG-4 Pressure




Figure 3-23 MSH Break. SG-1 Level (Wide Range)




Figure 3-24 MSH Break. SG-2 Level (Wide Range)




Figure 3-25 MSH Break. SG-3 Level (Wide Range)




Figure 3-26 MSH Break. SG-4 Level (Wide Range)




Figure 3-27 MSH Break. Turbine Mass Flow Rate




Figure 3-28 MSH Break. Mass Flow through MSIV




Figure 3-29 MSH Break. MFW Pumps Mass Flow Rate




Figure 3-30 MSH Break. AFW Pumps Mass Flow Rate




Figure 3-31 MSH Break. EFW Pumps Mass Flow Rate




Figure 3-32 MSH Break. HPIS-1 Mass Flow Rate




Figure 3-33 MSH Break. HPIS-2 Mass Flow Rate




Figure 3-34 MSH Break. HPIS-3 Mass Flow Rate




Figure 3-35 MSH Break. Break Mass Flow Rate




Figure 3-36 MSH Break. Maximal Cladding Temperature




Figure 3-37 MSH Break. Boric Acid Concentration in the Core

3.2 Loss of Turbine Condenser Vacuum

3.2.1 Brief Description of Initiating Event

This initiating event postulates loss of vacuum in the turbine condenser that leads to a trip of the turbine with closure of the stop valves and prohibition of operation of turbine bypass to the turbine condenser (BRU-K). According to the expected frequency of occurrence the initiating events is categorized as a postulated transient and leads to a decrease of heat removal by the secondary circuit.

3.2.2 Initial Conditions

The initial conditions selected for transient calculation correspond to those specified in Table 3-1.

3.2.3 Boundary Conditions

Assumptions on the systems availability that are considered in calculation of the transient are specified below.

The initiating event is modeled as closure of turbine stop valves (closure time is 0.5 s) with dependent failure of BRU-K.

No operator actions are simulated in the scenario.

Operation of ARM, RPL, PZ and UPZ to decrease reactor power is not considered. Reactor scram operates according to the design with a delay of 1.0 s from formation of actuation signal to a start of control rods drop. Maximal allowed time of control rods drop to the core (4 s) is assumed.

MFW pumps trip is postulated at the moment of turbine stop valves closure, operation of AFW pumps is not taken into account to prolong decrease of heat removal by the secondary circuit.

Operation of PRZ spray, as well as operation of the make-up and let-down system is also not taken into account.

3.2.4 Calculation Results

Sequence of events for this transient is presented in Table 3-3.

Table 3-3 Sequence of Events for Loss of Turbine Condenser Vacuum Transient

| TRACE Time, s | RELAP5 Time, s | Event | Description |
|----------------------|-----------------------|---|--|
| 0.0 | 0.0 | Start of turbine stop valves closure upon pressure increase in condenser. Prohibition for BRU-K operation | Due to loss of vacuum in a turbine condenser |
| 0.5 | 0.5 | Full closure of turbine stop valves. Trip of MFW pumps | Boundary conditions |
| 2.2 | 2.6 | Trip of PRZ heaters group no.1 | RCS pressure increase above 161 kgf/cm ² |
| 4.0 | 3.5 | Opening of steam dump valves to atmosphere (BRU-A). Start of BRU-A operation in pressure maintenance mode | Increase of SG pressure up to 73 kgf/cm ² |
| 6.0 | 5.8 | Reactor scram signal | Increase of SG pressure above 80 kgf/cm ² and time after RCP trip is less than 50 s |
| 10.0 | 8.0 | Opening of SG SRV Maximal secondary circuit pressure is reached (84.0 kgf/cm ² in TRACE calculation and 84.2 kgf/cm ² in RELAP5) | Increase of SG pressure above 84 kgf/cm ² |
| 10.0 | 13.5 | Maximal primary circuit pressure is reached (184.9 kgf/cm ² in TRACE calculation and 175.0 kgf/cm ² in RELAP5) | |
| 22.0 | 23.0 | Closure of SG SRV | Decrease of SG pressure below 70 kgf/cm ² |
| 30.0 | 40.0 | Start of PRZ heaters' groups operation | Switching on/off of PRZ heaters' groups according to design algorithm of RCS pressure maintenance |
| 50.0-60.0 | 50.0-60.0 | Trip of all RCPs Signal to close main control valves of MFW supply to individual SGs | Decrease of SG level for 500 mm below nominal (by wide range level meter) Due to trip of RCPs |
| 50.0 | 80.0 | Minimal RCS pressure is reached (143.0 kgf/cm ² in TRACE and 126 kgf/cm ² in RELAP5 calculation) | |
| 755.0 | 900.0 | Start of EFW supply to SG | Decrease of SG level below 1.35 m |
| 1750.0 | 1650.0 | Restoration of SG level | Due to EFW operation |
| 4000.0 | 4000.0 | End of calculation | Stabilization of main parameters |

Due to vacuum loss in the turbine condenser, a signal to close the turbine's stop valves is formed with a prohibition of BRU-K operation. At the moment of stop valves closure the MFW pumps trip is simulated (Figure 3-70). Fast termination of steam flow from SG causes increase of SG pressure (Figure 3-57 – Figure 3-60) with start of BRU-As operation in pressure maintenance mode (Figure 3-68), and initial (within first seconds of transient) increase in the primary circuit temperature (Figure 3-41 – Figure 3-48) and pressure (Figure 3-39). When SG pressure reaches 80 kgf/cm² the scram signal is formed and reactor power sharply decreases down to a decay heat (Figure 3-38). At 8.0 s in RELAP calculation and at 10.0 s in TRACE calculation the secondary circuit pressure increases up to 84 kgf/cm² that causes short-term opening of SG SRV (Figure 3-69).

Decrease of reactor power and heat removal by dumping steam via BRU-As causes decrease of RCS pressure and temperature until balance between heat generated by the reactor core and heat removed by the secondary circuit is established. Primary circuit pressure is maintained by periodic operation of PRZ heaters (Figure 3-54).

Due to trip of MFW pumps at the beginning of transient and postulated failure of AFW pumps the SG level gradually decreases (Figure 3-61 – Figure 3-64). Within 50–60 s of transient SG level decreases for 500 mm from the nominal value that causes actuation of signal to trip RCPs and termination of forced circulation of primary circuit coolant (Figure 3-49 – Figure 3-52). Further decrease of SG level down to 1.35 m leads to beginning of EFW supply to SGs at 900 s in RELAP calculation and 755 s in TRACE calculation.

At ~1500–1600 s SG level is restored by operation of EFW and within next 500–1000 s stabilization of the main primary and secondary circuit parameters occurs. The heat generated in the reactor core is removed in the natural circulation mode by the secondary circuit via dumping steam via BRU-As and SG feeding by EFW pumps from correspondent tanks. Calculation is terminated at 4000 s.

The maximal primary circuit pressure reached in calculation is 184.9/175.0 kgf/cm² (Figure 3-39) in RELAP and TRACE calculations, respectively. Maximal secondary pressure is 84.2/84.0 kgf/cm² (Figure 3-57 – Figure 3-60).

The plots of the main parameters of calculation are presented below on Figure 3-38 – Figure 3-73.




Figure 3-38 Loss of Turbine Condenser Vacuum. Core Thermal Power




Figure 3-39 Loss of Turbine Condenser Vacuum. RCS Pressure




Figure 3-40 Loss of Turbine Condenser Vacuum. Pressurizer Level




Figure 3-41 Loss of Turbine Condenser Vacuum. Coolant Temperature in Hot Leg, Loop 1




Figure 3-42 Loss of Turbine Condenser Vacuum. Coolant Temperature in Hot Leg, Loop 2




Figure 3-43 Loss of Turbine Condenser Vacuum. Coolant Temperature in Hot Leg, Loop 3




Figure 3-44 Loss of Turbine Condenser Vacuum. Coolant Temperature in Hot Leg, Loop 4




Figure 3-45 Loss of Turbine Condenser Vacuum. Coolant Temperature in Cold Leg, Loop 1




Figure 3-46 Loss of Turbine Condenser Vacuum. Coolant Temperature in Cold Leg, Loop 2




Figure 3-47 Loss of Turbine Condenser Vacuum. Coolant Temperature in Cold Leg, Loop 3




Figure 3-48 Loss of Turbine Condenser Vacuum. Coolant Temperature in Cold Leg, Loop 4




Figure 3-49 Loss of Turbine Condenser Vacuum. RCS Loop 1 Mass Flow Rate




Figure 3-50 Loss of Turbine Condenser Vacuum. RCS Loop 2 Mass Flow Rate




Figure 3-51 Loss of Turbine Condenser Vacuum. RCS Loop 3 Mass Flow Rate




Figure 3-52 Loss of Turbine Condenser Vacuum. RCS Loop 4 Mass Flow Rate




Figure 3-53 Loss of Turbine Condenser Vacuum. Make-Up and Let-Down Mass Flow




Figure 3-54 Loss of Turbine Condenser Vacuum. PRZ Heaters Power




Figure 3-55 Loss of Turbine Condenser Vacuum. PRZ Spray Mass Flow Rate




Figure 3-56 Loss of Turbine Condenser Vacuum. Core Reactivity




Figure 3-57 Loss of Turbine Condenser Vacuum. SG-1 Pressure




Figure 3-58 Loss of Turbine Condenser Vacuum. SG-2 Pressure




Figure 3-59 Loss of Turbine Condenser Vacuum. SG-3 Pressure




Figure 3-60 Loss of Turbine Condenser Vacuum. SG-4 Pressure




Figure 3-61 Loss of Turbine Condenser Vacuum. SG-1 Level (Wide Range)




Figure 3-62 Loss of Turbine Condenser Vacuum. SG-2 Level (Wide Range)




Figure 3-63 Loss of Turbine Condenser Vacuum. SG-3 Level (Wide Range)




Figure 3-64 Loss of Turbine Condenser Vacuum. SG-4 Level (Wide Range)




Figure 3-65 Loss of Turbine Condenser Vacuum. Mass Flow through MSIV




Figure 3-66 Loss of Turbine Condenser Vacuum. Turbine Mass Flow Rate




Figure 3-67 Loss of Turbine Condenser Vacuum. BRU-K Steam Mass Flow Rate




Figure 3-68 Loss of Turbine Condenser Vacuum. BRU-A Steam Mass Flow Rate




Figure 3-69 Loss of Turbine Condenser Vacuum. SG SRV Steam Mass Flow Rate




Figure 3-70 Loss of Turbine Condenser Vacuum. MFW Mass Flow Rate




Figure 3-71 Loss of Turbine Condenser Vacuum. AFW Mass Flow Rate




Figure 3-72 Loss of Turbine Condenser Vacuum. EFW Pumps Mass Flow Rate




Figure 3-73 Loss of Turbine Condenser Vacuum. Maximal Cladding Temperature

3.3 Trip of One RCP

3.3.1 Brief Description of Initiating Event

This initiating event assumes trip of 1 out of 4 operating RCPs. According to the expected frequency of occurrence the initiating events is categorized as transient and leads to a decrease of reactor coolant flow.

3.3.2 Initial Conditions

The initial conditions selected for transient calculation correspond to those specified in Table 3-1.

3.3.3 Boundary Conditions

Design operation of plant systems is taken into account.

RCP coast-down is performed according to the pump characteristics. Control of the reactor power is performed by ARM in neutron power maintenance mode and operation of RPL.

No operator actions are simulated in the scenario.

3.3.4 Calculation Results

Sequence of events for this transient is presented in Table 3-4.

Table 3-4 Sequence of Events for "Trip of One RCP" Transient

| TRACE Time, s | RELAP5 Time, s | Event | Description |
|---------------|----------------|---|-------------------------------|
| 0.0 | 0.0 | Trip of RCP-1 | IE occurrence |
| 0.0–89.0 | 0.0–90.0 | Formation of RPL signal to decrease reactor power until neutron power is lower than new power setpoint of 67% + 2%. | Due to trip of one out 4 RCPs |
| 42.0 | 41.5 | Flow reversal in RCS loop no.1 | Due to stoppage of RCP-1 |
| 95.0 | 100.0 | Start of ARM operation to maintain reactor power at 67% | |
| 110.0 | 125.0 | Minimal RCS pressure is 155.7 kgf/cm ² (TRACE) and 154.9 kgf/cm ² (RELAP5) | |
| 120.0 | 135.0 | Minimal PRZ level is 7.95/7.9 m | |
| 1000.0 | 1000.0 | End of calculation | |

Trip of one out of 4 operating RCPs results in a decrease of coolant flow through the reactor core and initial increase of RCS coolant temperature (Figure 3-77 – Figure 3-84). The allowed power setpoint is automatically changed by RPL from 102% to 69% and reactor power is decreased for 2% below the allowed value (Figure 3-74) by insertion of control rods to the reactor core with normal operation speed.

Due to decrease of coolant flow in loop no.1 (Figure 3-85) and decrease of energy transfer to the secondary circuit, SG-1 pressure decreases for the first 50 s of the transient (Figure 3-93). Until steam flow to the turbine is decreased (Figure 3-106) by partial closure of turbine's control valves an excessive steam flow (compared to new reactor power level) to the turbine causes decrease of RCS temperature (Figure 3-77 – Figure 3-84), RCS pressure (Figure 3-75) and PRZ level (Figure 3-76). The latter in turn leads to opening of make-up control valves (Figure 3-89) and switching on of the PRZ heaters groups (Figure 3-90) to restore PRZ level and primary circuit pressure.

Decrease of steam flow to the turbine results in a decrease of MFW flow (Figure 3-107). SG level (Figure 3-101 – Figure 3-104) is maintained at the nominal values by operation of MFW control valves.

The calculation is ended at 1000 s of transient close to the stabilization of all primary and secondary circuit parameters. At the end of calculation the heat generated in the reactor core at the reduced power level (~67%) is removed in forced circulation mode (with 3 RCPs in operation) by the secondary circuit with providing the steam produced in SGs to the turbine and SG feed by MFW pumps. In RCS loop no.1 the backward flow of coolant is established.

The plots of the main parameters of calculation are presented below on Figure 3-74 – Figure 3-109.




Figure 3-74 Trip of One RCP. Core Thermal Power




Figure 3-75 Trip of One RCP. RCS Pressure




Figure 3-76 Trip of One RCP. Pressurizer Level




Figure 3-77 Trip of One RCP. Coolant Temperature in Hot Leg, Loop 1




Figure 3-78 Trip of One RCP. Coolant Temperature in Hot Leg, Loop 2




Figure 3-79 Trip of One RCP. Coolant Temperature in Hot Leg, Loop 3




Figure 3-80 Trip of One RCP. Coolant Temperature in Hot Leg, Loop 4




Figure 3-81 Trip of One RCP. Coolant Temperature in Cold Leg, Loop 1




Figure 3-82 Trip of One RCP. Coolant Temperature in Cold Leg, Loop 2




Figure 3-83 Trip of One RCP. Coolant Temperature in Cold Leg, Loop 3




Figure 3-84 Trip of One RCP. Coolant Temperature in Cold Leg, Loop 4




Figure 3-85 Trip of One RCP. RCS Loop 1 Mass Flow Rate




Figure 3-86 Trip of One RCP. RCS Loop 2 Mass Flow Rate




Figure 3-87 Trip of One RCP. RCS Loop 3 Mass Flow Rate




Figure 3-88 Trip of One RCP. RCS Loop 4 Mass Flow Rate




Figure 3-89 Trip of One RCP. Make-Up and Let-Down Mass Flow




Figure 3-90 Trip of One RCP. PRZ Heaters Power




Figure 3-91 Trip of One RCP. PRZ Spray Mass Flow Rate




Figure 3-92 Trip of One RCP. Core Reactivity




Figure 3-93 Trip of One RCP. SG-1 Pressure




Figure 3-94 Trip of One RCP. SG-2 Pressure




Figure 3-95 Trip of One RCP. SG-3 Pressure




Figure 3-96 Trip of One RCP. SG-4 Pressure




Figure 3-97 Trip of One RCP. SG-1 Level (Wide Range)




Figure 3-98 Trip of One RCP. SG-2 Level (Wide Range)




Figure 3-99 Trip of One RCP. SG-3 Level (Wide Range)




Figure 3-100 Trip of One RCP. SG-4 Level (Wide Range)




Figure 3-101 Trip of One RCP. SG-1 Level (Narrow Range)




Figure 3-102 Trip of One RCP. SG-2 Level (Narrow Range)




Figure 3-103 Trip of One RCP. SG-3 Level (Narrow Range)




Figure 3-104 Trip of One RCP. SG-4 Level (Narrow Range)




Figure 3-105 Trip of One RCP. Mass Flow through MSIV




Figure 3-106 Trip of One RCP. Turbine Mass Flow Rate




Figure 3-107 Trip of One RCP. MFW Pumps Mass Flow Rate




Figure 3-108 Trip of One RCP. AFW Mass Flow Rate




Figure 3-109 Trip of One RCP. Maximal Cladding Temperature

3.4 Uncontrolled Withdrawal of Control Rods Group

3.4.1 Brief Description of Initiating Event

This initiating event assumes uncontrolled withdrawal of control group of control rods from the reactor core with a normal operating speed of 20 mm/s that can be caused by a malfunction of the reactor power control system. According to the expected frequency of occurrence the initiating events is categorized as a postulated transient that leads to an unintended increase of reactor power at the beginning of transient. The IE pertains to the IE group of anomalies in reactivity and power distribution in the reactor core.

3.4.2 Initial Conditions

The initial conditions selected for transient calculation correspond to those specified in Table 3-1.

3.4.3 Boundary Conditions

Assumptions on the systems availability that are considered in calculation of the transient are specified below.

No operator actions are simulated in the scenario.

Operation of ARM, RPL, PZ and UPZ to decrease power is not considered. Reactor scram occurs due to increase of neutron power to 107% taking into account +2% allowance for measurement error.

Loss of normal power supply is postulated at the time of reactor scram actuation. Postulated time delay for emergency diesel-generator (DG) start-up is 22 s.

3.4.4 Calculation Results

Sequence of events for this transient is presented in Table 3-5.

Table 3-5 Sequence of Events for "Uncontrolled Withdrawal of Control Rods Group" Transient

| TRACE Time, s | RELAP5 Time, s | Event | Description |
|---------------|----------------|--|---|
| 0.0 | 0.0 | Start of uncontrolled withdrawal of control group of control rods | |
| 20.0 | 17.0 | Start of PRZ spray valve YP13S02 opening | RCS pressure increase above 161 kgf/cm ² |
| 34.0 | 27.0 | Reactor scram | Reactor neutron power >107% +2% allowance for measurement error |
| | | Loss of normal power supply | Postulated condition |
| | | Turbine trip, trip of RCPs | Due to loss of normal power supply |
| | | Trip of MFW pumps | Postulated (after turbine trip) |
| 35.0 | 30.0 | Maximal RCS pressure is 161.5 kgf/cm ² (TRACE) and 165.5 kgf/cm ² (RELAP5) | |
| 35.0 | 30.0 | First peak of maximal cladding temperature (348°C in TRACE calculation and 345.2°C in RELAP5 calculation) | |
| 40.0 | 29.0 | BRU-A opening | Increase of pressure in correspondent steam line over 73+1 kgf/cm ² |
| 56.0 | 49.0 | DG start-up Start of sequential DG loading program (SLP) | Time delay for DG start-up is 22 s (postulated) |
| 74.0 | 75.0 | End of signal for opening of PRZ spray valve | Decrease of RCS pressure |
| 79.0 | 68.0 | Start of AFW supply to SG | Decrease of narrow range SG level below 0.22 m (after start-up of site emergency diesel-generators) |
| 220.0 | 251.0 | Second peak of maximal cladding temperature (316.5°C in TRACE calculation and 312.5°C in RELAP5 calculation) | |
| 1800.0 | 1800.0 | End of calculation | |

Uncontrolled withdrawal of the control group of control rods with a normal operating speed of 20 mm/s causes insertion of positive reactivity and thus, an initial increase of reactor power (Figure 3-110).

At 27.0/34.0 s (in RELAP and TRACE calculations, respectively), the reactor neutron power reaches 107.0+2% of the nominal value (Figure 3-110) that causes scram signal actuation. Increase of coolant temperature (Figure 3-113 – Figure 3-120) and RCS pressure (Figure 3-111) at the beginning of transient due to initial reactor power increase is quickly terminated after reactor scram, and RCS temperature and pressure decrease rapidly.

Simultaneously with reactor scram the loss of normal power supply is postulated that leads to a trip of RCPs (Figure 3-121 – Figure 3-124), closure of turbine stop valves (Figure 3-137), trip of MFW pumps (Figure 3-139) and formation of signal to start emergency DG (including additional site emergency DGs).

Closure of turbine's stop valves after the reactor scram causes sharp increase of the secondary circuit pressure (Figures 131–134). This causes actuation of BRU-A in pressure maintenance mode (Figure 3-138) that automatically decrease the secondary circuit pressure according to a design algorithm. After start-up of additional site emergency DGs, AFW pumps are started at 68/79 s of transient restoring FW supply to SGs (Figure 3-140).

Decrease of primary coolant temperature (Figure 3-113 – Figure 3-120) within first 100 s of transient and correspondent coolant shrinkage result in a decrease of PRZ level (Figure 3-112), which is gradually restored by operation of PRZ level controllers that adjust make-up and let-down flow (Figure 3-125).

Within 1800 s of transient all primary and secondary circuit parameters are close to stabilization. The decay heat is removed in natural circulation mode by the secondary circuit via BRU-A and AFW pumps operation.

The plots of the main parameters of calculation are presented below on Figure 3-110 – Figure 3-141.




Figure 3-110 Uncontrolled Withdrawal of CR Group. Core Thermal Power




Figure 3-111 Uncontrolled Withdrawal of CR Group. RCS Pressure




Figure 3-112 Uncontrolled Withdrawal of CR Group. Pressurizer Level




Figure 3-113 Uncontrolled Withdrawal of CR Group. Coolant Temperature in Hot Leg, Loop 1




Figure 3-114 Uncontrolled Withdrawal of CR Group. Coolant Temperature in Hot Leg, Loop 2




Figure 3-115 Uncontrolled Withdrawal of CR Group. Coolant Temperature in Hot Leg, Loop 3




Figure 3-116 Uncontrolled Withdrawal of CR Group. Coolant Temperature in Hot Leg, Loop 4




Figure 3-117 Uncontrolled Withdrawal of CR Group. Coolant Temperature in Cold Leg, Loop 1




Figure 3-118 Uncontrolled Withdrawal of CR Group. Coolant Temperature in Cold Leg, Loop 2




Figure 3-119 Uncontrolled Withdrawal of CR Group. Coolant Temperature in Cold Leg, Loop 3




Figure 3-120 Uncontrolled Withdrawal of CR Group. Coolant Temperature in Cold Leg, Loop 4




Figure 3-121 Uncontrolled Withdrawal of CR Group. RCS Loop 1 Mass Flow Rate




Figure 3-122 Uncontrolled Withdrawal of CR Group. RCS Loop 2 Mass Flow Rate




Figure 3-123 Uncontrolled Withdrawal of CR Group. RCS Loop 3 Mass Flow Rate




Figure 3-124 Uncontrolled Withdrawal of CR Group. RCS Loop 4 Mass Flow Rate




Figure 3-125 Uncontrolled Withdrawal of CR Group. Make-Up and Let-Down Mass Flow




Figure 3-126 Uncontrolled Withdrawal of CR Group. PRZ Heaters Power




Figure 3-127 Uncontrolled Withdrawal of CR Group. PRZ Spray Mass Flow Rate




Figure 3-128 Uncontrolled Withdrawal of CR Group. SG-1 Pressure




Figure 3-129 Uncontrolled Withdrawal of CR Group. SG-2 Pressure




Figure 3-130 Uncontrolled Withdrawal of CR Group. SG-3 Pressure




Figure 3-131 Uncontrolled Withdrawal of CR Group. SG-4 Pressure




Figure 3-132 Uncontrolled Withdrawal of CR Group. SG-1 Level (Wide Range)




Figure 3-133 Uncontrolled Withdrawal of CR Group. SG-2 Level (Wide Range)




Figure 3-134 Uncontrolled Withdrawal of CR Group. SG-3 Level (Wide Range)




Figure 3-135 Uncontrolled Withdrawal of CR Group. SG-4 Level (Wide Range)




Figure 3-136 Uncontrolled Withdrawal of CR Group. Mass Flow through MSIV




Figure 3-137 Uncontrolled Withdrawal of CR Group. Turbines Mass Flow Rate




Figure 3-138 Uncontrolled Withdrawal of CR Group. BRU-A Steam Mass Flow Rate




Figure 3-139 Uncontrolled Withdrawal of CR Group. MFW Pumps Mass Flow Rate




Figure 3-140 Uncontrolled Withdrawal of CR Group. AFW Mass Flow Rate




Figure 3-141 Uncontrolled Withdrawal of CR Group. Maximal Cladding Temperature

3.5 PRZ Surge Line Break

3.5.1 Brief Description of Initiating Event

This initiating event assumes break of surge line with equivalent diameter of 350 mm connecting hot leg of RCS loop no.4 with PRZ. According to the expected frequency of occurrence the initiating events is categorized as a design basis accident and pertains to loss of coolant accidents (LOCA) IE group.

3.5.2 Initial Conditions

The initial conditions selected for calculation of this accident correspond to those specified in Table 3-1.

3.5.3 Boundary Conditions

Assumptions on the systems availability that are considered in calculation of the accident are specified below.

Operator actions are not modeled.

Operation of ARM, RPL, PZ-2, PZ-3, and UPZ is not taken into account. Reactor scram operates according to the design with a delay of 0.3 s from formation of actuation signal to a start of control rods drop. Maximal allowed time of control rods drop to the core (4 s) is assumed.

Simultaneously with formation of reactor scram signal the loss of normal power supply is postulated resulting in a trip of RCPs, turbine and MFW pumps.

Operation of primary circuit make-up and let-down is not taken into account.

3.5.4 Calculation Results

Sequence of events for this accident are presented in Table 3-6.

Table 3-6 Sequence of Events for PRZ Surge Line Break Accident

| TRACE Time, s | RELAP5 Time, s | Event | Description |
|----------------------|-----------------------|---|---|
| 0.0 | 0.0 | PRZ surge line break (LOCA with equivalent diameter of 350 mm) | IE occurrence |
| 0.4 | 0.8 | Reactor scram actuation Loss of normal power supply | RCS pressure decrease below 148.0 kgf/cm ² at the reactor power greater than 75% |
| | | RCP trip, start of RCS coast-down Trip of turbine and MFW pumps | Postulated loss of normal power supply |
| 2.4 | 2.8 | ECCS safeguard actuation, signal to start emergency DG | Postulated loss of normal power supply + 2 s delay |
| 6.0 | 5.9 | Signal to open BRU-A | Pressure increase in relevant MSL over 73 kgf/cm ² |
| 24.4 | 24.8 | Start of emergency DG sequential loading program, HPIS and LPIS pumps start | 22 s delay for DG start-up after ECCS safeguard actuation |
| 42.4 | 42.8 | Start of HPIS injection to the primary circuit | SLP (after DG start-up) + transportation delay of 18 s |
| 45.0 | 43.0 | BRU-A closure | Pressure decrease in relevant MSL below 68 kgf/cm ² |
| 50.0 | 65.0 | Start of ECCS HA injection to the reactor | Decrease of RCS pressure below 60.0 kgf/cm ² |
| 95.0 | 145.0 | Start of stable LPIS injection to RCS | RCS pressure decrease below LPIS pump shut-off head |
| 350.0 | 260.0 | End of ECCS HA injection | HA depletion |
| 1200.0 | 1200.0 | End of calculation | Stable core cooling, stabilization of the main reactor parameters |

Break of PRZ surge line with equivalent diameter of 350 mm results in large break LOCA that causes fast decrease of RCS pressure (Figure 3-143) and PRZ level (Figure 3-144). After IE occurrence, due to RCS pressure decrease down to 148.0 kgf/cm² at the reactor power greater than 75%, a scram signal is generated at 0.22/0.26 s (in RELAP5 and TRACE calculations, respectively), and core thermal power is quickly reduced to the decay heat level (Figure 3-142).

Postulated loss of normal power supply results in a trip of the equipment powered from correspondent busbars, namely, RCP, PRZ heaters, BRU-K, and causes actuation of ECCS safeguard with a start of emergency DG. Turbine trip causes temporary increase of SG pressure (Figure 3-160 – Figure 3-163) with a maximal value of 77.5/74.2 kgf/cm² reached at

8/9 s. At 5.9/6.0 s after IE occurrence BRU-A actuation setpoints (increase of pressure in correspondent MSL over 73 kgf/cm²) are reached (Figure 3-169). Their operation and intensive energy loss via the break (and, consequently, cooling of SG by the primary circuit) result in a decrease of SG pressure below 68 kgf/cm² and closure of all BRU-As at 43/45 s of accident.

Nearly at the same time (at 65/50 s of accident) RCS pressure decreases below 60 kgf/cm² and HA injection to the reactor begins and continues to their depletion at 260/350 s (Figure 3-177 – Figure 3-180).

22 s after start of DG (delay for DG start-up) the sequential loading program is actuated with connection of equipment to emergency power supply busbars according to a design algorithm, and at 42.8/42.4 s after IE occurrence (with postulated 18 s delay for HPIS pump start-up and transport) HPIS starts to inject boric acid to the primary circuit (Figure 3-171 – Figure 3-173).

At 145.0/95.0 s of the accident RCS pressure decreases below LPIS pump shut-off head and LPIS injection to the primary circuit is started (Figure 3-174 – Figure 3-176). Combined operation of HPIS and LPIS pumps compensates coolant loss via the break and to 1000 s of calculation the majority of the primary and secondary circuit parameters are stabilized. Decay heat removal is provided by heat-up of the cold coolant injected by LPIS and HPIS, and energy loss via a break. Secondary circuit pressure decreases due to SG cooling down by the primary circuit.

During the accident, a stable decrease of the maximal cladding temperature from the initial value at normal power operation to ~100 °C is observed (Figure 3-181).

The calculation is ended at 1200 s of accident.

The plots of the main parameters of calculation are presented below on Figure 3-142 – Figure 3-183.




Figure 3-142 PRZ Surge Line Break. Core Thermal Power




Figure 3-143 PRZ Surge Line Break. RCS Pressure




Figure 3-144 PRZ Surge Line Break. Pressurizer Level




Figure 3-145 PRZ Surge Line Break. Coolant Temperature in Hot Leg, Loop 1




Figure 3-146 PRZ Surge Line Break. Coolant Temperature in Hot Leg, Loop 2




Figure 3-147 PRZ Surge Line Break. Coolant Temperature in Hot Leg, Loop 3




Figure 3-148 PRZ Surge Line Break. Coolant Temperature in Hot Leg, Loop 4




Figure 3-149 PRZ Surge Line Break. Coolant Temperature in Cold Leg, Loop 1




Figure 3-150 PRZ Surge Line Break. Coolant Temperature in Cold Leg, Loop 2




Figure 3-151 PRZ Surge Line Break. Coolant Temperature in Cold Leg, Loop 3




Figure 3-152 PRZ Surge Line Break. Coolant Temperature in Cold Leg, Loop 4




Figure 3-153 PRZ Surge Line Break. RCS Loop 1 Mass Flow Rate




Figure 3-154 PRZ Surge Line Break. RCS Loop 2 Mass Flow Rate




Figure 3-155 PRZ Surge Line Break. RCS Loop 3 Mass Flow Rate




Figure 3-156 PRZ Surge Line Break. RCS Loop 4 Mass Flow Rate




Figure 3-157 PRZ Surge Line Break. Make-Up and Let-Down Mass Flow




Figure 3-158 PRZ Surge Line Break. PRZ Heaters Power




Figure 3-159 PRZ Surge Line Break. Core Reactivity




Figure 3-160 PRZ Surge Line Break. SG-1 Pressure




Figure 3-161 PRZ Surge Line Break. SG-2 Pressure




Figure 3-162 PRZ Surge Line Break. SG-3 Pressure




Figure 3-163 PRZ Surge Line Break. SG-4 Pressure




Figure 3-164 PRZ Surge Line Break. SG-1 Level (Wide Range)




Figure 3-165 PRZ Surge Line Break. SG-2 Level (Wide Range)




Figure 3-166 PRZ Surge Line Break. SG-3 Level (Wide Range)




Figure 3-167 PRZ Surge Line Break. SG-4 Level (Wide Range)




Figure 3-168 PRZ Surge Line Break. Turbines Mass Flow Rate




Figure 3-169 PRZ Surge Line Break. BRU-A Steam Mass Flow Rate




Figure 3-170 PRZ Surge Line Break. MFW Pumps Mass Flow Rate




Figure 3-171 PRZ Surge Line Break. HPIS-1 Mass Flow Rate




Figure 3-172 PRZ Surge Line Break. HPIS-2 Mass Flow Rate




Figure 3-173 PRZ Surge Line Break. HPIS-3 Mass Flow Rate




Figure 3-174 PRZ Surge Line Break. LPIS-1 Mass Flow Rate




Figure 3-175 PRZ Surge Line Break. LPIS-2 Mass Flow Rate




Figure 3-176 PRZ Surge Line Break. LPIS-3 Mass Flow Rate




Figure 3-177 PRZ Surge Line Break. HA-1 Mass Flow Rate




Figure 3-178 PRZ Surge Line Break. HA-2 Mass Flow Rate




Figure 3-179 PRZ Surge Line Break. HA-3 Mass Flow Rate




Figure 3-180 PRZ Surge Line Break. HA-4 Mass Flow Rate




Figure 3-181 PRZ Surge Line Break. Maximal Cladding Temperature




Figure 3-182 PRZ Surge Line Break. Break Mass Flow Rate




Figure 3-183 PRZ Surge Line Break. Boric Acid Concentration in the Core

3.6 Inadvertent Opening of SG SRV in Hot Shutdown

3.6.1 Brief Description of Incident

The incident occurred at Khmelnitsky NPP unit 1 on August 07, 1999, with the reactor in "hot shutdown" state during planned unit start-up after refueling. According to the incident evaluation report [4] at 11:46 the inadvertent opening of SG-1 SRV TX50S04 occurred that resulted in actuation of "MSL break" safeguard (Pressure decrease in any MSL below 50 kgf/cm² at increase of difference between saturation temperatures of primary and secondary circuit over 75°C at RCS temperature >200°C) with closure of MSIV at MSL-1 and automatic start of safety systems. Actuation of safeguards "Backward pressure difference across MSL check valve > 2.0 kgf/cm²" in MSL-1,2,4 caused a trip of RCP-1,2,4.

Four minutes after the incident occurrence the SG-1 SRV was closed by operator and in next 5 minutes the automatically started safety systems were switched off. According to a description in [4], at 12:10 (at 12:04 according to plots in [4]) the operators restarted RCP-1,2,4 that caused restoration and stabilization of the primary and secondary circuit parameters.

It shall be noted that according to incident evaluation report [4] actuation of "MSL break" safeguard also caused isolation of SG-1 feedwater pipelines, however provided plots and simulation results do not allow to confirm this statement.

3.6.2 Initial Conditions

The initial conditions selected for the calculation of incident are presented in Table 3-7.

Table 3-7 Initial Conditions for Calculation of "Inadvertent Opening of SG SRV in Hot Shutdown" Incident

| Parameter | Units | Reported value [4] | Calculated value |
|---------------------------------------|---------------------|---|------------------|
| Core thermal power | MWt | – | 1.65 |
| Reactor outlet pressure | kgf/cm ² | 160.0 | 159.8 |
| Coolant temperature at reactor outlet | °C | 278.0 | 278.0 |
| Reactor coolant flow rate | m ³ /h | 84800 ⁺⁴⁰⁰⁰ ₋₄₈₀₀ | 84350 |
| PRZ level | m | 5.78±0.150 | 5.78 |
| SG pressure | kgf/cm ² | 63...64 | 63.5 |
| SG level (narrow range gauge) | m | 0.300±0.05 | 0.305...0.315 |

3.6.3 Boundary Conditions

Assumptions on the systems availability that are considered in calculation of the incident are specified below.

As an initiating event an inadvertent opening of SG-1 SRV is postulated at 0 s of calculation. Closure of the SRV is performed manually at 215 s. Actuation of the safeguards is simulated according to a design, except isolation of feedwater supply to SG-1, i.e. MFW control and cut-off valves to SG-1 remain open.

Trip of RCP-1, 2, 4 occurs after actuation of safeguard "Backward pressure difference across MSL check valve $> 2.0 \text{ kgf/cm}^2$ ". RCP-3 remains in operation (failure of above mentioned safeguard for MSL-3 is postulated). At 1080 s of incident restart of RCP-1, 2, 4 by operator is simulated.

3.6.4 Calculation Results

Sequence of events for this incident are presented in Table 3-8.

Table 3-8 Sequence of Events for "Inadvertent Opening of SG SRV in Hot Shutdown" Incident

| TRACE Time, s | NPP data Time, s | Event | Description |
|---------------|------------------|-----------------------------------|---|
| 0 | 0 | Opening of SG-1 SRV | IE occurrence |
| 5 | N/A | RCP-1 trip | Backward pressure difference across MSL-1 check valve > 2.0 kgf/cm ² |
| 33 | N/A | Automatic start of safety systems | Pressure decrease in any MSL below 50 kgf/cm ² at increase of difference between saturation temperatures of primary and secondary circuit over 75°C and RCS temperature >200°C |
| | | Closure of MSIV at MSL-1 | MSL-1 break safeguard actuation |
| 100 | N/A | RCP-4 trip | Backward pressure difference across MSL-4 check valve > 2.0 kgf/cm ² |
| 190 | N/A | RCP-2 trip | Backward pressure difference across MSL-2 check valve > 2.0 kgf/cm ² |
| 200 | N/A | PRZ heaters are switched off | Decrease of PRZ level below 4.2 m |
| 215 | 215 | Closure of SG-1 SRV | Operator action |
| | | Minimal SG-1 pressure is reached | 27.8 kgf/cm ² in TRACE calculation and 26.2 kgf/cm ² according to NPP data |
| 240 | 250 | Minimal RCS pressure is reached | 150.1 kgf/cm ² in TRACE calculation and 151.9 kgf/cm ² according to NPP data |
| 435 | N/A | PRZ heaters are switched on | Increase of PRZ level below 4.2 m and RCS pressure is below actuation setpoints |
| 570 | N/A | Closure of MSIV at MSL-2 | MSL-2 break safeguard actuation |
| 605 | N/A | Closure of MSIV at MSL-4 | MSL-4 break safeguard actuation |
| 637 | N/A | Closure of MSIV at MSL-3 | MSL-3 break safeguard actuation |
| 645 | N/A | PRZ heaters are switched off | Increase of RCS pressure above the setpoints |
| 1080 | 1080 | Restart of RCP-1,2,4 | Operator action |
| | | Maximal RCS pressure is reached | 168 kgf/cm ² in TRACE calculation and 169 kgf/cm ² according to NPP data |
| 1100 | N/A | PRZ heaters are switched on | Increase of PRZ level below 4.2 m and RCS pressure is below actuation setpoints |
| 1320 | N/A | PRZ heaters are switched off | Increase of RCS pressure above the setpoints |
| 1800 | 1800 | End of calculation | Stabilization of the main reactor parameters |

Note: N/A means that exact timing of the event is not specified in the incident evaluation report [4]

Opening of SG-1 SRV causes loss of secondary circuit coolant and rapid decrease of SG-1 pressure (Figure 3-192). Due to increase of backward pressure across MSL-1 check valve greater than 2 kgf/cm^2 the signal to trip RCP-1 is formed (Figure 3-189). At 33 s of incident the "MSL-1 break" (Pressure decrease in any MSL below 50 kgf/cm^2 at increase of difference between saturation temperatures of primary and secondary circuit over 75°C and RCS temperature $>200^\circ\text{C}$) is actuated with closure of MSIV at MSL-1 and automatic start of safety systems. Continued loss of secondary circuit coolant from SG-1 causes cool-down of the primary circuit and decrease of RCS pressure (Figure 3-185) and temperature (Figure 3-187, Figure 3-188). This in turn results in a decrease of PRZ level due to coolant shrinkage (Figure 3-186) and decrease of pressure in SG-2, 3, 4 (Figure 3-193 – Figure 3-195). The latter causes sequential (within first 190 s of accident) actuation of safeguards "Increase of backward pressure across MSL check valve greater than 2 kgf/cm^2 " to trip RCPs at other RCS loops (Figure 3-189) with the exception of loop no.3, where failure of actuation of correspondent safeguard is postulated.

At 200 s the PRZ level decreases below 4.2 m (Figure 3-186) with prohibition for PRZ heaters operation and PRZ heaters are switched off till PRZ level is restored at 435 s (Figure 3-191).

At 215 s the loss of secondary circuit coolant is terminated by manual closure of failed SG-1 SRV and SG-1 pressure (Figure 3-192), as well as RCS temperature (Figure 3-187, Figure 3-188) and pressure (Figure 3-185) start to recover. The minimal RCS pressure is 150.1 kgf/cm^2 according to TRACE calculation and 151.9 kgf/cm^2 according to NPP data plots in [4], and minimal SG-1 pressure reached is 27.8 kgf/cm^2 and 26.2 kgf/cm^2 , respectively.

Since RCS temperature remains lower than the secondary coolant temperature in SG-2,3,4, pressure in these SGs gradually decreases and after actuation of "MSL break" signals for these SGs, MSIVs at the correspondent steam lines are closed at 570–637 s of incident.

At 1080 s operator restarts RCP-1,2,4 (Figure 3-189). Operation of RCP-1 improves flow to PRZ spray and RCS pressure rapidly decreases (Figure 3-185). After temporary operation of PRZ heaters (Figure 3-191) at 1100–1320 s the RCS pressure is stabilized close to the nominal value.

The calculation is ended at 1800 s after stabilization of the main parameters of primary and secondary circuit. At the end of calculation the PRZ level slowly recovers (Figure 3-186) due to operation of primary circuit make-up (Figure 3-190).

The plots of the main parameters of calculation are presented below on Figure 3-184 – Figure 3-200.




Figure 3-184 Inadvertent Opening of SG SRV in Hot Shutdown. Core Thermal Power




Figure 3-185 Inadvertent Opening of SG SRV in Hot Shutdown. RCS Pressure




Figure 3-186 Inadvertent Opening of SG SRV in Hot Shutdown. Pressurizer Level




Figure 3-187 Inadvertent Opening of SG SRV in Hot Shutdown. Coolant Temperature in Hot Legs




Figure 3-188 Inadvertent Opening of SG SRV in Hot Shutdown. Coolant Temperature in Cold Legs




Figure 3-189 Inadvertent Opening of SG SRV in Hot Shutdown. RCS Loops Mass Flow Rate




Figure 3-192 Inadvertent Opening of SG SRV in Hot Shutdown. SG-1 Pressure




Figure 3-193 Inadvertent Opening of SG SRV in Hot Shutdown. SG-2 Pressure




Figure 3-194 Inadvertent Opening of SG SRV in Hot Shutdown. SG-3 Pressure




Figure 3-195 Inadvertent Opening of SG SRV in Hot Shutdown. SG-4 Pressure




Figure 3-196 Inadvertent Opening of SG SRV in Hot Shutdown. SG-1 Level (Wide Range)




Figure 3-197 Inadvertent Opening of SG SRV in Hot Shutdown. SG-2 Level (Wide Range)




Figure 3-198 Inadvertent Opening of SG SRV in Hot Shutdown. SG-3 Level (Wide Range)




Figure 3-199 Inadvertent Opening of SG SRV in Hot Shutdown. SG-4 Level (Wide Range)




Figure 3-200 Inadvertent Opening of SG SRV in Hot Shutdown. AFW Mass Flow Rate

4 CONCLUSIONS

After validation of VVER-1000/V-320 thermal-hydraulic model for TRACE code by simulating several operational events that had occurred at Ukrainian NPPs, the validation effort was extended by calculations of 5 DBA scenarios and comparing the results obtained with this model and correspondent RELAP5/Mod3.2 model. Both TRACE and RELAP5 models applied for these calculations are nearly identical with respect to model scope, nodalization, components geometry and equipment characteristics.

Comparison of the results obtained with TRACE and RELAP5 models indicates some differences in calculated parameters. Nevertheless, these differences do not affect significantly the overall behavior of the main parameters of the primary and secondary circuit and the sequence of events in the analyzed scenarios, and quantitatively the values are in a good agreement.

Additionally, the plant incident with inadvertent opening of steam generator safety relief valve with the reactor in hot shutdown state was simulated with the TRACE code. The results obtained in this calculation are in a good agreement with plant measured data.

The results of cross-code validation calculations and simulation of plant incidents demonstrate that developed VVER-1000/V-320 thermal-hydraulic model for TRACE code is able to reproduce adequately the NPP response to transients and accidents without core melt. For the majority of plant parameters good correspondence between TRACE and RELAP5 results or plant incidents data is obtained.

Based on the results of model validation it can be concluded that developed VVER-1000/V-320 thermal hydraulic model for TRACE computer code can be used for calculations of transients and accidents in support of regulatory review of safety analyses documentation.

5 REFERENCES

- [1] TRACE V5.840. User's Manual. Volume 1: Input Specification. Division of Safety Analysis, Office of Nuclear Regulatory Research, U. S. Nuclear Regulatory Commission, Washington, DC 20555-000.
- [2] TRACE V5.840. User's Manual. Volume 2: Modeling Guidelines. Division of Safety Analysis, Office of Nuclear Regulatory Research, U. S. Nuclear Regulatory Commission, Washington, DC 20555-001.
- [3] NUREG/IA-0490. TRACE VVER-1000/V-320 Model Validation. International Agreement Report, 2018.
- [4] 1KhME-P07-05-08-99. Khmel'nitsky NPP. Incident evaluation report. Inadvertent opening of SG-1 SRV TX50S04, 1999.

BIBLIOGRAPHIC DATA SHEET

(See instructions on the reverse)

NUREG/IA-0525

2. TITLE AND SUBTITLE

TRACE VVER-1000/V-320 Model Cross-Code Validation

3. DATE REPORT PUBLISHED

MONTH

YEAR

August

2021

4. FIN OR GRANT NUMBER

5. AUTHOR(S)

S. Iegan*, Y. Vorobyov**, O. Zhabin**, S. Yanovskiy**

6. TYPE OF REPORT

Technical

7. PERIOD COVERED (Inclusive Dates)

8. PERFORMING ORGANIZATION - NAME AND ADDRESS (If NRC, provide Division, Office or Region, U. S. Nuclear Regulatory Commission, and mailing address; if contractor, provide name and mailing address.)

*State Nuclear Regulatory Inspectorate of Ukraine, 9/11 Arsenalna Str., 01011 Kyiv, Ukraine

**State Scientific and Technical Center for Nuclear and Radiation Safety of Ukraine, 35-37 V. Stusa Str., 03142 Kyiv, Ukraine

9. SPONSORING ORGANIZATION - NAME AND ADDRESS (If NRC, type "Same as above", if contractor, provide NRC Division, Office or Region, U. S. Nuclear Regulatory Commission, and mailing address.)

Division of Systems Analysis
Office of Nuclear Regulatory Research
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555-0001

10. SUPPLEMENTARY NOTES

K.Tien, NRC Project Manager

11. ABSTRACT (200 words or less)

This report is developed by the State Nuclear Regulatory Inspectorate of Ukraine (SNRIU) and its technical support organization, the State Scientific and Technical Center for Nuclear and Radiation Safety of Ukraine (SSTC NRS), under Implementing Agreement On Thermal-Hydraulic Code Applications And Maintenance Between The United States Nuclear Regulatory Commission and State Nuclear Regulatory Inspectorate of Ukraine (signed in 2014) in accordance with Article III, Section C, of the Agreement. The report provides results of the comparison calculations conducted with application of SSTC NRS model of VVER-1000/V-320 for TRACE and RELAP5 computer codes. The calculation scenarios analyzed include design basis accidents and transients from several initiating event groups usually evaluated in safety analysis reports. Additionally, the plant incident with inadvertent opening of steam generator safety relief valve in hot shutdown is simulated.

12. KEY WORDS/DESCRIPTORS (List words or phrases that will assist researchers in locating the report.)

Accident Analysis, Pressurized Water Reactor, WWER-1000/V-320, RELAP5, TRACE, Comparative Calculations, Validation

13. AVAILABILITY STATEMENT

unlimited

14. SECURITY CLASSIFICATION

(This Page)

unclassified

(This Report)

unclassified

15. NUMBER OF PAGES

16. PRICE



Federal Recycling Program



**UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, DC 20555-0001**

OFFICIAL BUSINESS



@NRCgov

NUREG/IA-0525

TRACE VVER-1000/V-320 Model Cross-Code Validation

August 2021