

August 19, 2021

PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE - PNO-IV-21-001A

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information is as initially received without verification or evaluation, and is basically all that is known by the Region IV, Arlington, Texas staff on this date.

Facility

Union Electric Company
Callaway Plant
P.O. Box 620
Fulton, MO 65251
Docket: 50-483
License No. NPF-30

Licensee Emergency Classification

Notification of Unusual Event
 Alert
 Site Area Emergency
 General Emergency
 Not Applicable

SUBJECT: UPDATE -CALLAWAY RESTART FOLLOWING PLANT AUTOMATIC REACTOR TRIP DUE TO MAIN GENERATOR FAULT AND SHUTDOWN GREATER THAN 72 HOURS

DESCRIPTION:

Callaway Plant was restarted on August 2, 2021. Callaway plant had been shut down since December 24, 2020 due to an automatic reactor trip from 90 percent power because of a problem with the main generator, a non-safety system.

The licensee made repairs to the main generator. Plant operators commenced a reactor startup and the reactor was made critical on August 2, 2021. The unit was synchronized to the electrical grid on August 4, 2021, and reached full power on August 8, 2021, and remains at full power. The resident inspectors and one additional inspector were on site and monitored portions of the repair and startup activities.

On August 9, 2021, the licensee issued a press release to inform the public that the Callaway Plant outage was complete, and the plant was returned to full power.

The State of Missouri has been notified.

The information presented herein has been discussed with the licensee and is current as of August 11, 2021 at 3:37 pm.

ADAMS ACCESSION NUMBER: ML21231A149

CONTACTS: Neil O'Keefe
(817) 200-1141
Neil.O'Keefe@nrc.gov