



Joseph A. Dullinger  
Plant Manager

Calvert Cliffs Nuclear Power Plant  
1650 Calvert Cliffs Parkway  
Lusby, MD 20657  
410-495-5205 Office  
717-309-2403 Mobile  
www.exeloncorp.com  
joseph.dullinger@exeloncorp.com

10 CFR 50.73

September 23, 2021

U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, DC 20555

Calvert Cliffs Nuclear Power Plant, Unit No. 2  
Renewed Facility Operating License Nos. DPR-69  
NRC Docket No. 50-318

Subject: **Licensee Event Report 318-2021-003, Revision 00**  
**Auxiliary Feedwater Pump Inoperable Due to Improper Reset of Trip Throttle Valve**

The attached report is being sent to you as required by 10 CFR 50.73.

There are no regulatory commitments contained in this correspondence.

Should you have questions regarding this report, please contact Mr. Larry D. Smith at (410) 495-5219.

Respectfully,

A handwritten signature in black ink, appearing to read "JAD", written over the printed name of Joseph A. Dullinger.

Joseph A. Dullinger  
Plant Manager

JAD/ALS/Imd

Attachment: As stated

cc: NRC Project Manager, Calvert Cliffs  
NRC Regional Administrator, Region I

NRC Resident Inspector, Calvert Cliffs  
S. Seaman, DNR

bcc: D. M. Reddick  
D. P. Helker  
F. J. Mascitelli  
T. P. Haaf  
J. A. Dullinger  
C. J. Jackson  
H. M. Crockett  
D. J. Hild  
L. D. Smith  
A. L. Simpson  
L. M. Day (AIT No. IR04439901-12)  
EDMS

318/2021-003