



September 27, 2021

10 CFR 50.90
Docket No. 50-443
SBK-L-21105

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555-0001

Seabrook Station

Withdrawal of Emergency License Amendment Request 21-02, Service Water System / Ultimate Heat Sink One-Time Allowed Outage Time (AOT) Extension

References:

1. NextEra Energy Seabrook, LLC letter SBK-L-21103, "Request for Exercise of Enforcement Discretion," September 25, 2021 (ML21268A003).
2. NextEra Energy Seabrook, LLC letter SBK-L-21104, "Emergency License Amendment Request 21-02, Service Water System / Ultimate Heat Sink One-Time Allowed Outage Time (AOT) Extension," September 25, 2021 (ML21268A004).


In Reference 1, NextEra Energy Seabrook, LLC (NextEra) submitted a written request for approval of enforcement discretion, as discussed verbally between NextEra and the Nuclear Regulatory Committee (NRC) staff on September 23, 2021. During the call, NextEra verbally requested enforcement discretion pertaining to Technical Specification (TS) 3.7.4, "Service Water System / Ultimate Heat Sink." That request was to allow delaying taking actions specified within the Technical Specifications, and to provide additional time to process an Emergency License Amendment Request (LAR). The period of enforcement discretion requested was five days. In Reference 2, NextEra submitted an Emergency LAR that would modify TS 3.7.4 ACTION b, by extending the Allowed Outage Time (AOT) on a one-time basis for a Service Water (SW) system cooling tower cell from seven days to sixteen days.

Based upon subsequent repair efforts on SW cooling tower fan 51B (1-SW-FN-51B), a 24-hour endurance run, and declaration of operability prior to the expiration of the 5-day enforcement discretion period, NextEra hereby withdraws emergency LAR 21-02.

Should you have any questions regarding this information, please contact Matthew Levander, Licensing Manager, at (603) 773-7631.

Sincerely,

NextEra Energy Seabrook, LLC



Brian Booth
Site Vice President (SVP) – Seabrook Nuclear Power Station
NextEra Energy Seabrook, LLC

cc

NRC Region I Administrator
NRC Project Manager
NRC Senior Resident Inspector

Director Homeland Security and Emergency Management
New Hampshire Department of Safety
Division of Homeland Security and Emergency Management
Bureau of Emergency Management
33 Hazen Drive
Concord, NH 03305

Katharine Cederberg, Lead Nuclear Planner
The Commonwealth of Massachusetts
Emergency Management Agency
400 Worcester Road
Framingham, MA 01702-5399