

Inputs to Calculation

Irrigation rate	0.19 m ³ /y
Household water use family of 4	328.7 m ³ /y
meat and dairy cow water ingestion (1 dairy, 1 meat)	110 L/d
Drinking Water per person	478 l/y

Well Pumping Rate

	No Irrigation, No Garden, No Livestock	Irrigation of 22,000 m²	Irrigation of 40,000 m²
Household Water Use (m ³ /yr)	328.7	328.7	328.7
Meat and Dairy Cow (m ³ /yr)	0.0	40.2	40.2
Irrigation (m ³ /yr)	0.0	4180.0	7600.0
Drinking Water (family of 4) (m ³ /yr)	1.9	1.9	1.9
Well Pumping Rate (m ³ /yr)	330.6	4550.8	7970.8

Non Radionuclide Specific	25th	50th	75th
Cover erosion rate	7.59E-04	1.49E-03	2.92E-03
Contaminated zone erosion rate	7.59E-04	1.49E-03	2.92E-03
Contaminated zone b parameter	2.87	3.60	4.50
Evapotranspiration	0.62	0.75	0.87
Wind speed	3.27	3.75	4.22
Runoff coefficient	0.28	0.45	0.63
Well pump intake depth	21.40	34.80	59.00
b parameter of unstaured zone	2.87	3.60	4.50
mass loading for inhalation	1.84E-05	2.35E-05	2.87E-05
Indoor dust filtration factor	0.35	0.55	0.75
Depth of soil mixing layer	0.15	0.23	0.34
Depth of roots	1.23	2.15	3.08
Wet weight crop yield of fruit grain and non leafy vegetables	1.27	1.75	2.42
Weathering removal constant of all vegetation	21.50	33.00	47.90
Wet foliar interception fraction of leafy vegetables	0.43	0.58	0.70
Humidity in air	5.79	7.24	9.07

DCH 2015 2.13.1 Sand Soil Type

	log mea	std dev	25th	50th	75th
Am-241	6.91	1.95	2.69E+02	1.00E+03	3.73E+03
C-14	2.4	3.22	1.26E+00	1.10E+01	9.67E+01
Ce-144	5.99	1.00E-04	3.99E+02	3.99E+02	3.99E+02
Cm-243/ 244	8.13	2.64	5.72E+02	3.39E+03	2.01E+04
Co-58	5.56	2.89	3.70E+01	2.60E+02	1.82E+03
Co-60	5.56	2.89	3.70E+01	2.60E+02	1.82E+03
Cs-134	6.27	1.79	1.58E+02	5.28E+02	1.77E+03
Cs-137	6.27	1.79	1.58E+02	5.28E+02	1.77E+03
Eu-152	6.72	3.22	9.45E+01	8.29E+02	7.27E+03
Eu-154	6.72	3.22	9.45E+01	8.29E+02	7.27E+03
Eu-155	6.72	3.22	9.45E+01	8.29E+02	7.27E+03
Fe-55	5.77	1.00E-04	3.21E+02	3.21E+02	3.21E+02
H-3	-2.81	0.5	4.30E-02	6.02E-02	8.44E-02
Ni-59	4.87	2.3	2.76E+01	1.30E+02	6.15E+02
Ni-63	4.87	2.3	2.76E+01	1.30E+02	6.15E+02
Np-237	2.64	1.39	5.49E+00	1.40E+01	3.58E+01
Pu-238	5.99	1.39	1.56E+02	3.99E+02	1.02E+03
Pu-239/ 240	5.99	1.39	1.56E+02	3.99E+02	1.02E+03
Pu-241	5.99	1.39	1.56E+02	3.99E+02	1.02E+03
Sb-125	2.83	1.79	5.07E+00	1.69E+01	5.67E+01
Sr-90	3.09	1.79	6.57E+00	2.20E+01	7.35E+01
Tc-99	-3.22	1.1	1.90E-02	4.00E-02	8.39E-02

Radionuclide Specific - Kd

DCH 2015 Table 2.13.2, Loam Soil Type

	log mea	std dev	25th	50th	75th
Am-241	8.34	1.79	1.25E+03	4.19E+03	1.40E+04
C-14	2.4	3.22	1.26E+00	1.10E+01	9.67E+01
Ce-144	8.01	1.1	1.43E+03	3.01E+03	6.32E+03
Cm-243/ 244	9.85	0.69	1.19E+04	1.90E+04	3.02E+04
Co-58	6.7	2.71	1.31E+02	8.12E+02	5.05E+03
Co-60	6.7	2.71	1.31E+02	8.12E+02	5.05E+03
Cs-134	8.16	1.39	1.37E+03	3.50E+03	8.93E+03
Cs-137	8.16	1.39	1.37E+03	3.50E+03	8.93E+03
Eu-152	6.72	3.22	9.45E+01	8.29E+02	7.27E+03
Eu-154	6.72	3.22	9.45E+01	8.29E+02	7.27E+03
Eu-155	6.72	3.22	9.45E+01	8.29E+02	7.27E+03
Fe-55	6.79	0.69	5.58E+02	8.89E+02	1.42E+03
H-3	-2.81	0.5	4.30E-02	6.02E-02	8.44E-02
Ni-59	5.19	1.61	6.06E+01	1.79E+02	5.32E+02
Ni-63	5.19	1.61	6.06E+01	1.79E+02	5.32E+02
Np-237	3.14	1.39	9.05E+00	2.31E+01	5.90E+01
Pu-238	6.86	1.39	3.73E+02	9.53E+02	2.43E+03
Pu-239/ 240	6.86	1.39	3.73E+02	9.53E+02	2.43E+03
Pu-241	6.86	1.39	3.73E+02	9.53E+02	2.43E+03
Sb-125	4.11	1.1	2.90E+01	6.09E+01	1.28E+02
Sr-90	4.04	1.61	1.92E+01	5.68E+01	1.68E+02
Tc-99	-2.66	1.1	3.33E-02	6.99E-02	1.47E-01

Penetration Effective Basement Surface Area

Input to Calculation	
Conversion Factor	2.540E-02 m/in

Effective Penetration Surface Area

Basement	Internal Surface Area ¹ (m ²)	Internal Volume ¹	SA/V	Wall/Floor Surface Area ² (m ²)	Penetration Effective Fraction of Surface Area	
Auxiliary	4.41		0.56	7.9	5352.00	0.001
Containment	43.70		6.28	7.0	2361.00	0.019
Turbine	12.64		1.28	9.9	4013.00	0.0031
Intake Structure	57.56		25.07	2.3	2235.00	0.026

1) OPPD, FC-21-0002, Description of Embedded Piping, Penetrations, and Buried Pipe to Remain in Fort Calhoun End State

2) OPPD, FC-20-006, FCSBldg End State Concrete Surface Areas & Volumes

Soil DCGL

Radionuclide	DCGL (pCi/g)	
	0.15 m	1.0 m
Am-241	1.402E+02	3.053E+01
C-14	5.996E+01	1.019E+01
Ce-144	2.746E+02	2.319E+02
Cm-243	6.747E+01	3.060E+01
Cm-244	2.944E+02	5.766E+01
Co-58	3.631E+01	3.128E+01
Co-60	3.970E+00	3.086E+00
Cs-134	6.424E+00	4.237E+00
Cs-137	1.374E+01	7.656E+00
Eu-152	8.857E+00	7.748E+00
Eu-154	8.220E+00	7.168E+00
Eu-155	3.081E+02	3.027E+02
Fe-55	3.660E+04	2.122E+04
H-3	1.195E+04	8.655E+02
Ni-59	1.128E+04	2.307E+03
Ni-63	4.120E+03	8.424E+02
Np-237	4.723E+00	7.619E-01
Pu-238	1.752E+02	3.536E+01
Pu-239	1.578E+02	3.184E+01
Pu-240	1.578E+02	3.185E+01
Pu-241	5.666E+03	1.040E+03
Sb-125	2.662E+01	2.348E+01
Sr-90	1.111E+01	1.731E+00
Tc-99	1.356E+02	1.542E+01

BFM Insitu DCGL Calculation

Inputs to Calculation

unit activity over 1 m ³ of concrete	1 pCi
unit volume of fill	1 m ³
conversion factor	1.00E+06 cm ³ per m ³
bulk density of fill	1.49 g/cm ³
25 mrem/yr Dose Criterion	25 mrem/yr

Calculation

unit concentration in fill	LTP	6.71E-07 pCi/g per pCi/m ³
----------------------------	-----	---------------------------------------

BFM Insitu DCGL Calculation

	BFM Insitu DSR mrem/yr per pCi/g	BFM Insitu DCGL (DCGL) LTP Chapter 6 Equation 6-4 pCi/m ³
Am-241	8.025E+00	4.642E+06
C-14	1.591E+00	2.341E+07
Co-144	2.441E-02	1.526E+09
Cm-243	2.800E+00	1.330E+07
Cm-244	2.238E+00	1.664E+07
Co-58	5.019E-02	7.422E+08
Co-60	1.299E+00	2.868E+07
Cs-134	1.854E+00	2.009E+07
Cs-137	1.472E+00	2.531E+07
Eu-152	4.061E-02	9.178E+08
Eu-154	5.906E-02	6.307E+08
Eu-155	9.177E-03	4.059E+09
Fe-55	1.382E-03	2.695E+10
H-3	1.966E-01	2.727E+08
Ni-59	1.852E-02	2.011E+09
Ni-63	5.072E-02	7.344E+08
Np-237	4.406E+02	8.454E+04
Pu-238	1.173E+01	3.176E+06
Pu-239	1.302E+01	2.861E+06
Pu-240	1.302E+01	2.861E+06
Pu-241	2.577E-01	1.445E+08
Sb-125	3.042E-01	1.225E+08
Sr-90	2.694E+01	1.383E+06
Tc-99	4.512E+00	8.256E+06

LTP Chapter 6 Equation 6-3

$$C_{f,u} = \frac{A_{c,u}}{V_{f,u} \times 1 \times 10^6 \rho_f}$$

C_{f,u} = unit concentration in fill (pCi/g per pCi/m³)
 A_{c,u} = unit activity of 1 pCi over a 1 m² area of concrete (pCi)
 V_{f,u} = unit fill volume of 1 m³
 Conversion Factor = 1x10⁶ cm³ per m³
 ρ_f = bulk density of fill (assumed to be sand)

LTP Chapter 6 Equation 6-4

$$DCGL_{L,j} = \frac{25}{DSR_{L,j} C_{f,u}}$$

where:
 DCGL_{L,j} = insitu scenario DCGL for radionuclide j (pCi/m³)
 C_{f,u} = unit concentration in fill (pCi/g per pCi/m³) from Equation 6-3
 DSR_{L,j} = BFM Insitu dose to source ratio for radionuclide j (mrem/yr per pCi/g)
 25 = 25 mrem/yr dose criterion

WI meat and milk correction factor

1.078E-01

	DSR	WI Meat	WI Milk	WI Sum	WI Corrected	Corrected DSR DCGL Overestimate
Am-241						
C-14						
Co-144						
Cm-243						
Cm-244						
Co-58						
Co-60						
Cs-134						
Cs-137			2.623E-01	4.573E-01	7.196E-01	7.756E-02
Eu-152						-6.420E-01
Eu-154						0.000E+00
Eu-155						
Fe-55						
H-3						
Ni-59						
Ni-63						
Np-237						
Pu-238						
Pu-239						
Pu-240						
Pu-241						
Sb-125						
Sr-90						
Tc-99						

995.5' Elevation: Basement Fill Model - Drilling Spoils Scenario

Assumptions and Unit Conversion Factors

Diameter Borehole	8.00 in
Drilling Depth Ground to floor	8.50 ft
Drilling depth into floor concrete	1.00 in
Fill Density	1.49 g/cm ³
Unit activity in drilling spoils	1.00 pCi/g
Depth of drilling spoils spread on ground	0.15 m
conversion factor	1.00E+06 cm ³ /m ³
conversion factor	22.00 m/ft
conversion factor	0.3048 m/ft
conversion factor	0.0254 m/in

Calculations

Diameter Borehole	0.2032 m
Total drilling depth	2.62E+00 m
Drilling Spoils Volume (LTP Chapter 6 Equation 6-5)	8.48E-02 m ³
Concrete Concentration pCi/m ³ per 1 pCi/g in spoils (LTP Chapter 6 Equation 6-6)	3.90E+06 pCi/m ³ per pCi/g

Calculation of BFM Drilling Spoils DCGIs (pCi/m³)

Radionuclide	Drilling Spoils DSR (mrem/yr per pCi/g)	BFM Drilling Spoils DCGI (pCi/m ³) LTP Chapter 6 Equation 6-7
Am-241	3.627E-03	2.687E+10
C-14	6.344E-07	1.587E+14
Ce-144	6.556E-03	2.195E+10
Cm-243	1.638E-02	5.957E+09
Cm-244	1.169E-03	8.336E+10
Co-58	3.390E-02	2.875E+09
Co-60	2.920E-01	3.358E+08
Cs-134	1.698E-01	5.739E+08
Cs-137	7.161E-02	1.361E+09
Eu-152	1.374E-01	7.108E+08
Eu-154	1.460E-01	6.675E+08
Eu-155	5.241E-03	1.859E+10
Fe-55	4.148E-08	2.349E+15
H-3	8.452E-07	1.153E+14
Ni-59	2.433E-07	4.005E+14
Ni-63	6.613E-07	1.474E+14
Np-237	3.059E-02	3.186E+09
Pu-238	1.874E-03	5.200E+10
Pu-239	2.061E-03	4.728E+10
Pu-240	2.058E-03	4.735E+10
Pu-241	8.991E-05	1.084E+12
Sb-125	4.713E-02	2.068E+09
Sr-90	1.380E-03	7.062E+10
Tc-99	9.713E-05	1.003E+12

LTP Chapter 6 Equation 6-5

$$V_{ds} = \pi (r)^2 D_{ds}$$

where:
 V_{ds} = volume of the drilling spoils on ground surface (m³)
 π = pi constant
 r = radius of borehole (m)
 D_{ds} = depth of borehole (m)

LTP Chapter 6 Equation 6-6

$$C_{con} = \frac{V_{ds} \times 1 \times 10^6 \rho_f C_{ds}}{\pi (r)^2}$$

where:
 C_{con} = concrete concentration (pCi/m³) required to produce a unit concentration of 1 pCi/g concentration in drilling spoils (pCi/m³ per pCi/g)
 V_{ds} = volume of drilling spoils calculated by Equation 6-4 (m³)
 1×10^6 = conversion factor cm³/m³
 ρ_f = density of fill (drilling spoils) (g/cm³)
 C_{ds} = unit concentration in drilling spoils (1 pCi/g)
 π = pi constant
 r = radius of borehole (m)

LTP Chapter 6 Equation 6-7

$$DCGL_{ds,j} = \frac{25 C_{con}}{DSR_i}$$

where:
 $DCGL_{ds,j}$ = drilling spoils DCGI for radionuclide i (pCi/m³)
 C_{con} = concrete concentration required to produce 1 pCi/g average concentration in drilling spoils (Equation 6-4) (pCi/m³ per pCi/g)
 DSR_i = dose to source ratio for radionuclide i (mrem/yr per pCi/g)
 $25 = 25$ mrem/yr dose criterion

BFM Concrete and Liner Excavation Scenario DCGL

Inputs to Calculation			
unit activity over a 1 m ² area of concrete	1	pCi	
minimum wall thickness in all basements	2	ft	
conversion factor	30.48	cm/ft	
unit area of concrete wall	1	m ²	
conversion factor	1.00E+04	cm ² /m ²	
concrete density	2.2	g/cm ³	
Calculation			
unit concentration in excavated concrete			
LTP Chapter 6, Equation 6-8	7.46E-07	pCi/g per pCi/m ²	

BFM Concrete Excavation Scenario DCGL

	Soil DCGL 1.0 m (pCi/g)	Concrete Excavation DCGL (DCGL _{e,c}) ¹ pCi/m ²	Liner Excavation DCGL (DCGL _{e,l}) pCi/m ²
Am-241	3.053E+01	4.094E+07	3.155E+07
C-14	1.019E+01	1.367E+07	1.349E+07
Ce-144	2.319E+02	3.110E+08	6.179E+07
Cm-243	3.060E+01	4.104E+07	1.518E+07
Cm-244	5.766E+01	7.733E+07	6.624E+07
Co-58	3.128E+01	4.195E+07	8.170E+06
Co-60	3.086E+00	4.139E+06	8.933E+05
Cs-134	4.237E+00	5.682E+06	1.445E+06
Cs-137	7.656E+00	1.027E+07	3.092E+06
Eu-152	7.748E+00	1.039E+07	1.993E+06
Eu-154	7.168E+00	9.613E+06	1.850E+06
Eu-155	3.027E+02	4.060E+08	6.932E+07
Fe-55	2.122E+04	2.846E+10	8.235E+09
H-3	8.655E+02	1.161E+09	1.298E+09
Ni-59	2.307E+03	3.094E+09	2.538E+09
Ni-63	8.424E+02	1.130E+09	9.270E+08
Np-237	7.619E-01	1.022E+06	1.063E+06
Pu-238	3.536E+01	4.742E+07	3.942E+07
Pu-239	3.184E+01	4.270E+07	3.551E+07
Pu-240	3.185E+01	4.271E+07	3.551E+07
Pu-241	1.040E+03	1.395E+09	1.275E+09
Sb-125	2.348E+01	3.149E+07	5.990E+06
Sr-90	1.731E+00	2.321E+06	2.500E+06
Tc-99	1.542E+01	2.068E+07	2.313E+07

1) LTP Chapter 6, Equation 6-9

Sensitivity Analysis and DCGL Calculation for Liner Excavation

Inputs to calculation		
unit activity of 1 pCi over a liner area of 1 m ²	1	pCi
thickness of soil mixing zone	0.15	m
	1.00	m
unit area of liner and underlying soil	1	m ²
conversion factor	1.00E+06	cm ³ /m ³
soil density	1.50	g/cm ³
Calculation		
unit concentration in soil for 0.15 m soil thickness		
LTP Chapter 6 Equation 6-10	4.44E-06	pCi/g per pCi/m ²
unit concentration in soil for 1 m soil thickness		
LTP Chapter 6 Equation 6-10	6.67E-07	pCi/g per pCi/m ²

	Soil DCGL 0.15 m (pCi/g)	Soil 1.0 m DCGL (pCi/g)	Liner DCGL ² 0.15 m (pCi/m ²)	Liner DCGL ² 1.00 m (pCi/m ²)	0.15 m < 1.0 m?	Liner Excavation DCGL (DCGL _e)
Am-241	1.402E+02	3.053E+01	3.155E+07	4.580E+07	TRUE	3.155E+07
C-14	5.996E+01	1.019E+01	1.349E+07	1.529E+07	TRUE	1.349E+07
Ce-144	2.746E+02	2.319E+02	6.179E+07	3.479E+08	TRUE	6.179E+07
Cm-243	6.747E+01	3.060E+01	1.518E+07	4.590E+07	TRUE	1.518E+07
Cm-244	2.944E+02	5.766E+01	6.624E+07	8.649E+07	TRUE	6.624E+07
Co-58	3.631E+01	3.128E+01	8.170E+06	4.692E+07	TRUE	8.170E+06
Co-60	3.970E+00	3.086E+00	8.933E+05	4.629E+06	TRUE	8.933E+05
Cs-134	6.424E+00	4.237E+00	1.445E+06	6.356E+06	TRUE	1.445E+06
Cs-137	1.374E+01	7.656E+00	3.092E+06	1.148E+07	TRUE	3.092E+06
Eu-152	8.857E+00	7.748E+00	1.993E+06	1.162E+07	TRUE	1.993E+06
Eu-154	8.220E+00	7.168E+00	1.850E+06	1.075E+07	TRUE	1.850E+06
Eu-155	3.081E+02	3.027E+02	6.932E+07	4.541E+08	TRUE	6.932E+07
Fe-55	3.660E+04	2.122E+04	8.235E+09	3.183E+10	TRUE	8.235E+09
H-3	1.195E+04	8.655E+02	2.689E+09	1.298E+09	FALSE	1.298E+09
Ni-59	1.128E+04	2.307E+03	2.538E+09	3.461E+09	TRUE	2.538E+09
Ni-63	4.120E+03	8.424E+02	9.270E+08	1.264E+09	TRUE	9.270E+08
Np-237	4.723E+00	7.619E-01	1.063E+06	1.143E+06	TRUE	1.063E+06
Pu-238	1.752E+02	3.536E+01	3.942E+07	5.304E+07	TRUE	3.942E+07
Pu-239	1.578E+02	3.184E+01	3.551E+07	4.776E+07	TRUE	3.551E+07
Pu-240	1.578E+02	3.185E+01	3.551E+07	4.778E+07	TRUE	3.551E+07
Pu-241	5.666E+03	1.040E+03	1.275E+09	1.560E+09	TRUE	1.275E+09
Sb-125	2.662E+01	2.348E+01	5.990E+06	3.522E+07	TRUE	5.990E+06
Sr-90	1.111E+01	1.731E+00	2.500E+06	2.597E+06	TRUE	2.500E+06
Tc-99	1.356E+02	1.542E+01	3.051E+07	2.313E+07	FALSE	2.313E+07

2) LTP Chapter 6, Equation 6-11

LTP Chapter 6, Equation 6-8

$$C_{ec,u} = \frac{A_{c,u}}{t_w(30.48)UA_c(1 \times 10^4)\rho_c}$$

where:

$C_{ec,u}$ = unit concentration in excavated concrete (pCi/g per pCi/m²)
 $A_{c,u}$ = unit activity of 1 pCi over a 1 m² area of concrete (pCi)
 t_w = minimum wall thickness in all basements (ft)
 30.48 = cm/ft
 UA_c = unit area of concrete wall (1 m²)
 1×10^4 = cm²/m²
 ρ_c = density of concrete (2.2 g/cm³)

LTP Chapter 6, Equation 6-9

$$DCGL_{ec,i} = \frac{DCGL_{s,i}}{C_{ec,u}}$$

where:

$DCGL_{ec,i}$ = concrete excavation DCGL for radionuclide i (pCi/m²)
 $DCGL_{s,i}$ = soil DCGL (1 m thickness) for radionuclide i (pCi/g)
 $C_{ec,u}$ = unit concentration in excavated concrete from Equation 6-7
 (pCi/g per pCi/m²)

LTP Chapter 6, Equation 6-10

$$C_{s,t,u} = \frac{A_u}{tUA_l 1 \times 10^6 \rho_s}$$

where:

$C_{s,t,u}$ = unit concentration in soil for thickness t (pCi/g per pCi/m²)
 A_u = unit activity of 1 pCi over a liner area of 1 m² (1 pCi)
 t = thickness of soil mixing zone (0.15 m or 1 m)
 UA_l = unit area of liner and underlying soil (1 m²)
 1×10^6 = cm³/m³
 ρ_s = density of soil (1.5 g/cm³)

LTP Chapter 6, Equation 6-11

$$DCGL_{el,i} = \frac{DCGL_{s,t,i}}{C_{s,t,u}}$$

where:

$DCGL_{el,i}$ = liner excavation DCGL for radionuclide i (pCi/m²)
 $DCGL_{s,t,i}$ = soil DCGL for thickness t (0.15 or 1 m) for radionuclide i (pCi/g)
 $C_{s,t,u}$ = unit concentration in soil for thickness t (0.15 m or 1.0 m) from Equation 6-10 (pCi/g per pCi/m²)

BFM Wall/Floor DCGL (No IC Dose Correction)

	BFM insitu DCGL _i	BFM Drilling Spoils DCGL _{ds}	BFM Concrete Excavation DCGL _c	BFM Liner Excavation DCGL _l
	pCi/m ²	pCi/m ²	pCi/m ²	pCi/m ²
Am-241	4.642E+06	2.687E+10	4.094E+07	3.155E+07
C-14	2.341E+07	1.587E+14	1.367E+07	1.349E+07
Ce-144	1.526E+09	2.139E+10	3.110E+08	6.179E+07
Cm-243	1.330E+07	5.957E+09	4.104E+07	1.518E+07
Cm-244	1.664E+07	8.336E+10	7.733E+07	6.624E+07
Co-58	7.422E+08	2.875E+09	4.195E+07	8.170E+06
Co-60	2.868E+07	3.358E+08	4.139E+06	8.933E+05
Cs-134	2.009E+07	5.739E+08	5.682E+06	1.445E+06
Cs-137	2.531E+07	1.361E+09	1.027E+07	3.092E+06
Eu-152	9.173E+08	7.108E+08	1.039E+07	1.993E+06
Eu-154	6.307E+08	6.675E+08	9.613E+06	1.850E+06
Eu-155	4.059E+09	1.859E+10	4.060E+08	6.932E+07
Fe-55	2.695E+10	2.349E+15	2.846E+10	8.235E+09
H-3	2.727E+08	1.153E+14	1.161E+09	1.298E+09
Ni-59	2.011E+09	4.005E+14	3.094E+09	2.538E+09
Ni-63	7.344E+08	1.474E+14	1.130E+09	9.270E+08
Np-237	8.454E+04	3.180E+09	1.022E+06	1.063E+06
Pu-238	3.175E+06	5.200E+10	4.742E+07	3.942E+07
Pu-239	2.861E+06	4.728E+10	4.270E+07	3.551E+07
Pu-240	2.861E+06	4.735E+10	4.271E+07	3.551E+07
Pu-241	1.445E+08	1.084E+12	1.395E+09	1.275E+09
Sb-125	1.225E+08	2.068E+09	3.149E+07	5.990E+06
Sr-90	1.383E+06	7.062E+10	2.321E+06	2.500E+06
Tc-99	8.256E+06	1.003E+12	2.068E+07	2.313E+07

BFM Wall/Floor DCGL (Auxiliary, Turbine, Circulating Water Tunnels, Intake Structure) LTP Chapter 6 Equation 6-13	BFM Wall/Floor DCGL (Containment) LTP Chapter 6 Equation 6-13
pCi/m ²	pCi/m ²
4.168E+06	4.046E+06
8.629E+06	8.559E+06
2.553E+08	5.922E+07
1.003E+07	7.082E+06
1.369E+07	1.330E+07
3.916E+07	8.058E+06
3.578E+06	8.640E+05
4.396E+06	1.345E+06
7.265E+06	2.749E+06
1.013E+07	1.983E+06
9.336E+06	1.839E+06
3.619E+08	6.791E+07
1.384E+10	6.308E+09
2.208E+08	2.254E+08
1.219E+09	1.122E+09
4.451E+08	4.098E+08
7.808E+04	7.831E+04
2.976E+06	2.939E+06
2.681E+06	2.647E+06
2.681E+06	2.647E+06
1.310E+08	1.298E+08
2.475E+07	5.694E+06
8.666E+05	8.903E+05
5.900E+06	6.084E+06

LTP Chapter 6 Equation 6-13

$$DCGL_{wf} = \frac{1}{\left(\frac{1}{DCGL_i} + \frac{1}{DCGL_{ds}} + \frac{1}{DCGL_c}\right)}$$

where:

- DCGL_{wf} = BFM wall/floor DCGL
- DCGL_i = BFM *insitu* scenario DCGL
- DCGL_{ds} = BFM drilling spoils scenario DCGL
- DCGL_c = BFM excavation scenario DCGL

Embedded Pipe DCGL

Inputs to Calculation

	Floor Area (ft ²)	Embedded Pipe Internal Surface Area (ft ²)
Auxiliary Floor 971' elevation	6334	260
Auxiliary Floor 989' elevation	25,109	1320
Turbine Floor 990' elevation	26,235	2009
Unit Activity in Embedded Pipe	1 pCi/m ²	
conversion factor	0.0929 m ² /ft ²	
mix distance in fill	1 m	
conversion factor	1.00E+06 cm ³ /m ³	
bulk density	1.49 g/cm ³	
Dose Criterion	25 mrem/yr	

Unit Fill Concentration

LTP Chapter 6 Equation 6-15

Auxiliary Floor 971' elevation	2.75E-08 pCi/g per pCi/m ²
Auxiliary Floor 989' elevation	3.53E-08 pCi/g per pCi/m ²
Turbine Floor 990' elevation	5.14E-08 pCi/g per pCi/m ²

Embedded Pipe DCGL Calculation

	DSR		DCGL	
	Auxiliary Floor 971' elevation	Auxiliary Floor 989' elevation	Auxiliary Floor 989' elevation	Turbine Floor 990' elevation
	LTP Chapter 6 Equation 6-16	LTP Chapter 6 Equation 6-16	LTP Chapter 6 Equation 6-16	LTP Chapter 6 Equation 6-16
	mrem/yr per pCi/g	pCi/m ²	pCi/m ²	pCi/m ²
Am-241	1.851E+00	4.90E+08	3.83E+08	2.63E+08
C-14	5.787E-01	1.568E+09	1.224E+09	8.406E+08
Ce-144	4.811E-03	1.886E+11	1.473E+11	1.011E+11
Cm-243	5.938E-01	1.528E+09	1.193E+09	8.192E+08
Cm-244	4.747E-01	1.912E+09	1.493E+09	1.025E+09
Co-58	6.528E-03	1.390E+11	1.085E+11	7.452E+10
Co-60	1.691E-01	5.366E+09	4.190E+09	2.877E+09
Cs-134	1.365E-01	6.648E+09	5.191E+09	3.564E+09
Cs-137	1.084E-01	8.371E+09	6.537E+09	4.487E+09
Eu-152	9.568E-03	9.484E+10	7.406E+10	5.084E+10
Eu-154	1.392E-02	6.519E+10	5.090E+10	3.495E+10
Eu-155	2.164E-03	4.193E+11	3.274E+11	2.248E+11
Fe-55	3.283E-04	2.764E+12	2.158E+12	1.482E+12
H-3	3.725E-02	2.436E+10	1.902E+10	1.306E+10
Ni-59	4.373E-03	2.075E+11	1.620E+11	1.112E+11
Ni-63	8.698E-03	1.043E+11	8.146E+10	5.593E+10
Np-237	1.476E+02	6.148E+06	4.801E+06	3.296E+06
Pu-238	2.796E+00	3.246E+08	2.534E+08	1.740E+08
Pu-239	4.086E+00	2.221E+08	1.734E+08	1.190E+08
Pu-240	3.782E+00	2.399E+08	1.874E+08	1.286E+08
Pu-241	6.079E-02	1.493E+10	1.166E+10	8.002E+09
Sb-125	6.833E-02	1.328E+10	1.037E+10	7.119E+09
Sr-90	4.010E+00	2.263E+08	1.767E+08	1.213E+08
Tc-99	1.151E+00	7.884E+08	6.156E+08	4.226E+08

LTP Chapter 6 Equation 6-15

$$C_{f,ei} = \frac{A_{ep,u} SA_{ep,ei} 0.0929}{SA_{f,ei} 0.0929 D_m 1 \times 10^6 \rho_f}$$

where:

$C_{f,ei}$ = concentration in fill from release of activity from embedded pipe at floor elevation i (pCi/g per pCi/m²)
 $A_{ep,u}$ = unit activity in embedded pipe (1 pCi per m²),
 $SA_{ep,ei}$ = embedded pipe internal surface area in floor elevation i (ft²),
 0.0929 = Conversion Factor (m²/ft²)
 $SA_{f,ei}$ = floor surface area at elevation i (ft²),
 D_m = mix distance in fill (1 m)
 1×10^6 = Conversion factor (g/cm³)
 ρ_f = bulk density of fill (assumed to be sand) (g/cm³)

LTP Chapter 6 Equation 6-16

$$DCGL_{ep,ei,j} = \frac{25}{DSR_{ep,j} C_{f,ei}}$$

Where:

$DCGL_{ep,ei,j}$ = embedded pipe DCGL at floor elevation i for radionuclide j (pCi/m²)
 25 = 25 mrem/yr dose criterion
 $DSR_{ep,j}$ = embedded pipe DSR for radionuclide j (mrem/yr per pCi/g)
 $C_{f,ei}$ = concentration in fill from release of activity from embedded pipe at floor elevation i (Equation 6-15) (pCi/g per pCi/m²)

	16 sv/yr per Bq/g
Steel scrap mass	14657 t
conversion factor	1000 kg/t
Nureg-1640 surface dose factor	3.2 Sv/yr per Bq/cm2
Conversion Factor	0.0037 (mrem/yr per pCi/cm2) per (Sv/yr per Bq/cm2)
Nureg-1640 steel mass/surface ra	5.1 g/cm2
conversion factor	1.00E+04 cm2/m2

Calculation	
NUREG-1640 surface dose factor	0.01184 mrem/yr per pCi/cm2
NUREG-1640 surface dose factor	1.18E-06 mrem/yr per pCi/m2
25 mrem/yr limit	2.11E+07 pCi/m2 per 25 mrem/yr

in	4.5 OD	0.035908404
in	4.03 ID	0.032157971
length	435 m	0.003750433
	8053 kg/m3	0.391545238 m3
mass of aux embedd pipe		3153.113798 kg
pipe mass/surface area	#DIV/0!	g/cm2
pipe specific surface dose factor	#DIV/0!	Sv/yr per Bq/cm2
25 mrem/yr limit pipe specific	#DIV/0!	mrem/yr per pCi/g
mass corrected 25 mrem pipe spe	#DIV/0!	mrem/yr per pCi/g

Buried Pipe DCGL Calculation

Buried Pipe Excavation and *insitu* Scenario DCGL calculation

Inputs to Calculation		
unit activity in pipe over a 1 cm ² area		1 dpm
conversion factor		2.22 dpm/pCi
unit surface area of pipe (and underlying soil)		1 cm ²
thickness of soil mixing zone	excavation scenario	100 cm
	excavation scenario	15 cm
	<i>insitu</i> scenario	2.54 cm
density of soil	excavation scenario	1.5 g/cm ³
	<i>insitu</i> scenario	1.49 g/cm ³
Multiplication factor to calculate dpm/100 cm ² DCGL		100 cm ²
Dose Criterion		25 mrem/yr

Calculation	
0.15 m mix unit soil concentration buried pipe	
LTP Chapter 6 Equation 6-17	2.00E-02 pCi/g per dpm/cm ²
1.0 m mix unit soil concentration buried pipe	
LTP Chapter 6 Equation 6-17	3.00E-03 pCi/g per dpm/cm ²

Buried Pipe Excavation Scenario DCGL

	DSR		DCGL		1.0	Is 0.15 m Thickness DCGL less Than 1.0 m Thickness DCGL?	DCGL Buried Pipe Excavation Scenario
	0.15 m Mix Thickness	1.0 m Mix Thickness	0.15 m thickness	m thickness			
	mrem/yr per pCi/g	mrem/yr per pCi/g	LTP Chapter 6 Equation 6-19 (dpm/100 cm2)	LTP Chapter 6 Equation 6-19 (dpm/100 cm2)			
Am-241	1.678E-01	8.030E-01	7.442E+05	1.037E+06	TRUE	7.442E+05	
C-14	3.386E-02	2.315E-01	3.688E+06	3.596E+06	FALSE	3.596E+06	
Ce-144	8.733E-02	1.011E-01	1.430E+06	8.234E+06	TRUE	1.430E+06	
Cm-243	3.557E-01	7.916E-01	3.511E+05	1.052E+06	TRUE	3.511E+05	
Cm-244	8.069E-02	4.268E-01	1.548E+06	1.951E+06	TRUE	1.548E+06	
Co-58	6.581E-01	7.240E-01	1.898E+05	1.150E+06	TRUE	1.898E+05	
Co-60	5.938E+00	7.137E+00	2.103E+04	1.166E+05	TRUE	2.103E+04	
Cs-134	3.403E+00	4.209E+00	3.670E+04	1.978E+05	TRUE	3.670E+04	
Cs-137	1.481E+00	2.028E+00	8.432E+04	4.105E+05	TRUE	8.432E+04	
Eu-152	2.709E+00	3.010E+00	4.610E+04	2.766E+05	TRUE	4.610E+04	
Eu-154	2.916E+00	3.252E+00	4.282E+04	2.560E+05	TRUE	4.282E+04	
Eu-155	7.751E-02	7.738E-02	1.611E+06	1.076E+07	TRUE	1.611E+06	
Fe-55	9.315E-05	2.301E-04	1.341E+09	3.618E+09	TRUE	1.341E+09	
H-3	8.727E-04	1.539E-02	1.431E+08	5.409E+07	FALSE	5.409E+07	
Ni-59	5.204E-04	3.036E-03	2.400E+08	2.742E+08	TRUE	2.400E+08	
Ni-63	1.425E-03	8.314E-03	8.763E+07	1.001E+08	TRUE	8.763E+07	
Np-237	3.157E+00	1.994E+01	3.955E+04	4.175E+04	TRUE	3.955E+04	
Pu-238	1.304E-01	6.873E-01	9.576E+05	1.211E+06	TRUE	9.576E+05	
Pu-239	1.448E-01	7.633E-01	8.624E+05	1.091E+06	TRUE	8.624E+05	
Pu-240	1.447E-01	7.633E-01	8.630E+05	1.091E+06	TRUE	8.630E+05	
Pu-241	4.138E-03	2.354E-02	3.018E+07	3.537E+07	TRUE	3.018E+07	
Sb-125	9.037E-01	9.851E-01	1.382E+05	8.451E+05	TRUE	1.382E+05	
Sr-90	1.543E+00	1.019E+01	8.093E+04	8.170E+04	TRUE	8.093E+04	
Tc-99	1.550E-01	1.402E+00	8.056E+05	5.938E+05	FALSE	5.938E+05	

Buried Pipe *Insitu* Scenario DCGL Calculation

0.15 m mix unit soil concentration buried pipe	
LTP Chapter 6 Equation 6-15	1.19E-01 pCi/g per dpm/cm2

	DSR	DCGL
	0.0254 m Mix Thickness mrem/yr per pCi/g	Buried Pipe <i>insitu</i> Scenario LTP Chapter 6 Equation 6-16
Am-241	2.657E-02	7.905E+05
C-14	2.367E-03	8.874E+06
Ce-144	1.731E-04	1.213E+08
Cm-243	1.514E-02	1.387E+06
Cm-244	1.210E-02	1.736E+06
Co-58	4.426E-04	4.746E+07
Co-60	1.144E-02	1.836E+06
Cs-134	1.697E-02	1.238E+06
Cs-137	1.348E-02	1.558E+06
Eu-152	7.917E-05	2.653E+08
Eu-154	1.150E-04	1.826E+08
Eu-155	1.772E-05	1.185E+09
Fe-55	3.929E-06	5.346E+09
H-3	3.260E-04	6.443E+07
Ni-59	7.457E-05	2.817E+08
Ni-63	2.042E-04	1.029E+08
Np-237	1.057E+00	1.987E+04
Pu-238	2.854E-02	7.360E+05
Pu-239	3.170E-02	6.626E+05
Pu-240	3.170E-02	6.626E+05
Pu-241	7.593E-04	2.766E+07
Sb-125	1.038E-03	2.024E+07
Sr-90	2.537E-01	8.279E+04
Tc-99	1.424E-02	1.475E+06

Buried Pipe DCGL Calculation
LTP Chapter 6 Equation 6-20

Buried Pipe DCGL	
Am-241	3.833E+05
C-14	2.559E+06
Ce-144	1.413E+06
Cm-243	2.802E+05
Cm-244	8.182E+05
Co-58	1.890E+05
Co-60	2.079E+04
Cs-134	3.564E+04
Cs-137	7.999E+04
Eu-152	4.609E+04
Eu-154	4.281E+04
Eu-155	1.609E+06
Fe-55	1.072E+09
H-3	2.941E+07
Ni-59	1.296E+08
Ni-63	4.732E+07
Np-237	1.323E+04
Pu-238	4.161E+05
Pu-239	3.747E+05
Pu-240	3.748E+05
Pu-241	1.443E+07
Sb-125	1.372E+05
Sr-90	4.093E+04
Tc-99	4.234E+05

LTP Chapter 6 Equation 6-20

$$DCGL_{bp,i} = \frac{1}{(1/DCGL_{bpi,i} + 1/DCGL_{bpe,i})}$$

where:

DCGL_{bp,i} = Buried pipe DCGL for radionuclide i

DCGL_{bpi,i} = Buried pipe *insitu* scenario DCGL for radionuclide i

DCGL_{bpe,i} = Buried pipe excavation scenario DCGL for radionuclide i

LTP Chapter 6 Equation 6-17

$$C_{s,u,i} = \frac{A_{bp,u,i} / 2.22}{(SA_{bp,u,i} t_{m,i} \rho_s)}$$

where:

$C_{s,u,i}$ = unitized soil concentration for buried pipe scenario i (pCi/g per dpm/cm²)

$A_{bp,u}$ = unit activity in pipe over a 1 cm² area (1 dpm)

2.22 = conversion factor (dpm/pCi)

$SA_{bp,u}$ = unit surface area of buried pipe (1 cm²)

$t_{m,i}$ = thickness of soil mixing zone for buried pipe scenario i (*insitu* scenario 2.54 cm or excavation scenario 15 cm and 100 cm)

ρ_s = density of soil (g/cm³)

LTP Chapter 6 Equation 6-19

$$DCGL_{bp,s,i} = \left(\frac{25}{C_{bp,s} DSR_{bp,i}} \right) 100$$

where:

$DCGL_{bp,s,i}$ = buried pipe DCGL for scenario s and radionuclide i (dpm/100 cm²)

25 = 25 mrem/yr dose criterion

$C_{bp,s}$ = unitized soil concentration for buried pipe scenario s calculated using Equation 6-17 (pCi/g per dpm/cm²)

$DSR_{bp,i}$ = buried pipe DSR for radionuclide i (mrem/yr per pCi/g)

100 = 100 cm² to calculate the DCGL in units of dpm/100 cm².

ROC DCGL Adjusted for IC Radionuclide Dose Contribution

Inputs to Calculation

IC Dose contribution fraction for BFM wall/floor, soil, buried pipe, and above ground building	0.05
IC dose adjustment fraction for BFM wall/floor, soil, buried pipe, and above ground building	0.95
IC dose contribution Fraction for embedded pipe and fill	0.1
IC dose adjustment factor for embedded pipe and fill	0.9

IC Adjusted ROC

ROC	Soil DCGL (pCi/g) IC Adjusted	
	0.15 m	1.0 m
C-14	5.70E+01	9.68E+00
Co-60	3.77E+00	2.93E+00
Cs-137	1.31E+01	7.27E+00
Eu-152	8.41E+00	7.36E+00

ROC	BFM Wall/Floor DCGL (pCi/m ²)	IC Adjusted
	Auxiliary, Turbine, Circulating Water Tunnels, Intake Structure	
C-14	8.20E+06	8.13E+06
Co-60	3.40E+06	8.21E+05
Cs-137	6.90E+06	2.61E+06
Eu-152	9.62E+06	1.88E+06
Sr-90	8.23E+05	8.46E+05

ROC	Embedded Pipe DCGL (pCi/m ²) IC Adjusted		
	Auxiliary Floor 971' elevation (pCi/m ²)	Auxiliary Floor 989' elevation (pCi/m ²)	Turbine Floor 990' elevation (pCi/m ²)
C-14	1.41E+09	1.10E+09	7.57E+08
Co-60	4.83E+09	3.77E+09	2.59E+09
Cs-137	7.53E+09	5.88E+09	4.04E+09
Eu-152	8.54E+10	6.67E+10	4.58E+10
Sr-90	2.04E+08	1.59E+08	1.09E+08

ROC	Buried Pipe DCGL (dpm/100 cm ²) IC Adjusted
C-14	2.43E+06
Co-60	1.98E+04
Cs-137	7.60E+04
Eu-152	4.38E+04

ROC	Above Ground Building DCGL ¹ (dpm/100 cm ²) IC Adjusted	Above Ground Building DCGL (dpm/100 cm ²) IC Adjusted
C-14	3.70E+06	3.52E+06
Co-60	7.10E+03	6.75E+03
Cs-137	2.80E+04	2.66E+04
Eu-152 ²	1.27E+04	1.21E+04

1) Screening Values NUREG-1757, Vol 2, Table H-1

2) Eu-152 screening value is the P_{crit} 0.90 from Table 5.19 of NUREG/CR-5512, Volume 3

ROC	Fill DCGL (pCi/g) IC Adjusted
C-14	1.29E+01
Co-60	1.59E+01
Cs-137	1.36E+01
Eu-152	5.50E+02

Existing Groundwater Dose Conversion Factors

ROC	Water Dependent Dose ¹ at t=1 yr (mrem/yr)	Well Water Concentration ¹ at t = 1 yr (pCi/L)	Existing Groundwater Dose Conversion Factor (mrem/yr per pCi/L) LTP Chapter 6 Equation 6-21
C-14	0.45	1.663E+02	2.68E-03
Co-60	0.15	5.886E+00	2.52E-02
Cs-137	0.11	1.544E+00	6.86E-02
Eu-152	0.01	2.505E+00	3.63E-03
Sr-90	3.95	3.585E+01	1.10E-01

1) RESRAD File "FCS Embedded Pipe DSR"

LTP Chapter 6 Equation 6-21

$$DCF_{egw,i} = \frac{D_{wd,t,i}}{C_{ww,t,i}}$$

where:

DCF_{egw,i} = dose conversion factor for radionuclide i (mrem/yr per pCi/L)
 D_{wd,t,i} = water dependent dose at time t for radionuclide i (mrem/yr)
 C_{ww,t,i} = well water concentration at time t for radionuclide i (pCi/L)

Basment Backfill DCGL

	BFM insitu Fill DCGL mrem/yr per pCi/g
Am-241	3.115E+00
C-14	1.433E+01
Ce-144	1.023E+03
Cm-243	8.928E+00
Cm-244	1.117E+01
Co-58	4.575E+02
Co-60	1.767E+01
Cs-134	1.197E+01
Cs-137	1.508E+01
Eu-152	6.108E+02
Eu-154	4.200E+02
Eu-155	2.703E+03
Fe-55	1.716E+04
H-3	1.733E+02
Ni-59	1.190E+03
Ni-63	4.345E+02
Np-237	5.655E-02
Pu-238	2.131E+00
Pu-239	1.919E+00
Pu-240	1.919E+00
Pu-241	9.916E+01
Sb-125	8.165E+01
Sr-90	8.859E-01
Tc-99	5.399E+00

Soil Area Factors

Input to Calculation

1 m ² LPAF	1.00 m
2 m ² LPAF	1.41
5 m ² LPAF	2.24
10 m ² LPAF	3.16
100 m ² LPAF	10.00
143 m ² LPAF	11.96

	Soil Area Factor DCGL 0.15 m (pCi/m ²)					
	1 m ²	2 m ²	5 m ²	10 m ²	100 m ²	143 m ²
C-14	2.048E+07	8.550E+06	2.531E+06	9.712E+05	3.529E+04	2.085E+04
Co-60	4.876E+01	2.772E+01	1.493E+01	9.826E+00	5.117E+00	4.925E+00
Cs-137	1.976E+02	1.133E+02	6.136E+01	4.045E+01	2.144E+01	2.066E+01
Eu-152	1.032E+02	5.885E+01	3.177E+01	2.092E+01	1.104E+01	1.064E+01
Ni-63	2.177E+07	1.102E+07	4.445E+06	2.229E+06	2.236E+05	1.564E+05
Sr-90	1.027E+04	5.402E+03	2.383E+03	1.282E+03	1.588E+02	1.128E+02

	Soil Area Factor 0.15 m (pCi/m ²)					
	1 m ²	2 m ²	5 m ²	10 m ²	100 m ²	143 m ²
C-14	3.42E+05	1.43E+05	4.22E+04	1.62E+04	5.89E+02	3.48E+02
Co-60	1.23E+01	6.98E+00	3.76E+00	2.48E+00	1.29E+00	1.24E+00
Cs-137	1.44E+01	8.25E+00	4.47E+00	2.94E+00	1.56E+00	1.50E+00
Eu-152	1.17E+01	6.64E+00	3.59E+00	2.36E+00	1.25E+00	1.20E+00
Ni-63	5.28E+03	2.67E+03	1.08E+03	5.41E+02	5.43E+01	3.80E+01
Sr-90	9.24E+02	4.86E+02	2.14E+02	1.15E+02	1.43E+01	1.02E+01

	Soil Area Factor DCGL 1.0 m (pCi/m ²)					
	1 m ²	2 m ²	5 m ²	10 m ²	100 m ²	143 m ²
C-14	1.719E+06	7.712E+05	2.536E+05	1.052E+05	4.607E+03	2.773E+03
Co-60	3.427E+01	2.020E+01	1.113E+01	7.390E+00	4.279E+00	4.147E+00
Cs-137	1.495E+02	8.897E+01	4.929E+01	3.277E+01	1.876E+01	1.798E+01
Eu-152	7.513E+01	4.444E+01	2.454E+01	1.631E+01	9.537E+00	9.273E+00
Ni-63	3.600E+06	1.806E+06	7.237E+05	3.621E+05	3.624E+04	2.534E+04
Sr-90	2.252E+03	1.146E+03	4.705E+02	2.394E+02	2.502E+01	1.754E+01

	Soil Area Factor 1.0 m (pCi/m ²)					
	1 m ²	2 m ²	5 m ²	10 m ²	100 m ²	143 m ²
C-14	1.69E+05	7.57E+04	2.49E+04	1.03E+04	4.52E+02	2.72E+02
Co-60	1.11E+01	6.55E+00	3.61E+00	2.39E+00	1.39E+00	1.34E+00
Cs-137	1.95E+01	1.16E+01	6.44E+00	4.28E+00	2.45E+00	2.35E+00
Eu-152	9.70E+00	5.74E+00	3.17E+00	2.11E+00	1.23E+00	1.20E+00
Ni-63	4.27E+03	2.14E+03	8.59E+02	4.30E+02	4.30E+01	3.01E+01
Sr-90	1.30E+03	6.62E+02	2.72E+02	1.38E+02	1.45E+01	1.01E+01

Inputs to Calculation

Conversion factor	0.0037 (mrem/yr per pCi/cm ²) per (Sv/yr per Bq/cm ²)
Conversion factor	1.00E+04 cm ² per m ²
dose criterion	25 mrem/yr
years before excavatiuon occurs	30 yr

NUREG-1640, Table 2.1 - Effective Dose Equivalent

LLBP Offsite Recycle/Disposal Concentrations
That Result in 25 mrem/yr
LTP Chapter 6, Equation 6-25

	Half-Life	Concrete		Steel		BFM Wall/Floor DCGL (Auxiliary, Turbine, Circulating Water Tunnels, Intake Structure)		BFM Wall/Floor DCGL (Containment)	Auxiliary BFM Wall/Floor DCGL less than concrete recycle/disposal?	Containment BFM Wall/Floor DCGL less than steel recycle/disposal?
		Sv/yr per Bq/cm ²	Sv/yr per Bq/cm ²	pCi/m ³ per 25 mrem/yr	pCi/m ³ per 25 mrem/yr					
Am-241	432.2	2.20E-03	9.40E+00	3.22E+10	7.54E+06	4.168E+06	4.046E+06	TRUE	TRUE	
C-14	5730	4.10E-04	6.30E-03	1.654E+11	1.076E+10	8.629E+06	8.559E+06	TRUE	TRUE	
Ce-144	0.7784	1.90E-02	2.00E-01	1.414E+21	1.343E+20	2.553E+08	5.922E+07	TRUE	TRUE	
Cm-243	28.5	1.10E-01	6.60E+00	1.274E+09	2.123E+07	1.003E+07	7.082E+06	TRUE	TRUE	
Cm-244	18.11	6.40E-02	5.20E+00	3.328E+09	4.095E+07	1.369E+07	1.330E+07	TRUE	TRUE	
Co-58	0.19	2.70E-01	3.30E+00	3.007E+55	2.460E+54	3.916E+07	8.058E+06	TRUE	TRUE	
Co-60	5.271	1.00E+00	1.00E+01	3.489E+09	3.489E+08	3.578E+06	8.640E+05	TRUE	TRUE	
Cs-134	2.062	5.80E-01	8.60E+00	2.787E+12	1.879E+11	4.396E+06	1.345E+06	TRUE	TRUE	
Cs-137	30	2.20E-01	3.20E+00	6.142E+08	4.222E+07	7.265E+06	2.749E+06	TRUE	TRUE	
Eu-152	13.33	4.40E-01	4.30E+00	7.305E+08	7.475E+07	1.013E+07	1.983E+06	TRUE	TRUE	
Eu-154	8.8	4.90E-01	4.30E+00	1.464E+09	1.668E+08	9.336E+06	1.839E+06	TRUE	TRUE	
Eu-155	4.96	1.10E-02	8.80E-02	4.062E+11	5.077E+10	3.619E+08	6.791E+07	TRUE	TRUE	
Fe-55	2.7	7.60E-06	9.10E-05	1.963E+16	1.640E+15	1.384E+10	6.308E+09	TRUE	TRUE	
H-3	12.35	2.40E-04	3.80E-03	1.516E+12	9.573E+10	2.208E+08	2.254E+08	TRUE	TRUE	
Ni-59	7.50E+04	7.60E-06	9.10E-05	8.893E+12	7.427E+11	1.219E+09	1.122E+09	TRUE	TRUE	
Ni-63	96	7.40E-06	9.40E-05	1.134E+13	8.926E+11	4.451E+08	4.088E+08	TRUE	TRUE	
Np-237	2.14E+06	3.80E+00	6.20E+01	1.778E+07	1.090E+06	7.808E+04	7.831E+04	TRUE	TRUE	
Pu-238	87.74	1.00E-01	6.10E+00	8.563E+08	1.404E+07	2.976E+06	2.939E+06	TRUE	TRUE	
Pu-239	2.41E+04	1.10E-01	6.60E+00	6.148E+08	1.025E+07	2.681E+06	2.647E+06	TRUE	TRUE	
Pu-240	6.54E+03	1.10E-01	6.60E+00	6.162E+08	1.027E+07	2.681E+06	2.647E+06	TRUE	TRUE	
Pu-241	1.44E+01	2.20E-03	1.10E-01	1.301E+11	2.602E+09	1.310E+08	1.298E+08	TRUE	TRUE	
Sb-125	2.77E+00	1.50E-01	1.40E+00	8.189E+11	8.773E+10	2.475E+07	5.694E+06	TRUE	TRUE	
Sr-90	29.12	5.20E-03	1.20E-01	2.653E+10	1.150E+09	8.666E+05	8.903E+05	TRUE	TRUE	
Tc-99	2.13E+05	2.20E-02	3.20E-01	3.072E+09	2.112E+08	5.900E+06	6.084E+06	TRUE	TRUE	

LTP Chapter 6, Equation 6-25

$$C_{m,i} = \frac{25(1 \times 10^4)}{(DF_{m,i} 0.0037 e^{-(\lambda_i 30)})}$$

where:

- C_{m,i} = concentration in material m (concrete or steel) for radionuclide i that results in a recycle/disposal dose of 25 mrem/yr (pCi/m³)
- 25 = 25 mrem/yr dose criterion
- 1x10⁴ = conversion factor (cm²/m²)
- DF_{m,i} = NUREG-1640, Table 2.1 dose factor for material m and radionuclide i (Sv/yr per Bq/cm²)
- 0.0037 = conversion factor (mrem/yr per pCi/cm² per Sv/yr per Bq/cm²)
- λ_i = radioactive decay constant for radionuclide i (.693/t_{1/2})
- 30 = time after license termination that large-scale excavation occurs (yr)

LEBP Embedded Pipe Drilling Spills

Assumptions and Unit Conversion Factors

Diameter Borehole	9	in
Drilling Depth (ft)	21.4	m
Concrete foundation depth	12	ft
Embedded Pipe Internal Diameter		
Auxiliary	4.83	in
Turbine (max Turbine EP 02)	18.81	in
Fill and soil density	9.4	in
Unit activity in drilling spoils	1.5	g/cm ³
Depth of drilling spoils spread on ground	0.15	m
conversion factor	2.00E-06	cm ³ /m ³
conversion factor	0.0254	m/in
conversion factor	6.45E-04	m ² /ft ²
dose criterion	25	mrem/yr
years after license termination	30	yr
Drilling spoils spread depth on ground surface	0.15	m
Calculations		
Drilling Spoils Volume	0.69	m ³
LTP Chapter 6, Equation 6-22	4.63	m ²
Spread area	2.15	m
Length Parallel to Aquifer Flow		
Aux EP 4.03 in concentration (pCi/m ² per 1 pCi/g) in spoils	1.59E-07	pCi/m ² per pCi/g
LTP Chapter 6, Equation 6-23		
Aux EP 18.81 in concentration (pCi/m ² per 1 pCi/g) in spoils	1.61E-07	pCi/m ² per pCi/g
LTP Chapter 6, Equation 6-23		
Turbine EP 9.4 in concentration (pCi/m ² per 1 pCi/g) in spoils	6.83E-06	pCi/m ² per pCi/g
LTP Chapter 6, Equation 6-23		

LTP Chapter 6, Equation 6-22

$$V_{dr} = \pi (0.0254d/2)^2 D_{dr}$$

where:
 V_{dr} = volume of the drilling spoils on ground surface (m³)
 π = pi constant
 0.0254 = conversion factor m/in
 d = diameter of borehole (in) = 8 in
 D_{dr} = depth of borehole (m) = 21.4 m

LTP Chapter 6, Equation 6-23

$$C_{sp,25} = \frac{V_{dr} \times 10^{10} p_{sp,25} C_{sp,25}}{A_{sp}}$$

where:
 $C_{sp,25}$ = embedded pipe concentration (pCi/m²) required to produce a unit concentration of 1 pCi/g concentration in drilling spoils (pCi/m³ per pCi/g)
 V_{dr} = volume of drilling spoils calculated by Equation 6-22 (m³)
 10^{10} = conversion factor cm³/m³
 $p_{sp,25}$ = density of fill soil (g/cm³)
 $C_{sp,25}$ = unit concentration in drilling spoils (1 pCi/g)
 A_{sp} = internal surface area of embedded pipe contacted by drill (m²)

and

$$A_{sp,4.83} = \pi \times 4.83d (6.45 \times 10^{-4})$$

$$A_{sp,18.81} = \pi \times 18.81d (6.45 \times 10^{-4})$$

$$A_{sp,9.4} = \pi \times 9.4d (6.45 \times 10^{-4})$$

where:
 $A_{sp,4.83}$ = internal surface area of 4.83 inch internal diameter pipe that is contacted by 8 in diameter drill
 d = diameter of drill borehole = 8 in
 6.45×10^{-4} = conversion factor m²/ft²
 $A_{sp,18.81}$ = internal surface area of 18.81 inch internal diameter pipe that is contacted by 8 inch diameter drill
 $A_{sp,9.4}$ = internal surface area of 9.4 inch internal diameter pipe that is contacted by 8 inch diameter drill

LEBP Embedded Pipe Drilling Spoils Concentration That Results to 25 mrem/yr (pCi/m²)

Radionuclide	Half-life ^a	Auxiliary EP 4.03 in ID		Auxiliary EP 18.81 in ID		Turbine EP 9.4 in ID		Auxiliary Basement			Turbine Basement		
		EP LBP Drilling Spoils Concentration (pCi/m ²)	LTP Chapter 6, Equation 6-24	EP LBP Drilling Spoils Concentration (pCi/m ²)	LTP Chapter 6, Equation 6-24	EP LBP Drilling Spoils Concentration (pCi/m ²)	LTP Chapter 6, Equation 6-24	4.03/971	4.03/989	18.81/971	18.81/989	9.4/990	
Am-241	432.2	1.028E-02	4.066E+10	4.10E+10	1.749E+10	0.01	0.01	0.01	0.01	0.01	0.01	0.01	
C-14	5730	8.899E-06	4.493E+13	4.526E+13	1.926E+13	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
Cu-64	0.7784	2.448E-02	6.470E+21	6.518E+21	2.774E+21	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
Ce-143	28.5	4.099E-03	1.020E+10	1.028E+10	4.374E+09	0.15	0.15	0.15	0.15	0.15	0.15	0.15	
Cm-244	18.11	1.795E-03	6.992E+11	7.047E+11	2.999E+11	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
Co-58	0.59	1.638E-01	2.604E+16	2.629E+16	1.106E+16	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
Co-60	5.271	1.595E-03	1.206E+10	1.209E+10	5.520E+09	0.47	0.32	0.41	0.32	0.41	0.32	0.52	
Co-134	2.062	9.205E-01	1.025E+13	1.045E+13	4.488E+12	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
Co-137	30	3.883E-01	2.025E+09	2.057E+09	8.755E+08	4.08	3.19	4.05	3.16	5.10	3.16	5.10	
Eu-152	13.33	7.499E-01	2.527E+09	2.546E+09	1.083E+09	37.31	29.31	37.25	29.09	46.93	29.09	46.93	
Eu-154	8.8	7.995E-01	5.294E+09	5.333E+09	2.206E+09	12.32	9.62	12.32	9.54	15.40	9.54	15.40	
Eu-155	4.96	2.599E-02	1.054E+12	1.021E+12	4.454E+11	0.41	0.32	0.41	0.32	0.52	0.32	0.52	
Fe-55	2.7	2.688E-07	3.395E+18	3.360E+18	1.490E+18	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
H-3	12.32	9.798E-06	3.699E+14	3.727E+14	1.586E+14	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
N-19	7.50E-04	1.905E-06	2.202E+14	2.107E+14	8.948E+13	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
Nd-63	96	1.210E-06	9.495E+13	9.566E+13	4.071E+13	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
Np-237	2.14E+06	1.568E-01	2.541E+09	2.565E+09	1.089E+09	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
Pu-238	87.74	2.872E-03	1.758E+11	1.750E+11	7.337E+10	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
Pu-239	2.41E+04	1.175E-03	1.257E+11	1.271E+11	5.389E+10	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
Pu-240	6.54E+03	3.157E-03	1.266E+11	1.279E+11	5.427E+10	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
Pu-241	1.44E+01	2.486E-04	6.279E+12	6.326E+12	2.602E+12	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
Sp-125	2.77E+00	2.555E-01	2.854E+12	2.854E+12	1.215E+12	0.00	0.00	0.00	0.00	0.00	0.00	0.01	
Sr-90	28.12	1.795E-03	8.305E+10	8.307E+10	3.562E+10	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
Tc-99	2.13E+05	7.804E-04	5.105E+11	5.143E+11	2.189E+11	0.00	0.00	0.00	0.00	0.00	0.00	0.00	

LTP Chapter 6, Equation 6-24

$$C_{sp,25} = \frac{25}{DSR}$$

where:
 $C_{sp,25}$ = concentration in embedded pipe that results in 25 mrem/yr the LEBP drilling spoils scenario for radionuclide (pCi/m²)
 DSR = dose to source ratio for radionuclide (1 mrem/yr per pCi/g)
 25 = 25 mrem/yr dose criterion

1) RESRAD Users Manual Version 6 Table 3.1

Is BFM Embedded Pipe DCLG less than Embedded Pipe LBP Drilling Spoils Concentration?