

# Does AI HEAF Require a Change to Modeled ZOI?

## It is a safety concern warranting action

- OECD non-prototypic test but no ZOI measured

## It is not a safety concern

- Cables very robust
- 100,000s of component operating years with AI widespread
- No op ex shows an increased ZOI
  - Harris HEAF with AI
    - Actual ZOI bounded by modeled ZOI
    - Cables in ZOI functional
  - Robinson within modeled ZOI
- Appendix R separation – change in ZOI would have to be very large