

DRAWING SOURCE: A 70
CADD: C 60
MAN: 57 59
DD CODE: GD 55 56
MISC: 53
INSTALLATION DIVISION NAME: B 52
TYPE: L 51
PROJECT LOCATION: DIABLO 45-50
UNIT No.: 2 44
16-44
CENTRIFUGAL CHARGING PUMPS
DWG TYPE SUBJECT: 4 14

NOTES


- 43/TS - TRANSFER SWITCH TRANSFERS CONTROL FROM MAIN CONTROL BOARD TO HOT SHUTDOWN PANEL (LOCATED AT SWITCHGEAR).
- 43 - MODE SELECTOR SWITCH FOR SELECTING "AUTO" OR "MANUAL" MODE (LOCATED AT HOT SHUTDOWN PANEL).

Δ - REMOTE CONTROL SWITCH LOCATED AT HOT SHUTDOWN PANEL.

REFERENCES

1. LOGIC DIAG SYMBOLS _____ 19425
2. SCHEMATIC DIAG CHARGING PP _____ 441312
3. SLM&R DIAG 4KV BUS F _____ 441229
4. SLM&R DIAG 4KV BUS G & H _____ 441230
5. LOGIC DIAG 4KV BUS F AUTO TRANSFER _____ 441286
6. LOGIC DIAG 4KV BUS G AUTO TRANSFER _____ 441297

DWG NO.



COAST VALLEYS DIVISION

MICROFILM 5

BILL OF MATL

DWG LIST


SUPSDS

SUPSD BY

SHEET NO. SHEETS

102789 5

UI-1941010



CHARGING PUMP AUXILIARY LUBE OIL PUMP

5	M Basu	Signature	C12314	12/31/94
REV	REGISTERED ENGINEER	SIGNATURE	CA REG NO.	EXP DATE

NUCLEAR SAFETY RELATED

KEY DWG--SECTION 3 UNIT 2

102789D.E62 04-27-94 WAA

NO.	DATE	DESCRIPTION	GM/SPEC	DWN	CHKD	SUPV	APVD BY
5	5-5-94	ADD ALARM INPUT AT 43/MAN INPUT (FCT 17116)	---	WAA	WBJ	JRN	MB
4	1-20-94	REV LOGIC; DEL STAR NOTE; ADD REF 5 & 6 (FCT-16395)	---	DWL	WG	KS	MB
1	9-30-75	APPROVED FOR CONSTRUCTION	169972	EZ	---	LRW	DN

APPROVED BY	GM 169972
LRW	SUPV H. HERTING
DN	DSGN E. ZEITER
JWC	CHKD EZ
TAB	OK HH DPJ
DATE	9-23-75
SCALES	NONE

LOGIC DIAGRAM CENTRIFUGAL CHARGING PUMPS

DIABLO CANYON
DEPARTMENT OF ENGINEERING
PACIFIC GAS AND ELECTRIC COMPANY
SAN FRANCISCO, CALIFORNIA

NI 805