



- NOTES.**
1. (NOT USED)
  2. DELETED
  3. LOOP SEAL TO EXTEND 12" BELOW AND ABOVE OVERFLOW NOZZLE (54B-C)
  4. DELETED
  5. SEE VALVE SPEC. DWG. 063479 & BID SPEC. 8802 (50B-B-54B-E)
  6. BORIC ACID TANKS #1 & 2 LOOP SEALS ARE SERVICED BY A COMMON FLEXIBLE HOSE (50B-D)
  7. THROTTLE TO MAINTAIN BORIC ACID TRANSFER PUMP FLOW BELOW 85 GPM.
  8. 1" x .065 WALL SS TUBING FROM SAMPLE SINK 0-1. (56B-A)
  9. INSULATE WITH 2 LAYERS OF LEWCO FT60 OR EQUIV. INSULATION (57B-B) (57B-A)
  10. FOR HATCHED AREAS, SEE UNIT 1 DRAWING.
  11. CONNECTION POINT FOR FLEX EQUIPMENT. (57B-B)

REF. DWG. DC-663210-171

**UNIT 2**

DIABLO CANYON POWER PLANT - PG&E CO.  
 CHEMICAL & VOLUME CONTROL SYSTEM

DRAWING	SHEET	PAGE	REV
108008	5B	0	91

RASTER=108008-5B-0.dgn  
 DCN=108008-5B-0.dgn  
 CAD User: ZNS4 Date: 06-19-2019

06-19-2019	ZNS4	FXC2	N/A	NOT REQUIRED PER CF3. ID5	-	-	-	Revised Per DDN-2*1883
DATE	DWN	RE	IV	PROFESSIONAL ENGINEER	PE DISC.	PE#	PE EXP.	DFT-7*4887