



- NOTE:
1. ALL SPRINKLER PIPING & VALVES WITHIN THE TURBINE BLDG. ARE P.G.&E. CODE CLASS "G1", SPEC. 8724, EXCEPT AS NOTED
  2. PIPING INDICATED BY BROKEN LINES ARE DELUGE SYS.
  3. M-S-R MOISTURE SEPARATORS REHEATER (41A-E)
  4. FLOW SWITCH CONNECTION SEE D.C. 663086-86
  5. KENNEDY 3" CAST IRON GATE VALVE, FIG. 68.
  6. FS-11 & FS-17 ARE FLANGED FOR REMOVAL/CLEANING.
  7. REPLACEMENT PIPING INSTALLED TO SPEC "HI"
  8. PORTIONS OF PIPING INSTALLED TO SPEC "HI"

**TURBINE BLDG. UNIT 2**  
WET & DELUGE  
AUTOMATIC FIRE SPRINKLER SYSTEM

REFERENCES: 520245 COVER SHEET

46	EL. 85'
47	
48	
49	EL. 104'
50	
51	
52	EL. 119'
53	
54	
55	
56	
57	

UNIT 2  
DIABLO CANYON POWER PLANT - PG&E CO.  
FIRE PROTECTION SYSTEMS

DRAWING	SHEET	PAGE	REV
108018	4A	0	32

RASTER=108018-4A-0.dgn  
 DCN=108018-4A-0.dgn  
 CAD User: ZNS4 Date: 03-20-2018