



- NOTES:**
- 3/8" TUBING INSERTED IN 3/4" NOMINAL PIPE AT VALVE <47B-A>
  - DASHED LINES INDICATE GUARD ON PIPING. <43B-B> GUARD PIPE ON HYDROGEN LINES IS SEISMICALLY QUALIFIED. (REF AR# A062995 & A0642979).
  - VALVE ACTUATED AUTOMATICALLY BY GAS ANALYZER I&6 CHANNEL AC-1067 <46B-A>
  - REINSTALLED ORIGINAL STYLE HANDWHEELS ON THESE VALVES <41B-D/E>
  - STOCK CODE 77-7585 <42B-B>
  - DELETED.
  - SEE 6011930-178 FOR CHECK VALVE DETAILS <43B-B>

DIABLO CANYON POWER PLANT - PG&E CO.			
CHEMICAL & VOLUME CONTROL SYSTEM			
DRAWING	SHEET	PAGE	REV
102008	4B	0	115

UNIT 1

RASTER=102008-4B-0.dgn  
 DCN=102008-4B-0.dgn  
 CAD User: ZNS4 Date: 02-25-2019

02-25-2019	ZNS4	FXC2	N/A	NOT REQUIRED PER CF3.1D5	-	-	-	Revised Per DDN-2*1840
DATE	DWN	RE	IV	PROFESSIONAL ENGINEER	PE DISC.	PE#	PE EXP.	DFC-3*2901