



- NOTES:
1. ALL PIPING THIS SHEET SHALL BE PG&E CLASS [E] UNLESS OTHERWISE NOTES.
 2. PIPE SLOPE OR PITCH SHALL BE 1/4" PER 10 FT LENGTH.

UNIT 1

DIABLO CANYON POWER PLANT - PG&E CO.
AUXILIARY STEAM SYSTEM

DRAWING	SHEET	PAGE	REV
102006	5	0	33

RASTER=102006s5.dgn
 DGN=102006s5.dgn
 CAD User: ZNS4 Date:09-30-2015

09-30-2015	ZNS4	KJD3	N/A	NOT REQUIRED PER CF3.ID5	-	-	-	REVISED PER DDN-2*1035
DATE	DWN	RE	IV	PROFESSIONAL ENGINEER	PE DISC.	PE#	PE EXP.	