



- NOTES:**
- 7'-6" LONG SCHEDULE 10S STANDPIPE. BOTH ENDS CAPPED A MINIMUM 3 PSI WATER PRESSURE IS REQUIRED AT NOZ. 19 (38-B)
 - THIS PIPING SHOULD BE SLOPED DOWNHILL THROUGH THE RUN OF THE DRAIN (39-D)
 - LABYRINTH SEAL THERMAL BARRIER (35-D)
 - MAKEUP WATER LINE FROM THE PRESSURIZER RELIEF TANK PRIMARY MAKEUP WATER SUPPLY (35-C)
 - TOP OF LOOP SEAL IS 6" ABOVE NOZ. 11 (37-E)
 - ALL ITEM NUMBERS IN CVCS ARE SHOWN WITHOUT PREFIX PGECS.
 - ANCHOR/DARLING 1"-1878GB, DC-6006473-157, S/C 94-3771. (31-E)
 - CODE CLASS BOUNDARIES ARE DEFINED IN DRAWING 663207 SHEET 56. (35-D)

UNIT 1

DIABLO CANYON POWER PLANT - PG&E CO.
CHEMICAL & VOLUME CONTROL SYSTEM

DRAWING	SHEET	PAGE	REV
102008	3	0	116

RASTER: 2008s3.dgn
 DGN: 2008s3.dgn
 CAD User: JBMX Date: 07-11-2012

07-11-2012	JBMX	FAZI	KERSI J. DALAL	MECHANICAL	M 16690	3/31/2014	REVISED PER DFT-7*1625
DATE	DWN	RE	IV	PROFESSIONAL ENGINEER	PE DISC.	PE#	PE EXP.