



DC-663293-1
GENERATOR EXCITER
 2 COILS PER COOLER

DC-663293-1
FUSE WHEEL
 2 COILS PER COOLER

DC-663292-11
GENERATOR SEAL OIL COOLERS

DC-663326-22 AND -57
ISO-PHASE BUS
 COOLERS
 2 COILS PER COOLER INCL. 15HT-2A2EP

NOTES:

1. PIPING LINE DESIGNATION NO'S TO BE "K" SPEC.
2. ALL PIPING THIS SHEET SHALL BE PG & E. CLASS "E".
- 3 "VICTAULIC" TYPE COUPLING TYP OF 12 . SEE DC 663293-1 (71-D)

4. CORROSION MONITOR/SAMPLER IS CHEMISTRY CONTROLLED AND MAY BE REMOVED AND REINSTALLED AS NEEDED.
5. SS TUBING FOR COOLER VENTS AND DRAINS BY PG&E. SEE N-MOD A0726979.

DIABLO CANYON POWER PLANT - PG&E CO.			
SERVICE COOLING WATER SYSTEM			
DRAWING	SHEET	PAGE	REV
102015	7	0	40

UNIT 1

RASTER=102015s7.dgn
 DGN=102015s7.dgn
 CAD User: Date:2009-03-25

INPGIC	2009-03-25	AJFJ	FxC2		KERSI J. DALAL	MECHANICAL	M 16690	3/31/2010	REVISED PER DDN-2*209-00
1 Size	DATE	DWN	RE	IV	PROFESSIONAL ENGINEER	PE DISC.	PE#	PE EXP.	DFC-3*319-00, & DFC-3*383-01