



SPECIAL LEGEND

- XXXXX NEXT ADJACENT SHEET IN DIRECTION SHOWN
- ABBREV SERVICE
- FILTER FLOWS
- OVERBOARD
- SUPPLY
- RECYCLE TO SUMPS, TANKS AND FILTERS
- FLUSH WTR
- ABS-AUX BLDG SUMP 0-1
- MEDT-MISC EQUIP DRAIN TANK 0-1

LAUNDRY/DISTILLATE TANK PUMPS
DC-663210-24

- NOTES:**
1. ALL PIPING: S2 SPEC & 2" EXCEPT AS NOTED.
 2. VALVES WITH ITEM NOS. ARE SPECIFIED ON SPEC 0722, UNLESS OTHERWISE NOTED.
 3. INSTRUMENT ROOT VALVES SHALL BE INSTALLED & FURNISHED BY KELLOGG UNDER SPEC 8711 WITH PG&E MARK NO. V-0265. SIC/53C-B, C, D
 4. TANKS ARE SUPPLIED WITH DIAPHRAGM MEMBRANE SIC/53C-B
 5. ALL PIPING SHOWN ON THIS SHEET SHALL BE PG&E CODE CLASS "H" EXCEPT AS NOTED.
 6. TANKS ARE NOT IN (W) SCOPE. SIC/53C-B
 7. TEMPORARY STRAINER IS PLACED IN THE SPOOL PIECE DURING FLUSHING OPERATIONS. STRAINER MUST BE REMOVED BEFORE PLANT START-UP. SIC-D, 53C-C
 8. 3"-316SS WAFER CHECK VALVE MARUN - DUO MODEL NO. G15CMF. SIC-A
 9. FAUCET & P-TRAP INCLUDED WITH SINK 50C-B

UNIT 1

DIABLO CANYON POWER PLANT - PG&E CO.
LIQUID RADWASTE SYSTEM

DRAWING	SHEET	PAGE	REV
102019	50	0	83

RASTER=2019s5c.dgn
 DGN=2019s5c.dgn
 CAD User: ADMI Date: 08-24-2009

INPG1C
1 Size

08-24-2009	ADMI	FxC2	KERSI J. DALAL	MECHANICAL	M 16690	3/31/2010	REVISED PER DDN-2*150-0
DATE	DWN	RE	PROFESSIONAL ENGINEER	PE DISC.	PE#	PE EXP.	