



- NOTES:
1. ALL PIPING ON THIS SHEET SHALL BE PG&E SPEC. "F" AND CODE CLASS "H" UNLESS OTHERWISE NOTED
 2. ALL 1" VALVES ON THIS SHEET IN "F" SPEC. LINES ARE SARAN LINED NATURAL RUBBER DIAPHRAGM VALVES; DC-663125-16 UNLESS OTHERWISE NOTED
 3. TANKS TO BE CARBON STEEL WITH RUBBER LINING
 4. DELETED
 5. LOOP SEAL IN TANK OVERFLOW LINES ARE PROVIDED TO PRECLUDE FLOW FROM ONE TANK TO THE OTHER
 6. DC-663125-19 OR EQUIVALENT IF USED IN HORIZONTAL POSITION
 7. DIAPHRAGM VALVE, DOW FIG. # 373
 8. VERTICAL CHECK VALVE, DOW FIG. # 356
 9. 3" Ø HORIZONTAL CHECK VALVE, DOW FIG. # 355
 10. SAMPLE LINE WAS ADDED TO EXISTING VENT VALVE

DIABLO CANYON POWER PLANT - PG&E CO.
 LIQUID RADWASTE SYSTEM

DRAWING	SHEET	PAGE	REV
102019	6A	0	82

08-24-2009	ADMI	FxC2		KERSI J. DALAL	MECHANICAL	M 16690	3/31/2010	REVISED PER DDN-2*150
DATE	DWN	RE	IV	PROFESSIONAL ENGINEER	PE DISC.	PE#	PE EXP.	& DAS-6*192

RASTER=I02019s6A.dgn
 DGN=I02019s6A.dgn
 CAD User: ADMI Ddt: 08-24-2009