



SPECIAL SYMBOLS THIS SHT. ONLY
"FA-2" BROKEN DOWN F = DWG. AREA
A = ANNULUS
Z = FUNNEL NO.

- NOTES:**
- SUPPLIED UNDER SPEC. 8700, REF. DWG. 500197. (39-C)
 - ALL VALVES WITH ITEM NUMBERS ARE SPECIFIED ON SPEC. 0722 UNLESS OTHERWISE NOTED.
 - LOCATE CLOSE TO CONTAINMENT WALL (39-C)
 - TRANSFER TUBE FLANGE LEAK TEST CONNECTION. REF. DWG. DC 663 2 23 48. (38-C)
 - NITROGEN SEAL, DROP PIPE SHALL TERMINATE BELOW MINIMUM PUMPING LEVEL. (33-B)
 - ALL PIPING ON THIS SHEET SHALL BE PG&E CODE CLASS "E", EXCEPT AS NOTED.
 - THE REACTOR COOLANT PUMP OIL COLLECTION PANS & SPILL COLLECTION TANKS ARE SEISMICALLY QUALIFIED IN ACCORDANCE WITH DESIGN CRITERIA MEMORANDUM M-72
 - CIRCLE SEAL MODEL # 2971-4PP-.15 (33-B)
 - TE-943 IS TO BE MOUNTED ON WALL OR BRACKET CLOSE TO LT-942/943 SENSORS. (34-C)
 - LT-942 & 943 ARE INSTALLED SPARES AND CAN BE RE-USED IN THE EVENT LT-942A/943A IS OUT OF SERVICE. (34/35-C)
 - SUMP GRATING SHALL BE INSTALLED DURING MODES 1, 2, 3 AND 4. STRAINER SHALL BE REMOVED DURING NORMAL OPERATION. STRAINER AND GRATING SHALL BE INSTALLED DURING MODES 5 & 6. A FILTER (DC 663211-92) MAY REPLACE THE STRAINER DURING CAVITY WASHDOWN. (37-C)
 - THE BALLS FOR VALVES FCV-253 AND FCV-500 HAVE A PRESSURE RELIEF HOLE DRILLED IN THE UPSTREAM SIDE WHEN THE VALVE IS IN THE CLOSED POSITION. SEE DC 663166-7 & -8 RESPECTIVELY FOR DETAILS.

DIABLO CANYON POWER PLANT - PG&E CO.
LIQUID RADWASTE SYSTEM

DRAWING	SHEET	PAGE	REV
102019	3	0	90

10-15-2013	MNRU	FxC2	KJD3	NOT REQUIRED	N/A	N/A	N/A	REVISED PER DDN-2*1115
DATE	DWN	RE	IV	PROFESSIONAL ENGINEER	PE DISC.	PE#	PE EXP.	

RASTER=002e1357.DGN
DGN=002e1357.D
CAD User: MNRU Dated: 10-15-2013