



- NOTES:
1. ALL TUBING STEEL
 2. ALL PIPE SCH 40 - ASTM A53
 3. ALL CONNECTORS - S.S.
 4. ALL PIPE FITTINGS - ASTM A-105 GR.2

SIS PUMP.	1-1	1-2
DRAIN LINE NUMBER	S2 693 2	S2 1614 2

DRAWING STATUS	SY	DATE
PWR PLANT EQUIPMENT		
APPROVED FOR CONSTRUCTION		
APPROVED FOR CONSTRUCTION		

SIS. PUMP 1-1
SEAL & DRIP POCKET DRAIN SYSTEM
SEE TABLE FOR PUMP 1-2

SIZE NPT	NO REQ'D. FOR ONE	DESCRIPTION
1 1/2"	AS REQ'D.	PIPE - C.T.S.
1"	AS REQ'D.	TUBING .049 WALL THICKNESS
3/4"	AS REQ'D.	TUBING .049 WALL THICKNESS
2"	1	TEE - 2000#
1 1/2"	2	CROSS-2000#
1 1/2"	1	ELBOW - 2000#
1 1/2"x1"	2	HEX BUSHING
1 1/2"x1/2"	4	HEX BUSHING
2"x1 1/2"	2	HEX BUSHING
1"	4	16-16 FBZ-SS-OR EQUAL ①
1/2"	8	12-8 FBZ-SS-OR EQUAL ①

WESTINGHOUSE FL. CORP. - APD.

PUMP NO.	SPIN NO.
② 45493/99	PSE SIAPSI - 1/2
45491/92	AEP SIAPSI - 1/2
45490/94	AMP SIAPSI - 1/2
45495/96	PNJ SIAPSI - 1/2
45497/98	PGE SIAPSI - 1/2
45489/500	PEG SIAPSI - 1/2

SAFETY INJECTION
CUST. OR NO. 54-E-705-03B SUPP.
DATE: 6-25-69

OUR OR NO. 346-354
212-JTCN-10564

DC-663216-28 UNIT-1 ⑬

REV	CHANGE MADE	DATE	PACIFIC PUMPS INC. LOS ANGELES, CALIF. SEAL & DRIP POCKET DRAIN PIPING
①	PARKER FITTINGS REVISED 20G		
②	PUMP SPIN NOS UP-DATED	4-6-70	
③			
DRAWN BY			DATE & TIME
CHECKED			SCALE
APPROVED			PART NO.
			CSD-45489-1

P G & E CO.		102009	REV.
SHEET 6	PAGE 0		19

CAD User: CMG9 Date: 4-26-1999
DGN=2009S6.DGN
RASTER=2009S6.TIF

INPGIC	4/27/99	CMG9	FXC2	-	KERSI J. DALAL	MECHANICAL	M 16690	3/31/2000	Enhanced per FCT 023917
	DATE	DWN	RE	IV	PROFESSIONAL ENGINEER	PE DISC.	PE#	PE EXP.	