



- NOTES:
1. ALL PIPING THIS SHEET SHALL BE PG&E CLASS **E** UNLESS OTHERWISE NOTED.
  2. PIPE SLOPE OR PITCH SHALL BE 1/4" PER 10 FT LENGTH.

BUILDING HEATING DRAIN RECEIVER PUMPS  
DC-663039-6

UNIT 2

DIABLO CANYON POWER PLANT - PG&E CO.

DRAWING	SHEET	PAGE	REV
108006	5	0	13

RASTER=108006s5.dgn  
 DCN=108006s5.dgn  
 CAD User: MNRU Date: 05-14-2015