



| | | | | | | | | |
|------------|------|------|------|-----------------------|----------|-----|---------|------------------------|
| 01-27-2014 | MNRU | FxC2 | KJD3 | NOT REQUIRED | N/A | N/A | N/A | REVISED PER DFT-7*2459 |
| DATE | DWN | RE | IV | PROFESSIONAL ENGINEER | PE DISC. | PE# | PE EXP. | |

NOTES:

- 1. VALVE CHAINED & LOCKED
CLOSED PER OP F-2:1
* DENOTES CHEMISTRY VALVE
- 2. USED FOR EMERGENCY SPENT
FUEL POOL MAKEUP. SEE AP-22
DO NOT REMOVE HOSE COUPLING
- 3. SHADED AREA ABANDONED EQUIP
- 4. PIPING IS SS SCH 40 THR'D
SEE DWG. 224924 FOR DETAILS.