



- NOTES:**
1. FOR RELATIVE LOCATION OF CONTROL ROOM AREA, SEE SHEET 13.
 2. ELECTRIC DUCT HEATER IEH-27 (EH-N) IS SUPPLIED WITH REDUNDANT HEATING ELEMENTS (A & B). >173-B
 3. FOR LEGEND, ABBREVIATIONS & GENERAL NOTES, SEE SHEET 2 (108023) AND SHEET 3 (108001).
 4. NUMBERS IN BRACKETS [] ARE ORIGINAL ARCHITECTURAL TAG NUMBERS.
 5. FOR OPERATING MODES, SEE HVAC AIR FLOW DIAGRAM DWG. 511157.
 6. S-35 & S-36 AIR CONDITIONING PIPING REFERENCE: ISOMETRIC DRAWING NO. 513506 FOR LINE NUMBERS & CODING.
 7. CONTROL ROOM PRESSURIZATION SYS. CEL & RE CROSS REFERENCE COORDINATES REFER RESPECTIVELY TO INSTRUMENTATION DRAWINGS 102031 & 102931 ONLY.
 8. RE-21 IS COMMON AND IS SHOWN ON THE SOUTH OR UNIT 2 SIDE >168-D. IT IS SHOWN HERE DOTTED >179-A FOR REFERENCE PURPOSE ONLY.

△ 19
 CROSS-HATCHED AREAS ARE COMMON AND ARE NO LONGER UPDATED ON THIS UNIT 2 SHEET. (SEE 102023)

CONTROL ROOM HVAC (NORTH)
 (SAFEGUARD SYSTEM)

P.G.&E. CO.	DRAWING NUMBER	REV
	108023	19
SHEET 17 OF SHEETS		

COMMON (UNIT 1 & 2)