



PLAN-TOP DECK AREA 1

AREA No. 1 AREA No. 2
See Dwg. 59460

- NOTES:
- FOR EMBEDDED STEEL, PIPING, GROUND CABLES, ANCHOR BOLTS, ETC. THAT MAY NOT BE SHOWN, SEE APPROPRIATE DRAWINGS.
 - TOP DECK EL. (+)17.5' IS NORMAL ELEVATION. FOR HIGH AND LOW POINT ELEVATION, SEE DRAINAGE PLAN, SEE DWG 438087.
 - FOR EMBEDDED PIPING SEE DWG. 57743 & 501034.
 - ALL PROJECTING FLOOR SLEEVES AS LISTED ON DWGS. 049047 & 049048 ARE TO BE COATED INSIDE AND OUTSIDE TO A LENGTH OF 1'-0". COATING TO BE PITTSBURG PLATE GLASS CO. "COAL CO" UC-40101. COAL TAR EPOXY. DRY FILM THICKNESS IS MILS.
 - Ⓢ DENOTES CATHODIC PROTECTION JUNCTION BOX (SEE ELECTRICAL DWGS. 500816 & 500817).
 - PE-1-T-2-10 & ALIKE RIGGING PAD EYE I.D. NO. SEE DWG. 063652 & DWG. 4004960.

REFERENCES:

FOR ADD'L REFERENCES DWGS. SEE DWG LIST	438050
REQUIREMENTS FOR GATES	438073
MISCELLANEOUS METAL DETAILS AND NOTES	438085
DRAINAGE PLAN	438087
CATHODIC PROTECTION	438076
PLAN-TOP DECK AREA: REINF.	59465
CONDUIT AND LIGHTING LAYOUT	500816
MISC. CONCRETE SECTIONS AND DETAILS	438082
BAR RACK DETAILS	438077
RETAINING WALL	438070
STANDARD MECH'L DWG.	053093
GRATING MOD.	DC 6003729 SHTS 6&7
UP GRADES HATCHES	061338 SHTS 17 THRU 21
VENTILATION SHAFT MODIFICATION	468490 AND 468491
STRUCTURAL STEEL AND REINF. CONC. UNIT-1	4004966
VENTILATION SHAFT MODIFICATION	468494 AND 468495
STRUCTURAL STEEL AND REINF. CONC. UNIT-2	061338
INTAKE STRUCTURE MOD.	063652
INTAKE RIGGING PADEYE	4004960
RIGGING DEVICE SCHEDULE	683864-40, 56, 58, 156 THRU 159, 259, 315 THRU 317, 323 THRU 326-99A
CONCRETE LIFT	663370-57 THRU 62, 65, 66, 69, 70, 1039, 1194, 1260 THRU 1316, 1372 THRU 1377,
REBAR	1402, 1403, 1427, 1458, 1464, 1473 THRU 1515
EMBEDDED METAL	663385-211 12 THRU 16, 21, 23 THRU 27, 58, 59, 62, 64, 67, 69, 77, 78, 88, 89, 92, 93, 95, 96, 105, 112, 124, 125, 678606-35, 36, 37, 81, 82, 83, 92, 93, 98.
TSFB EMBEDDED ANODES	061338-98 THRU 121
HANDRAILS AT BAR RACK OPENINGS	6023229-99
SEAWALL EMBEDDED ANODES	393127

DATE	03-06-2019	REVISION DESCRIPTION	Revised Per DFT-74167
D.D.	RNJU		
R.E.	FAZI		
I.V.	N/A		
P.E.	N/A		