

NOTES:

1. ALL PIPING BETWEEN ISOLATION VALVES INSTALLED PER GI REQUIREMENTS, BUT SEISMICALLY QUALIFIED TO G REQUIREMENTS.
2. FOR CONTINUATION OF PIPING, REFER TO SPRINKLER SYSTEM DC-693299-5, EL. 73'. (CCW PUMP AND CHARGING PUMP ROOMS)
3. DELETED
4. VALVES ON MANIFOLD LINES 5918 NEED NOT BE UL LISTED.
5. HOSES TO BE INSTALLED FOLLOWING A SEISMIC EVENT WHEN NORMAL COOLANT WATER TO CHARGING PUMPS IS LOST. HOSES ARE NOT REQUIRED DURING NORMAL OPERATION.

CCW & CHARGING PUMP ROOMS  
FIREWATER SPRINKLER  
SYSTEM SUPPLY

56-A

K-5914-3

NOTE 1

GI

2-1294

$\Delta 1$   
30

5916-2 1/2

NOTE 2

5917-2

NOTE 2

NOTE 2

NOTE 2

5915-1 1/4

NOTE 5

K-5918-1

NOTE 1

GI

NOTE 4

G

G-0627

K-5918-1

FI 263

V-0673  
(TYP. 2)

FE 263

C-0651

V-0672

NOTE 5

LUBE OIL COOLERS CCW SUPPLY

101-C 14

CHARGING PUMP 2-1

62-C 14

CHARGING PUMP 2-2

CHARGING PUMPS' SEAL & LUBE OIL COOLERS  
EMERGENCY TIE-IN FROM AUX. BLDG. FIRE PROTECTION SYSTEM

UNIT 2

DIABLO CANYON POWER PLANT - PG&E CO.			
FIRE PROTECTION SYSTEMS			
DRAWING	SHEET	PAGE	REV
108018	5A	0	30

08-06-2015	ZNS4	Fxc2	KJD3	NOT REQUIRED PER CF3.1D5	-	-	-	REVISED PER DFT-7*3183
DATE	DWN	RE	IV	PROFESSIONAL ENGINEER	PE DISC.	PE#	PE EXP.	

RASTER=108018.s5g.dgn  
DGN=108018.s5g.dgn  
CAD User: ZNS4 Date: 08-06-2015