



- NOTES
1. ALL PIPING ON THIS SHEET - PG&E CLASS [E] EXCEPT AS NOTED.
 2. ALL MANUAL VALVES BY PG&E SHALL BE UNDER SPEC 0722 EXCEPT AS NOTED.
 3. GAS DECAY TANKS 2-1, 2-2 & 2-3 ARE SHOWN ON FILLING, VENTING & RECYCLING MODE RESPECTIVELY.
 4. DELETED.
 5. FLANGES FUNCTION IS TO FACILITATE MAINTENANCE AND CALIBRATION OF RV-246. [31-A-E]
 6. CHECK VALVE PISTON INSTALLED WITHOUT THE SPRING. [35-A10-B]
 7. CODE CLASS 'E' 300-LB FLANGE COOR. 37-C/E
 8. WASTE GAS COMPRESSOR SEAL WATER COOLERS ARE DESIGN CLASS II AND SEISMICALLY ANALYZED IN ACCORDANCE WITH DESIGN CRITERIA MEMORANDUM M-61.
 9. 3/4" O GRINNELL DIAPHRAGM VALVE (4R-71229) [33-D]
 10. NUPRO VALVE MODEL SS-DLTW6. [37-A-E]

UNIT 2 DIABLO CANYON POWER PLANT - PG&E CO.
GASEOUS RADWASTE SYSTEM

DRAWING	SHEET	PAGE	REV
108024	3	0	25

RASTER=108024.S3.dgn
DGN=108024.S3.dgn
CAD User: AUFJ Date: 04-08-2011