



COMPONENT COOLING WATER PUMPS COOLING REQUIREMENTS DC-66323-1

- NOTES:
1. PXS TO BE LOCATED WITHIN 1' OF HEAT EXCHANGER (53A-D)
 2. LOCATE FLANGE FOR EASY CONNECTION OF TEMPORARY VALVE AND PRESSURE TEST GAGE. REPLACE WITH BLIND FLANGE AFTER TEST (53A-B)
 3. VALVE IS NON-CLASS I. 2" BALL VALVE WITH 2" FLANGE AT ONE END AND 2" MALE NIPPLE AT OTHER END. ONLY ONE VALVE WILL BE USED AT SEVERAL

3.(CONT) TEST POINTS REMOVE VALVE PRIOR TO OPERATION. SYS IS CLASS I (53A-B)

UNIT-1

P G & E CO.		102014	REV. 45
SHEET 5A	PAGE 0		

CAD User: PMH2 Date: 3-01-2001
 DGN=2014S5A.DGN
 RASTER=2014S5A.TIF

INPGIC	3/1/01	PMH2	FXC2	-	KERSI J. DALAL	MECHANICAL	M 16690	3/31/2004	Revised per FCT 025489
	DATE	DWN	RE	IV	PROFESSIONAL ENGINEER	PE DISC.	PE#	PE EXP.	