



- NOTES:**
1. CHEMICAL FLUSH CONNECTIONS ARE 3/4" SPEC K WITH G-0627 ROOT VALVE (TYP. OF 3 LOC.)
 2. PIPING LINE DESIGNATION NOS TO BE 'K' SPECS.
 3. ALL PIPING THIS SHEET SHALL BE PG&E CLASS "E"
 4. CHECK VALVE IS KEROTEST MODEL 6032-71

UNIT I

DIABLO CANYON POWER PLANT - PG&E CO.
SERVICE COOLING WATER SYSTEM

DRAWING	SHEET	PAGE	REV
102015	4A	0	39

RASTER=1020154a.dgn
 DGN=1020154a.dgn
 CAD User: JAR0 Date:01-28-2008

INPG2ND
1 Size

01-28-2008	JAR0	Fxc2		KERSI J. DALAL	MECHANICAL	M 16690	3/31/2008	REVISED PER FCT-32782
DATE	DWN	RE	IV	PROFESSIONAL ENGINEER	PE DISC.	PE#	PE EXP.	