



GENERAL NOTES

1. 1/2" φ C.S. PACKLESS METAL DIAPHRAGM GLOBE VALVE, 500# NPT ENDS, KEROTEST 60A/64A-C/E. 37⁶
2. FCV-703 & 704 ARE CONNECTED WITH A COMMON OPERATOR CONTROLLED BY A TIMED SOLENOID.
3. VENDOR SUPPLIED, SKID MOUNTED EQUIPMENT.

~~ALL PIPING SHALL BE PIPE CLASS E~~

HYDROGEN GAS DRYER
DC-663287-1B

5. 3/4" φ SS PACKLESS METAL DIAPHRAGM GLOBE VALVE, 300#, SW ENDS, KEROTEST MODEL NO. R42 U06 SW. 37⁶

UNIT-1

35⁴

FG&E CO.	102022	REV. 38
SHEET 6A		
	MICROFILM	

RM INDEXED Rev