



NOTES:
 1. ALL TUBING STEEL
 2. ALL PIPE SCH 40 - ASTM A53
 3. ALL CONNECTORS - S.S.
 4. ALL PIPE FITTINGS - ASTM A-105 GR. 2
 5. ALL PIPING ON THIS SHEET IS CONSIDERED CODE CLASS 'E'

SIS PUMP	2-1	2-2
DRAIN LINE NUMBER	S2 693 2	S2 164 2

SIS. PUMP 2-1
SEAL & DRIP POCKET DRAIN SYSTEM
 SEE TABLE FOR PUMP 2-2

SIZE MPT	NO REQ'D. FOR ONE	DESCRIPTION
1 1/2"	AS REQ'D.	PIPE - C.T.S.
1"	AS REQ'D.	TUBING .049 WALL THICKNESS
3/4"	AS REQ'D.	TUBING .049 WALL THICKNESS
2"	1	TEE - 2000#
1 1/2"	2	CROSS-2000#
1 1/2"	1	ELBOW - 2000#
1 1/2"x1"	2	HEX BUSHING
1 1/2"x1/2"	4	HEX BUSHING
2"x1 1/2"	2	HEX BUSHING
1"	4	16-16 FBZ-SS-OR EQUAL ①
1/2"	8	12-8 FBZ -SS-OR EQUAL ①

WESTINGHOUSE EL. CORP.-APP.

PUMP NO.	SPIN NO.
② 45493/99	PSE SIAPSI - 1/2
45491/92	AEP SIAPSI - 1/2
45490/94	AMP SIAPSI - 1/2
45495/96	PNJ SIAPSI - 1/2
45497/98	PGE SIAPSI - 1/2
45489/500	PEG SIAPSI - 1/2

SAFETY INJECTION
 CUST. OR. NO. 54-E-705-03B SUPP
 DATE: 6-25-69

DC-663216-28

UNIT - 2

OUR OR. NO. 346-384
2/2-JTCN-105764

P G & E CO.	DRAWING NUMBER	REVISION
	108009	17
SHEET 6 OF SHEETS	MICROFILM	

RM INDEXED REV 17

THIS DRAWING HAS BEEN REPRODUCED
 WITHOUT CHANGE FROM ORIGINAL DRAWING
 CHANGE NO. 1 DATE 11-1-65 APPROVED: [Signature]

SCANNED 11/17
 APPD 16/17