



ABANDONED IN PLACE

UNIT-2 BORIC ACID EVAPORATOR

- NOTES:**
1. STRAINERS REQUIRE FLANGE AND SUCTION PIPING FLEXIBLE ENOUGH TO FACILITATE INSTALLATION OF PANCAKE STRAINERS FOR START-UP.
  2. THIS SYSTEM IS PROVIDED AS A PACKAGE AND SUPPLIED BY WESTINGHOUSE. SEE DC-663210-148 FOR PIPING AND VALVE SPECS. INCLUDED IN THE EQUIPMENT SKID ASSEMBLY.
  3. FOR REF. NOS. INDICATED BY [ ] SEE REF. DWG DC-663210-02.
  4. ALL VALVE WITH ITEM NUMBERS TO BE UNDER SPEC. 0722.
  5. 3/8" TUBING INSERTED IN 3/4" NOMINAL PIPE AT VALVE. (52C-C)
  6. HIGH POINT LOOP IN LINE 2561 TO PREVENT LIQUID FROM ENTERING VENT HEADER (53C-E)
  7. ALL PIPING SHOWN ON THIS SHEET SHALL BE CLASS "E" EXCEPT AS NOTED.
  8. VENT CONDENSER, EVAPORATOR CONDENSER AND DISTILLATE COOLER ARE DESIGN CLASS II AND ARE SEISMICALLY ANALYZED BY THE SUPPLIER.
  9. SAMPLE COOLER 47 IS DESIGN CLASS II AND IS SEISMICALLY ANALYZED PER DESIGN CRITERIA MEMORANDUM M-61.
  10. DRAGON MODEL 500F 3/8" GLOBE VALVE, 45V OR EQUIVALENT (53C-C)
  11. HCV-740 IS A XOMOX MODEL 1265W-3/4" WITH XOMOX 7 SLEEVE (54C-B)
  12. RV-54 RUPTURE DISK INTERNAL REMOVED.
  13. THESE VALVE INTENTIONALLY LEFT OPEN & UNCAPPED.

DIABLO CANYON POWER PLANT - PG&E CO.			
CHEMICAL & VOLUME CONTROL SYSTEM			
DRAWING	SHEET	PAGE	REV
108008	5C	0	75

RASTER=108008-5C-0.dgn  
 DGN=108008-5C-0.dgn  
 CAD User: ZNS4 Date:06-11-2018

06-11-2018	ZNS4	FXC2	N/A	NOT REQUIRED PER CF3.ID5	-	-	-	Revised Per DDT-4*1627
DATE	DWN	RE	IV	PROFESSIONAL ENGINEER	PE DISC.	PE#	PE EXP.	