



- NOTES:**
- ANCHOR/DARLING 3/4"-1878GB { DC-6006473-9 { 31A-D } 32A-A } 32A-E }  
S/C 94-2820
  - 7'-6" LONG SCHEDULE 10S STANDPIPE. BOTH ENDS CAPPED A MINIMUM 3 PSI WATER PRESSURE IS REQUIRED AT NOZ. 19 <38A-B>
  - THIS PIPING SHOULD BE SLOPED DOWNHILL THROUGH THE RUN OF THE DRAIN <39A-D>
  - LABYRINTH SEAL THERMAL BARRIER <35A-D>
  - MAKEUP WATER LINE FROM THE PRESSURIZER RELIEF TANK PRIMARY MAKEUP WATER SUPPLY <35A-D>
  - ALL ITEM NUMBERS IN CVCS ARE SHOWN WITHOUT PREFIX PGECs.
  - TOP OF LOOP SEAL IS 6" ABOVE NOZ. 11 <37A-C>
  - ANCHOR/DARLING 1"-1878GB, DC-6006473-157, S/C 94-3771. <31A-E> ^2
  - CODE CLASS BOUNDARIES ARE DEFINED IN DWG 663207 SH.56. <35A-C>

REF. DWG. DC-663210-14

UNIT 1

DIABLO CANYON POWER PLANT - PG&E CO.			
CHEMICAL & VOLUME CONTROL SYSTEM			
DRAWING	SHEET	PAGE	REV
102008	3A	0	114

RASTER=2008s3a.dgn  
 DCN=2008s3a.dgn  
 CAD User: AJFJ Date: 06-06-2012