



YARD LOOP

NOTES

- LEGEND: ACP ASBESTOS CEMENT PIPE
 □ FIRE HYDRANT: FH (26-D)
 □ FIREWATER HOSEREEL: FW (26-D)
 ⊠ POST INDICATOR ISOLATION VALVE: FP (26-D)
 ⊠ UNDERGROUND VALVE: FU (29-B)
- ALL OUTDOOR PIPING AND VALVES ON THIS SHEET ARE BY CIVIL UNDER SPEC 8831 EXCEPT TRANS. DELUGE SYSTEMS (FCV 208, 209, 210, 211, 212, 213, & 214) WHICH ARE UNDER SPEC 8724 OR AS NOTED MECH PIPING AND VALVES.

REFERENCE DRAWINGS:
 TRANSFORMER DELUGE SYSTEM: DC-663086-113, 115, 222, 223, 224, 227 & 229
 FIREWATER HOSEREEL STATION DETAILS: 064358 AND 064359

NOTES (CONT.)

- CHECK-VALVES ARE CRANE 150#, 147-1/2"
 GATE VALVES ARE CRANE 150#, 47-1/2"
- TEMPORARY CONNECTION FROM HYDRANT PROVIDES COOLING WATER FOR AIR-DRYER 0-5 AFTERCOOLER DURING OUTAGES. (26-D)

P G & E CO.		108018	REV. 45
SHEET 2	PAGE 0		

CAD User: NDNI Date: 8-23-2001
 DCN-001F1037.DGN
 PASTER-001F1037.TIF