



- NOTES**
- PG&E CLASS CODE [] MANUAL VALVES WITH ITEM NOS. ARE UNDER SPEC 8762 EXCEPT AS NOTED
 - ON ALL TRAPS AND LCV DRAINS, FULL INSULATION IS USED UPSTREAM AND PERSONNEL PROTECTION DOWNSTREAM
 - (W) DENOTES WESTINGHOUSE NOZZLE
 - ALL PIPING THIS SHEET PG&E CLASS CODE []
 - REFER TO E-H SYS. DWG 108020 SHTS 3&3A

6. ADDITIONAL INST & NOZZLES FOR LP MS-R DRAIN TANK

LP MS-R DRAIN-TK	LI NOZ N8/N7	LS (LOA) NOZ N8/N9	LB (HIA) NOZ N10/N11
2-1A	253	253A	253B
2-1B	254	254A	254B
2-1C	255	255A	255B

6A. 4"-600# GATE VALVE VELAN MOD #312-2054P-02TS WITH 1/2" BYPASS VALVE STOCK CODE 85-1109 [34 38-E]

7. 3/4"-1200# GLOBE VALVE, WALWORTH MODEL 5585 [39-E]

- 2 1/2" PIPING DENOTED IS PG&E PIPING SPEC 56 EXCEPT MATERIAL IS 304L AND SOCKET WELDING ENDS ARE USED AT ELBOWS [34, 36, 38 E]
- 1/2" SW GLOBE VALVE, VOGT SW-12141 FHF [35-C]
- CONDENSER N, INJECTION FOR DISSOLVED O, CONTROL IS THROUGH PX-367 AND PX-369. FOR N₂ SUPPLY, SEE DWG 108005 COORD 79-C. [36-C] [38-C]
- DELETED

DIABLO CANYON POWER PLANT - PG&E CO.
TURBINE STEAM SUPPLY SYSTEM

DRAWING	SHEET	PAGE	REV
108004	4	0	92