



- NOTE:**
1. ALL PIPING ON THIS SHEET SHALL BE PG&E CODE CLASS E.
  2. ALL PIPING AND VALVES ON THIS SHEET SHALL BE INSTALLED UNDER SPEC. 8711.
  3. ALL MANUAL VALVES SHALL BE V-0673 UNLESS OTHERWISE NOTED
  4. ALL CHECK VALVES SHALL BE C-0651
  - 5 1" VOGT GLOBE, SW-3241
  - 6 IDEAL AREOSMITH NEEDLE VALVES, V-51-12-43 (1/2") & 51-4-23 (1/4"), CAST BRONZE BODY WITH SS NEEDLE

7 1/4" 150 #s SS, SOCKET-WELD ENDS (FOR 40S PIPE)  
 GLOBE VALVE (PACIFIC MODEL #G-62-108 OR EQUAL)  
 8. REGULATING VALVE, WHITEY SS-6NRF4

**FEEDWATER HEATERS**

**UNIT - 2**

PG & E CO.	108005	REV.	46
SHEET 7	PAGE 0		

CAD User:RJN3 Date: 4-24-1998  
 DGN:800557.DGN  
 PASTER:800557.TIF