



NOTES:

1. ALL PIPING ON THIS SHEET TO BE CODE CLASS E
2. ALL ISOLATION VALVES ON THIS SHEET WITH PG&E MARK NO' s, SHALL BE FURNISHED BY SPEC 8711
3. PIPING & SWAGE MATERIAL SHALL BE PER SPEC S2 EXCEPT THAT THE WALL THICKNESS SHALL BE SCH. 80 & MATERIAL SHALL BE TP 304L; FOR VALVE & FLANGE, USE TP 304 56-B,E
4. PIPING MATERIALS SHALL BE ASTM A335 GR. P-22, SCH. 160 54/55-B,D
5. FLANGE PAIRS IMMEDIATELY UPSTREAM & DOWNSTREAM OF FLOW SECTIONS FE-612/FE-613 & IMMEDIATELY UPSTREAM OF PCV-72/PCV-73 ARE PER PIPE SPEC. K. 57-C,E
6. PALL FILTER P/N: HH8600B16**TBP INSTALLED PER ATMM A0543788 52-E 52-B,C

FEEDWATER PUMPS SHAFT SEAL SYSTEM
DC-663055-2,5

107-B 04
HP STM PURITY
ANALYZER
SAMPLE RETURN

P G & E CO.		108003	REV.
SHEET 5	PAGE 0		50

CAD User: rxg2 Date: 10-16-2002
 DGN: ERU09579.DGN
 PASTER: ERU09579.TIF