



- NOTES:**
1. ALL PIPING ON THIS SHEET SHALL BE PG&E CODE CLASS E. ALL MAIN FEEDWATER & FEEDWATER BY-PASS PIPING FROM THE CODE CLASS BREAK CHECK VALVE TO THE G-LINE ANCHOR AT THE TURBINE BUILDING WALL IS SEISMICALLY ANALYZED.
 2. ALL VALVES ON THIS SHEET WITH ITEM NO. SHALL BE SPEC 8762.
 3. 6" 900# GATE VALVES PURCHASED UNDER P.O. 4R-66018
 4. DELETED
 5. VENT, DRAIN AND TEST CONNECTION PIPING ON BYPASS LINES IS K16 SPEC UNLESS OTHERWISE NOTED
 6. VALVES FCV-510, 520, 530, 540, 1510, 1520, 1530 & 1540 ARE "Q" SAFETY RELATED DESIGN CLASS I.
 7. DELETED
 8. SEE DWGS 500142 & 500144 FOR PIPING MATERIAL CHROMIUM REQUIREMENTS.

UNIT I

DIABLO CANYON POWER PLANT - PG&E CO.
FEEDWATER SYSTEM

DRAWING	SHEET	PAGE	REV
102003	3A	0	70

RASTER=102003.s3a.dgn
 DGN=102003.s3a.dgn
 CAD User: JBMX Date: 06-06-2012