



NOTE  
 1. 1/2 SCH 80 PIPE ANSI B167 ALLOY 600 (INCONEL 600)  
 2. 1/2"-3000# SW ELI ANSI B36.10 WPNC1 (INCONEL 600) PORTIONS OF THIS PIPE REPLACED DUE TO EROSION/CORROSION. DOES NOT CONFORM TO THE PIPE SPEC. SEE APPROPRIATE ISOMETRIC DWG FOR DETAILS.  
 3. NOZZLE I.D. CLAD WITH INCONEL. (46-D) (46-C) (46-A)

DIABLO CANYON POWER PLANT - PG&E CO.  
 EXTRACTION STEAM AND HEATER DRIP SYSTEMS

DRAWING	SHEET	PAGE	REV
108005	4	0	56

UNIT 2

RASTER=108005s4XX.dgn  
 DGN=108005s4XX.dgn  
 CAD User: ZNS4 DDate: 03-17-2015

03-17-2015	ZNS4	KJD3	N/A	NOT REQUIRED PER CF3.1D5	-	-	-	REVISED PER DFT-7*2977
DATE	DWN	RE	IV	PROFESSIONAL ENGINEER	PE DISC.	PE#	PE EXP.	