



SJAE JET AIR INLET

JETS	LINE NO.'S
1-2	1087
3-4	1086
5-6	2603
7-8	2604

- NOTES:**
1. VALVE WITH ITEM NO. SHALL BE PER SPEC 1363.
 2. ALL PIPING ON THIS SHEET ARE CODE CLASS E UNLESS OTHERWISE NOTED.
 3. HALF COUPLING USED AS A CONDENSER LEAK DETECTION PROBE. (GG-A)
 4. FE-81 SPOOL PIECE TO MEET K SPEC REQMTS WITH THE EXCEPTION OF USING A 2" SCH. 40 PIPE. FE-81 SPOOL IS INSTALLED ON LINE K-1091-4".
 5. FOR FUTURE CHEMICAL INSPECTION SYSTEM (65-A)

DIABLO CANYON POWER PLANT - PG&E CO.
CONDENSATE SYSTEM

DRAWING	SHEET	PAGE	REV
108002	6	0	87

UNIT 2