


TABLE OF SAFETY CLASS STRUCTURES

<u>NO.</u>	<u>STRUCTURE</u>
1	REACTOR BUILDING COMPLEX
2	AUXILIARY BUILDING
3	FUEL HANDLING BUILDING
4	INTERMEDIATE BUILDING
5	CONTROL COMPLEX
6	RADWASTE BUILDING
7	DIESEL GENERATOR BUILDING
8	OFF GAS BUILDING
9	INTAKE STRUCTURES
10	INTAKE TUNNEL
11	EMERG.SERV.WATER PUMPHOUSE
12	DISCHARGE STRUCTURE
13	DISCHARGE TUNNEL
*	UNIT 2 REACTOR BUILDING COMPLEX AND UNIT 2 AUXILIARY BUILDING ARE ABANDONED, RETIRED-IN-PLACE



(REV. 19 10/2015)

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

LOCATION OF
SAFETY CLASS STRUCTURES

FIGURE 3.2-1

Removed in Accordance with RIS 2015-17

<p>PERRY NUCLEAR POWER PLANT 10 CENTER RD., PERRY, OHIO 44081</p>
<p>SCOPE OF HIGH ENERGY, SAFE SHUTDOWN AND BREAK EXCLUSION PIPING, FOR REACTOR BUILDING, ELEV. 574'-10" - EAST FIGURE 3.6-1 (DWG. D-303-0601-00000)</p>

Removed in Accordance with RIS 2015-17

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

SCOPE OF HIGH ENERGY, SAFE SHUTDOWN
AND BREAK EXCLUSION PIPING,
FOR REACTOR BUILDING, ELEV. 574'-10" -WEST
FIGURE 3.6-2
(DWG. D-303-0602-00000)

Removed in Accordance with RIS 2015-17

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

SCOPE OF HIGH ENERGY, SAFE SHUTDOWN
AND BREAK EXCLUSION PIPING, FOR
REACTOR BUILDING, ELEV. 599'-9" - EAST

FIGURE 3.6-3

Removed in Accordance with RIS 2015-17

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

SCOPE OF HIGH ENERGY, SAFE SHUTDOWN
AND BREAK EXCLUSION PIPING, FOR
REACTOR BUILDING, ELEV. 599'-9" - WEST

FIGURE 3.6-4

Removed in Accordance with RIS 2015-17

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

SCOPE OF HIGH ENERGY, SAFE SHUTDOWN
AND BREAK EXCLUSION PIPING, FOR
REACTOR BUILDING, ELEV. 620'-6" - EAST

FIGURE 3.6-5

Removed in Accordance with RIS 2015-17

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

SCOPE OF HIGH ENERGY, SAFE SHUTDOWN
AND BREAK EXCLUSION PIPING, FOR
REACTOR BUILDING, ELEV. 620'-6" - WEST

FIGURE 3.6-6

Removed in Accordance with RIS 2015-17

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

PIPING ARRANGEMENTS FOR FEEDWATER
IN REACTOR BUILDING AND STEAM TUNNEL

FIGURE 3.6-7
(DWG. D-304-0078-00000)

Removed in Accordance with RIS 2015-17

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

SCOPE OF HIGH ENERGY, SAFE SHUTDOWN
AND BREAK EXCLUSION PIPING, FOR
REACTOR BUILDING, ELEV. 642'-0" - EAST

FIGURE 3.6-8

Removed in Accordance with RIS 2015-17

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

SCOPE OF HIGH ENERGY, SAFE SHUTDOWN
AND BREAK EXCLUSION PIPING, FOR
REACTOR BUILDING, ELEV. 642'-0" - WEST

FIGURE 3.6-9

Removed in Accordance with RIS 2015-17

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

SCOPE OF HIGH ENERGY, SAFE SHUTDOWN AND
BREAK EXCLUSION PIPING, FOR
REACTOR BUILDING, STANDBY LIQUID CONTROL
FIGURE 3.6-10
(DWG. D-304-0691-00000)

Removed in Accordance with RIS 2015-17

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

SCOPE OF HIGH ENERGY, SAFE SHUTDOWN AND
BREAK EXCLUSION PIPING, FOR
REACTOR BUILDING, STANDBY LIQUID CONTROL
FIGURE 3.6-11
(DWG. D-304-0692-00000)

Removed in Accordance with RIS 2015-17

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

SCOPE OF HIGH ENERGY, SAFE SHUTDOWN
AND BREAK EXCLUSION PIPING, FOR
REACTOR BUILDING, ELEV. 652'-2" - EAST

FIGURE 3.6-12

Removed in Accordance with RIS 2015-17

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

SCOPE OF HIGH ENERGY, SAFE SHUTDOWN
AND BREAK EXCLUSION PIPING, FOR
REACTOR BUILDING, ELEV. 652'-2" - WEST

FIGURE 3.6-13

Removed in Accordance with RIS 2015-17

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

SCOPE OF HIGH ENERGY, SAFE SHUTDOWN
AND BREAK EXCLUSION PIPING, FOR
REACTOR BUILDING, ELEV. 664'-7" - EAST

FIGURE 3.6-14

Removed in Accordance with RIS 2015-17

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

SCOPE OF HIGH ENERGY, SAFE SHUTDOWN
AND BREAK EXCLUSION PIPING, FOR
REACTOR BUILDING, ELEV. 664'-7" - WEST

FIGURE 3.6-15

Removed in Accordance with RIS 2015-17

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

SCOPE OF HIGH ENERGY, SAFE SHUTDOWN
AND BREAK EXCLUSION PIPING, FOR
REACTOR BUILDING, CONTAINMENT SPRAY

FIGURE 3.6-16

Removed in Accordance with RIS 2015-17

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

SCOPE OF HIGH ENERGY, SAFE SHUTDOWN
AND BREAK EXCLUSION PIPING, FOR
REACTOR BUILDING, CONTAINMENT SPRAY

FIGURE 3.6-17

Removed in Accordance with RIS 2015-17

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

SCOPE OF HIGH ENERGY, SAFE SHUTDOWN AND
BREAK EXCLUSION PIPING, FOR
AUXILIARY BUILDING, ELEV. 574'-10" - EAST

FIGURE 3.6-18

Removed in Accordance with RIS 2015-17

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

SCOPE OF HIGH ENERGY, SAFE SHUTDOWN AND
BREAK EXCLUSION PIPING, FOR
AUXILIARY BUILDING, ELEV. 574'-10" - WEST

FIGURE 3.6-19

Removed in Accordance with RIS 2015-17

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

SCOPE OF HIGH ENERGY, SAFE SHUTDOWN AND
BREAK EXCLUSION PIPING, FOR
AUXILIARY BUILDING, ELEV. 599'-0" - EAST

FIGURE 3.6-20

Removed in Accordance with RIS 2015-17

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

SCOPE OF HIGH ENERGY, SAFE SHUTDOWN AND
BREAK EXCLUSION PIPING, FOR
AUXILIARY BUILDING, ELEV. 599'-0" - WEST

FIGURE 3.6-21

Removed in Accordance with RIS 2015-17

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

SCOPE OF HIGH ENERGY, SAFE SHUTDOWN AND
BREAK EXCLUSION PIPING, FOR
AUXILIARY BUILDING, ELEV. 620'-6" - EAST

FIGURE 3.6-22

Removed in Accordance with RIS 2015-17

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

SCOPE OF HIGH ENERGY, SAFE SHUTDOWN AND
BREAK EXCLUSION PIPING, FOR
AUXILIARY BUILDING, ELEV. 620'-6" - WEST

FIGURE 3.6-23

Removed in Accordance with RIS 2015-17

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

SCOPE OF HIGH ENERGY, SAFE SHUTDOWN AND
BREAK EXCLUSION PIPING, FOR
AUXILIARY BUILDING, STEAM TUNNEL,
ELEVS. 614'-6" AND 620'-6"
FIGURE 3.6-24

Removed in Accordance with RIS 2015-17

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

SCOPE OF HIGH ENERGY, SAFE SHUTDOWN AND
BREAK EXCLUSION PIPING, FOR
INTERMEDIATE BUILDING, ELEV. 574'-10" -
NORTHWEST
FIGURE 3.6-25

Removed in Accordance with RIS 2015-17

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

SCOPE OF HIGH ENERGY, SAFE SHUTDOWN AND
BREAK EXCLUSION PIPING, FOR
INTERMEDIATE BUILDING, ELEV. 574'-10" -
SOUTHWEST
FIGURE 3.6-26

Removed in Accordance with RIS 2015-17

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

SCOPE OF HIGH ENERGY, SAFE SHUTDOWN AND
BREAK EXCLUSION PIPING, FOR
INTERMEDIATE BUILDING, ELEV. 574'-10" -
CENTER
FIGURE 3.6-27

Removed in Accordance with RIS 2015-17

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

SCOPE OF HIGH ENERGY, SAFE SHUTDOWN AND
BREAK EXCLUSION PIPING, FOR
INTERMEDIATE BUILDING, ELEV. 574'-10" -
EAST
FIGURE 3.6-28

Removed in Accordance with RIS 2015-17

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

SCOPE OF HIGH ENERGY, SAFE SHUTDOWN AND
BREAK EXCLUSION PIPING, FOR
INTERMEDIATE BUILDING, ELEV. 599'-0" -
NORTHWEST
FIGURE 3.6-29

Removed in Accordance with RIS 2015-17

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

SCOPE OF HIGH ENERGY, SAFE SHUTDOWN AND
BREAK EXCLUSION PIPING, FOR
INTERMEDIATE BUILDING, ELEV. 599'-0" -
SOUTHWEST
FIGURE 3.6-30

Removed in Accordance with RIS 2015-17

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

SCOPE OF HIGH ENERGY, SAFE SHUTDOWN AND
BREAK EXCLUSION PIPING, FOR
INTERMEDIATE BUILDING, ELEV. 620'-6" -
NORTHWEST
FIGURE 3.6-31

Removed in Accordance with RIS 2015-17

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

SCOPE OF HIGH ENERGY, SAFE SHUTDOWN AND
BREAK EXCLUSION PIPING, FOR
INTERMEDIATE BUILDING, ELEV. 620'-6" -
SOUTHWEST
FIGURE 3.6-32

Removed in Accordance with RIS 2015-17

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

SCOPE OF HIGH ENERGY, SAFE SHUTDOWN AND
BREAK EXCLUSION PIPING, FOR
INTERMEDIATE BUILDING, ELEV. 620'-6" -
CENTER
FIGURE 3.6-33

Removed in Accordance with RIS 2015-17

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

SCOPE OF HIGH ENERGY, SAFE SHUTDOWN AND
BREAK EXCLUSION PIPING, FOR
INTERMEDIATE BUILDING, ELEV. 639'-6" -
NORTHWEST
FIGURE 3.6-34

Removed in Accordance with RIS 2015-17

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

SCOPE OF HIGH ENERGY, SAFE SHUTDOWN AND
BREAK EXCLUSION PIPING, FOR
INTERMEDIATE BUILDING, ELEV. 639'-6" -
SOUTHWEST
FIGURE 3.6-35

Removed in Accordance with RIS 2015-17

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

SCOPE OF HIGH ENERGY, SAFE SHUTDOWN AND
BREAK EXCLUSION PIPING, FOR
INTERMEDIATE BUILDING, ELEV. 654'-6" -
NORTHWEST
FIGURE 3.6-36

Removed in Accordance with RIS 2015-17

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

SCOPE OF HIGH ENERGY, SAFE SHUTDOWN AND
BREAK EXCLUSION PIPING, FOR
INTERMEDIATE BUILDING, ELEV. 654'-6" -
SOUTHWEST
FIGURE 3.6-37

Removed in Accordance with RIS 2015-17

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

SCOPE OF HIGH ENERGY, SAFE SHUTDOWN AND
BREAK EXCLUSION PIPING, FOR
INTERMEDIATE BUILDING, ELEV. 655'-0" -
WEST
FIGURE 3.6-38

Removed in Accordance with RIS 2015-17

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

SCOPE OF HIGH ENERGY, SAFE SHUTDOWN AND
BREAK EXCLUSION PIPING, FOR
CONTROL COMPLEX, ELEV. 574'-10" - EAST

FIGURE 3.6-39

Removed in Accordance with RIS 2015-17

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

PIPING ARRANGEMENT FOR CCCW-CONTROL
COMPLEX, ELEV. 574'-10" - WEST

FIGURE 3.6-40
(DWG. D-923-0002-00000)

Removed in Accordance with RIS 2015-17

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

PIPING ARRANGEMENT FOR ESW-CONTROL
COMPLEX

FIGURE 3.6-41
(DWG. D-304-0804-00000)

Removed in Accordance with RIS 2015-17

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

PIPING ARRANGEMENT FOR ESW-CONTROL
COMPLEX

FIGURE 3.6-42
(DWG. D-304-0802-00000)

Removed in Accordance with RIS 2015-17

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

PIPING ARRANGEMENT FOR
CCCW-CONTROL COMPLEX, ELEV. 679'-6" - EAST

FIGURE 3.6-43
(DWG. D-923-0005-00000)

Removed in Accordance with RIS 2015-17

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

PIPING ARRANGEMENT FOR
CCCW-CONTROL COMPLEX, ELEV. 679'-6" - WEST

FIGURE 3.6-44
(DWG. D-923-0004-00000)

Removed in Accordance with RIS 2015-17

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

PIPING ARRANGEMENT FOR
ESW-DIESEL GENERATOR BUILDING

FIGURE 3.6-45
(DWG. D-304-0805-00000)

Removed in Accordance with RIS 2015-17

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

PIPING ARRANGEMENT FOR RADWASTE
BUILDING AUXILIARY STEAM



FIGURE 3.6-46
(DWG. D-304-0058-00000)

Removed in Accordance with RIS 2015-17

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

ENVIRONMENTAL ZONE MAP EMERGENCY
SERVICE WATER PUMPHOUSE
PLANS AND ELEVATIONS
FIGURE 3.11-47
(DWG. E-022-0067-00000)

TYPICAL FORCE DEFLECTION CURVE FOR
A 6-BAR, 24-in. PIPE RESTRAINT LOADED AT 0°




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Typical Restraint Force-
Deflection Curve

Figure 3.6-48




(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Break Locations and Restraints -
PDA Verification Program



Figure 3.6-49



(A) CIRCUMFERENTIAL BREAK - FULL SEPARATION



(B) CIRCUMFERENTIAL BREAK - PARTIAL SEPARATION



(C) LONGITUDINAL BREAK


(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Jet Characteristics


Figure 3.6-50



PERRY NUCLEAR POWER PLANT

Homogeneous Jet Asymptotic Area-
Saturated Water and Steam
Blowdown

Figure 3.6-51




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

fL/D Versus Ratio of Width of Jet at Asymptotic Plane to Width of Jet at Break Plane - Steam

Figure 3.6-52




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT


fL/D Versus Ratio of Width of Jet at Asymptotic Plane to Width of Jet at Break Plane - Saturated Water

Figure 3.6-53



(Rev. 12 1/03)

	PERRY NUCLEAR POWER PLANT
Typical Pipe Whip Restraint Configuration Figure 3.6-54	



PEN. NO.	LOCATION	SAFETY CLASS
P415	AS SHOWN 3'-8" WEST OF 0° ϕ	1
P424	OPPOSITE 3'-8" EAST OF 0° ϕ	1
P416	AS SHOWN 11'-0" WEST OF 0° ϕ	1
P422	OPPOSITE 11'-0" EAST OF 0° ϕ	1


- NOTES -
- FOR WELD ENG. DETAILS, SEE DWG. B-301-001.
 - THIS DRAWING TO BE WORKED IN CONJUNCTION WITH B-312-001 THRU B-312-005 (CONTAINMENT VESSEL PENETRATION LIST).
 - FLUED HEADS AND STEAM PIPES TO BE SUPPLIED BY G.E. PENETRATION ASSEMBLY FABRICATION BY SP-525 CONTRACTOR, INSTALLATION BY SP-30 CONTRACTOR.
 - FOR SECTION AND DETAILS, SEE DWG. B-312-042.
 - S.W. INDICATES SHOP WELD. - F.W. INDICATES FIELD WELD.
 - SAFETY CLASS REFERS TO PROCESS PIPE ONLY. PROCESS PIPE SUPPORTS TO BE IN ACCORDANCE WITH NF, OTHER INTEGRAL PARTS TO BE IN ACCORDANCE WITH MC OF THE ASME SECTION III CODE.
 - ALL ATTACHMENTS AND COMPONENTS MARKED THUS * ARE INTEGRAL PARTS OF THE CONTAINMENT PENETRATION ASSEMBLY.
 - FOR MATERIAL AND SPECIFICATIONS, SEE GRI SPEC. SP-527-454B-00 AND SP-525-454B-00.
 - PROVIDE 22" X 6" X 2-1/2" LUBRITE PAD. BOTTOM SURFACE OF PAD TO BE MACHINED IN FIELD TO ACCOMMODATE MISALIGNMENT AND TOLERANCE.

FOR FIELD WELD REQUIREMENTS SEE ECN# 5166-38-88, 5166-38-88A, 5292-44-417, 6554-44-641, & 5166-38-88/B. THIS DWG. DOES NOT REFLECT FINAL DESIGN INFO. FOR FINAL DESIGN & ANALYSIS INFO. SEE TUBE TEMPL. DWG. 701935Y-C1-4, 701935Y-D1-1, 701935Y-C1-3.

- (NOTES CONTINUED)
- AFTER THREADING THE GUARD PIPE, BUILD UP SUFFICIENT WELD AROUND THE HOLE TO HAVE A FLAT SURFACE (TO BE MACHINED FLAT) AS A CONTACT AREA FOR THE LOCKNUT.
 - NUT IS TO BE TIGHTENED IN A MANNER TO PREVENT ANY SLIPPAGE BETWEEN THE PROCESS PIPE AND PROCESS PIPE CLAMP AND THEN TACK WELDED TO BOLT.
 - DIMENSIONS NOT SHOWN ON BOTH OF THE ABOVE DETAILS ARE TYPICAL FOR ALL TYPE K PENETRATION.



THIS USAR FIGURE CONTAINS HISTORICAL INFORMATION. FOR CURRENT INFORMATION SEE ASSOCIATED SYSTEM DIAGRAM USAR FIGURE.

(Rev. 14 10/05)

 **PERRY NUCLEAR POWER PLANT**

Penetration Guard Pipe Type
"K" Main Steam

Figure 3.6-55
(Dwg. B-312-641)



NOTES:-

- FOR WELD END DETAILS! SEE DWG. D-301-801.
- THIS DRAWING TO BE WORKED IN CONJUNCTION WITH B-312-601 THRU B-312-605 (CONTAINMENT VESSEL PENETRATION LIST)
- PROCESS PIPE SUPPLIED BY SP-527 CONTRACTOR. PENETRATION ASSEMBLY FABRICATED BY SP-525 CONTRACTOR AND INSTALLED BY SP-44 CONTRACTOR.
- FOR SECTIONS AND DETAILS, SEE DWG. B-312-603 (P421) AND B-312-670 (P422).
- S.W. - INDICATES SHOP WELD.
F.W. - INDICATES FIELD WELD.
- SAFETY CLASS REFERS TO PROCESS PIPE ONLY. PROCESS PIPE SUPPORTS TO BE IN ACCORDANCE WITH NF, OTHER INTEGRAL PARTS TO BE IN ACCORDANCE WITH MC OF THE ASME SECTION I, II CODE.
- ALL ATTACHMENTS AND COMPONENTS MARKED THUS ARE INTEGRAL PARTS OF THE CONTAINMENT PENETRATION ASSEMBLY.
- FOR MATERIAL AND SPECIFICATIONS, SEE BAI SPEC SP-627-4549-00 AND SP-628-4549-00.
- PROVIDE 22" X 6" 2-1/4" LUBRITE PAD. BOTTOM SURFACE OF PAD TO BE MACHINED IN FIELD TO ACCOMMODATE MISALIGNMENT AND TOLERANCES.
- AFTER THREADING THE GUARD PIPE, BUILD-UP SUFFICIENT WELD AROUND THE HOLE TO HAVE A FLAT SURFACE (TO BE MACHINED FLAT) AS A CONTACT AREA FOR THE LOCKNUT.
- NUT IS TO BE TIGHTENED IN 3 BANNER TO PREVENT ANY SLIPPAGE BETWEEN THE PROCESS PIPE AND PROCESS PIPE CLAMP, AND THEN TACK WELDED TO BOLT.
- ALL DIMENSIONS SHOWN IN CHART ARE IN INCHES.
- GUARD PIPE TO BE 23.750" O.D., X 19.750" I.D., AT GUARD PIPE W/IDE P-422 ONLY.







THIS USAR FIGURE CONTAINS HISTORICAL INFORMATION. FOR CURRENT INFORMATION SEE ASSOCIATED SYSTEM DIAGRAM USAR FIGURE.

(Rev. 14 10/05)

PERRY NUCLEAR POWER PLANT

Penetration Guard Pipe Type
"J" RCIC AND RHR

Figure 3.6-56
(Dwg. B-312-639)



NOTES:
 1. FOR NOTES, SEE DRAWING B-312-0656-00000.


FOR FIELD WELD REQ.
 SEE ECN 5427-44-437/A
 THIS DWG. DOES NOT REFLECT FINAL
 DESIGN INFO. FOR FINAL DESIGN
 & ANALYSIS INFO SEE TUBE TURN
 DWGS. 70195Y-C193.4 & C70195Y-C193.3.

(Rev. 13 12/03)


PERRY NUCLEAR POWER PLANT

Penetration Guard Pipe
 Details Type "J"

Figure 3.6-57
 (Dwg. B-312-640)



- NOTES -
- FOR WELD END DETAILS, SEE DWG. B-301-801, (FIGURE NO. 3)
 - THIS DRAWING TO BE WORKED IN CONJUNCTION WITH B-312-601 THRU B-312-605 (CONTAINMENT VESSEL PENETRATION LIST).
 - PROCESS PIPE SUPPLIED BY SP-527 CONTRACTOR. PENETRATION ASSEMBLY FABRICATION BY SP-525 CONTRACTOR, INSTALLATION BY SP-44 CONTRACTOR.
 - FOR SECTIONS AND DETAILS, SEE DWG. B-312-662.
 - S.W. INDICATES SHOP WELD.
F.W. INDICATES FIELD WELD.
 - ALL ATTACHMENTS AND COMPONENTS MARKED THUS * ARE INTEGRAL PARTS OF THE CONTAINMENT PENETRATION ASSEMBLY.
 - SAFETY CLASS REFERS TO PROCESS PIPE ONLY. PROCESS PIPE SUPPORTS TO BE IN ACCORDANCE WITH NF. OTHER INTEGRAL PARTS TO BE IN ACCORDANCE WITH MC OF THE ASME SECTION III CODE.
 - FOR MATERIAL AND SPECIFICATIONS, SEE GAI SPECIFICATION SP-527-4549-00 AND SP-525-4549-00.
 - PROVIDE 17" X 3" X 2-1/4" LUBRITE PAD. BOTTOM SURFACE OF PAD TO BE MACHINED IN FIELD TO ACCOMMODATE MISALIGNMENT AND TOLERANCES.
 - AFTER THREADING THE GUARD PIPE, BUILD UP SUFFICIENT WELD AROUND THE HOLE TO HAVE A FLAT SURFACE (TO BE MACHINED FLAT) AS A CONTACT AREA FOR THE LOCKNUT.
 - NUT IS TO BE TIGHTENED IN A MANNER TO PREVENT ANY SLIPPAGE BETWEEN THE PROCESS PIPE AND PROCESS PIPE CLAMP AND THEN TACK WELDED TO 90°.



FOR FIELD WELD REQUIREMENTS SEE EOM
5150-44-393/A & 6856-44-641/A

THIS DWG. DOES NOT REFLECT
FINAL DESIGN INFO. FOR
FINAL DESIGN & ANALYSIS
INFO. SEE TUBE TURN DWGS.
#70195Y-D33.1, 70195Y-
C33.4 & 70195Y-C33.3.


(Rev. 14 10/05)

PERRY NUCLEAR POWER PLANT

Penetration Guard Pipe
Type "Q" Feedwater

Figure 3.6-58
(Dwg. B-312-650)

THIS USAR FIGURE CONTAINS
HISTORICAL INFORMATION. FOR
CURRENT INFORMATION SEE
ASSOCIATED SYSTEM DIAGRAM
USAR FIGURE.





PLAN VIEW

PEN NO	LOCATION	SAFETY CLASS
P423	5'-4" WEST OF 0° CL	1

NOTES:

1. FOR WELD END DETAILS, SEE DWG. D-301-801.
 2. THIS DRAWING TO BE WORKED IN CONJUNCTION WITH DWG. B-312-801 THRU B-312-805 (CONTAINMENT VESSEL PENETRATION LIST).
 3. S.W. - INDICATES SHOP WELD.
F.W. - INDICATES FIELD WELD.
 4. PROCESS PIPE SUPPLIED BY SP-527 CONTRACTOR, PENETRATION ASSEMBLY FABRICATED BY SP-525 CONTRACTOR AND INSTALLED BY 3A-44 CONTRACTOR.
 5. SAFETY CLASS REFERS TO PROCESS PIPE ONLY. PROCESS PIPE SUPPORTS TO BE IN ACCORDANCE WITH NF, OTHER INTERNAL PARTS TO BE IN ACCORDANCE WITH MC OF THE ASME SECTION III CODE.
 6. FOR SECTIONS AND DETAILS, SEE DWG. B-312-840.
 7. ALL ATTACHMENTS AND COMPONENTS MARKED THUS * ARE INTEGRAL PARTS OF THE CONTAINMENT PENETRATION ASSEMBLY.
 8. FOR MATERIAL AND SPECIFICATIONS, SEE GAI SPECIFICATION SP-527-4548-00 AND SP-525-4548-00.
 9. PROVIDE 6" X 5" X 2" LUBRITE PAD. BOTTOM SURFACE OF PAD TO BE MACHINED IN FIELD TO ACCOMMODATE MISALIGNMENT AND TOLERANCES.
 10. BOLT IS TO BE TIGHTENED IN A MANNER TO PREVENT ANY SLIPPAGE BETWEEN THE PROCESS PIPE AND PROCESS PIPE CLAMP AND THEN TACK WELDED TO BOLT.
- FOR FIELD WELD REQUIREMENTS SEE ECN
 *5427-44-437A & 6856-44-641/A
 THIS DWG. DOES NOT REPRESENT FINAL DESIGN OR CONSTRUCTION DRAWING & ANALYSIS. SEE TUBE TURNING DWG.
 *70195Y-C193.4, *70195Y-D193.1, & *70195Y-C193.3




THIS JSAR FIGURE CONTAINS HISTORICAL INFORMATION. FOR CURRENT INFORMATION SEE ASSOCIATED SYSTEM DIAGRAM JSAR FIGURE.

(Rev. 14 10/05)

PERRY NUCLEAR POWER PLANT

Penetration Guard Pipe
Type "J" MS Drain

Figure 3.6-59
(Dwg. B-312-656)





* SEE NOTE #7

SEE NOTE #5

PEN. NO	LOCATION	SAFETY CLASS
P123	16'-0" EAST OF 0° CL	1

PLAN VIEW


- NOTES:-
1. FOR WELD END DETAILS, SEE DWG. B-301-801
 2. THIS DRAWING TO BE WORKED IN CONJUNCTION WITH DWG. B-312-801 THRU B-312-805 (CONTAINMENT VESSEL PENETRATION LIST).
 3. S.W. - INDICATED SHOP WELD
F.W. - INDICATED FIELD WELD.
 4. PROCESS PIPE SUPPLIED BY SP-527 CONTRACTOR, PENETRATION ASSEMBLY FABRICATED BY SP-525 CONTRACTOR AND INSTALLED BY SP-44 CONTRACTOR.
 5. SAFETY CLASS REFERS TO PROCESS PIPE ONLY. PROCESS PIPE SUPPORTS TO BE IN ACCORDANCE WITH NF, OTHER INTEGRAL PARTS TO BE IN ACCORDANCE WITH MC OF THE ASME SECTION III CODE.
 6. FOR SECTIONS AND DETAILS, SEE DWG. B-312-800.
 7. ALL ATTACHMENTS AND COMPONENTS MARKED THIS * ARE INTEGRAL PARTS OF THE CONTAINMENT PENETRATION ASSEMBLY.
 8. FOR MATERIAL AND SPECIFICATIONS, SEE DAT SPECIFICATION SP-527-4540-00 AND SP-525-4540-00.
 9. PROVIDE 8" X 8" X 2" W/WHITE PAD. BOTTOM SURFACE OF PAD TO BE MACHINED IN FIELD TO ACCOMMODATE MISALIGNMENT AND TOLERANCES.
 10. NUT IS TO BE TIGHTENED IN A MANNER TO PREVENT ANY SLIPPAGE BETWEEN THE PROCESS PIPE AND PROCESS PIPE CLAMP AND THEN TACK WELDED TO BOLT.
- THIS DWG DOES NOT REFLECT STRAIT DESIGN INFO. FOR FINAL DESIGN & ANALYSIS INFO. SEE TUBE TURNS DWG. 70195Y-D117.1, 70195Y-C117.4 & 70195Y-E117.3.
- FOR FIELD WELD REQUIREMENTS SEE ECN #2412-20-43), 5175-44-4011A & 6856-44-5A11A



THIS USAR FIGURE CONTAINS HISTORICAL INFORMATION. FOR CURRENT INFORMATION SEE ASSOCIATED SYSTEM DIAGRAM USAR FIGURE.

(Rev. 14 10/05)

	PERRY NUCLEAR POWER PLANT
	Penetration Guard Pipe Type "J" RCIC
	Figure 3.6-60 (Dwg. B-312-657)



FOR FIELD WELD REQUIREMENTS
SEE ECN # 5163-44-596/A.
THIS DWG. DOES NOT REFLECT FINAL
DESIGN INFO. FOR FINAL DESIGN &
ANALYSIS INFORMATION SEE TUBE
TURNS DWGS. # 70195Y-D49.1, #
70195Y-C49.3, # 70195Y-C49.4
70195Y-D201.1, C201.3, C201.4

* SEE NOTE #7
DWG. B-312-639.



NOTES:-
1. FOR NOTES, SEE DRAWING
B-312-639.

(Rev. 12 1/03)

PERRY NUCLEAR POWER PLANT

Penetration Guard Pipe
Details Type "J"

Figure 3.6-61
(Dwg. B-312-663)



- PLAN VIEW**
- NOTES:-
- FOR WELD END DETAILS, SEE DWS. D-301-601.
 - THIS DRAWING TO BE WORKED IN CONJUNCTION WITH DWS. B-312-801 THRU B-312-804 (CONTAINMENT VESSEL PENETRATION LIST).
 - S.W. - INDICATED SHOP WELD
F.W. - INDICATED FIELD WELD
 - PROCESS PIPE SUPPLIED BY SP-527 CONTRACTOR. PENETRATION ASSEMBLY FABRICATED BY SP-525 CONTRACTOR AND INSTALLED BY SP-44 CONTRACTOR.
 - SAFETY CLASS REFERS TO PROCESS PIPE ONLY. PROCESS PIPE SUPPORTS TO BE IN ACCORDANCE WITH NF, OTHER INTEGRAL PARTS TO BE IN ACCORDANCE WITH MC OF THE ASME SECTION III CODE.
 - FOR SECTIONS AND DETAILS, SEE DWS. B-312-668.
 - ALL ATTACHMENTS AND COMPONENTS MARKED THUS * ARE INTEGRAL PARTS OF THE CONTAINMENT PENETRATION ASSEMBLY.
 - FOR MATERIAL AND SPECIFICATIONS, SEE BAI SPECIFICATION SP-527-4542-00 AND SP-525-4549-00.
 - PROVIDE 3/4" x 2" LLITE PAD, BOTTOM SURFACE OF PAD TO BE MATCHED TO FIELD TO ACCOMMODATE MISALIGNMENT AND TOLERANCES.
 - NUT IS TO BE TIGHTENED IN A MANNER TO PREVENT ANY SLIPPAGE BETWEEN ONE PROCESS PIPE AND PROCESS PIPE CLAMP AND THEN TACK WELDED TO POLY.

THIS DWG. DOES NOT REFLECT FINAL DESIGN INFO.
FOR FINAL DESIGN & ANALYSIS INFO,
SEE TUBE TURNS DWGS. # 70195Y-017.3,
70195Y-D125.1, # 70195Y-C117.4
FOR FIELD WELD REQUIREMENTS SEE ECN
2440-44-52, # 2413-44-22,
5165-44-378/A & 4856-44-241/A


THIS USAR FIGURE CONTAINS HISTORICAL INFORMATION. FOR CURRENT INFORMATION SEE ASSOCIATED SYSTEM DIAGRAM USAR FIGURE.

(Rev. 14 10/05)

PERRY NUCLEAR POWER PLANT


Penetration Guard Pipe
Type "J" RWCU

Figure 3.6-62
(Dwg. B-312-667)



NOTES:
 1. FOR NOTES, SEE DRAWING B-312-638.

(Rev. 14 10/05)


PERRY NUCLEAR POWER PLANT

Penetration Guard Pipe
 Details Type "J"


Figure 3.6-64
 (Dwg. B-312-670)

FOR FIELD WELD REQUIREMENTS
 SEE ECN 2414-27-12-5170-44-899/A

THIS DWG. DOES NOT REFLECT FINAL DESIGN INFO. FOR
 FINAL DESIGN & ANALYSIS INFO. SEE TUBE TURNS
 DWGS. 70195Y, D201.1, C201.3, C201.4 &
 70195Y-D49.1, C49.3, C49.4.

THIS USAR FIGURE CONTAINS
 HISTORICAL INFORMATION. FOR
 CURRENT INFORMATION SEE
 ASSOCIATED SYSTEM DIAGRAM
 USAR FIGURE.

*** INACTIVE PIPE WHIP RESTRAINT**



NOTE: 1) Perry unique break locations designations in parenthesis.

STEAM LINES A & C SHOWN

(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Main Steam System Piping
Postulated Break Locations
and Restraint Locations

Figure 3.6-65 (Sheet 1 of 2)

*** INACTIVE PIPE WHIP RESTRAINT**



STEAM LINES B & D SHOWN









(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT


Main Steam System Piping
Postulated Break Locations
and Restraint Locations










Figure 3.6-65 (Sheet 2 of 2)



			
RESTRAINT	BALL JOINT	SPRING HANGER	SNUBBER
			
IN BEND ENDS	GUIDE	ISOLATION VALVE	RELIEF VALVE
JOINT NUMBER S101C - LINE LR - STRUT S - SNUBBER EQUIPMENT NO.			




(Rev. 12 1/03)














	PERRY NUCLEAR POWER PLANT
	Line A - Main Steam Piping Stress Node Locations Figure 3.6-65a



		
		
		
<p>RESTRAINT</p> <p>BALL JOINT</p> <p>IF BEND ENDS</p> <p>SPRING HANGER</p> <p>GUIDE</p> <p>ISOLATION VALVE</p> <p>RELIEF VALVE</p> <p>SNUBBER</p> <p>JOINT NUMBER</p> <p>SUPPORT LINE R - STRUT S - SNUBBER</p> <p>EQUIPMENT NO.</p>		



(Rev. 12 1/03)


	PERRY NUCLEAR POWER PLANT
<p>Line A - Main Steam Piping Stress Node Locations (Sweepolet)</p>	
<p>Figure 3.6-65b</p>	

	SNUBBER		JOINT NUMBER		STOIC LINE NO.		R = STRUT		S = SNUBBER		EQUIPMENT NO.
	SPRING HANGER		GUIDE		ISOLATION VALVE		RELIEF VALVE				
	RESTRAINT		BALL JOINT		IN BEND ENDS						



SEE DETAIL "A"














(Rev. 12 1/03)






PERRY NUCLEAR POWER PLANT


Node Point Stress Analysis
Diagram - Main Steam
Lines C and B













Figure 3.6-65c


		
RESTRAINT	SPRING HANGER	SNUBBER
		
BALL JOINT	GUIDE	JOINT NUMBER
		
IN BEND ENDS	ISOLATION VALVE	S101C LINE
		
		R - STRUT
		
		S - STRUT
		
		RELIEF VALVE
		
		EQUIPMENT NO.




(Rev. 12 1/03)













	PERRY NUCLEAR POWER PLANT
	Node Point Stress Analysis Diagram - Main Steam Lines C and B (Sweepolet)
	Figure 3.6-65d


			
RESTRAINT	BALL JOINT	SPRING HANGER	SNUBBER
			
IN BEND ENDS	GUIDE	ISOLATION VALVE	RELIEF VALVE
			
JOINT	STRUT	SNUBBER	EQUIPMENT NO.




(Rev. 12 1/03)

	PERRY NUCLEAR POWER PLANT
Node Point Stress Analysis Diagram - Main Steam Line D	
Figure 3.6-65e	


		
		
		
		




GLOBAL COORDINATE SYSTEM




LOCAL COORDINATE SYSTEM



(Rev. 12 1/03)

	PERRY NUCLEAR POWER PLANT
	Node Point Stress Analysis Diagram - Main Steam Line D (Sweepolet)
Figure 3.6-65f	



THIS IS REPRESENTATIVE OF LOOP 'B'
 LOOP 'A' SAME AS LOOP 'B' (EXCEPT FOR RHR SUCTION)

BREAKS ARE POSTULATED ONLY
 AT NUMBERED LOCATIONS SHOWN

*** INACTIVE - THE PIPE BREAKS ASSOCIATED
 WITH THESE RESTRAINTS HAVE
 BEEN DELETED.**


(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Recirculation System Piping
 Postulated Break Locations
 and Restraint Locations

Figure 3.6-66



* ~~INACTIVE~~ POSTULATED BREAKS
ASSOCIATED WITH THIS RESTRAINT
HAVE BEEN DELETED.


(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

RHR Suction Line Postulated
Break Locations
and Restraint Locations


Figure 3.6-66a



	SUCTION, DISCHARGE AND RHR GATE VALVES
	FLOW CONTROL VALVE
	SPRING HANGER
	CONSTANT SUPPORT HANGER
	SNUBBER
	STRUT
	ANCHOR

(Rev. 12 1/03)

	PERRY NUCLEAR POWER PLANT
	Recirculation System Node Diagram (Loop A and B)
Figure 3.6-66b	




(Rev. 12 1/03)

PERRY NUCLEAR POWER PLANT

Pipe Rupture Locations
Feedwater Inside Containment

Figure 3.6-67



(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Pipe Rupture Locations
LPCI (RHR) Inside Containment

Figure 3.6-68

NOTES:
 1- BREAKS ARE POSTULATED ONLY
 AT NUMBERED LOCATIONS SHOWN.



(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Pipe Rupture Locations
 Low Pressure Core Spray
 Inside Containment

Figure 3.6-69a

NOTE:
 1- BREAKS ARE POSTULATED
 ONLY AT NUMBERED LOCATIONS
 SHOWN.




(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT


Pipe Rupture Locations
 High Pressure Core Spray
 Inside Containment

Figure 3.6-69b












(Rev. 12 1/03)



 PERRY NUCLEAR POWER PLANT
Pipe Rupture Locations RCIC Steam - Inside Containment
Figure 3.6-70



(Rev. 12 1/03)


PERRY NUCLEAR POWER PLANT
 Pipe Rupture Locations RCIC
 Steam Supply - Outside Containment
 Figure 3.6-70a

			
RESTRAINT	BALL JOINT	SPRING HANGER	SNUBBER
			
IN BEND ENDS	GUIDE	ISOLATION VALVE	RELIEF VALVE
JOINT NUMBER		EQUIPMENT NO.	
S = STRUT		S = SNUBBER	
STAY NO.			




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

RCIC Steam Piping Inside Containment
Stress Node Locations

Figure 3.6-70b




NOTE:
 1- PIPE RUPTURES ARE POSTULATED
 ONLY AT FITTING WELDS SHOWN.

(Rev. 12 1/03)


PERRY NUCLEAR POWER PLANT


Pipe Rupture Locations Head Spray
 Fitting Drain to MS "A"

Figure 3.6-71



(Rev. 12 1/03)


	PERRY NUCLEAR POWER PLANT
CRD Supply - Inside Containment Figure 3.6-72 (Sheet 1 of 3)	





CONT. ON DWG.
FIG. 3.6-72 SHEET 1

NOTES:
1- BREAKS ARE POSTULATED AT EACH WELD AND FITTING SHOWN.
2- THRUST IS FROM SUPPLY SIDE ONLY.


(Rev. 12 1/03)

	PERRY NUCLEAR POWER PLANT
CRD Supply - Inside Containment Figure 3.6-72 (Sheet 2 of 3)	



NOTES:
1- BREAKS ARE POSTULATED AT EACH WELD AND FITTING SHOWN.
2- THRUST IS FROM SUPPLY SIDE ONLY.


(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

CRD Supply - Inside Containment


Figure 3.6-72 (Sheet 3 of 3)



*** INACTIVE - THE PIPE BREAKS ASSOCIATED WITH THESE RESTRAINTS HAVE BEEN DELETED.**

(REV. 19 10/2015)

<p>PERRY NUCLEAR POWER PLANT 10 CENTER RD., PERRY, OHIO 44081</p>
<p>PIPE RUPTURE LOCATIONS RWCU - INSIDE CONTAINMENT</p>
<p>FIGURE 3.6-73</p>



NOTES:
 1. NO BREAKS ARE POSTULATED, ALL PIPE SHOWN IS IN BREAK EXCLUSION AREA.
 2. NO RESTRAINTS.


(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT


Pipe Rupture Locations MS Drain
 Inside Containment


Figure 3.6-74



NOTES:
 1- LONGITUDINAL BREAKS ARE EVALUATED AT EACH LOCATION IN ADDITION TO CIRCUMFERENTIAL
 2- LINE "A" SHOWN, LINES "B", "C", & "D" SIMILAR.

(Rev. 12 1/03)

	PERRY NUCLEAR POWER PLANT
Pipe Rupture Locations MS Outside Containment	
Figure 3.6-75	




NOTES:
 1-LONGITUDINAL BREAKS ARE POSTULATED AT EACH LOCATION IN ADDITION TO CIRCUMFERENTIAL.

(Rev. 12 1/03)

PERRY NUCLEAR POWER PLANT


Pipe Rupture Locations FW
 Outside Containment


Figure 3.6-76



- NOTES:**
- 1 - ALL LINES CONTAIN WATER EXCEPT 3" CONNECTING "S" WITH W, X, Y AND Z, MS "A" WHICH IS STEAM.
 - 2 - EQUALIZING LINE HAS BREAKS POSTULATED AT EACH WELD TO VALVE OR FITTING.
 - 3 - DRAIN LINES DOWN STREAM OF VALVES B21F420A, B, C & D HAVE BREAKS POSTULATED AT EACH WELD TO VALVE OR FITTING.
 - 4 - MAIN STEAM LINES DO NOT HAVE ANY POSTULATED BREAKS IN THIS AREA.

(Rev. 12 1/03)

 PERRY NUCLEAR POWER PLANT
Pipe Rupture Locations MS Drains/ LCS Outside Containment
Figure 3.6-77



NOTES:

- 1- PIPE RUPTURES ARE POSTULATED AT WAI AND WBI FOR FEEDWATER LINES "A" AND "B."
- 2 LINES FROM RWCU AND RHR SHOWN ARE PART OF THE FEEDWATER BREAK EXCLUSION AREA.


(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT


Pipe Rupture Locations RWCU/RHR
To FW Outside Containment


Figure 3.6-78




NOTES:
 1. THRUST FROM BOILER SIDE ONLY.
 2. PIPE RUPTURES ARE POSTULATED AT EACH WELD, VALVE, & FITTING SHOWN.



(Rev. 12 1/03)

	PERRY NUCLEAR POWER PLANT
Pipe Rupture Locations Auxiliary Steam Outside Containment	
Figure 3.6-79	




(Rev. 12 1/03)

	PERRY NUCLEAR POWER PLANT
Pipe Rupture Locations RWCU Outside Containment	
Figure 3.6-80	




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Jet Impingement Recirculation Jet Striking HPCS

Figure 3.6-84



NOTES:

- 1- IMPINGEMENT ON 106° BUNDLE FROM RDA8 AT 120° IS OPPOSITE HAND.
- 2- IMPINGEMENT ON 254° BUNDLE FROM RDB7 AT 240° IS SIMILAR TO THAT SHOWN FOR RDA7.
- 3- IMPINGEMENT ON 286° BUNDLE FROM RDB8 AT 300° IS SIMILAR TO RDA8.


(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Jet Impingement Recirculation Jet Striking CRD Lines

Figure 3.6-85




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Jet Impingement LPCI "B"
Jet Striking HPCS

Figure 3.6-90




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Jet Impingement HPCS Jet Striking
LPCI "B"

Figure 3.6-91




(Rev. 12 1/03)

PERRY NUCLEAR POWER PLANT

Jet Impingement MS Jet Striking
Shield Building

Figure 3.6-92




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Feedwater Break WB9C -
Reactor Vessel Side (14" line)

Figure 3.6-95




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Feedwater Break WB12C -
Reactor Vessel Side (20" line)

Figure 3.6-96




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Feedwater Break WB11 -
End Cap Break (20" line)

Figure 3.6-97



THRUST (KIPS)


(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Feedwater Longitudinal Break
at Node 46 In Turbine Building

Figure 3.6-98




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Typical Jet Impingement Force Time
History (Example is a Feedwater
Line Break at the RPV Nozzle)

Figure 3.6-99




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Typical Pipe Whip Restraint Force

Figure 3.6-100



FORCE DESCRIPTION (ALL FUNCTIONS OF TIME)

1. PRESSURE LOADS
2. JET IMPINGEMENT FORCE
3. JET REACTION FORCE
4. PIPE RESTRAINT LOAD


(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Pressure/Forces in Asymmetric
Loading Analyses

Figure 3.6-101




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Safe Shutdown Earthquake
Design Response Spectra -
Horizontal Motion

Figure 3.7-1




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Safe Shutdown Earthquake
Design Response Spectra -
Vertical Motion

Figure 3.7-2




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Operating Basis Earthquake
Design Response Spectra -
Horizontal Motion

Figure 3.7-3



(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Operating Basis Earthquake
Design Response Spectra -
Vertical Motion

Figure 3.7-4

RESPONSE SPECTRUM - H1



(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Response Spectra -
Horizontal Motion H1
(2% and 5% Damping)

Figure 3.7-5

RESPONSE SPECTRUM - H1



(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Response Spectra -
Horizontal Motion H1
(7% and 10% Damping)

Figure 3.7-6

RESPONSE SPECTRUM - H2



(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Response Spectra -
Horizontal Motion H2
(2% and 5% Damping)

Figure 3.7-7

RESPONSE SPECTRUM - H2



(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Response Spectra -
Horizontal Motion H2
(7% and 10% Damping)

Figure 3.7-8

RESPONSE SPECTRUM - V



(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Response Spectra -
Vertical Motion
(2% and 5% Damping)

Figure 3.7-9

RESPONSE SPECTRUM - V





(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Response Spectra -
Vertical Motion
(7% and 10% Damping)

Figure 3.7-10




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Seismic Model for the
Reactor Building



Figure 3.7-11



LUMPED MASS MODEL

(Rev. 12 1/03)


	<p>PERRY NUCLEAR POWER PLANT</p>
<p>Seismic Model for Auxiliary Building</p>	
<p>Figure 3.7-12</p>	



LUMPED MASS MODEL

(Rev. 12 1/03)


	PERRY NUCLEAR POWER PLANT
	Seismic Model for Intermediate and Fuel Handling Buildings
Figure 3.7-13	




LUMPED MASS MODEL

CROSS SECTION

(Rev. 12 1/03)

	PERRY NUCLEAR POWER PLANT
Seismic Model for Control Complex	
Figure 3.7-14	




(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Reactor Pressure Vessel
and Internals Seismic Model


Figure 3.7-16




PLAN VIEW
INSTRUMENT ORIENTATION
DETAIL




PLAN VIEW
OD51N0232




OD51N0231 LOCATION DETAIL
REACTOR BUILDING EL. 642'-0"




PLAN VIEW
OD51N0231




OD51N0230 LOCATION DETAIL
REACTOR BUILDING EL. 664'-7"




PLAN VIEW
OD51N0230




OD51N0233 LOCATION DETAIL
INTERMEDIATE BUILDING EL. 574'-10"





PLAN VIEW
OD51N0233



OD51N0234 & OD51R0234 LOCATION DETAIL
INTERMEDIATE BUILDING EL. 599'-0"



PLAN VIEW
OD51N0234




(REV. 20 10/2017)

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

SEISMIC INSTRUMENTATION
INSTALLATION DETAILS

FIGURE 3.7-17
(DWG. D-814-0663-00000)




- NOTES:
- ONE SHIELD BLOCK MAY BE ELIMINATED FROM THE UNIT #2 EQUIPMENT HATCH PROVIDED THAT UNIT #2 IS NOT OPERATIONAL.

(Rev. 12 1/03)


PERRY NUCLEAR POWER PLANT


Typical Section of
Reactor Building Complex

Figure 3.8-1



(Rev. 12 1/03)

	PERRY NUCLEAR POWER PLANT
Typical Section Through Ring Girder of Shield Building Wall	
Figure 3.8-2	




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Typical Reinforced Section for
the Shield Building Wall and Dome

Figure 3.8-3




(Rev. 12 - 1/03)

 **PERRY NUCLEAR POWER PLANT**


Containment Vessel Personnel
Access Airlock Detail


Figure 3.8-4



- NOTES:
- ONE SHIELD BLOCK MAY BE ELIMINATED FROM THE UNIT #2 EQUIPMENT HATCH PROVIDED THAT UNIT #2 IS NOT OPERATIONAL.

(Rev. 12 1/03)

	PERRY NUCLEAR POWER PLANT
Containment Vessel Equipment Access Hatch and Shield Structure	
Figure 3.8-5	





(Rev. 12 1/03)

PERRY NUCLEAR POWER PLANT

Typical Mechanical Penetration Details
for Reactor Building Complex

Figure 3.8-6




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT


Typical Electrical Penetration Details
for Reactor Building Complex

Figure 3.8-7




THIS USAR FIGURE CONTAINS HISTORICAL INFORMATION. FOR CURRENT INFORMATION SEE ASSOCIATED SYSTEM DIAGRAM USAR FIGURE.

(Rev. 14 10/05)


 **PERRY NUCLEAR POWER PLANT**


Reinforced Sections of the Shield Building Steam Tunnel Area

Figure 3.8-8
(Dwg. D-411-165)



(Rev. 12 1/03)

	PERRY NUCLEAR POWER PLANT
Analytical Model of Shield Building	
Figure 3.8-9	




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Temperature Profiles Through
Shield Building

Figure 3.8-10




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Analytical Model of the
Shield Steam Tunnel Area

Figure 3.8-11



- NOTES:-
1. ALL DIMENSIONS FOR HORIZONTAL REINFORCEMENT ARE AND LEVELS BASED ON PAGES OF D-411-129.
 2. ALL DIMENSIONS FOR VERTICAL REINFORCEMENT ARE AND LEVELS BASED ON PAGES OF D-411-129.
 3. REINFORCEMENT BARS SHALL BE PLACED AS SHOWN ON THE DRAWING. WHEN ANY CORNER PENETRATION SLEEVES OR HOLES IN PLACE SHOWN AS CIRCLES ON THE DRAWING, THE DISTANCE FROM THE CENTER OF THE SLEEVE OR HOLES TO THE CENTER OF THE REINFORCEMENT BAR SHALL BE AS SHOWN ON THE DRAWING. THE CLEARANCE SPECIFIED IN NOTE 1) (D-411-129) AND IN D-411-129 DO NOT APPLY.
 4. THE CONTRACTOR SHALL FILL OUT AND MODEL BE REINFORCED WITHIN THE STEAM TUNNEL BLOCK OUT TO FACILITATE PLACEMENT OF THE REINFORCEMENT AND PENETRATION SLEEVES WITH THE APPROVAL OF THE SITE ORGANIZATION RESPONSIBLE FOR THE WORK. A MINIMUM SPACING OF 1'-0" BETWEEN SCHEDULE REINFORCEMENT BARS MUST BE MAINTAINED ON ALL GRID SCHEDULES, UNLESS OTHER OTHERWISE. THE LOCATION OF SCHEDULES SHALL BE SHOWN BY THE AS BUILT DRAWING.
 5. CORNER SLEEVE LOCATIONS SHALL BE PLACED APPROXIMATELY AS SHOWN ON THE DRAWING. CORNER SLEEVES SHALL BE PLACED FROM THE EXTERIOR AND EXTENSIONS SHOWN BECAUSE OF TOLERANCE ACCUMULATIONS.
 6. WELLS SHALL BE LOCATED AS CLOSE AS POSSIBLE TO PENETRATION BUT IN NO CASE FURTHER THAN 1'-0" FROM THE PENETRATION, UNLESS OTHERWISE APPROVED BY THE ENGINEER. EACH STANDARD WELLS LOCATED BY D-411-129 OR ALTERNATE PENETRATIONS SHALL BE PLACED SUCH THAT THE CLOSEST POINT OF THE WELLS IS WITHIN 1'-0" OF THE PENETRATION UNLESS OTHERWISE APPROVED BY THE ENGINEER.
 7. SCHEDULE REINFORCEMENT BARS ON BOTH SIDES OF THE PENETRATION SHALL BE PLACED AS SHOWN ON THE DRAWING. A MINIMUM OF 1'-0" CLEARANCE SHALL BE MAINTAINED FROM THE WELLS AND PENETRATIONS SHALL BE MAINTAINED FROM THE PENETRATION (SIDE OF THE WELLS). THE CLEARANCE SPECIFIED IN NOTE 1) (D-411-129) AND D-411-129 DO NOT APPLY.
 8. WELLS WITHIN THE STEAM TUNNEL BLOCK OUT HAVE BEEN DETAILLED FROM DRAWING OF TOLERANCE ACCUMULATIONS AND MAY BE FITTED THROUGH AS RECEIVED BY THE CONTRACTOR.
 9. STANDARD #11 BARS SHALL BE PLACED AT 12" ON CENTER TO CENTER, UNLESS OTHERWISE SPECIFIED ON THE DRAWING. FOR BARS SPACED 4" ON CENTER, THE BARS SHALL BE PLACED SUCH THAT THE STRAIGHT LENGTH PAST THE FACE OF THE APPROPRIATE PENETRATION IS 1'-0" MINIMUM. FOR BARS SPACED AT LEAST 8" ON CENTER, 12" STRAIGHT LENGTH PAST THE FACE OF THE APPROPRIATE PENETRATION SHALL BE 1'-0" MINIMUM.
 10. FOR ADDITIONAL NOTES AND REVISIONS, SEE D-411-129.

- REFERENCES:-
- D-411-129 REINFORCEMENT LIST (REV)
 - D-411-129 REINFORCEMENT LIST (REV)
 - D-411-129 REINFORCEMENT LIST (REV)
 - D-411-129 REINFORCEMENT LIST (REV)
 - D-411-129 REINFORCEMENT LIST (REV)

THIS USAR FIGURE CONTAINS HISTORICAL INFORMATION. FOR CURRENT INFORMATION SEE ASSOCIATED SYSTEM DIAGRAM USAR FIGURE.


(Rev. 14 10/05)

PERRY NUCLEAR POWER PLANT

Reinforcement-Shield Building
Steam Tunnel Area

Figure 3.8-12
(Dwg. D-411-130)

ELEVATION - STEAM TUNNEL BLOCKOUT
OUTSIDE FACE REIN.




(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Reactor Building Steel Frame
Pool Swell Analysis Model

Figure 3.8-13




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Typical Detail of Containment
Vessel Polar Crane Bracket

Figure 3.8-14




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Detail of Fuel Transfer Penetration


Figure 3.8-15



ANGLES
X 35.00
Y 30.00
Z 0.



VIEW 1



VIEW 2

(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT


Containment - Finite Element
Model - STRAP

Figure 3.8-16 (Sheet 1 of 2)

VIEW 2 SHOWN HERE
 HAS BEEN ROTATED 90°
 ABOUT THE VERTICAL (Y)
 AXIS.
 THE PLOT SHOWS THE
 NODE AND ELEMENT
 NUMBERS OF THE MODEL.
 N = NODE NO.
 (N) = ELEMENT NO.




VIEW 2 (ENLARGED)



ANGLES
 X -99.0
 Y 0.
 Z 0.

THIS PLOT SHOWS AN ENLARGEMENT
 OF THE NODES AND ELEMENTS AT
 THE TOP OF THE DOME.
 THE MODEL HAS BEEN ROTATED -90°
 ABOUT THE X AXIS.

ANGLES
 X 35.00
 Y 30.00
 Z 0.




THE ABOVE PLOT SHOWS THE NODE AND ELEMENT
 NUMBERS FOR THE POLAR CRANE GIRDER MODEL,
 WHICH HAS BEEN ROTATED INTO VIEW.

(Rev. 12 1/03)



Containment - Finite Element
 Model - STRAP

Figure 3.8-16 (Sheet 2 of 2)




(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Containment - Finite Element
Model - GHOSH WILSON

Figure 3.8-17




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Containment Vessel Embedment Model

Figure 3.8-18





(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Containment Vessel Embedment Model

Figure 3.8-19




(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Containment Vessel Equipment Hatch
Finite Element Model

Figure 3.8-20



COLLAR AND BARREL
FINITE ELEMENT MODEL (BARREL)



PERSONNEL AIR LOCK COLLAR AND BARREL
FINITE ELEMENT COMPUTER MODEL

(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Containment Vessel Airlock
Finite Element Model

Figure 3.8-21

MAX. TOLERANCE
PERFECT SHAPE
MIN. TOLERANCE

MODELED SHAPE
(EXAGGERATED)



"FLAT" DOME BUCKLING
SHAPE - MARC PROGRAM

MAX. TOLERANCE
PERFECT SHAPE
MIN. TOLERANCE

MODELED SHAPE
(EXAGGERATED)



"WAVY" DOME BUCKLING
SHAPE - MARC PROGRAM

(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT


Containment Vessel Flat Dome
Buckling Program and Wavy
Dome Buckling Program



Figure 3.8-22

FIGURE 3.8-23
LOAD-DEFLECTION CURVES
BELLEVILLE WASHER




(Rev. 12 1/03)

	PERRY NUCLEAR POWER PLANT
	Bellville Washer Load-Deflection Curve
	Figure 3.8-23




SECTION A-A




SECTION B-B

(Rev. 12 1/03)

 **PERRY NUCLEAR POWER PLANT**

General Arrangement of Bio Shield Wall, RPV Pedestal and Mat

Figure 3.8-24





(Rev. 12 1/03)

PERRY NUCLEAR POWER PLANT



Recirculation Suction
Flow Diverter

Figure 3.8-25
(Dwg. E-018-001)



DETAIL "A"
SHOWING RPV PEDESTAL EMBEDMENT

SECTION C-C




DETAIL "B"
SHOWING REACTOR HOLD DOWN AREA


DETAIL "C"
SHOWING WEIR WALL LINER EMBEDMENT


(Rev. 12 1/03)

	PERRY NUCLEAR POWER PLANT
	RPV Pedestal Embedment Weir Wall Liner Embedment and Reactor Hold Down Area
	Figure 3.8-26




(Rev. 12 1/03)


 PERRY NUCLEAR POWER PLANT
Typical Reinforced Section of Weir Mat and Weir Wall
Figure 3.8-27



SECTION SHOWING DRYWELL WALL VENT STRUCTURE & BASE MAT EMBEDMENT



SECTION "B-B"



SECTION A-A


(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Drywell Vent Structure,
Base Mat Embedment and
Transition to Reinforced Concrete

Figure 3.8-28





(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT


Typical Reinforced Section
Through Drywell Wall

Figure 3.8-29





(Rev. 12 1/03)


	PERRY NUCLEAR POWER PLANT
	Details of Drywell Head, Bulkhead Plate and Seal
	Figure 3.8-30



PLAN-DRYWELL PERSONNEL LOCK AND SHIELD DOORS




ELEVATION I-I




SEE FIGURE 3.8-99 FOR SECTION


SECTION 2-2

(Rev. 12 1/03)


	PERRY NUCLEAR POWER PLANT
	Drywell Personnel Access Lock and Shield Door
	Figure 3.8-31



PLAN - DRYWELL EQUIPMENT HATCH



SECTION 3-3



ELEVATION 1-1

SECTION 2-2


(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT


Drywell Equipment Access Hatch


Figure 3.8-32



FLOOR FRAMING PLAN
 FLOOR ELEV. 599'-9"
 UNIT 1


(Rev. 12 1/03)


	PERRY NUCLEAR POWER PLANT
	Reactor Building Complex Floor Plan at Elev. 599'-9"
	Figure 3.8-33



FLOOR FRAMING PLAN
 FLOOR ELEV. 630'-1" - INSIDE 36'-6" R
 FLOOR ELEV. 620'-6" - OUTSIDE 36'-6" R

(Rev. 12 1/03)

	PERRY NUCLEAR POWER PLANT
	Reactor Building Complex Floor Plan at Elev. 620'-6" and 630'-1"
	Figure 3.8-34




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT


Reactor Building Complex
Floor Plan at Elev. 642'-0"

Figure 3.8-35




FLOOR FRAMING PLAN
ELEV. 664'-7"

(Rev. 12 1/03)



Reactor Building Complex
Floor Plan at Elev. 664'-7"

Figure 3.8-36




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Reactor Building Complex
Floor Plan at Elev. 689'-6"

Figure 3.8-37







(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Temperature Profiles Through
Foundation Mat

Figure 3.8-38







(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Temperature Profiles Through
Drywell Wall

Figure 3.8-40




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Temperature Profiles Through
Drywell Top Slab and Fuel Pool
Wall

Figure 3.8-41




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Drywell Finite Element Model

Figure 3.8-42




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Elastic Model for Predicting
Thermal Induced Forces

Figure 3.8-43




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Drywell Personnel Access
Airlock
Finite Element Model

Figure 3.8-44



VIEW LOOKING AT OUTSIDE SURFACE



(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT


Drywell Equipment Hatch
Finite Element Model

Figure 3.8-45



(Rev. 12 1/03)

	PERRY NUCLEAR POWER PLANT
Analytical Model of Drywell Steam Tunnel Area	
Figure 3.8-46	




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Drywell Vent Structure
Finite Element Model

Figure 3.8-47




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT


Drywell Vent Structure Steam
Relief Valve Penetration
Finite Element Model


Figure 3.8-48



RPV PEDESTAL STARDYNE MODEL
 LOOKING DOWN AT ELEV. 7244"
 (B10 WALL RPV INTERFACE)


(Rev. 12 1/03)


	PERRY NUCLEAR POWER PLANT
RPV Pedestal Finite Element Model Figure 3.8-49 (Sheet 1 of 7)	



RPV PEDESTAL STARDYNE MODEL
 LOOKING DOWN AT ELEV. 7204.75"
 (TOP OF CRD OPENING)

(Rev. 12 1/03)

	PERRY NUCLEAR POWER PLANT
RPV Pedestal Finite Element Model Figure 3.8-49 (Sheet 2 of 7)	



RPV PEDESTAL STARDYNE MODEL
BOTTOM OF CRD OPENING


(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

RPV Pedestal Finite Element Model

Figure 3.8-49 (Sheet 3 of 7)



(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

RPV Pedestal Finite Element Model

Figure 3.8-49 (Sheet 4 of 7)

RPV PEDESTAL MODEL
 CRD OPENING BRACES
 (ELEMENTS WITHOUT NUMBERS NOT USED)



















(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

RPV Pedestal Finite Element Model

Figure 3.8-49 (Sheet 5 of 7)



(Rev. 12 1/03)





PERRY NUCLEAR POWER PLANT

RPV Pedestal Finite Element Model

Figure 3.8-49 (Sheet 6 of 7)

RPV PEDESTAL STARDYNE MODEL
WEBS




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

RPV Pedestal Finite Element Model

Figure 3.8-49 (Sheet 7 of 7)




PERRY NUCLEAR POWER PLANT


Biological Shield Wall
Finite Element Model

Figure 3.8-50 (Sheet 1 of 6)


BIOLOGICAL SHIELD WALL
STARDYNE MODEL
PLAN VIEWS




SECTIONAL PLAN 3
AT ELEV. 7563'



SECTIONAL PLAN 5
AT ELEV. 7408'





SECTIONAL PLAN 4
AT ELEV. 7563'



SECTIONAL PLAN 6
AT ELEV. 7300'

(Rev. 12 1/03)

	PERRY NUCLEAR POWER PLANT
Biological Shield Wall Finite Element Model	
Figure 3.8-50 (Sheet 2 of 6)	




BIOLOGICAL SHIELD WALL
 STARDYNE MODEL
 VERTICAL STIFFENERS

(Rev. 12 1/03)

PERRY NUCLEAR POWER PLANT


Biological Shield Wall
 Finite Element Model

Figure 3.8-50 (Sheet 3 of 6)



BIOLOGICAL SHIELD WALL
STARDYNE MODEL
VERTICAL STIFFENERS


(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Biological Shield Wall
Finite Element Model

Figure 3.8-50 (Sheet 4 of 6)



(Rev. 12 1/03)

PERRY NUCLEAR POWER PLANT

Biological Shield Wall
Finite Element Model


Figure 3.8-50 (Sheet 5 of 6)

BIOLOGICAL SHIELD WALL
STARDYNE MODEL
OUTER LINER STRETCHOUT

328	329	330	331	332	333	334	335	336	337	338	339	340	341	342	343	344	345	346	347	348	349	350	351	352	353	354	355	356	357	358	359	360	361	362	363	364	365	366	367	368	369	370	371	372	373	374	375	376	377	378	379	380	381	382	383	384	385	386	387	388	389	390	391	392	393	394	395	396	397	398	399	400	401	402	403	404	405	406	407	408	409	410	411	412	413	414	415	416	417	418	419	420	421	422	423	424	425	426	427	428	429	430	431	432	433	434	435	436	437	438	439	440	441	442	443	444	445	446	447	448	449	450	451	452	453	454	455	456	457	458	459	460	461	462	463	464	465	466	467	468	469	470	471	472	473	474	475	476	477	478	479	480	481	482	483	484	485	486	487	488	489	490	491	492	493	494	495	496	497	498	499	500	501	502	503	504	505	506	507	508	509	510	511	512	513	514	515	516	517	518	519	520	521	522	523	524	525	526	527	528	529	530	531	532	533	534	535	536	537	538	539	540	541	542	543	544	545	546	547	548	549	550	551	552	553	554	555	556	557	558	559	560	561	562	563	564	565	566	567	568	569	570	571	572	573	574	575	576	577	578	579	580	581	582	583	584	585	586	587	588	589	590	591	592	593	594	595	596	597	598	599	600	601	602	603	604	605	606	607	608	609	610	611	612	613	614	615	616	617	618	619	620	621	622	623	624	625	626	627	628	629	630	631	632	633	634	635	636	637	638	639	640	641	642	643	644	645	646	647	648	649	650	651	652	653	654	655	656	657	658	659	660	661	662	663	664	665	666	667	668	669	670	671	672	673	674	675	676	677	678	679	680	681	682	683	684	685	686	687	688	689	690	691	692	693	694	695	696	697	698	699	700	701	702	703	704	705	706	707	708	709	710	711	712	713	714	715	716	717	718	719	720	721	722	723	724	725	726	727	728	729	730	731	732	733	734	735	736	737	738	739	740	741	742	743	744	745	746	747	748	749	750	751	752	753	754	755	756	757	758	759	760	761	762	763	764	765	766	767	768	769	770	771	772	773	774	775	776	777	778	779	780	781	782	783	784	785	786	787	788	789	790	791	792	793	794	795	796	797	798	799	800	801	802	803	804	805	806	807	808	809	810	811	812	813	814	815	816	817	818	819	820	821	822	823	824	825	826	827	828	829	830	831	832	833	834	835	836	837	838	839	840	841	842	843	844	845	846	847	848	849	850	851	852	853	854	855	856	857	858	859	860	861	862	863	864	865	866	867	868	869	870	871	872	873	874	875	876	877	878	879	880	881	882	883	884	885	886	887	888	889	890	891	892	893	894	895	896	897	898	899	900	901	902	903	904	905	906	907	908	909	910	911	912	913	914	915	916	917	918	919	920	921	922	923	924	925	926	927	928	929	930	931	932	933	934	935	936	937	938	939	940	941	942	943	944	945	946	947	948	949	950	951	952	953	954	955	956	957	958	959	960	961	962	963	964	965	966	967	968	969	970	971	972	973	974	975	976	977	978	979	980	981	982	983	984	985	986	987	988	989	990	991	992	993	994	995	996	997	998	999	1000
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	------

BIOLOGICAL SHIELD WALL
STARDYNE MODEL
INNER LINER STRETCHOUT

(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Biological Shield Wall
Finite Element Model

Figure 3.8-50 (Sheet 6 of 6)


- NOTES:
1. ALL VERTICAL REINFORCEMENT SHOWN ON THIS DRAWING IS TO BE PLACED IN LAYER 1 AS SHOWN IN TYPICAL SECTION THROUGH STEAM TUNNEL AREA, ON DWG. D-411-154, UNLESS SHOWN OTHERWISE.
 2. ALL HORIZONTAL REINFORCEMENT SHOWN ON THIS DRAWING IS TO BE PLACED IN LAYER 2 AS SHOWN IN TYPICAL SECTION THROUGH STEAM TUNNEL AREA, ON DWG. D-411-154, UNLESS SHOWN OTHERWISE.
 3. ALL RADIAL REINFORCEMENT SHOWN ON THIS DRAWING IS TO BE PLACED IN LAYER 3 AS SHOWN IN TYPICAL SECTION THROUGH STEAM TUNNEL AREA.
 4. FOR ADDITIONAL NOTES AND REINFORCEMENT, SEE DWS. D-411-154.
 5. ALL DIAGONAL REINFORCEMENT SHOWN ON THIS DRAWING IS TO BE PLACED ON 45° CENTER-TO-CENTER, UNLESS SHOWN OTHERWISE.
 6. ALL HORIZONTAL REINFORCEMENT SHOWN ON THIS DRAWING IS TO BE CENTERED BETWEEN VERTICAL VERTICAL REINFORCEMENT, UNLESS SHOWN OTHERWISE.
 7. ALL VERTICAL REINFORCEMENT SHOWN ON THIS DRAWING IS TO BE CENTERED BETWEEN HORIZONTAL VERTICAL REINFORCEMENT, UNLESS SHOWN OTHERWISE.

- REFERENCES:
- D-411-154 REINFORCEMENT LIST (WWT)
 - D-411-154 REINFORCEMENT LIST (CHST)
 - D-411-154 REINFORCEMENT LIST (CHST)
 - D-411-154 REINFORCEMENT LIST (STRAIGHT)

THIS SYMBOL (Ⓢ) INDICATES 2#D998 (BUNDLED) PLACED RADially AS SHOWN UNLESS NOTED OTHERWISE (158# PCS. TOTAL)

FOR ADDITIONAL REINF. IN DRYWELL WALL SEE DWG. D-411-153

FOR ADDITIONAL REINF. IN DRYWELL WALL SEE DWG. D-411-152.



THIS USAR FIGURE CONTAINS HISTORICAL INFORMATION. FOR CURRENT INFORMATION SEE ASSOCIATED SYSTEM DIAGRAM USAR FIGURE.


(Rev. 14 10/05)

PERRY NUCLEAR POWER PLANT


Reinforcement-Drywell Wall Steam Tunnel Area

Figure 3.8-51
 (Dwg. D-411-157)

AUXILIARY ELEVATION—STEAM TUNNEL AREA
(INSIDE FACE REINFORCING)



(Rev. 12 1/03)


	PERRY NUCLEAR POWER PLANT
	Reinforced Section of the Drywell Wall Steam Tunnel Area
Figure 3.8-52 (Dwg. D-411-159)	

Removed in Accordance with RIS 2015-17



PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

EMERGENCY SERVICE
WATER PUMPHOUSE

FIGURE 3.8-64
(DWG. E-015-0002-00000)



PLOT PLAN - INTAKE & DISCHARGE STRUCTURES
 200 0 200 400
 SCALE IN FEET



PT.	PLANT SITE GRID COORDINATES		OHIO STATE GRID COORDINATES	
	NORTH COORD.	EAST COORD.	NORTH COORD.	EAST COORD.
1	50,224.0000	0,240.0000	795,491.0000	2,260,480.0000
2	50,224.0000	0,257.0000	795,290.7000	2,260,290.2700
3	50,220.0000	0,273.0000	795,272.0000	2,260,290.2000
4	50,218.0000	0,226.0000	795,266.0000	2,260,272.0000
5	50,218.0000	0,222.0000	795,266.0000	2,260,272.0000
6	50,218.0000	0,246.0000	795,272.0000	2,260,272.0000
7	50,212.0000	0,246.0000	795,272.0000	2,260,272.0000
8	50,212.0000	0,244.0000	795,272.0000	2,260,272.0000
9	50,212.0000	0,244.0000	795,272.0000	2,260,272.0000
10	50,212.0000	0,244.0000	795,272.0000	2,260,272.0000
11	50,212.0000	0,244.0000	795,272.0000	2,260,272.0000
12	50,212.0000	0,244.0000	795,272.0000	2,260,272.0000




NOTE:
 BOUNDARY LOCATIONS OF INTAKE AND DISCHARGE STRUCTURES SHOWN IN THIS DRAWING ABOVE ARE GIVEN BY THE TOWNSHIPS PLAT RECORDS FOR MATHEMATICAL VERIFICATION ONLY.

(Rev. 12 1/03)


PERRY NUCLEAR POWER PLANT

Offshore Intake and Discharge Structures

Figure 3.8-65
(Dwg. D-736-012)







(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Intake and Discharge
Tunnel Profiles

Figure 3.8-66
(Dwg. D-736-013)




(Rev. 12 1/03)


 **PERRY NUCLEAR POWER PLANT**

Intake Structure, Discharge Structure and Alternate Emergency Service Water Intake



Figure 3.8-67




PLAN
MULTI PORT INTAKE STRUCTURES
CAISSON ARRANGEMENT




SECTION I-I




ENLARGED PLAN
TYPICAL CAISSON
REINFORCEMENT



SECTION 2-2







(Rev. 12 1/03)


 **PERRY NUCLEAR POWER PLANT**

Multiport Intake Structures -
Caisson Arrangement

Figure 3.8-68




(Rev. 12 1/03)


 PERRY NUCLEAR POWER PLANT

Typical Offshore Elbow and Shaft Transition


Figure 3.8-69




PLAN




SECTION C-C PROFILE
ALTERNATE EMERGENCY SERVICE WATER INTAKE TUNNEL



SECTION B-B PROFILE
SERVICE WATER INTAKE TUNNEL



SECTION A-A PROFILE
EMERGENCY SERVICE WATER INTAKE TUNNEL




(Rev. 12 1/03)

PERRY NUCLEAR POWER PLANT


Plan and Profiles -
Service Water Tunnels

Figure 3.8-70

TYPICAL CIRCULAR SECTION



TYPICAL HORSESHOE SECTIONS












(Rev. 12 1/03)

PERRY NUCLEAR POWER PLANT

Typical Tunnel Sections

Figure 3.8-71
















Note:
Approved alternate watertight access covers may be substituted for exterior manholes.

(REV. 21 10/2019)

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

UNDERDRAIN GRAVITY
DISCHARGE MANHOLES

FIGURE 3.8-73 (SHEET 1 OF 2)




Note:
Approved alternate watertight access covers may be substituted for exterior manholes.

(REV. 21 10/2019)





PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

UNDERDRAIN GRAVITY
DISCHARGE MANHOLES

FIGURE 3.8-73 (SHEET 2 OF 2)



LOC. OF PIPES (UNDERGROUND) THAT COME UP THRU THE FDN. LOC. VARIES FOR UNIT 1 & UNIT 2. SEE KEY PLAN & PIPING DWG. E-303-016. PIPES TO BE IN PLACE BEFORE CONC. IS POURED.



PLAN-CONDENSATE STORAGE TANK FOOTER, RING WALL & DIKE WALL
 2 REQ'D. ONE AS SHOWN FOR UNIT 1 & ONE OP. HAND FOR UNIT 2 - SEE KEY PLAN.
 WORK THIS PLAN IN CONJUNCTION WITH SECTIONAL PLAN 6-6 DWG. D-434-352 AND SECTIONAL PLAN 9-9 DWG. D-434-353











SECTION I-I

(REV. 19 10/2015)

PERRY NUCLEAR POWER PLANT
 10 CENTER RD., PERRY, OHIO 44081

**CONDENSATE STORAGE TANK
 SUPPORT STRUCTURE**

FIGURE 3.8-74



- NOTES:**
1. CONCRETE TO HAVE A MINIMUM COMPRESSIVE STRENGTH OF 3000 PSI AT THE END OF 28 DAYS.
 2. ALL WORK INDICATED ON THIS DRAWING TO BE INCLUDED WITH AND SHALL BE DONE IN ACCORDANCE WITH SPECIFICATION SP-93-4548-00 AND ITS ATTACHMENT SPECIFICATIONS.
 3. EMBEDDED STEEL SHOWN ON THIS DRAWING SHALL BE FABRICATED AND DELIVERED IN ACCORDANCE WITH SPECIFICATION SP-93-4548-00 AND INSTALLED IN ACCORDANCE WITH SPECIFICATION SP-93-4548-00 AND ITS ATTACHMENT SPECIFICATIONS.
 4. SIDES OF KEYS TO HAVE A 2" IN 12" SLOPE.
 5. ALL EXPOSED CORNERS TO HAVE A 3/4" CHAMFER.
 6. ALL CONSTRUCTION JOINTS BELOW GRADE TO HAVE A 5" PVC WATERSTOP.
 7. CONCRETE INDICATED AS "WED MAT" OR PROTECTIVE CONCRETE SHALL HAVE A MINIMUM COMPRESSIVE STRENGTH OF 1500 PSI AT THE END OF 28 DAYS.
 8. FOR SLEEVE INSTALLATION, SEE DWG. B-422-001.
 9. CENTERLINE OF PADWYE TO BE ON CENTERLINE OF HILTI PLATE ± 2". THE MAXIMUM ALLOWABLE LOAD FOR EACH LIFTING LUG IS 5800 LBS.
 10. TO FACILITATE INSTALLATION OF THE SOUTH-WEST AND SOUTH-EAST PADWYES, A TOTAL OF ONE (1) EXISTING REBAR, AT EACH LOCATION, MAY BE CUT.

- REFERENCES:**
- 7-103-016 PIPING
 - 2-218-020 ELECTRICAL
 - 1-4-1-350 REINFORCEMENT LIST
 - 1-424-503 REINFORCEMENT LIST
 - 1-422-008 SLEEVE LIST
 - 2-015-024 LAYOUT

(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Layout-Service Water Valve Pit


Figure 3.8-75

(Dwg. D-434-561)


NUCLEAR SAFETY RELATED




SECTIONAL PLAN 6-6




PLAN-TOP SLAB
ELEC. MANHOLE #2




ELEVATION 1-1 AS SHOWN AND NOTED
ELEVATION 2-2 OFF HAND



SECTIONAL PLAN 7-7




ELEVATION 3-3



ELEVATION 4-4

NUCLEAR SAFETY RELATED



ELEVATION 5-5

• • • 10" MINIMUM GAP AT 3 LOCATIONS
• • • MINIMUM GAP AT 1 LOCATION
• • • 1/2" STEEL COVER PLATE
SEE DETAIL, P. 3, SECTION 15-15 ON
DRAWING D-426-600-0000

NOTES:
1. FOR NOTES AND ADDITIONAL REFERENCES, SEE DRAWING D-426-601.

REFERENCES:
S-424-100 REINFORCEMENT LIST (BENT)
S-424-113 REINFORCEMENT LIST (STRAIGHT)


(Rev. 15 10/07)

 PERRY NUCLEAR POWER PLANT

Electrical Manholes

Figure 3.8-76

(Dwg. D-426-602)




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Finite Element Model for
Static Stress Analysis of Tunnels

Figure 3.8-77




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT


Finite Element Model for
Seismic Analysis of Tunnels


Figure 3.8-78




TYP WATERPROFING DETAILS

(Rev. 12 1/03)

	PERRY NUCLEAR POWER PLANT
	<p>Waterproofing Details</p> <p>Figure 3.8-79</p>



PLAN-FOOTING & CAISSON LOCATIONS
SCALE 1/4"=1'-0"




NOTES:


1. CONCRETE TO HAVE MINIMUM COMPRESSIVE STRENGTH OF 3000 P.S.I. AT THE END OF 28 DAYS.
2. IF MINIMUM SPACED LENGTHS AND/OR SPACING REQUIREMENTS CANNOT BE MET FOR ANY CAISSON DUE TO LOWER ELEVATION OF COMPETENT SHALE, ENGINEER SHALL BE CONTACTED FOR INSTRUCTIONS BEFORE PLACING ANY CONCRETE FOR THIS CAISSON.
3. ALL WORK INDICATED ON THIS DRAWING SHALL BE DONE IN ACCORDANCE WITH SPECIFICATION 05-20-4040-00 AND ITS ATTACHMENTS SPECIFICATIONS.
4. BOTTOM OF ALL FOOTINGS SHALL EXTEND A MINIMUM OF 2'-0" INTO COMPETENT SHALE, UNLESS NOTED.
5. AS AN ALTERNATE TO DETAIL 'C' THE BELL MAY BE CARRIED OUT BY POURING THE POROUS CONCRETE THROUGH A BLOCKOUT AND LATER REMOVING THE POROUS CONCRETE AND THE SHALE IN THE AREA OF THE FOOTING AS SHOWN IN DETAIL 'C'.

REFERENCES:


- D-410-127 SLAB EL. 620'-4" - CONCRETE OUTLINE
- D-410-110 SLAB EL. 620'-4" - REINFORCING FLAGSMET
- D-410-301 SET/REINFORCEMENT LIST (VERT & STRAIGHT BARS)



DETAIL 'A'




DETAIL 'B'




SECTION '1-1'

SECTION '2-2'




PLAN-FOOTING TYPE 'E'




DETAIL 'C'

THIS USAR FIGURE CONTAINS HISTORICAL INFORMATION. FOR CURRENT INFORMATION SEE ASSOCIATED SYSTEM DIAGRAM USAR FIGURE.




SECTION '4-4'


SECTION '5-5'



PLAN-FOOTING TYPE 'A'





PLAN-FOOTING TYPE 'D'



PLAN-FOOTING TYPE 'B'

(Rev. 14 10/05)


PERRY NUCLEAR POWER PLANT
 Caissons for Fuel Handling Building
 Figure 3.8-80
 (Dwg. D-415-111)




(Rev. 12 1/03)

PERRY NUCLEAR POWER PLANT


Foundation Details of Safety Class Structures


Figure 3.8-81




SECTION THRU CONTAINMENT FOUNDATION MAT

(Rev. 12 1/03)

	PERRY NUCLEAR POWER PLANT
	Typical Section Through Reactor Building Foundation Mat Figure 3.8-82




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Reinforcement Plan of
Reactor Building Foundation Mat

Figure 3.8-83




(Rev. 12 1/03)

PERRY NUCLEAR POWER PLANT

Weir Mat and Wall
Finite Element Model

Figure 3.8-85




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Elastic Model for Predicting
Thermal Induced Forces of
Weir Wall and Mat

Figure 3.8-86






(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Plan View-Drywell Top Slab
(Elev. 664'-7") Reinforcement

Figure 3.8-87





(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Reinforcing Drawing of Drywell
Equipment Hatch Area

Figure 3.8-88





(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Reinforcing Drawing of Drywell
Personnel Lock Area

Figure 3.8-89





(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Base Mat Shear Key Arrangement -
Auxiliary Building

Figure 3.8-90





(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Base Mat Shear Key Arrangement -
Fuel Handling Building

Figure 3.8-91





(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Base Mat Shear Key Arrangement -
Intermediate Building

Figure 3.8-92





(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Base Mat Shear Key Arrangement -
Radwaste Building

Figure 3.8-93





(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Base Mat Shear Key Arrangement -
Control Complex

Figure 3.8-94




(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Base Mat Shear Key Arrangement -
Offgas Building


Figure 3.8-95




PLAN - SUMP ROOM POOL SWELL PROTECTION STRUCTURE



SECTION 1-1 (AS SHOWN)
SECTION 2-2 (OPP. HAND)



SECTION 3-3 (AS SHOWN & NOTED)
SECTION 4-4 (AS SHOWN & NOTED)






SECTION 5-5

(Rev. 12 1/03)




Drywell Sump Room
Pool Swell Protection Structure

Figure 3.8-96




THIS DRAWING IS CLASSIFIED AS USAR SPECIFIC

(Rev. 12 1/03)

 **PERRY NUCLEAR POWER PLANT**

Drywell T.I.P. Drive Pool Swell Protection Structure

Figure 3.8-97




PLAN-EQUIPMENT HATCH POOL SWELL PROTECTION STRUCTURE






SECTION 1-1

SECTION 2-2 (AS SHOWN)
SECTION 3-3 (OPP. HAND)


SECTION 4-4

(Rev. 12 1/03)

	PERRY NUCLEAR POWER PLANT
Drywell Equipment Hatch Pool Swell Protection Structure	
Figure 3.8-98	




(Rev. 12 1/03)

 PERRY NUCLEAR POWER PLANT

Drywell Personnel Lock
Pool Swell Protection Switch

Figure 3.8-99





NOTE 1: AUTOMATIC FUNCTIONS OF THE ALARMS WERE DISABLED DUE TO EQUIPMENT OBSOLESCENCE.

(REV. 21 10/2019)

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

PERSONNEL AIR LOCK
SEAL TEST SYSTEM TYPICAL

FIGURE 3.8-100



- NOTES:
1. ALL WORK SHOWN ON THIS DRAWING SHALL BE FABRICATED AND DELIVERED IN ACCORDANCE WITH SPECIFICATION SP-201-4410-00 AND ITS ATTACHED SPECIFICATIONS.
 2. ALL WORK SHOWN ON THIS DRAWING SHALL BE INSTALLED IN ACCORDANCE WITH SPECIFICATION SP-201-4410-00 AND ITS ATTACHED SPECIFICATIONS.
 3. ALL STEEL LINES TO FABRICATE BIOLOGICAL SHIELD WALL TO BE EA-21, GRADE 70, UNLESS NOTED OTHERWISE.
 4. ALL PIPE SLEEVE PENETRATIONS TO BE AS SHOWN AND UNLESS NOTED OTHERWISE.
 5. ALL FACE PLATES AND WEB PLATES TO BE 1/2\"/>


BIOLOGICAL SHIELD WALL - STRETCH-OUT
 VIEW OF OUTSIDE FACE LOOKING TOWARD E REAC. BLOCK

NOTE:
 FOR MISCELLANEOUS ATTACHMENT AND INTERNAL STIFFENER DETAILS NOT SHOWN ON THIS DRAWING, SEE STRETCH-OUT ON DRAWING D-511-203.

- REFERENCES:
- D-511-201 P.P.P. POSTAL WALL LINER DETAILS STRETCH-OUT EL. 301'-0"
 - D-511-181 12\"/>


THIS USAR FIGURE CONTAINS HISTORICAL INFORMATION. FOR CURRENT INFORMATION, SEE ASSOCIATED SYSTEM DIAGRAM USAR FIGURE.

(Rev. 14 10/05)


 **PERRY NUCLEAR POWER PLANT**


Reactor Building Biological Shield Wall Liner Details

Figure 3.8-101
 (Dwg. D-511-201)




(Rev. 12 1/03)

	PERRY NUCLEAR POWER PLANT
	Reactor Building Basemat: Design Moment vs. Reinforced Section Moment Capacity Figure 3.8-102




(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT





Reactor Building Mat: Design
 Shear Envelope vs. Mat
 Shear Capacity

Figure 3.8-103



(Rev. 12 1/03)

	PERRY NUCLEAR POWER PLANT
Main Steam Drywell Wall Embedded Sleeve Detail	
Figure 3.8-104	




(Rev. 12 1/03)


 **PERRY NUCLEAR POWER PLANT**

ASHSD 2 Model for Annulus
Concrete Design

Figure 3.8-105




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

ANSYS Thermal Model
for Annulus Concrete Design

Figure 3.8-106



FOR DETAILS SEE SUB-FIGURE AS INDICATED
(SHEETS 2 THROUGH 5)

(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Containment Fix Thermal
Stress Model

Figure 3.8-107 (Sheet 1 of 5)

NOT TO SCALE



(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Containment Fix Thermal
Stress Model

Figure 3.8-107 (Sheet 2 of 5)

1 ROW OF COMPRESSIBLE
MATERIAL ELEMENTS ON
TOP OF ALL STIFFENER
WEBS



(Rev. 12 1/03)

SUB-FIGURE B
FIRST LEVEL FIXED MODEL


NOT TO SCALE



PERRY NUCLEAR POWER PLANT

Containment Fix Thermal
Stress Model

Figure 3.8-107 (Sheet 3 of 5)



SUB-FIGURE C
SECOND LEVEL FIXED MODEL

NOT TO SCALE


(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Containment Fix Thermal
Stress Model

Figure 3.8-107 (Sheet 4 of 5)



SUB-FIGURE D
TOP OF FIX MODEL

(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Containment Fix Thermal
Stress Model

Figure 3.8-107 (Sheet 5 of 5)


NOT TO SCALE



PERRY NUCLEAR POWER PLANT

Containment Stiffener
Chock Model


Figure 3.8-108 (Sheet 1 of 5)




FLANGE, WEB, AND SHELL NODE AND ELEMENT LAYOUTS INCLUDE AN ALPHABETICAL REFERENCE TO NODE SPRING CONSTANTS, INTENDED TO REPRESENT CONCRETE OR CRUSHABLE MATERIAL. SPRINGS ON SHELL AND FLANGE ARE RADIAL, AND ON WEB ARE VERTICAL.

SUB-FIGURE A
 CHOCK MODEL
 (CHOCK NODES AND ELEMENTS)


(Rev. 12 1/03)


	PERRY NUCLEAR POWER PLANT
Containment Stiffener Chock Model	
Figure 3.8-108 (Sheet 2 of 5)	



SUB-FIGURE B
 STIFFENER WEB MODEL
 (WEB NODES AND ELEMENTS (NTS))

(Rev. 12 1/03)

	PERRY NUCLEAR POWER PLANT
Containment Stiffener Chock Model	
Figure 3.8-108 (Sheet 3 of 5)	



SUB-FIGURE C
SHELL MODEL
(SHELL NODES AND ELEMENTS (NTS))


(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Containment Stiffener
Chock Model

Figure 3.8-108 (Sheet 4 of 5)



SUB-FIGURE D
STIFFENER FLANGE MODEL
(FLANGE NODES AND ELEMENTS (NTS))


(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Containment Stiffener
Chock Model

Figure 3.8-108 (Sheet 5 of 5)



SEE SUB-FIGURES A, B, C, AND D
FOR DETAILS (SHEETS 2 THROUGH 5)

(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Response Spectra Model


Figure 3.8-109 (Sheet 1 of 5)

...



SUB-FIGURE A
CONCRETE FIX MODEL


(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Response Spectra Model

Figure 3.8-109 (Sheet 2 of 5)



(Rev. 12 1/03)


SUB-FIGURE B
SHELL MODEL



PERRY NUCLEAR POWER PLANT


Response Spectra Model

Figure 3.8-109 (Sheet 3 of 5)




(Rev. 12 1/03)

SUB-FIGURE C
SHIELD BUILDING MODEL

	PERRY NUCLEAR POWER PLANT
Response Spectra Model	
Figure 3.8-109 (Sheet 4 of 5)	

SHEAR LINKS
 (189) thru (203)

SCALE, 1:40



(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

SUB-FIGURE D
 SUPPRESSION POOL MODEL


Response Spectra Model

Figure 3.8-109 (Sheet 5 of 5)




PROVIDE 21" WIDE, 3/2" DP. SHEAR KEY
IN CONTAINMENT BASE MATERIAL
SHEAR KEY TO BE CENTERED BETWEEN
SHIELD WALL & CONT. VESSEL PL. FOR
FULL CIRCUMFERENCE OF REACTOR BLDG.

TYPICAL CROSS SECTION SHOWING ANNULUS
CONCRETE AND REINFORCING DETAILS



TYPICAL DETAIL OF PENETRATION THRU ANNULUS CONCRETE




SECTION I-I

(Rev. 12 1/03)

PERRY NUCLEAR POWER PLANT

Compressible Material
Around Penetration

Figure 3.8-110



ACCELERATION (g's)


(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Horizontal Spectrum RCIC Turbine

Figure 3.9-1



(Rev. 12 1/03)


ACCELERATION (g/s)



PERRY NUCLEAR POWER PLANT


Vertical Spectrum RCIC Turbine

Figure 3.9-2



ACCELERATION (g)
(Rev. 12 1/03)

	PERRY NUCLEAR POWER PLANT
Horizontal Spectrum SSE Condition for the RHR Heat Exchanger	
Figure 3.9-3	



(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Vertical Spectrum SSE
Condition for the RHR
Heat Exchanger

Figure 3.9-4

Item	Name	Material
1	Shell-Cylinder	304L S.S.
2	Head-Ellip.	304L S.S.
3	Head-Ellip. w/Nozzle	304L S.S.
4	Leg—L2½X2½X3/8	304 S.S.
5	Anchor Bolt	N/A



A. Seismic Analysis Summary

1. Predicted Fundamental Frequency: 71.6 Hz
2. Fundamental Mode: Lateral motion of the tank causing cantilever flexing of the support legs

B. Stress Analysis Summary

1. Status of Stress Levels for Original Design: Satisfactory, no reinforcing pads required
2. Overstressed Items in Original Design: None
3. Plant Condition During Overstressing: N/A
4. Modifications to Overstressed Items: None
5. Final Status of Stress Levels for Modified Design: Satisfactory

(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Analysis Summary for Main Steam
Isolation Valve Accumulator Tank-
Tank No. 1, 1B21-A001A, etc.

Figure 3.9-5

Item	Name	Material
1	Shell-Cylinder	304L S.S.
2	Head-Ellip	304L S.S.
3	Head-Ellip w/Nozzle	304L S.S.
4	Leg—L2½X2½X3/8	304 S.S.
5	Anchor Bolt	N/A



A. Seismic Analysis Summary

1. Predicted Fundamental Frequency: 63.7 Hz
2. Fundamental Mode: Lateral motion of the tank causing cantilever flexing of the support legs.

B. Stress Analysis Summary

1. Status of Stress Levels for Original Design: Satisfactory, no reinforcing pads required
2. Overstressed Items in Original Design: None
3. Plant Condition During Overstressing: N/A
4. Modifications to Overstressed Items: None
5. Final Status of Stress Levels for Modified Design: Satisfactory

(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Analysis Summary for ADS Safety/
Relief Valve Accumulator Tank-
Tank No. 2, 1B21-A003A, etc.

Figure 3.9-6

Item	Name	Material
1	3/8" Flat Top *	SA283-C
2	1/4" Cyl. Shell *	SA283-C
3	3/8" Flat Bottom *	SA283-C
4	3/8" & 1/2" Bracket	SA283-C
5	5/8" Flange	SA283-C
6	Bolts - 1/2" Dia.	SA307-B
7	Bolts - 1" Dia.	N/A

* Corroded Thickness



A. Seismic Analysis Summary

1. Predicted Fundamental Frequency: 251 Hz
2. Fundamental Mode: Vertical motion of tank causing the bracket support to flex.

B. Stress Analysis Summary

1. Status of Stress Levels for Original Design: Satisfactory with reinforcing pad
2. Overstressed Items in Original Design: None
3. Plant Condition During Overstressing: N/A
4. Modifications to Overstressed Items: None
5. Final Status of Stress Levels for Modified Design: Satisfactory


(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Analysis Summary for Control
Complex Chilled Water Expansion
Tank-Tank No. 3, P47-A002A, etc.

Figure 3.9-7



Item	Name	Material
1	1/4" Cyl. Shell *	SA283-C
2	1/4" F & D Head *	SA283-C
3	1/4" Web	SA 36
4	5/16" Rib	SA 36
5	3/8" Base Plate	SA 36
6	Bolts - 1" Dia.	N/A

* Corroded Thickness

A. Seismic Analysis Summary

1. Predicted Fundamental Frequency: 23.9 Hz
2. Fundamental Mode: Axial motion of the tank causing saddles to flex.

B. Stress Analysis Summary

1. Status of Stress Levels for Original Design: Satisfactory with reinforcing pad sizes from
2. Overstressed Items in Original Design: None
3. Plant Condition During Overstressing: N/A
4. Modifications to Overstressed Items: None
5. Final Status of Stress Levels for Modified Design: Satisfactory

(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Analysis Summary for Emergency
Closed Cooling Surge Tank-
Tank No. 4, 1P42-A001A, etc.

Figure 3.9-8

Item	Name	Material
1	¼" Flat Top	304L S.S.
2	¼" Cyl. Shell	304L S.S.
3	¼" F & D Bottom	304L S.S.
4	¼" Skirt	304 S.S.
5	3/8" Gusset	304 S.S.
6	8" X ½" Bar	304L S.S.
7	L3" X 2" X ¼"	304 S.S.
8	Bolts – 1¼" Dia.	N/A



A. Seismic Analysis Summary

1. Predicted Fundamental Frequency: 15.0 Hz
2. Fundamental Mode: Cantilever flexing of the tank on the skirt support

B. Stress Analysis Summary

1. Status of Stress Levels for Original Design: Unsatisfactory
2. Overstressed Items in Original Design: ⑧
3. Plant Condition During Overstressing: Faulted
4. Modifications to Overstressed Items:
 - a. Item ⑧ – 1¼" Dia. Bolts replaced by 1½" Dia. Bolts
 - b. Necessary reinforcing pad sizes
 - c. Necessary base plate dimensions to accommodate the 1½" Dia. Bolts
5. Final Status of Stress Levels for Modified Design: Satisfactory


(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Analysis Summary for Fuel Pool
Surge Tank-Tank No. 5,
G41-A002A, etc.

Figure 3.9-9



Item	Name	Material
1	5/16" Cylinder*	SA283-C
2	1/2" F & D Head*	SA283-C
3	L 5 x 3-1/2 x 3/8*	SA36

*Corroded Thickness

A. Seismic Analysis Summary

1. Predicted Fundamental Frequency: N/A
2. Fundamental Mode: N/A, soil displacements influence the structural behavior of tank under seismic conditions. Refer to Section VI for details.

B. Stress Analysis Summary

1. Status of Stress Levels for Original Design: Unsatisfactory
2. Overstressed Items in Original Design: ③
3. Plant Condition During Overstressing: Upset + OBE, Faulted
4. Modifications to Overstressed Items:
 - a. Item ③ – L 5 X 3½ X 7/16 ring stiffener replaced by WT 5 X 30 ring stiffener.
 - b. Necessary reinforcing pad sizes
5. Final Status of Stress Levels for Modified Design: Satisfactory


(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Analysis Summary for Standby
 Diesel Generator Fuel Oil
 Storage Tank-Tank No. 6,
 1R45-A002A, etc.

Figure 3.9-10



Item	Name	Material
1	5/16" Cylinder*	SA283-C
2	7/16" F & D Head*	SA283-C
3	L 4 x 4 x 7/16*	SA36

*Corroded Thickness

A. Seismic Analysis Summary

1. Predicted Fundamental Frequency: N/A
2. Fundamental Mode: N/A, soil displacements influence the structural behavior of tank under seismic conditions.

B. Stress Analysis Summary

1. Predicted Fundamental Frequency: N/A
2. Overstressed Items in Original Design: ③
3. Plant Condition During Overstressing: Upset + OBE, Faulted
4. Modifications to Overstressed Items:
 - a. Item ③ – L 4 X 4 ½ ring stiffener replaced by WT 5 X 22.5 ring stiffener.
 - b. Item ③ – WT 5 X 22.5 moved from outside of tank to inside of tank.
 - c. Necessary reinforcing pad sizes
5. Final Status of Stress Levels for Modified Design: Satisfactory

(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Analysis Summary for HPCS Diesel
Generator Fuel Oil Storage Tank-
Tank No. 7, 1R45-A004, etc.

Figure 3.9-11

Item	Name	Material
1	5/16" Flat Head	304L S.S.
2	1/4" Cyl. Shell	304L S.S.
3	1/4" Bottom	304L S.S.
4a	8" sch 40, l = 6"	A53B
4b	8" sch 40, l = 92.5"	A53B
5a	3" sch 40, l = 59.2"	A53B
5b	3" sch 40, l = 118.3"	A53B
6	L 6 X 4 X 1/4	A36
7	L 6 X 4 X 3/8	A36
8	Bolts - 2" Dia.	N/A



A. Seismic Analysis Summary

1. Predicted Fundamental Frequency: 9.6 Hz
2. Fundamental Mode: Lateral motion of the tank causing cantilever flexing of the supports.

B. Stress Analysis Summary

1. Status of Stress Levels for Original Design: Unsatisfactory
2. Overstressed Items in Original Design: (7)
3. Plant Condition During Overstressing: Faulted
4. Modifications to Overstressed Items:
 - a. Item (7) - L 6 X 4 X 3/8 ring stiffener replaced by L 6 X 6 X 3/8 ring stiffener
 - b. Item (6) - L 6 X 4 X 1/4 roof beam unavailable. L 6 X 4 X 3/8 roof beam will be used instead.
 - c. Necessary reinforcing pad sizes
5. Final Status of Stress Levels for Modified Design: Satisfactory

(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Analysis Summary for Reactor Water
Cleanup F/D BW Settling Tank-
Tank No. 8, G50-A013A, etc.

Figure 3.9-12

Item	Name	Material
1	3/8" Flat Head	Incoloy 825
2	1/4" Cyl. Shell	Incoloy 825
3	1/4" Bottom	Incoloy 825
4a	8" sch 40, l = 6"	A53B
4b	8" sch 40, l = 80.5"	A53B
5a	3" sch 40, l = 69.4"	A53B
5b	3" sch 40, l = 129.8"	A53B
6	L 7 X 4 X 3/8	A36
7	L 6 X 4 X 3/8	A36
8	Bolts - 2" Dia.	N/A



A. Seismic Analysis Summary

1. Predicted Fundamental Frequency: 8.9 Hz
2. Fundamental Mode: Lateral motion of tank causing cantilever flexing of supports

B. Stress Analysis Summary

1. Status of Stress Levels for Original Design: Unsatisfactory
2. Overstressed Items in Original Design: (4a), (4b), (5a), (5b), (7)
3. Plant Condition During Overstressing: Upset + OBE, Faulted
4. Modifications to Overstressed Items:
 - a. Item (4a), (4b) - 8" Sch 40 pipe column replaced by 8" Sch 80 pipe column
 - b. Item (5a), (5b) - 3" Sch 40 pipe brace replaced by 4" Sch 40 pipe brace
 - c. Item (7) - L6 X 4 X 3/8 ring stiffener replaced by WT 6 X 22.5 ring stiffener
 - d. Necessary reinforcing pad sizes
5. Final Status of Stress Levels for Modified Design: Satisfactory

(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Analysis Summary for Concentrated
Waste Tank-Tank No. 9,
G50-A006A, etc.

Figure 3.9-13

Item	Name	Material
1	Shell-Cylin.	304L S.S.
2	Head-Ellip.	304L S.S.
3	Head-Ellip w/Nozzle	304L S.S.
4	Leg- L 2½X2½X3/8	304 S.S.
5	Anchor Bolt	N/A



A. Seismic Analysis Summary

1. Predicted Fundamental Frequency: 87.8 Hz
2. Fundamental Mode: Lateral motion of the tank causing cantilever flexing of the support legs.

B. Stress Analysis Summary

1. Status of Stress Levels for Original Design: Satisfactory, no reinforcing pads required
2. Overstressed Items in Original Design: None
3. Plant Condition During Overstressing: N/A
4. Modifications to Overstressed Items: None
5. Final Status of Stress Levels for Modified Design: Satisfactory

(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Analysis Summary for Safety Relief
Valve Accumulator Tank-
Tank No. 10, 1B21-A004A, etc.

Figure 3.9-14

Item	Name	Material
1	¼" Cyl. Shell *	SA283-C
2	¼" F & D Head *	SA283-C
3	4" Sch 40, l = 54 3/8	SA53-E/B
4	2" Sch 40, l = 59.1	SA53-E/B
5	L 4 X 3 X ¼	SA36
6	Bolts - 1¼" Dia.	N/A

* Corroded Thickness



A. Seismic Analysis Summary

1. Predicted Fundamental Frequency: 20.3 Hz
2. Fundamental Mode: Lateral motion of tank causing cantilever flexing of supports

B. Stress Analysis Summary

1. Status of Stress Levels for Original Design: Satisfactory with reinforcing pad sizes from
2. Overstressed Items in Original Design: None
3. Plant Condition During Overstressing: N/A
4. Modifications to Overstressed Items: None
5. Final Status of Stress Levels for Modified Design: Satisfactory


(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT


Analysis Summary for HPCS Diesel
Fuel Oil Day Tank-
Tank No. 12, 1R45-A005, etc.

Figure 3.9-15



(Rev. 12 1/03)

	PERRY NUCLEAR POWER PLANT
Transient Pressure Differentials Following a Steamline Break (Shroud Support, Core Plate, Upper Shroud)	
Figure 3.9-16	




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Transient Pressure Differentials
Following a Steamline Break
(Average Channel Wall Bottom,
Top Guide)

Figure 3.9-17




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Typical Relief Valve Opening
Transient Forcing Function

Figure 3.9-18



(Rev. 12 1/03)


NOTE:
THIS FIGURE SHOWS GENERAL
LOCATION AND CONFIGURATION
OF MAJOR COMPONENTS ONLY



PERRY NUCLEAR POWER PLANT

Reactor Vessel Cutaway

Figure 3.9-19




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Reactor Internals Flow Paths

Figure 3.9-20





(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Fuel Support Pieces

Figure 3.9-21




(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT



Jet Pump

Figure 3.9-22



(Rev. 12 1/03)

	PERRY NUCLEAR POWER PLANT
Pressure Nodes Used for Depressurizaion Analysis	
Figure 3.9-23	



- NOTES:**
- EVENTS AND TRANSIENTS (1) AND (2) THROUGH (21) ARE "NORMAL CONDITIONS" OR "UPSET CONDITIONS" AS DEFINED IN PARAGRAPHS 00-3113.1 AND 00-3113.2 OF SECTION 111 OF THE 1974 ASME B AND PY CODE.
 - EVENT (2) IS A "TESTING CONDITION" AS DEFINED IN PARAGRAPH 00-3114 OF SECTION 111 OF THE 1974 ASME B AND PY CODE.
 - EVENTS AND TRANSIENTS (22) THROUGH (28) ARE "EMERGENCY CONDITIONS" AS DEFINED IN PARAGRAPH 00-3115.3 OF SECTION 111 OF THE 1974 ASME B AND PY CODE. THE ACTUAL 40 YEAR ENCOUNTER PROBABILITIES ARE 1.1E-1.
 - EVENT (27) IS A "FAULTED CONDITION" AS DEFINED IN PARAGRAPH 00-3112.4 OF SECTION 111 OF THE 1974 ASME B AND PY CODE.
 - LEAK CHECKS AT 400 PSIG PRIOR TO POWER OPERATIONS. 3 CYCLES/START-UP.
 - MECHANICAL LOADS DUE TO SAFETY RELIEF VALVE DISCHARGE SHOULD ALSO BE CONSIDERED. (SEE REFERENCE 1).
 - FLOW CURVES SHOW RECOVERY AFTER CLEARING CONDITIONS THAT CAUSED SCRAM.
 - FEEDWATER FLOW TURNED OFF - ON 6 TIMES PER HOUR DURING PERIODS OF LOW FEEDWATER FLOW.
 - EVENT (8) ASSUMES 100% STEAM BYPASS CAPABILITY. FOR REACTOR PLANTS WITH LESS THAN 100% BYPASS CAPABILITY, THE TRANSIENTS WILL BE LESS SEVERE. FLOW INCREASES AFTER 2 TO 10 MINUTES.
 - THERMAL SLEEVE IS SHOWN AS ONE POSSIBLE METHOD OF ACCOMMODATING ΔT BETWEEN CLEAN-UP AND FW STREAMS. OTHER METHODS WHICH MEET APPLICABLE CODE REQUIREMENTS MAY BE USED.
 - IN LIEU OF USING THE PEAK PRESSURE AS DESIGN PRESSURE FOR ACTIVE VALVES, IT IS PERMISSIBLE TO DEMONSTRATE BY OVERPRESSURE TESTING THAT THE VALVE RETAINS OPERABILITY SUBSEQUENT TO THE TRANSIENT.
 - AN ADDITIONAL SINGLE CYCLE EMERGENCY CONDITION OF 1000 PSIG AT 370°F EXISTS FOR THE CLASS 1 FEEDWATER PIPING UPSTREAM OF FWS.
 - FATIGUE ANALYSIS RESULTS OF COMPONENTS THAT CONSIDER THE CYCLIC INFORMATION CONTAINED ON THIS DRAWING HAVE BEEN USED AS INPUT TO THE FATIGUE MONITORING PROGRAM, NEW AS WELL AS REVISED FATIGUE ANALYSES UTILIZING THE CYCLIC INFORMATION CONTAINED HEREIN REQUIRE INTERFACE WITH THE FATIGUE MONITORING PROGRAM SOFTWARE ADMINISTRATOR.

SUPPLEMENTAL DOCUMENTS UNDER THE FOLLOWING IDENTITIES ARE TO BE USED IN CONJUNCTION WITH THIS DRAWING.

1. CLASS 1 PIPING CYCLES MAIN STEAM	REFERENCE DESIGNATION
2. PIPING AND INSTRUMENT SYMBOLS	021-3000 A02-100


NUCLEAR SAFETY RELATED

(Rev. 18 10/13)

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

Feedwater Design Transients

Figure 3.9-24 (Sheet 1 of 2)
(DWG. D-306-0081-00000)





(Rev. 16 10/09)

PERRY NUCLEAR POWER PLANT



Feedwater Design Transients

Figure 3.9-24 (Sheet 2 of 2)

(Dwg. D-306-082)



- NOTES:-
- EVENTS AND TRANSIENTS (1) AND (2) THROUGH (21) ARE "NORMAL CONDITIONS" OR "UPSET CONDITIONS" AS DEFINED IN PARAGRAPHS 10-3112.1 AND 10-3112.2 OF SECTION 111 OF THE 1974 ASME B AND PV CODE.
 - EVENT (2) IS A "TESTING CONDITION" AS DEFINED IN PARAGRAPH 10-3114 OF SECTION 111 OF THE 1974 ASME B AND PV CODE.
 - EVENTS AND TRANSIENTS (22) THROUGH (26) ARE "EMERGENCY CONDITIONS" AS DEFINED IN PARAGRAPH 10-3113.3 OF THE 1974 ASME B AND PV CODE. THE ACTUAL 40 YEAR ENCOUNTER PROBABILITIES ARE 1E-7.
 - EVENT (27) IS A "FAULTED CONDITION" AS DEFINED IN PARAGRAPH 10-3113.4 OF SECTION 111 OF THE 1974 ASME B AND PV CODE.
 - LEAK CHECKS AT 400 PSIG PRIOR TO POWER OPERATION 3 CYCLES/START-UP (SEE TABLE 1).
 - WORKING EVENTS 8, 10, AND 11 THERE WILL BE A PRESSURE PULSE IN THE MAIN STEAM LINE CAUSED BY TURBINE STOP VALVE CLOSURE. DURATION IS DEPENDENT UPON R.L.L. PIPE WORK ISOLATION AND VALVE STROKE TIME AND IS TO BE DETERMINED BY AC. VALVE STROKE IS MAXIMUM PERMISSIBLE. DRYS DO NOT ACTIVATE DUE TO SHORT DURATION OF PULSE.
 - IF THE STEAM DRAIN LINES DIFFER FROM THE MAIN STEAM LINE THEY WILL BE REPRESENTED BY A DASH LINE. THE STEAM LINE DRAINS (7-15) OPEN WHEN STEAM FLOW DRIPS BELOW 500 WATTS.
 - DURING THE "PAUSE" BETWEEN EVENTS 10 AND 10 THE STEAM TEMPERATURE RISES FROM 340°F TO THE TEMPERATURE OF THE METAL PIPING, 400°F AT THIS POINT THE FLUID TEMPERATURE AND PIPE TEMPERATURE BECOMES THE SAME. FLOODING STARTS AFTER REACHES 400°F BUT AFTER ANY SET TIME STEAM HEAT UP TIME FROM 350°F TO 400°F IS > 3 MINIMUM.
 - STEAM LINES SECTION 1-2-3-4-7 HEAD VENT SECTION 12-13-14 RCIC SECTION 2-3-4-8A DRAIN LINES SECTION 9-10-11.
 - THIS "STEP CHANGE" DEPICTS A STRAIGHT TEMPERATURE DROP AS SOON AS FLOW STARTS.
 - THE STEAM DRAIN TEMPERATURE WILL DROP AT 40°F/HR TO AMBIENT TEMPERATURE AS LONG AS MAIN STEAM FLOW REMAINS ABOVE 500 WATTS THE RISE IN DRAIN TEMPERATURE WHEN FLOW IS BELOW 500 WATTS IS A STEP CHANGE DUE TO IMMEDIATE STEAM FLOW THROUGH DRAIN LINES.
 - TOTAL NUMBER OF MULTIPLE SAFETY RELIEF VALVE LIFTS EQUALS TOTAL OF EVENTS 10, 11, AND 20, 3 TIMES PER EVENT = 90 LIFTS IN EVENTS 21, 22, AND 23. UNLESS OTHERWISE NOTED, THESE SHOULD BE CONSIDERED TO BE 2/3 TO ALL OF THE VALVES INDEPENDENT OF PEAK PRESSURE SHOWN ON THE DIAGRAM.
 - TOTAL NUMBER OF RELIEF VALVE LIFTS FOR ALL EVENTS IS 1000. THIS IS FOR THE HIGHEST DUTY CYCLE VALUE.
 - FOR PART 2, TWO ADDITIONAL EMERGENCY EVENTS UNOVERTAKEN SCRAM AND ACTUAL SCRAM HAS MAY BE COMBINED AND ENVELOPED BY CURVES SHOWN.
 - IN LIEU OF USING THE PEAK PRESSURE AS DESIGN PRESSURE FOR ACTIVE VALVES IT IS PERMISSIBLE TO DEMONSTRATE BY OVERPRESSURE TESTING THAT THE VALVE REMAINS OPERABILITY SUBSEQUENT TO THE TRANSIENTS.
 - FATIGUE ANALYSIS RESULTS OF COMPONENTS THAT CONSIDER THE CYCLIC INFORMATION CONTAINED ON THIS DRAWING HAVE BEEN USED AS INPUT TO THE FATIGUE MONITORING PROGRAM, NEW AS WELL AS REVISED FATIGUE ANALYSES UTILIZING THE CYCLIC INFORMATION CONTAINED HEREIN REQUIRE INTERFACE WITH THE FATIGUE MONITORING PROGRAM SOFTWARE ADMINISTRATOR.




SUPPLEMENTAL DOCUMENTS UNDER THE FOLLOWING IDENTITIES ARE TO BE USED IN CONNECTION WITH THIS DRAWING.

REFERENCE DESIGNATOR
442-000


(REV. 19 10/2015)

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

MAIN STEAM
DRAINS DESIGN TRANSIENTS
FIGURE 3.9-25 (SHEET 1 OF 2)
(DWG. D-306-0605-00000)





(Rev. 16 10/09)



PERRY NUCLEAR POWER PLANT

Main Steam Drains
Design Transients

Figure 3.9-25 (Sheet 2 of 2)
(Dwg. D-306-606)



NOTES:

- BEYOND POINT (1), NO REACTOR VESSEL THERMAL TRANSIENTS PROPAGATE. DURING PLANT OPERATION, AN AXIAL THERMAL GRADIENT EXISTS FROM POINT (1) TO PENETRATION AT SUPPORT RING AND BULKHEAD. THE TEMPERATURE GRADIENT IS SHOWN ON FIGURE 2 OF THIS DESIGN SPECIFICATION. BEYOND THE SUPPORT RING AND BULKHEAD PENETRATION, THE LINES ARE AT AMBIENT CONDITIONS.
- EVENTS AND TRANSIENTS (1) AND (3) THROUGH (21) ARE "NORMAL CONDITIONS" OR "UPSET CONDITIONS" AS DEFINED IN PARAGRAPH NB-3113.1 AND NB-3113.2 OF SECTION III OF THE 1974 ASME B AND PV CODE.
- EVENT (2) IS A "TESTING CONDITION" AS DEFINED IN PARAGRAPH NB-3114 OF SECTION III OF THE 1974 ASME B AND PV CODE. IN ADDITION TO THE 40 PRESSURE TESTING CONDITION CYCLES SHOWN, THERE MAY BE UP TO 10 ADDITIONAL HYDROTEST CYCLES THAT ARE NOT REQUIRED BY ABOVE CODE TO BE INCLUDED IN FATIGUE EVALUATION.
- EVENTS AND TRANSIENTS (22) THROUGH (26) ARE "EMERGENCY CONDITIONS" AS DEFINED IN PARAGRAPH NB-3113.3 OF THE 1974 ASME B AND PV CODE. THE ACTUAL 40 YEAR ENCOUNTER PROBABILITIES ARE < 10⁻¹.
- EVENT (27) IS A "FAULTED CONDITION" AS DEFINED IN PARAGRAPH NB-3113.4 OF SECTION III OF THE 1974 ASME B AND PV CODE.
- LEAK CHECKS AT 400 PSIG PRIOR TO POWER OPERATION 3 CYCLES/START-UP.
- DURING EVENTS (8), (10), AND (11) THERE WILL BE A PRESSURE PULSE IN THE MAIN STEAM LINE CAUSED BY TURBINE STOP VALVE CLOSURE. MAGNITUDE IS DEPENDENT UPON H.P.L., PIPE CONFIGURATION AND VALVE STROKE TIME AND IS DETERMINED BY AE. VALUE SHOWN IS MAXIMUM PERMISSIBLE. SRY'S DO NOT ACTIVATE DUE TO SHORT DURATION OF PULSE.
- DURING THE "PAUSE" BETWEEN EVENTS (13) AND (14) THE STEAM TEMPERATURE RISES FROM 350°F TO THE TEMPERATURE OF THE METAL PIPING, 400°F. AT THIS POINT THE FLUID TEMPERATURE AND PIPE TEMPERATURE BECOMES THE SAME. ALSO, AT THIS TIME, FLOODING STARTS. STEAM HEAT UP TIME FROM 350°F TO 400°F IS > 5 MINUTES.

NOTES: (CONTINUED ON B-306-634)


(Rev. 16 10/09)



PERRY NUCLEAR POWER PLANT

Reactor Core Isolation
Cooling Design Transients

Figure 3.9-26 (Sheet 1 of 4)
(Dwg. B-306-631)




(Rev. 16 10/09)



PERRY NUCLEAR POWER PLANT

Reactor Core Isolation
Cooling Design Transients

Figure 3.9-26 (Sheet 2 of 4)
(Dwg. B-306-632)



CLASS 1 PIPING BETWEEN MAIN STEAM "A" AND OUTBOARD ISOLATION VALVE MO-FOG4

FOR NOTES AND LINE SEGMENT IDENTIFICATION, SEE B-306-G31


(Rev. 16 10/09)




PERRY NUCLEAR POWER PLANT

Reactor Core Isolation Cooling Design Transients

Figure 3.9-26 (Sheet 3 of 4)
(Dwg. B-306-633)



- NOTES: (CONTINUED FROM B-306-631)
9. IN EVENT (20A), EACH INCREASING TEMPERATURE STEP CHANGE (40 TO 525°F, 40 TO 490°F, AND 40 TO 485°F) OCCURS OVER A 2 MINUTE TIME PERIOD.
 10. THE 900 GPM FLOW RATE IN EVENTS (15), (16), AND (17) IS THE RHR SYSTEM FLOW FROM THE DISCHARGE OF THE LOOP A RHR PUMP.
 11. THE 700 GPM FLOW RATE IN EVENTS (20A) AND (20B) IS THE RCIC SYSTEM FLOW FROM THE DISCHARGE OF THE RCIC PUMP.
 12. FATIGUE ANALYSIS RESULTS OF COMPONENTS THAT CONSIDER THE CYCLIC INFORMATION CONTAINED ON THIS DRAWING HAVE BEEN USED AS INPUT TO THE FATIGUE MONITORING PROGRAM. NEW AS WELL AS REVISED FATIGUE ANALYSES UTILIZING THE CYCLIC INFORMATION CONTAINED HEREIN REQUIRE INTERFACE WITH THE FATIGUE MONITORING PROGRAM SOFTWARE ADMINISTRATOR.





(Rev. 18 10/13)

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

Reactor Core Isolation
Cooling Design Transients

Figure 3.9-26 (Sheet 4 of 4)
(DWG. B-306-0634-00000)



- NOTES:
- EVENTS AND TRANSIENTS (1) AND (3) THROUGH (11) ARE "NORMAL CONDITIONS" OR "UPSET CONDITIONS" AS DEFINED IN PARAGRAPHS NB-3113.1 AND NB-3113.2 OF SECTION III OF THE 1074 ASME B AND PV CODE.
 - EVENT (2) IS A "TESTING CONDITION" AS DEFINED IN PARAGRAPH NB-3114 OF SECTION III OF THE 1074 ASME B AND PV CODE.
 - EVENTS AND TRANSIENTS (12) THROUGH (14) ARE "EMERGENCY CONDITIONS" AS DEFINED IN PARAGRAPH NB-3113.3 OF SECTION III OF THE 1074 ASME B AND PV CODE. THE ACTUAL 40-YEAR ENCOUNTER PROBABILITIES ARE 1.0×10^{-4} .
 - EVENT (27) IS A "FAULTED CONDITION" AS DEFINED IN PARAGRAPH NB-3113.4 OF SECTION III OF THE 1074 ASME B AND PV CODE.
 - LEAKS AT 400 PSIG PRIOR TO POWER OPERATIONS, 3 CYCLES/START-UP.
 - MECHANICAL LOADS DUE TO SAFETY RELIEF VALVE DISCHARGE SHOULD ALSO BE CONSIDERED. (SEE REFERENCE 1).
 - THIS DIAGRAM SHOWS LOCATIONS FOR LOOP C. FOR LOOPS A AND B, THE INJECTION VALVE IS BETWEEN CONTAINMENT AND DRYWELL.
 - SECTION 6 GETS A PRESSURE PULSE (INSTANTANEOUS) TO 500 PSIG AT THIS POINT.
 - IN LIEU OF USING THE PEAK PRESSURE AS DESIGN PRESSURE FOR ACTIVE VALVES, IT IS PERMISSIBLE TO DEMONSTRATE BY OVERPRESSURE TESTING THAT THE VALVE RETAINS OPERABILITY SUBSEQUENT TO THE TRANSIENT.
 - NO REACTOR VESSEL THERMAL GRADIENTS PROPAGATE BEYOND POINT (1) TO THE DRYWELL WALL PENETRATION. THIS TEMPERATURE GRADIENT IS SHOWN ON FIGURE 2 OF THE DESIGN SPECIFICATION. BEYOND THE DRYWELL WALL PENETRATION, THE LINES ARE AT AMBIENT CONDITIONS.
 - FATIGUE ANALYSIS RESULTS OF COMPONENTS THAT CONSIDER THE CYCLIC INFORMATION CONTAINED ON THIS DRAWING HAVE BEEN USED AS INPUT TO THE FATIGUE MONITORING PROGRAM. NEW AS WELL AS REVISED FATIGUE ANALYSES UTILIZING THE CYCLIC INFORMATION CONTAINED HEREIN REQUIRE INTERFACE WITH THE FATIGUE MONITORING PROGRAM SOFTWARE ADMINISTRATOR.

SUPPLEMENTAL DOCUMENTS UNDER THE FOLLOWING IDENTITIES ARE TO BE USED IN CONJUNCTION WITH THIS DRAWING.


1. CLASS 1 PIPING CYCLES IN IN STEAM	REFERENCE DESIGNATOR 021-0000
2. PIPING AND INSTRUMENT SYMBOLS	042-1010

(Rev. 18 10/13)

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

Residual Heat Removal
Design Transients

Figure 3.9-27 (Sheet 1 of 4)
(DWG. D-306-0641-00000)






(Rev. 16 10/09)



PERRY NUCLEAR POWER PLANT

Residual Heat Removal
Design Transients

Figure 3.9-27, (Sheet 2 of 4)
(Dwg. D-306-642)



RHR SHUTDOWN SUCTION LINE (CLASS 1 PIPING) FROM RECIRCULATION LOOP 'B' TO OUTBOARD ISOLATION VALVE A008




NOTES:
 1. FOR NOTES AND LINE SYMBOL IDENTIFICATION, SEE DRAWING D-306-643.

(Rev. 16 10/09)

PERRY NUCLEAR POWER PLANT

Residual Heat Removal Design Transients


Figure 3.9-27 (Sheet 3 of 4)
 (Dwg. D-306-643)



RHR SHUTDOWN SUCTION LINE (CLASS 1 PIPING) FROM RECIRCULATION LOOP "B" TO OUTBOARD ISOLATION VALVE FOOS



NOTE:
1. FOR NOTES AND LINE NUMBER IDENTIFICATION, SEE DRAWING D-306-644.

(Rev. 16 10/09)



PERRY NUCLEAR POWER PLANT
Residual Heat Removal
Design Transients

(Figure 3.9-27 (Sheet 4 of 4))
(Dwg. D-306-644)






- NOTES:-**
- EVENTS AND TRANSIENTS (1) AND (3) THROUGH (21) ARE "NORMAL CONDITIONS" OR "UPSET CONDITIONS" AS DEFINED IN PARAGRAPHS NB-3113.1 AND NB-3113.2 OF SECTION III OF THE 1974 ASME B AND PV CODE.
 - EVENT (2) IS A "TESTING CONDITION" AS DEFINED IN PARAGRAPH NB-3114 OF SECTION III OF THE 1974 ASME B AND PV CODE.
 - EVENTS AND TRANSIENTS (22) THROUGH (28) ARE "EMERGENCY CONDITIONS" AS DEFINED IN PARAGRAPH NB-3113.3 OF SECTION III OF THE 1974 ASME B AND PV CODE. THE ACTUAL 40 YEAR ENCOUNTER PROBABILITIES ARE $<10^{-7}$.
 - EVENT (27) IS A "FAULTED CONDITION" AS DEFINED IN PARAGRAPH NB-3113.4 OF SECTION III OF THE 1974 ASME B AND PV CODE.
 - LEAK CHECKS AT 400 PSIG PRIOR TO POWER OPERATION 3 CYCLES/START-UP.
 - MECHANICAL LOADS DUE TO SAFETY RELIEF VALVE DISCHARGE SHOULD ALSO BE CONSIDERED (SEE REFERENCE 1).
 - IN LIEU OF USING THE PEAK PRESSURE AS DESIGN PRESSURE FOR ACTIVE VALVES, IT IS PERMISSIBLE TO DEMONSTRATE BY OVERPRESSURE TESTING THAT THE VALVE RETAINS OPERABILITY SUBSEQUENT TO THE TRANSIENT.
 - NO REACTOR VESSEL THERMAL GRADIENTS PROPORTATE BEYOND POINT (2). DURING PLANT OPERATION, AN AXIAL THERMAL GRADIENT EXISTS FROM POINT (2) TO THE DRYWELL WALL PENETRATION. THIS TEMPERATURE GRADIENT IS SHOWN ON FIGURE 2 OF THIS DESIGN SPECIFICATION.
 - THE TIME INTERVALS FOR THE PRESSURE/TEMPERATURE CYCLES OF EVENT (28) ARE SHOWN ON THE SAME NUMBERED EVENT ON THE R.E. REACTOR CYCLES DRAWING (GAI FOLDER NO. 4549-88-437-2-8). THE DURATION OF THE FLOW/TEMPERATURE TRANSIENTS FOR EVENT (28) IS SHOWN ON THE R.E. REACTOR VESSEL NOZZLE THERMAL CYCLES DRAWING (GAI FOLDER NO. 4549-88-341-7-2).
 - FATIGUE ANALYSIS RESULTS OF COMPONENTS THAT CONSIDER THE CYCLIC INFORMATION CONTAINED ON THIS DRAWING HAVE BEEN USED AS INPUT TO THE FATIGUE MONITORING PROGRAM, NEW AS WELL AS REVISED FATIGUE ANALYSES UTILIZING THE CYCLIC INFORMATION CONTAINED HEREIN REQUIRE INTERFACE WITH THE FATIGUE MONITORING PROGRAM SOFTWARE ADMINISTRATOR.
- SUPPLEMENTAL DOCUMENTS UNDER THE FOLLOWING IDENTITIES ARE TO BE USED IN CONJUNCTION WITH THIS DRAWING.**
- | REFERENCE DESIGNATOR | IDENTITY |
|----------------------|-------------------------------------|
| 821-3000 | 1. CLASS 1 PIPING CYCLES MAIN STEAM |
| 442-1010 | 2. PIPING AND INSTANTANEOUS SYMBOLS |

(Rev. 18 10/13)

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

High Pressure Core Spray
Design Transients

Figure 3.9-28 (Sheet 1 of 2)
(DWG. D-306-0701-00000)





(Rev. 16 10/09)


PERRY NUCLEAR POWER PLANT

High Pressure Core Spray
Design Transients


Figure 3.9-28 (Sheet 2 of 2)
(Dwg. D-306-702)



- NOTES:
- EVENTS AND TRANSIENTS (1) AND (3) THROUGH (21) ARE "NORMAL CONDITIONS" OR "UPSET CONDITIONS" AS DEFINED IN PARAGRAPHS NB-3113.1 AND NB-3113.2 OF SECTION III OF THE 1974 ASME B AND PY CODE.
 - EVENT (2) IS A "TESTING CONDITION" AS DEFINED IN PARAGRAPH NB-3114 OF SECTION III OF THE 1974 ASME B AND PY CODE.
 - EVENTS AND TRANSIENTS (22) THROUGH (26) ARE "EMERGENCY CONDITIONS" AS DEFINED IN PARAGRAPH NB-3113.3 OF SECTION III OF THE 1974 ASME B AND PY CODE. THE ACTUAL 40 YEAR ENCOUNTER PROBABILITIES ARE <0.1 .
 - EVENT (27) IS A "FAULTED CONDITION" AS DEFINED IN PARAGRAPH NB-3113.4 OF SECTION III OF THE 1974 ASME B AND PY CODE.
 - LEAK CHECKS AT 400 PSIG PRIOR TO POWER OPERATION. 3 CYCLES/START-UP.
 - MECHANICAL LOADS DUE TO SAFETY RELIEF VALVE DISCHARGE SHOULD ALSO BE CONSIDERED (SEE REFERENCE 1).
 - SECTION 8 GETS A PRESSURE PULSE (INSTANTANEOUS) TO 800 PSIG AT THIS POINT.
 - IN LIEU OF USING THE PEAK PRESSURE AS DESIGN PRESSURE FOR ACTIVE VALVES, IT IS PERMISSIBLE TO DEMONSTRATE BY OVERPRESSURE TESTING THAT THE VALVE REMAINS OPERABILITY SUBSEQUENT TO THE TRANSIENT.
 - NO REACTOR VESSEL THERMAL GRADIENTS PROPAGATE BEYOND POINT 2. DURING PLANT OPERATION, AN AXIAL THERMAL GRADIENT EXISTS FROM POINT 2 TO THE DRYWELL WALL PENETRATION. THIS THERMAL GRADIENT IS SHOWN IN FIGURE 2 OF THIS DESIGN SPECIFICATION. BEYOND THE DRYWELL WALL PENETRATION, THE LINES ARE AT AMBIENT CONDITIONS.
 - FATIGUE ANALYSIS RESULTS OF COMPONENTS THAT CONSIDER THE CYCLIC INFORMATION CONTAINED ON THIS DRAWING HAVE BEEN USED AS INPUT TO THE FATIGUE MONITORING PROGRAM. NEW AS WELL AS REVISED FATIGUE ANALYSES UTILIZING THE CYCLIC INFORMATION CONTAINED HEREIN REQUIRE INTERFACE WITH THE FATIGUE MONITORING PROGRAM SOFTWARE ADMINISTRATOR.



- SUPPLEMENTAL DOCUMENTS UNDER THE FOLLOWING IDENTITIES ARE TO BE USED IN CONJUNCTION WITH THIS DRAWING.
- | IDENTITY | REFERENCE DESIGNATION |
|---------------------------------------|-----------------------|
| 1. CLASS 1 PIPING CYCLES - MAIN STEAM | 821-3000 |
| 2. PIPING AND INSTRUMENT SYMBOLS | 442-1010 |




(Rev. 18 10/13)

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

Low Pressure Core Spray
Design Transients

Figure 3.9-29 (Sheet 1 of 2)
(DWG. D-306-0705-00000)





(Rev. 16 10/09)

PERRY NUCLEAR POWER PLANT

Low Pressure Core Spray
Design Transients

Figure 3.9-29 (Sheet 2 of 2)
(Dwg. D-306-706)





NOTES

- EVENTS 4 TRANSIENTS (1) THROUGH (21) ARE "NORMAL CONDITIONS" OR "UPSET CONDITIONS" AS DEFINED IN PARAGRAPH NB-315.1.4.3.15.2 OF SECTION III OF THE 1974 ASME B4 PV CODE.
- EVENT 2 IS A "TESTING CONDITION" DEFINED IN PARAGRAPH NB-315.1.4 OF SECTION III OF THE 1974 ASME B 4 PV CODE.
- EVENTS 7 TRANSIENTS (22) THROUGH (26) ARE "EMERGENCY CONDITIONS" AS DEFINED IN PARAGRAPH NB-315.5 OF SECTION III OF THE 1974 ASME B 4 PV CODE. THE 1974 ASME B 4 PV CODE PROVISIONS ARE APPLIED.
- EVENT 27 IS A "FAULTED CONDITION" DEFINED IN PARAGRAPH NB-315.4 OF SECTION III OF THE 1974 ASME B 4 PV CODE.
- LEAK CHECKS PRIOR TO POWER OPERATION, 5 PRESSURE CYCLES/START-UP.
- MECHANICAL LOADS DUE TO SAFETY RELIEF VALVE DISCHARGE SHOULD ALSO BE CONSIDERED (SEE REF 1).
- 250 CLEANUP SYSTEM TRIPS SHALL BE ASSUMED (ZERO RWCU FLOW).
- ACTIVE LOOP SAME AS EVENT 12.
- THE TEMPERATURES SHALL BE USED AS BOUNDARY CONDITIONS FOR THE REGR. LOOP PIPING AND EQUIPMENT IN CONTACT WITH THE CONTAINED FLUID.
- THERE ARE 4-6 RISERS DEPENDING ON THE PLANT. SEE REGR. RECIRC. (R/R) P&ID DATA FOR SPECIFIC PLANT. THE FLOW IN SECT 7-5 WILL DIVIDE EQUALLY IN THE RISERS.
- FOR THE CASE WHEN ONE RECIRCULATION LOOP IS OUT OF SERVICE AND VALVED OFF, A LEAKY Suction VALVE CAN MAINTAIN THE Suction LINE AT 540°F WHILE THE DISCHARGE LINE COOLS TO 100°F OR A LEAKY DISCHARGE VALVE CAN MAINTAIN THE DISCHARGE LINE AT 540°F WHILE THE Suction LINE COOLS TO 100°F. 20 TIMES MAX AT 6 100°F/HR.
- FLOW IN SEGMENT 11-12 IS ~1% OF RATED Suction LINE FLOW.
- WITH THE EXCEPTION OF EVENT 12, THE TEMP IN SEGMENT 11-2 IS THE SAME AS SEGMENT 11-1.
- FOR ALL EVENTS THE PRESSURE 11-12 IS THE SAME AS SEGMENT 11-1.
- 1% FLOW SHOWN FOR A GIVEN PIPE SEGMENT IS THE RATIO OF THE PIPE SEGMENT'S FLOW TO THAT SEGMENT'S RATED FLOW. THE ONLY EXCEPTION IN SEGMENT 5-4 (LOOP B ONLY) WHERE THE 1% FLOW IS THE RATIO OF THE ACTUAL FLOW TO THE Suction PIPING RATED FLOW. RATED FLOW FOR SEGMENT 5-4 (RHR Suction LINE) IS 17% OF THE RATED Suction LINE FLOW.
- FOR PART 2, TWO ADDITIONAL EMERGENCY EVENTS (INDEPENDENT SCRAMS/ACTUAL SCRAMS) HAVE BEEN COMBINED AND ENVELOPED BY CURVE SHOWN.
- IN LIEU OF USING THE PEAK PRESSURE AS DESIGN PRESSURE FOR ACTIVE VALVES, IT IS PERMISSIBLE TO DEMONSTRATE BY OVERPRESSURE TESTING THAT THE VALVE REMAINS OPERABILITY SUBSEQUENT TO THE TRANSIENT.
- FATIGUE ANALYSIS RESULTS OF COMPONENTS THAT CONSIDER THE CYCLIC INFORMATION CONTAINED ON THIS DRAWING HAVE BEEN USED AS INPUT TO THE FATIGUE MONITORING PROGRAM NEW AS WELL AS REVISED FATIGUE ANALYSES UTILIZING THE CYCLIC INFORMATION CONTAINED HEREIN REQUIRE INTERFACE WITH THE FATIGUE MONITORING PROGRAM SOFTWARE ADMINISTRATOR.
- SINGLE LOOP REACTOR RECIRCULATION PUMP OPERATION HAS BEEN ADDED AS A LICENSE CONDITION IN USAR APPENDIX 15F. DURING THIS CONDITION THE IDLE RECIRCULATION LOOP AND ASSOCIATED REACTOR WATER CLEAN-UP VALVES ARE NOT ISOLATED AND REMAIN AT TEMPERATURE. ISOLATION OF THE IDLE LOOP IS CONSIDERED AN EMERGENCY CONDITION AND IS LIMITED TO 5 THERMAL CYCLES OVER THE PLANT LIFE (REFERENCE GE LETTER J8894845).

SUPPLEMENTAL DOCUMENTS: DOCUMENTS UNDER THE FOLLOWING IDENTITIES ARE TO BE USED IN CONJUNCTION WITH THIS DRAWING

1. CLASS 1 PIPING CYCLES - MAIN STEAM	REFERENCE DESIGNATOR B21-0000
2. PIPING AND INSTRUMENTATION SYMBOLS	A42-1010


CLASS 1 PIPING BETWEEN REACTOR RECIRCULATION LOOPS AND OUTBOARD ISOLATION VALVE FO04.



(REV. 19 10/2015)

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

REACTOR WATER CLEAN-UP
DESIGN TRANSIENTS
FIGURE 3.9-30 (SHEET 1 OF 4)
(DWG. D-306-0661-00000)




(Rev. 16 10/09)

PERRY NUCLEAR POWER PLANT

Reactor Water Clean-Up
 Design Transients


Figure 3.9-30 (Sheet 2 of 4)
 (Dwg. D-306-662)




CLASS 1 PIPING BETWEEN REACTOR
VESSEL, PRIMARY HEAT EXCHANGER
AND CONDENSER
IS NOT CLASSIFIED

NOTE:
1. THIS SYSTEM HAS LOW BURST RESISTANCE.
SEE SECTION 3-200-00.

(Rev. 16 10/09)


PERRY NUCLEAR POWER PLANT

Reactor Water Clean-Up
 Design Transients
 Figure 3.9-30 (Sheet 3 of 4)
 (Dwg. D-306-663)



CLASS 1 PIPING BETWEEN REACTOR VESSEL, DRAIN NOZZLE AND CONNECTION TO RWCU CLEAN-UP LINE.

NOTE: 1. FOR WATER AND LINE WEIGHT IDENTIFICATION, SEE DRAWING D-306-664.


(Rev. 16 10/09)



PERRY NUCLEAR POWER PLANT

Reactor Water Clean-Up
Design Transients

Figure 3.9-30 (Sheet 4 of 4)
(Dwg. D-306-664)




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Typical Vertical Board

Figure 3.10-1




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Typical Instrument Rack

Figure 3.10-2




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Typical Local Rack

Figure 3.10-3



(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Typical NEMA-12 Enclosure

Figure 3.10-4

ZONE	DRAWING	CLASS	DESCRIPTION	TYPICAL EQUIPMENT	ZONE	DRAWING	CLASS	DESCRIPTION	TYPICAL EQUIPMENT
AUXILIARY BUILDING					EMERGENCY SERVICE WATER PUMPHOUSE				
AB-1	002	HARSH	HVAC EQUIPMENT AREAS	AUXILIARY BUILDING HVAC EQUIPMENT PANELS, INST & CONTROLS	ES-W	035	MILD	GENERAL AREA	EMERGENCY SERVICE WATER PUMPS & MOTORS
AB-1E	002	HARSH	HVAC EQUIPMENT AREAS ELEVATION 620'-6"	AUXILIARY BUILDING HVAC EQUIPMENT PANELS, INST & CONTROLS					
AB-2E	002	HARSH	LPCS PUMP ROOMS	LPCS PUMP, MOTOR, PANELS, I & C					
AB-2W	002	HARSH	HPCS PUMP ROOMS	HPCS PUMP, MOTOR, PANELS, I & C					
AB-3	003	HARSH	RCIC TURBINE & PUMP ROOMS	RCIC PUMP TURBINE, GLAND SEAL & COMPRESSOR PANEL, INST & CONTROLS	FB-1	040 SH. 1	MILD	FUEL POOL PUMP AREA	FUEL POOL PUMP & MOTORS, RAD MONITORS, PANELS, INST & CONTROLS, LEAK DETECTION EQUIP, FUEL POOL HEAT EXCH, CHILLED WATER PUMPS & SERVICE AIR
AB-4	004	HARSH	RHR PUMP ROOMS	RHR PUMPS & MOTORS, HEAT EXCHANGER PANELS, INST & CONTROLS	FB-2	040 SH. 1	MILD	OPERATING FLOOR	NEUTRON SYS AMPLIFIERS, POOL RAD MONITORS, AUX PLATFORMS FUEL PREP MACHINES, PANELS, INST & CONTROLS
AB-5	005	HARSH	RWCU PUMP ROOMS	RWCU PUMPS & MOTORS PANEL, INSTRUMENTS & CONTROLS					CRD PUMPS & MOTORS, RADIATION MONITORS, FUEL HANDLING HVAC EQUIPMENT
AB-6	005	MILD	CORRIDORS OUTSIDE ECCS ROOMS	MISC. INSTRUMENTS AND CONTROL PANELS	FB-3-574	040 SH. 1	HARSH	AREA AT 574' ELEVATION	
AB-7E	006	HARSH	STEAM TUNNEL	MSIV'S & NS SHUTOFF SYSTEM MSIV LEAK DETECTION EQUIPMENT	FB-3-N	040 SH. 2	HARSH	NORTHERN HALF AT 599' ELEVATION	
AB-7W	006	HARSH	STEAM TUNNEL	MSIV'S & NS SHUTOFF SYSTEM MSIV LEAK DETECTION EQUIPMENT	FB-3-S	040 SH. 2	HARSH	SOUTHERN HALF AT 599' ELEVATION	
AB-8	007	HARSH	PIPING CONTAINMENT PENETRATIONS/CHASE	MISC. PIPING/ISOLATION VALVES	FB-4	041	MILD	HVAC EQUIPMENT AREAS	AEGTS FANS, FILTERS, CONTROLS, CV & DW PURGE SYS FANS FILTERS & CONTROLS, FUEL HANDLING AREA VENT SYSTEM FANS, FILTERS INTERM, BLDG HVAC EQUIPMENT PAGE/PARTY BATTERY BACKUP SYSTEM
AB-9	007	HARSH	CORRIDORS OUTSIDE ECCS PUMP ROOMS	PANELS, INSTRUMENTS & CONTROLS	FB-5	041	MILD	ELECTRICAL PENETRATION AREA	ELECTRICAL PENETRATIONS PANELS, INST & CONTROLS
AB-10	008	HARSH	ADHR HEAT EXCHANGER AREA	ADHR HEAT EXCHANGER, MISC. PIPING & VALVES	FB-6	041	HARSH	PIPE CHASE (EL. 585'-0")	MISC INSTRUMENTATION
					FB-7	042	HARSH	AEGTS AREA	ANNULUS EXHAUST GAS TREATMENT SYSTEM EQUIPMENT AND CONTROLS
					FB-8	042	HARSH	FUEL HANDLING BUILDING EXHAUST FILTER ROOM	FH BLDG EXHAUST FILTER & INSTRUMENTATION
CONTROL BUILDING					HEATER BAY INSTRUMENT ROOM				
CB-1	010	MILD	CONTROL ROOM	CONTROL BOARD PGCC	HB-1	047	MILD	HEATER BAY EL. 667'-6"	INSTRUMENTS
CB-2-B	010	MILD	DIV. 1/DIV. 2 AND HPCS BATTERY ROOMS	DC SYSTEM/BATTERIES					
CB-2-620	010	MILD	MCC SWITCHGEAR, AND MISC. EQUIPMENT AREAS	SWITCHGEAR, LOAD CENTERS, MCC'S, RPS MG SETS, REMOTE S/D PANEL					
CB-2-638	010	MILD	DC SWITCHGEAR AND CABLE SPREADING AREA	DC SWITCHGEAR, CABLES, ELECTRICAL DISTRIBUTION PANELS					
CB-3	010	MILD	HVAC EQUIPMENT AREAS	FANS, CHILLERS & CHILLER PUMPS PANELS, INST & CONTROLS					
CB-4	011	MILD	CONTROLLED ACCESS & MISC EQUIPMENT AREA	CONTROL ACCESS LABS, LOCKER ROOMS, NUCLEAR CLOSED COOLING WATER PUMPS & HEAT EXC. COMPUTER	OG-B	046	MILD	OFF-GAS BUILDING EXHAUST AREA	OFF-GAS TREATMENT AND MONITORING EQUIPMENT
CB-5	012	MILD	EMERGENCY CLOSED COOLING PUMP AREA	EMERGENCY CLOSED COOLING PUMP & HEAT EXCH CONTROL COMPLEX CHILLED WATER INST./SERVICE AIR					
CONTAINMENT					OUTSIDE				
CT-0	020	HARSH	CONTAINMENT ANNULUS	ISOLATION VALVES	OU-T	047	MILD	GENERAL YARD AREA	INSTRUMENTS, VALVES
CT-1	020 021	HARSH	ABOVE REFUELING FLOOR	REFUELING PLATFORM, FUEL PREPARATION MACHINES, RADIATION & ATMOSPHERE MONITORS					
CT-2	021	HARSH	IMMEDIATELY ABOVE SUPPRESSION POOL	TIP DRIVE SYSTEM, C&I PANELS					
CT-3	022	HARSH	HCU FLOOR	HCU UNITS & PANELS, MULTIPLEXER					
CT-4	022 023	HARSH	SLCS AREA	SLC SYSTEM EQUIPMENT & PANEL	TB-1	050	HARSH	STEAM LINE AREA UNDER HP TURBINE	STOP VALVES, CONTROL VALVES & PRESSURE TRANSMITTERS
CT-5	023 024	HARSH	RWCU ROOMS	RWCU HEAT EXCH & F/D UNITS & PUMPS, BACKWASH RECEIVING TANK & VALVE HOLDING PUMP	TB-2	050 051	HARSH	HEATER BAY & TURB BLDG OUTSIDE SHIELD WALLS	PANELS, INST & CONTROLS
CT-6	024	HARSH	STEAM TUNNEL	MAIN STEAM PIPING, FW PIPING RWCU PIPING, RADWASTE PIPING	TB-3	051	HARSH	TURBINE BLDG WEST END EL. 620'-6"	TURBINE MAINTENANCE EQUIPMENT
CT-7	025	HARSH	SLCS AREA (SUBJECT TO CONTAINMENT SPRAY)	SLC SYSTEM EQUIPMENT & PANELS					
CT-8	025 026	HARSH	AREAS ADJACENT TO RWCU ROOMS (SUBJ. TO CONT. SPRAY)	RWCU EQUIPMENT					
DIESEL GENERATOR BUILDING					NOTES: 1. ZONES ARE ILLUSTRATED ON DRAWING E-022-0060 THROUGH E-022-0067 AND B-022-0068 ENVIRONMENTAL CONDITIONS IN EACH ZONE ARE PROVIDED BY DRAWING B-022-0002 THROUGH B-022-0051 2. DRAWINGS AS LISTED ARE PRECEDED BY B-022- 3. CLASSIFICATION DEFINITIONS: HARSH ENVIRONMENT - THOSE ZONES WHERE THE ENVIRONMENTAL CONDITIONS EXCEED SIGNIFICANTLY THE NORMAL/ABNORMAL RANGE AS A RESULT OF A DBE. MILD ENVIRONMENT - THOSE ZONES WHERE THE ENVIRONMENTAL CONDITIONS DO NOT SIGNIFICANTLY EXCEED THE NORMAL/ABNORMAL RANGE AS A RESULT OF A DBE.				
DG-1	027	MILD	GENERAL AREA - DIV. 1 / 2	DIESEL GENERATOR & ACCESSORIES, DIESEL GENERATOR CONTROL PANELS & MOTOR CONTROL CENTER					
DG-2	027	MILD	GENERAL AREA - DIV. 3	DIESEL GENERATOR & ACCESSORIES, DIESEL GENERATOR CONTROL PANELS & MOTOR CONTROL CENTER					
DRYWELL									
DW-1	030	HARSH	OUTSIDE RPV SHIELD WALL - NOT AT CORE MIDPLANE	RECIRCULATION SYSTEM EQUIPMENT RECIRCULATION SUSPENSION					
DW-2	030 031	HARSH	OUTSIDE RPV SHIELD WALL - AT CORE MIDPLANE	CONDENSER CHAMBERS, GROSS GAMMA DETECTION, SAFETY/RELIEF VALVES, MSIV'S					
DW-3	031	HARSH	UNDER RPV	CONTROL ROD DRIVES, NEUTRON MONITORS, VESSEL SKIRT FLANGE BOTTOM HEAD INSULATION, CRD REMOVAL PLATFORM					
DW-4	032	HARSH	DRYWELL DOME	VESSEL HEAD AND INSULATION VESSEL-TO-DRYWELL SEAL					
DW-5	032	HARSH	RPV SKIRT	VESSEL SUPPORT SKIRT					

(REV. 19 10/2015)

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

ENVIRONMENTAL ZONES
LEAD SHEET
FIGURE 3.11-10
(DWG. B-022-0001-00000)

PLANT OPERATING CONDITION	SIGNIFICANT EVENT	CYCLES	CONDITION DURATION (1)	TEMPERATURE °F	RELATIVE HUMIDITY(2) @ T FINAL (2)	PRESSURE	GAMMA RADIATION(3)		SUPPLEMENTARY DATA
							MAX DOSE RATE RADS/HR	DOSE INTEGRATED RADS	
ZONE AB-1 / AB-1E (HARSH) HVAC EQUIPMENT AREAS									
NORMAL MAX MIN AVERAGE	NORMAL FULL POWER OPERATION	1	8407 HRS 3503 HRS 338,390 HRS	115 60 90	90 20 50	ATMOSPHERE ATMOSPHERE ATMOSPHERE	2.5x10 ⁻³	8.8x10 ²	(4) (9) (10)
ABNORMAL MAX MIN	LOSS OF HVAC	1	100 HRS	124	90 20	ATMOSPHERE ATMOSPHERE			(5) (6)
ACCIDENT MAX AVERAGE (180 DAYS)	LOCA INSIDE CONTAINMENT SAFETY RELATED COOLING SYSTEM RUNNING	1		124 114	90 max 20 min	ATMOSPHERE ATMOSPHERE			(7)
ACCIDENT	LOCA INSIDE CONTAINMENT	1	1 HR 6 HR 24 HRS 30 DAYS 100 DAYS 180 DAYS				3.76x10 ¹	3.32x10 ¹ 2.25x10 ² 3.52x10 ² 4.00x10 ² 4.00x10 ²	
ACCIDENT	LOCA INSIDE CONTAINMENT	1	1 HR 8 HR 24 HR 30 DAYS 60 DAYS 180 DAYS				1.77x10 ⁴	1.36x10 ⁴ 4.47x10 ⁴ 6.09x10 ⁴ 9.78x10 ⁵ 1.02x10 ⁵ 1.04x10 ⁵	(11)
ACCIDENT	RHR 10" LINE BREAK - STEAM SUPPLY LINE W/LOOP IN ZONE AB-4	1	0 SEC 1.0 SEC 2.0 SEC 10.0 SEC 19.0 SEC 25.0 SEC 30.0 SEC 45.0 SEC 3.0 MIN 15 MIN 35 MIN 60 MIN 1 DAY	115 193 224 296 302 298 288 264 237 200 184 155 123	90 100 100 100 100 100 100 90 90 90 90 90 90	ATMOSPHERE 0.3 PSIG 0.3 PSIG 0.3 PSIG 0.3 PSIG 0.3 PSIG 0.3 PSIG ATMOSPHERE ATMOSPHERE ATMOSPHERE ATMOSPHERE ATMOSPHERE ATMOSPHERE			AIR STEAM STEAM STEAM STEAM STEAM STEAM STEAM AIR AIR AIR AIR AIR
ZONE AB-2E (HARSH) LPCS PUMP ROOM									
NORMAL MAX MIN AVERAGE	NORMAL FULL POWER OPERATION	1	8407 HRS 3503 HRS 338,390 HRS	107 71 84	90 20 50	ATMOSPHERE ATMOSPHERE ATMOSPHERE	3.5x10 ⁰	1.57x10 ⁵	(4) (9) (10)
ABNORMAL MAX MIN	LOSS OF HVAC	1	100 HRS	126 126	90 20	ATMOSPHERE ATMOSPHERE			(5) (6)
ACCIDENT MAX AVERAGE (180 DAYS)	LOCA INSIDE CONTAINMENT	1		146 146	90 max 20 min	ATMOSPHERE ATMOSPHERE			(7)
ACCIDENT	LOCA INSIDE CONTAINMENT	1	0 TO 1 HR 6 HR 24 HRS 30 DAYS 100 DAYS 180 DAYS				2.42x10 ⁵	1.88 x10 ⁵ 7.34 x10 ⁵ 1.85 x10 ⁶ 1.55 x10 ⁷ 2.90 x10 ⁷ 4.09 x10 ⁷	(8)
ZONE AB-2W (HARSH) HPCS PUMP ROOM									
NORMAL MAX MIN AVERAGE	NORMAL FULL POWER OPERATION	1	8407 HRS 3503 HRS 338,390 HRS	111 75 88	90 20 50	ATMOSPHERE ATMOSPHERE ATMOSPHERE	3.5x10 ⁰	1.57x10 ⁵	(4) (9) (10)
ABNORMAL MAX MIN	LOSS OF HVAC	1	100 HRS	126	90 20	ATMOSPHERE ATMOSPHERE			(5) (6)
ACCIDENT MAX AVERAGE (180 DAYS)	LOCA INSIDE CONTAINMENT	1		154 154	90 max 20 min	ATMOSPHERE ATMOSPHERE			(7)
ACCIDENT	LOCA INSIDE CONTAINMENT	1	0 TO 1 HR 6 HR 24 HRS 30 DAYS 100 DAYS 180 DAYS				2.42 x10 ⁵	1.88 x10 ⁵ 7.34 x10 ⁵ 1.85 x10 ⁶ 1.55 x10 ⁷ 2.90 x10 ⁷ 4.09 x10 ⁷	(8)

NOTES:

- TIME DURATION SHOWN IS FOR EACH OCCURRENCE OF THE LISTED SIGNIFICANT EVENT. FOR NORMAL FULL POWER OPERATION, HOURS REPRESENT THE TIME FOR WHICH THE MAXIMUM, MINIMUM AND NORMAL WEIGHTED AVERAGE TEMPERATURE OCCUR OVER THE POSTULATED 40 YEAR PLANT LIFE. THE ONE CYCLE LISTED FOR THE NORMAL FULL POWER OPERATION REPRESENTS THIS 40 YEAR DURATION MINUS ANY SIGNIFICANT TRANSIENTS. THE SUM OF THE NORMAL AND THE ABNORMAL DURATIONS SHOULD THEREFORE EQUAL 40 YEARS (350,400 HOURS).
- CONDITION DURATION DOES NOT APPLY TO PERCENT RELATIVE HUMIDITY. PERCENT RELATIVE HUMIDITY IN RELATION TO SPECIFIED TIME DURATIONS HAS NOT BEEN POSTULATED EXCEPT FOR HIGH ENERGY LINE BREAK TRANSIENTS.
- INTEGRATED GAMMA RADIATION IS OVER 40 YEARS FOR NORMAL PLANT OPERATION AND 180 DAYS FOR ACCIDENT CONDITIONS. FOR ACCIDENT CONDITIONS, RADIATION DOSES ARE BASED ON RELEASES INSIDE CONTAINMENT ONLY, UNLESS OTHERWISE NOTED.
- TEMPERATURES SHOWN OCCUR DURING NORMAL PLANT OPERATING MODES. THESE NORMAL PLANT OPERATING MODES INCLUDE THE FOLLOWING:
 - NORMAL FULL POWER OPERATION
 - HOT STANDBY (OCCURS APPROXIMATELY 5.5 TIMES PER YEAR FOR 5 DAYS.
 - NORMAL SHUTDOWN (OCCURS APPROXIMATELY 2.7 TIMES PER YEAR FOR 10 DAYS.
 - CONTINUATION OF SHUTDOWN (OCCURS APPROXIMATELY 1 TIME PER YEAR FOR 30 DAYS.
 - TESTING (DURATIONS VARY.)
- MINIMUM TEMPERATURES SHOWN ARE BASED ON SYSTEM OPERATION DURING THE ABOVE NORMAL PLANT OPERATING MODES. MINIMUM TEMPERATURES FOR THE 'PLANT OFF', OR TOTAL SHUTDOWN CONDITION ARE NOT SHOWN. DURING THE PLANT OFF CONDITION (OR THOSE TIMES WHEN A SYSTEM OR EQUIPMENT IS NOT IN OPERATION WITHIN A ZONE), THE PLANT HEATING SYSTEMS ARE DESIGNED TO MAINTAIN A MINIMUM TEMPERATURE OF 60°F.
- MODERATE ENERGY PIPE BREAKS IN THIS ZONE COULD CAUSE LOCALIZED WETTING AND 100 PERCENT RELATIVE HUMIDITY FOR A DURATION OF 24 HOURS MAXIMUM. FLUID TEMPERATURES IN LOCAL MODERATE ENERGY LINES MAY EXCEED THE LISTED MAXIMUM AMBIENT TEMPERATURE FOR THIS ZONE AND SHOULD BE ADDRESSED IF THE EQUIPMENT TO BE QUALIFIED IS WETTED BY SPRAY FROM MODERATE ENERGY BREAKS.
- LOSS OF HVAC IN THE CONTEXT OF THESE TABLES MEANS LOSS OF NON-SAFETY HVAC DUE TO A LOSS OF OFFSITE POWER (LOOP). THE TEMPERATURES SHOWN ARE BASED ON AN ASSUMED INITIAL TEMPERATURE EQUAL TO THE NORMAL PLANT OPERATING CONDITION MAXIMUM TEMPERATURE.
- ACCIDENT TEMPERATURES SHOWN ARE BASED ON HEAT LOADS FROM SYSTEMS OPERATING IN THE DESIGNATED AREA WHICH ARE ESSENTIAL TO BRINGING THE PLANT TO SHUTDOWN CONDITION FOLLOWING AN ACCIDENT.
- FOR QUALIFICATION OF EQUIPMENT TO AN ATWS EVENT, A RADIATION ENVIRONMENT EQUIVALENT TO 10% OF THE GIVEN LOCA DOSES MAY BE USED.
- FOR TYPICAL NORMAL OPERATION RADIATION SOURCES REFER TO USAR SECTION 3.11.5.2.1.
- A RELATIVE HUMIDITY (RH) OF 20% IS THE AVERAGE MINIMUM RH GENERIC TO BWR6/MARK III PLANTS. THIS IS NOT A REQUIREMENT SINCE THE MINIMUM RH DOES NOT NEED TO BE CONTROLLED. THE RH MAY DROP BELOW 20% WITH NO ADVERSE AFFECT ON PLANT EQUIPMENT.
- ZONE AB-1E ONLY. HVAC EQUIPMENT AREA - ELEVATION 620'-6".

REFERENCES:

- 022-0001-00000 ENVIRONMENTAL CONDITIONS - PLANT LAYOUT, LEAD SHEET
- 022-0003-00000 ENVIRONMENTAL CONDITIONS - AUXILIARY BUILDING

(REV. 19 10/2015)

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

ENVIRONMENTAL CONDITIONS
FOR AUXILIARY BUILDING
FIGURE 3.11-11
(DWG. B-022-0002-00000)

PLANT OPERATING CONDITION	SIGNIFICANT EVENT	CYCLES	CONDITION DURATION (1)	TEMPERATURE	RELATIVE HUMIDITY(2) T FINAL (%)	PRESSURE	GAMMA RADIATION(3)		SUPPLEMENTARY DATA
				*F			MAX DOSE RATE RADS/HR	DOSE INTEGRATED RADS	
ZONE AB-3 (HARSH) RCIC TURBINE AND PUMP ROOM									
NORMAL MAX MIN AVERAGE	NORMAL FULL POWER OPERATION TESTING	1	8407 HRS 3503 HRS 338,390 HRS	126 98 109	90 20 50	ATMOSPHERE ATMOSPHERE ATMOSPHERE	2.5x10 ⁻² 1.16x10 ⁰	8.8x10 ³ 1.16x10 ⁰	(4) (9) (10)
ABNORMAL MAX MIN	LOSS OF HVAC TOTAL NON-ACCIDENT INTEGRATED DOSE	1	100 HRS	141	90 20	ATMOSPHERE ATMOSPHERE		9.4x10 ³	(6) 9.4x10 ³ IS THE SUM OF TESTING TRANSIENTS PLUS NORMAL PLANT OPERATION RADIATION DOSES.
ACCIDENT	RWCU BREAK IN ZONE AB-5	1	0 SEC 14 SEC 30 SEC 40 SEC 10 MIN 71 MIN 1 DAY 180 DAYS	126 155 151 151 147 126 126 126	90 100 100 90 90 90 90 90	0.0 PSIG 3.0 PSIG 0.4 PSIG 0.0 PSIG 0.0 PSIG 0.0 PSIG 0.0 PSIG 0.0 PSIG			ENVIRONMENTAL MEDIUM AIR STEAM STEAM STEAM/AIR AIR AIR AIR AIR
ACCIDENT	RCIC BREAK IN ZONE AB-3 W/LOOP	1	0 SEC 1.0 SEC 2.0 SEC 4.0 SEC 10.5 SEC 20.0 SEC 30.0 SEC 40.0 SEC 130.0 SEC 300.0 SEC 30 MIN 166 MIN 4 HR	126 237 252 269 284 282 278 277 206 191 160 140 126	90 100 100 100 100 100 100 90 90 90 90 90	0.0 PSIG 4.0 PSIG 2.6 PSIG 1.3 PSIG 1.1 PSIG 1.0 PSIG 0.1 PSIG 0.0 PSIG 0.0 PSIG 0.0 PSIG 0.0 PSIG 0.0 PSIG 0.0 PSIG			AIR STEAM STEAM STEAM STEAM STEAM STEAM/AIR STEAM/AIR STEAM/AIR STEAM/AIR AIR AIR
ACCIDENT MAX AVERAGE (180 DAYS)	LOCA IN CONTAINMENT EMERGENCY EQUIPMENT RUNNING IN ZONE AB-3	1		143 143	90 max 20 min	0.0 PSIG 0.0 PSIG 0.0 PSIG			(7)
ACCIDENT	CONTROL ROD DROP ACCIDENT (CRDA)	1	1 HR 6 HR 24 HRS 30 DAYS 100 DAYS 180 DAYS				4.86x10 ³	3.08x10 ³ 3.27x10 ³ 3.27x10 ³ 3.37x10 ³ 3.44x10 ³ 3.52x10 ³	
	ANTICIPATED TRANSIENT WITHOUT SCRAM (ATWS)	1	1 HR 6 HR 24 HRS 30 DAYS 100 DAYS 180 DAYS				1.51x10 ⁵	4.45x10 ⁴ 4.73x10 ⁴ 4.71x10 ⁴ 4.83x10 ⁴ 4.93x10 ⁴ 5.04x10 ⁴	

NOTES:

1. TIME DURATION SHOWN IS FOR EACH OCCURRENCE OF THE LISTED SIGNIFICANT EVENT. FOR NORMAL FULL POWER OPERATION, HOURS REPRESENT THE TIME FOR WHICH THE MAXIMUM, MINIMUM, AND NORMAL WEIGHTED AVERAGE TEMPERATURE OCCUR OVER THE POSTULATED 40 YEAR PLANT LIFE. THE ONE CYCLE LISTED FOR THE NORMAL FULL POWER OPERATION REPRESENTS THIS 40 YEAR DURATION MINUS ANY SIGNIFICANT TRANSIENTS. THE SUM OF THE NORMAL AND THE ABNORMAL DURATIONS SHOULD THEREFORE EQUAL 40 YEARS (350,400 HOURS).
2. CONDITION DURATION DOES NOT APPLY TO PERCENT RELATIVE HUMIDITY. PERCENT RELATIVE HUMIDITY IN RELATION TO SPECIFIED TIME DURATIONS HAS NOT BEEN POSTULATED EXCEPT FOR HIGH ENERGY LINE BREAK TRANSIENTS.
3. INTEGRATED GAMMA RADIATION IS OVER 40 YEARS FOR NORMAL PLANT OPERATION, AND 180 DAYS FOR ACCIDENT CONDITIONS. FOR ACCIDENT CONDITIONS, RADIATION DOSES ARE BASED ON RELEASES INSIDE CONTAINMENT ONLY, UNLESS OTHERWISE NOTED.
4. TEMPERATURES SHOWN OCCUR DURING NORMAL PLANT OPERATING MODES. THESE NORMAL PLANT OPERATING MODES INCLUDED THE FOLLOWING:
 - a. NORMAL FULL POWER OPERATION
 - b. HOT STANDBY (OCCURS APPROXIMATELY 5.5 TIMES PER YEAR FOR 5 DAYS)
 - c. NORMAL SHUTDOWN (OCCURS APPROXIMATELY 2.7 TIMES PER YEAR FOR 10 DAYS)
 - d. CONTINUATION OF SHUTDOWN (OCCURS APPROXIMATELY 1 TIME PER YEAR FOR 30 DAYS)
 - e. TESTING (DURATIONS VARY)
5. MINIMUM TEMPERATURES SHOWN ARE BASED ON SYSTEM OPERATION DURING THE ABOVE NORMAL PLANT OPERATING MODES. MINIMUM TEMPERATURES FOR THE "PLANT OFF", OR TOTAL SHUTDOWN CONDITION ARE NOT SHOWN. DURING THE PLANT OFF CONDITION, (OR THOSE TIMES WHEN A SYSTEM OR EQUIPMENT IS NOT IN OPERATION WITHIN A ZONE), THE PLANT HEATING SYSTEMS ARE DESIGNED TO MAINTAIN A MINIMUM TEMPERATURE OF 60° F.
6. MODERATE ENERGY PIPE BREAKS IN THIS ZONE COULD CAUSE LOCALIZED WETTING AND 100 PERCENT RELATIVE HUMIDITY FOR A DURATION OF 24 HOURS MAXIMUM. FLUID TEMPERATURES IN LOCAL MODERATE ENERGY LINES MAY EXCEED THE LISTED MAXIMUM AMBIENT TEMPERATURE FOR THIS ZONE AND SHOULD BE ADDRESSED IF THE EQUIPMENT TO BE QUALIFIED IS WETTED BY SPRAY FROM MODERATE ENERGY BREAKS.
7. LOSS OF HVAC IN THE CONTEXT OF THESE TABLES MEANS LOSS OF NON-SAFETY HVAC DUE TO A LOSS OF OFFSITE POWER(LOOP). THE TEMPERATURES SHOWN ARE BASED ON AN ASSUMED INITIAL TEMPERATURE EQUAL TO THE NORMAL PLANT OPERATING CONDITION MAXIMUM TEMPERATURE.
8. ACCIDENT TEMPERATURES SHOWN ARE BASED ON HEAT LOADS FROM SYSTEMS OPERATING IN THE DESIGNATED AREA WHICH ARE ESSENTIAL TO BRINGING THE PLANT TO SHUTDOWN CONDITION FOLLOWING AN ACCIDENT.
9. FOR QUALIFICATION OF EQUIPMENT TO AN ATWS EVENT, A RADIATION ENVIRONMENT EQUIVALENT TO 10% OF THE GIVEN LOCA DOSES MAY BE USED.
10. FOR TYPICAL NORMAL OPERATION RADIATION SOURCES REFER TO USAR SECTION 3.11.5.2.1.

REFERENCE DRAWINGS:

B-022-001
B-022-002

(REV. 19 10/2015)

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

ENVIRONMENTAL CONDITIONS
FOR AUXILIARY BUILDING
FIGURE 3.11-12
(DWG. B-022-0003-00000)

PLANT OPERATING CONDITION	SIGNIFICANT EVENT	CYCLES	CONDITION DURATION (1)	TEMPERATURE	RELATIVE HUMIDITY(2) • T FINAL (%)	PRESSURE	GAMMA RADIATION(3)		SUPPLEMENTARY DATA
				°F			MAX DOSE RATE RADS/HR	DOSE INTEGRATED RADS	
ZONE AB-4 (HARSH) RHR PUMP ROOMS									
NORMAL MAX MIN AVERAGE	NORMAL FULL POWER OPERATION	1	8298 HRS 3457 HRS 333,985 HRS	114 71 92	90 20 50	ATMOSPHERE ATMOSPHERE ATMOSPHERE	1.72x10 ⁰	3.0x10 ⁵	(4) (9) (10)
NORMAL MAX MIN	PLANT SHUTDOWN (SHUTDOWN COOLING MODE)	120	30 HRS	144	90 20	ATMOSPHERE			
NORMAL MAX MIN	PLANT SHUTDOWN (SUPPRESSION POOL COOLING)	30	8 HRS	129	90 20	ATMOSPHERE			
NORMAL MAX MIN	PLANT SHUTDOWN (SRV TRANSIENTS)	108	6.67 HRS	129	90 20	ATMOSPHERE			
ABNORMAL MAX MIN	LOSS OF HVAC	1	100 HRS	124	90 20	ATMOSPHERE			(6) ENVIRONMENTAL MEDIUM
ACCIDENT	RHR 10" LINE BREAK-STEAM SUPPLY LINE W/LOOP	1	0 SEC 1.0 SEC 2.0 SEC 10.0 SEC 19.0 SEC 25.0 SEC 30.0 SEC 45.0 SEC 3 MIN 15.0 MIN 35.0 MIN 60 MIN 1 DAY	114 193 224 246 302 298 288 264 237 200 184 155 123	90 100 100 100 100 100 100 90 90 90 90 90	0.0 PSIG 2.7 PSIG 2.6 PSIG 2.6 PSIG 2.6 PSIG 2.2 PSIG 0.9 PSIG 0.0 PSIG 0.0 PSIG 0.0 PSIG 0.0 PSIG 0.0 PSIG 0.0 PSIG			AIR STEAM STEAM STEAM STEAM STEAM STEAM AIR AIR AIR AIR AIR
ACCIDENT	LOCA IN CONTAINMENT EMERGENCY EQUIPMENT RUNNING IN ZONE AB-4	1	0 MIN 60 MIN 30 HRS 120 HRS 180 DAY AVERAGE	114 158 158 125 125	90 MAX 20 MIN	ATMOSPHERE ATMOSPHERE ATMOSPHERE ATMOSPHERE			(7)
ACCIDENT	LOCA IN CONTAINMENT	1	1 HR 6 HRS 24 HRS 30 DAYS 100 DAYS 180 DAYS				3.52x10 ⁵	2.65x10 ⁵ 9.94x10 ⁵ 2.33x10 ⁶ 1.85x10 ⁷ 3.32x10 ⁷ 4.64x10 ⁷	(8)

NOTES:

1. TIME DURATION SHOWN IS FOR EACH OCCURRENCE OF THE LISTED SIGNIFICANT EVENT, FOR NORMAL FULL POWER OPERATION HOURS REPRESENT THE TIME FOR WHICH THE MAXIMUM, MINIMUM, AND NORMAL WEIGHTED AVERAGE TEMPERATURE OCCUR OVER THE POSTULATED 40 YEAR PLANT LIFE. THE ONE CYCLE LISTED FOR THE NORMAL FULL POWER OPERATION REPRESENTS THIS 40 YEAR DURATION MINUS ANY SIGNIFICANT TRANSIENTS. THE SUM OF THE NORMAL AND THE ABNORMAL DURATIONS SHOULD THEREFORE EQUAL 40 YEARS (350,400 HOURS).
2. CONDITION DURATION DOES NOT APPLY TO PERCENT RELATIVE HUMIDITY. PERCENT RELATIVE HUMIDITY IN RELATION TO SPECIFIED TIME DURATIONS HAS NOT BEEN POSTULATED EXCEPT FOR HIGH ENERGY LINE BREAK TRANSIENTS.
3. INTEGRATED GAMMA RADIATION IS OVER 40 YEARS FOR NORMAL PLANT OPERATION, AND 180 DAYS FOR ACCIDENT CONDITIONS. FOR ACCIDENT CONDITIONS, RADIATION DOSES ARE BASED ON RELEASES INSIDE CONTAINMENT ONLY, UNLESS OTHERWISE NOTED.
4. TEMPERATURES SHOWN OCCUR DURING NORMAL PLANT OPERATING MODES. THESE NORMAL PLANT OPERATING MODES INCLUDED THE FOLLOWING:
 - a. NORMAL FULL POWER OPERATION
 - b. CONTINUATION OF SHUTDOWN (OCCURS APPROXIMATELY 1 TIME PER YEAR FOR 30 DAYS)
 - c. TESTING (DURATIONS VARY)
 MINIMUM TEMPERATURES SHOWN ARE BASED ON SYSTEM OPERATION DURING THE ABOVE NORMAL PLANT OPERATING MODES. MINIMUM TEMPERATURES FOR THE 'PLANT OFF', OR TOTAL SHUTDOWN CONDITION ARE NOT SHOWN. DURING THE PLANT OFF CONDITION, (OR THOSE TIMES WHEN A SYSTEM OR EQUIPMENT IS NOT IN OPERATION WITHIN A ZONE), THE PLANT HEATING SYSTEMS ARE DESIGNED TO MAINTAIN A MINIMUM TEMPERATURE OF 60° F.
5. MODERATE ENERGY PIPE BREAKS IN THIS ZONE COULD CAUSE LOCALIZED WETTING AND 100 PERCENT RELATIVE HUMIDITY FOR A DURATION OF 24 HOURS MAXIMUM. FLUID TEMPERATURES IN LOCAL MODERATE ENERGY LINES MAY EXCEED THE LISTED MAXIMUM AMBIENT TEMPERATURE FOR THIS ZONE AND SHOULD BE ADDRESSED IF THE EQUIPMENT TO BE QUALIFIED IS WETTED BY SPRAY FROM MODERATE ENERGY BREAKS.
6. LOSS OF HVAC IN THE CONTEXT OF THESE TABLES MEANS LOSS OF NON-SAFETY HVAC DUE TO A LOSS OF OFFSITE POWER(LOOP). THE TEMPERATURES SHOWN ARE BASED ON AN ASSUMED INITIAL TEMPERATURE EQUAL TO THE NORMAL PLANT OPERATING CONDITION MAXIMUM TEMPERATURE.
7. ACCIDENT TEMPERATURES SHOWN ARE BASED ON HEAT LOADS FROM SYSTEMS OPERATING IN THE DESIGNATED AREA WHICH ARE ESSENTIAL TO BRINGING THE PLANT TO SHUTDOWN CONDITION FOLLOWING AN ACCIDENT. THIS CONDITION REFLECTS THE SHUTDOWN COOLING MODE AND ENVELOPS ALL OTHER ACCIDENT MODES (SUPPRESSION POOL COOLING) IN THE RHR PUMP ROOM.
8. FOR QUALIFICATION OF EQUIPMENT TO AN ATWS EVENT, A RADIATION ENVIRONMENT EQUIVALENT TO 10% OF THE GIVEN LOCA DOSES MAY BE USED.
9. FOR TYPICAL NORMAL OPERATION RADIATION SOURCES REFER TO USAR SECTION 3.11.5.2.1.
10. A RELATIVE HUMIDITY (RH) OF 20% IS THE AVERAGE MINIMUM RH GENERIC TO BWR6/MARK III PLANTS. THIS IS NOT A REQUIREMENT SINCE THE MINIMUM RH DOES NOT NEED TO BE CONTROLLED. THE RH MAY DROP BELOW 20% WITH NO ADVERSE AFFECT ON PLANT EQUIPMENT.

REFERENCE DRAWINGS:

B-022-001

(REV. 19 10/2015)

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

ENVIRONMENTAL CONDITIONS
FOR AUXILIARY BUILDING
FIGURE 3.11-13
(DWG. B-022-0004-00000)

PLANT OPERATING CONDITION	SIGNIFICANT EVENT	CYCLES	CONDITION DURATION (1)	TEMPERATURE *F	RELATIVE HUMIDITY(2) % T FINAL (%)	PRESSURE	GAMMA RADIATION(3)		SUPPLEMENTARY DATA
							MAX DOSE RATE RADS/HR	DOSE INTEGRATED RADS	
ZONE AB-5 (HARSH) RWCU PUMP ROOMS									
NORMAL MAX MIN AVERAGE	NORMAL FULL POWER OPERATION	1	8407 HRS 3503 HRS 338,390 HRS	122 91 100	90 20 50	ATMOSPHERE ATMOSPHERE ATMOSPHERE	7.0x10 ⁰	2.5x10 ⁶	(4) (9) (10)
ABNORMAL MAX MIN	LOSS OF HVAC	1	100 HRS	120	90 20	ATMOSPHERE			(6)
ACCIDENT	RCIC 4" LINE BREAK IN ZONE AB-3 W/LOOP	1	0 SEC 1.0 SEC 2.0 SEC 4.0 SEC 10.5 SEC 20.0 SEC 40.0 SEC 130.0 SEC 300.0 SEC 30 MIN 166 MIN 4 HR	121 200 230 259 283 281 278 276 206 191 160	90 100 100 100 100 100 100 90 90 90 90	0.0 PSIG 2.5 PSIG 1.5 PSIG 0.7 PSIG 0.6 PSIG 0.5 PSIG 0.1 PSIG 0.0 PSIG 0.0 PSIG 0.0 PSIG 0.0 PSIG			ENVIRONMENTAL MEDIUM AIR STEAM STEAM STEAM STEAM STEAM STEAM AIR AIR AIR AIR
ACCIDENT MAX AVERAGE (180 DAYS)	LOCA INSIDE CONTAINMENT IE COOLING SYSTEM RUNNING	1		123 118	90 max 20 min	ATMOSPHERE ATMOSPHERE			(7)
ACCIDENT	LOCA INSIDE CONTAINMENT	1	1 HR 6 HRS 24 HRS 30 DAYS 100 DAYS 180 DAYS				4.41x10 ⁵	4.20x10 ⁵ 1.37x10 ⁶ 2.63x10 ⁶ 7.67x10 ⁶ 1.01x10 ⁷ 1.16x10 ⁷	(8)
ZONE AB-6 (MILD) CORRIDORS OUTSIDE ECCS PUMP ROOMS (EL.568'-4')									
NORMAL MAX MIN AVERAGE	NORMAL FULL POWER OPERATION	1	8407 HRS 3503 HRS 338,390 HRS	107 78 89	90 20 50	ATMOSPHERE ATMOSPHERE ATMOSPHERE	2.5x10 ⁻³	8.8x10 ²	(4) (5) (9) (10)
ABNORMAL MAX MIN	LOSS OF HVAC	1	100 HRS	122	90 20	ATMOSPHERE			
ACCIDENT MAX AVERAGE (180 DAYS)	LOCA INSIDE CONTAINMENT	1		124 123	90 max 20 min	ATMOSPHERE ATMOSPHERE			(7)
ACCIDENT	LOCA INSIDE CONTAINMENT		1 HR 6 HRS 24 HRS 30 DAYS 100 DAYS 180 DAYS				2.77x10 ¹	1.99x10 ¹ 6.95x10 ² 1.81x10 ³ 1.20x10 ³ 1.89x10 ³ 2.16x10 ³	

NOTES:

1. TIME DURATION SHOWN IS FOR EACH OCCURRENCE OF THE LISTED SIGNIFICANT EVENT, FOR NORMAL FULL POWER OPERATION, HOURS REPRESENT THE TIME FOR WHICH THE MAXIMUM, MINIMUM, AND NORMAL WEIGHTED AVERAGE TEMPERATURE OCCUR OVER THE POSTULATED 40 YEAR PLANT LIFE. THE ONE CYCLE LISTED FOR THE NORMAL FULL POWER OPERATION REPRESENTS THIS 40 YEAR DURATION MINUS ANY SIGNIFICANT TRANSIENTS. THE SUM OF THE NORMAL AND THE ABNORMAL DURATIONS SHOULD THEREFORE EQUAL 40 YEARS (350,400 HOURS).
2. CONDITION DURATION DOES NOT APPLY TO PERCENT RELATIVE HUMIDITY. PERCENT RELATIVE HUMIDITY IN RELATION TO SPECIFIED TIME DURATIONS HAS NOT BEEN POSTULATED EXCEPT FOR HIGH ENERGY LINE BREAK TRANSIENTS.
3. INTEGRATED GAMMA RADIATION IS OVER 40 YEARS FOR NORMAL PLANT OPERATION, AND 180 DAYS FOR ACCIDENT CONDITIONS. FOR ACCIDENT CONDITIONS, RADIATION DOSES ARE BASED ON RELEASES INSIDE CONTAINMENT ONLY, UNLESS OTHERWISE NOTED.
4. TEMPERATURES SHOWN OCCUR DURING NORMAL PLANT OPERATING MODES. THESE NORMAL PLANT OPERATING MODES INCLUDED THE FOLLOWING:
 - a. NORMAL FULL POWER OPERATION
 - b. HOT STANDBY (OCCURS APPROXIMATELY 5.5 TIMES PER YEAR FOR 5 DAYS)
 - c. NORMAL SHUTDOWN (OCCURS APPROXIMATELY 2.7 TIMES PER YEAR FOR 10 DAYS)
 - d. CONTINUATION OF SHUTDOWN (OCCURS APPROXIMATELY 1 TIME PER YEAR FOR 30 DAYS)
 - e. TESTING (DURATIONS VARY)
 MINIMUM TEMPERATURES SHOWN ARE BASED ON SYSTEM OPERATION DURING THE ABOVE NORMAL PLANT OPERATING MODES. MINIMUM TEMPERATURES FOR THE 'PLANT OFF', OR TOTAL SHUTDOWN CONDITION ARE NOT SHOWN. DURING THE PLANT OFF CONDITION, (OR THOSE TIMES WHEN A SYSTEM OR EQUIPMENT IS NOT IN OPERATION WITHIN A ZONE), THE PLANT HEATING SYSTEMS ARE DESIGNED TO MAINTAIN A MINIMUM TEMPERATURE OF 60° F.
5. MODERATE ENERGY PIPE BREAKS IN THIS ZONE COULD CAUSE LOCALIZED WETTING AND 100 PERCENT RELATIVE HUMIDITY FOR A DURATION OF 24 HOURS MAXIMUM. FLUID TEMPERATURES IN LOCAL MODERATE ENERGY LINES MAY EXCEED THE LISTED MAXIMUM AMBIENT TEMPERATURE FOR THIS ZONE AND SHOULD BE ADDRESSED IF THE EQUIPMENT TO BE QUALIFIED IS WETTED BY SPRAY FROM MODERATE ENERGY BREAKS.
6. LOSS OF HVAC IN THE CONTEXT OF THESE TABLES MEANS LOSS OF NON-SAFETY HVAC DUE TO A LOSS OF OFFSITE POWER(LOOP). THE TEMPERATURES SHOWN ARE BASED ON AN ASSUMED INITIAL TEMPERATURE EQUAL TO THE NORMAL PLANT OPERATING CONDITION MAXIMUM TEMPERATURE.
7. ACCIDENT TEMPERATURES SHOWN ARE BASED ON HEAT LOADS FROM SYSTEMS OPERATING IN THE DESIGNATED AREA WHICH ARE ESSENTIAL TO BRINGING THE PLANT TO SHUTDOWN CONDITION FOLLOWING AN ACCIDENT. THIS CONDITION REFLECTS THE 'SHUTDOWN COOLING MODE' AND ENVELOPS ALL OTHER ACCIDENT MODES (STEAM CONDENSING AND SUPPRESSION POOL COOLING) IN THE RHR PUMP ROOM.
8. FOR QUALIFICATION OF EQUIPMENT TO AN ATWS EVENT, A RADIATION ENVIRONMENT EQUIVALENT TO 10% OF THE GIVEN LOCA DOSES MAY BE USED.
9. FOR TYPICAL NORMAL OPERATION RADIATION SOURCES REFER TO USAR SECTION 3.11.5.2.1.
10. A RELATIVE HUMIDITY (RH) OF 20% IS THE AVERAGE MINIMUM RH GENERIC TO BWR6/MARK III PLANTS. THIS IS NOT A REQUIREMENT SINCE THE MINIMUM RH DOES NOT NEED TO BE CONTROLLED. THE RH MAY DROP BELOW 20% WITH NO ADVERSE AFFECT ON PLANT EQUIPMENT.

REFERENCE DRAWINGS:

B-022-001

(REV. 19 10/2015)

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

ENVIRONMENTAL CONDITIONS
FOR AUXILIARY BUILDING
FIGURE 3.11-14
(DWG. B-022-0005-00000)

PLANT OPERATING CONDITION	SIGNIFICANT EVENT	CYCLES	CONDITION DURATION (1)	TEMPERATURE	RELATIVE HUMIDITY (2) @ T FINAL (%)	PRESSURE	GAMMA RADIATION (3)		SUPPLEMENTARY DATA
				*F			MAX DOSE RATE RADS/HR	DOSE INTEGRATED RADS	
ZONE AB-7E (HARSH) STEAM TUNNEL EAST									
NORMAL MAX MIN AVERAGE	NORMAL FULL POWER OPERATION	1	8407 HRS 3503 HRS 338.390 HRS	138 119 129	90 20 50	ATMOSPHERE ATMOSPHERE ATMOSPHERE	8.4x10 ⁰	2.4x10 ⁶	(4) (9) (10)
ABNORMAL MAX MIN	LOSS OF HVAC	1	100 HRS	150	90 20	ATMOSPHERE			(6)
ACCIDENT	MAIN STEAM LINE BREAK IN ZONE AB-7	1	0.0 SEC 1.0 SEC 6.2 SEC 1.5 HRS 2.0 HRS 2.5 HRS 3.5 HRS 5.0 HRS 9.0 HRS 12.0 HRS 24 HRS 180 DAYS	132 310 310 310 212 160 150 140 130 125 117 117	90 100 100 100 100 100 100 100 100 100 90 90	0.0 PSIG 8.5 PSIG 1.0 PSIG 1.0 PSIG 0.0 PSIG 0.0 PSIG 0.0 PSIG 0.0 PSIG 0.0 PSIG 0.0 PSIG 0.0 PSIG 0.0 PSIG			ENVIRONMENTAL MEDIUM AIR STEAM STEAM STEAM STEAM STEAM/AIR STEAM/AIR STEAM/AIR AIR AIR AIR AIR
ACCIDENT	LOCA INSIDE CONTAINMENT	1	1 HR 6 HRS 24 HRS 30 DAYS 100 DAYS 180 DAYS				2.32x10 ⁶	1.40x10 ⁶ 4.50x10 ⁶ 8.45x10 ⁶ 1.78x10 ⁷ 1.89x10 ⁷ 1.93x10 ⁷	(8)
ACCIDENT MAX AVERAGE (180 DAYS)	LOCA INSIDE CONTAINMENT	1		152 144	90 max 20 min	ATMOSPHERE ATMOSPHERE			
ZONE AB-7W (HARSH) STEAM TUNNEL WEST									
NORMAL MAX MIN AVERAGE	NORMAL FULL POWER OPERATION	1	8407 HRS 3503 HRS 338.390 HRS	144 118 132	90 20 50	ATMOSPHERE ATMOSPHERE ATMOSPHERE	8.4x10 ⁰	2.4x10 ⁶	(4) (9) (10)
ABNORMAL MAX MIN	LOSS OF HVAC	1	100 HRS	150	90 20	ATMOSPHERE			(6)
ACCIDENT	MAIN STEAM LINE BREAK IN ZONE AB-7	1	0.0 SEC 1.0 SEC 6.2 SEC 1.5 HRS 2.0 HRS 2.5 HRS 3.5 HRS 5.0 HRS 9.0 HRS 12.0 HRS 24 HRS 180 DAYS	144 310 310 310 212 160 150 140 130 125 117 117	90 100 100 100 100 100 100 100 100 100 90 90	0.0 PSIG 8.5 PSIG 1.0 PSIG 1.0 PSIG 0.0 PSIG 0.0 PSIG 0.0 PSIG 0.0 PSIG 0.0 PSIG 0.0 PSIG 0.0 PSIG 0.0 PSIG			ENVIRONMENTAL MEDIUM AIR STEAM STEAM STEAM STEAM STEAM/AIR STEAM/AIR STEAM/AIR AIR AIR AIR AIR
ACCIDENT	LOCA INSIDE CONTAINMENT	1	1 HR 6 HRS 24 HRS 30 DAYS 100 DAYS 180 DAYS				2.32x10 ⁶	1.40x10 ⁶ 4.50x10 ⁶ 8.45x10 ⁶ 1.78x10 ⁷ 1.89x10 ⁷ 1.93x10 ⁷	(8)
ACCIDENT MAX AVERAGE (180 DAYS)	LOCA INSIDE CONTAINMENT	1		152 144	90 max 20 min	ATMOSPHERE ATMOSPHERE			

NOTES:

1. TIME DURATION SHOWN IS FOR EACH OCCURRENCE OF THE LISTED SIGNIFICANT EVENT. FOR NORMAL FULL POWER OPERATION, HOURS REPRESENT THE TIME FOR WHICH THE MAXIMUM, MINIMUM, AND NORMAL WEIGHTED AVERAGE TEMPERATURE OCCUR OVER THE POSTULATED 40 YEAR PLANT LIFE. THE ONE CYCLE LISTED FOR THE NORMAL FULL POWER OPERATION REPRESENTS THIS 40 YEAR DURATION MINUS ANY SIGNIFICANT TRANSIENTS. THE SUM OF THE NORMAL AND THE ABNORMAL DURATIONS SHOULD THEREFORE EQUAL 40 YEARS (350,400 HOURS).
2. CONDITION DURATION DOES NOT APPLY TO PERCENT RELATIVE HUMIDITY. PERCENT RELATIVE HUMIDITY IN RELATION TO SPECIFIED TIME DURATIONS HAS NOT BEEN POSTULATED EXCEPT FOR HIGH ENERGY LINE BREAK TRANSIENTS.
3. INTEGRATED GAMMA RADIATION IS OVER 40 YEARS FOR NORMAL PLANT OPERATION, AND 180 DAYS FOR ACCIDENT CONDITIONS. FOR ACCIDENT CONDITIONS, RADIATION DOSES ARE BASED ON RELEASES INSIDE CONTAINMENT ONLY, UNLESS OTHERWISE NOTED.
4. TEMPERATURES SHOWN OCCUR DURING NORMAL PLANT OPERATING MODES. THESE NORMAL PLANT OPERATING MODES INCLUDED THE FOLLOWING:
 - A. NORMAL FULL POWER OPERATION
 - B. HOT STANDBY (OCCURS APPROXIMATELY 5.5 TIMES PER YEAR FOR 5 DAYS)
 - C. NORMAL SHUTDOWN (OCCURS APPROXIMATELY 2.7 TIMES PER YEAR FOR 10 DAYS)
 - D. CONTINUATION OF SHUTDOWN (OCCURS APPROXIMATELY 1 TIME PER YEAR FOR 30 DAYS)
 - E. TESTING (DURATIONS VARY)
 MINIMUM TEMPERATURES SHOWN ARE BASED ON SYSTEM OPERATION DURING THE ABOVE NORMAL PLANT OPERATING MODES. MINIMUM TEMPERATURES FOR THE 'PLANT OFF' OR TOTAL SHUTDOWN CONDITION ARE NOT SHOWN. DURING THE PLANT OFF CONDITION, (OR THOSE TIMES WHEN A SYSTEM OR EQUIPMENT IS NOT IN OPERATION WITHIN A ZONE), THE PLANT HEATING SYSTEMS ARE DESIGNED TO MAINTAIN A MINIMUM TEMPERATURE OF 60° F.
5. MODERATE ENERGY PIPE BREAKS IN THIS ZONE COULD CAUSE LOCALIZED WETTING AND 100 PERCENT RELATIVE HUMIDITY FOR A DURATION OF 24 HOURS MAXIMUM. FLUID TEMPERATURES IN LOCAL MODERATE ENERGY LINES MAY EXCEED THE LISTED MAXIMUM AMBIENT TEMPERATURE FOR THIS ZONE AND SHOULD BE ADDRESSED IF THE EQUIPMENT TO BE QUALIFIED IS WETTED BY SPRAY FROM MODERATE ENERGY BREAKS.
6. LOSS OF HVAC IN THE CONTEXT OF THESE TABLES MEANS LOSS OF NON-SAFETY HVAC DUE TO A LOSS OF OFFSITE POWER(LODP). THE TEMPERATURES SHOWN ARE BASED ON AN ASSUMED INITIAL TEMPERATURE EQUAL TO THE NORMAL PLANT OPERATING CONDITION MAXIMUM TEMPERATURE.
7. ACCIDENT TEMPERATURES SHOWN ARE BASED ON HEAT LOADS FROM SYSTEMS OPERATING IN THE DESIGNATED AREA WHICH ARE ESSENTIAL TO BRINGING THE PLANT TO SHUTDOWN CONDITION FOLLOWING AN ACCIDENT.
8. FOR QUALIFICATION OF EQUIPMENT TO AN ATWS EVENT, A RADIATION ENVIRONMENT EQUIVALENT TO 10% OF THE GIVEN LOCA DOSES MAY BE USED.
9. FOR TYPICAL NORMAL OPERATION RADIATION SOURCES REFER TO USAR SECTION 3.11.5.2.1.
10. A RELATIVE HUMIDITY (RH) OF 20% IS THE AVERAGE MINIMUM RH GENERIC TO BWR6/MARK III PLANTS. THIS IS NOT A REQUIREMENT SINCE THE MINIMUM RH DOES NOT NEED TO BE CONTROLLED. THE RH MAY DROP BELOW 20% WITH NO ADVERSE AFFECT ON PLANT EQUIPMENT.

REFERENCE DRAWINGS:

B-022-001

(REV. 19 10/2015)

PERRY NUCLEAR POWER PLANT 10 CENTER RD., PERRY, OHIO 44081
ENVIRONMENTAL CONDITIONS FOR AUXILIARY BUILDING FIGURE 3.11-15 (DWG. B-022-0006-000000)

PLANT OPERATING CONDITION	SIGNIFICANT EVENT	CYCLES	CONDITION DURATION (1)	TEMPERATURE	RELATIVE HUMIDITY(2) @ T FINAL (%)	PRESSURE	GAMMA RADIATION(3)		SUPPLEMENTARY DATA
				*F			MAX DOSE RATE RADS/HR	DOSE INTEGRATED RADS	
ZONE AB-8 (HARSH) PIPING CONTAINMENT PENETRATION/CHASE									
NORMAL MAX MIN AVERAGE	NORMAL FULL POWER OPERATION	1	8407 HRS 3503 HRS 338.390 HRS	114 63 88	90 20 50	ATMOSPHERE ATMOSPHERE ATMOSPHERE	2.2×10^{-1}	7.75×10^6	(4) (9) (10)
ABNORMAL MAX MIN	LOSS OF HVAC	1	100 HRS	119	90 20	ATMOSPHERE			(5) (6)
ACCIDENT MAX AVERAGE (180 DAYS)	LOCA INSIDE CONTAINMENT	1		147 147	90 MAX 20 MIN	ATMOSPHERE ATMOSPHERE			(7)
ACCIDENT	LOCA INSIDE CONTAINMENT	1	1 HR 6 HRS 24 HRS 30 DAYS 100 DAYS 180 DAYS				1.16×10^5	8.82×10^4 3.57×10^5 9.02×10^5 7.17×10^6 1.33×10^7 2.04×10^7	(8)
ZONE AB-9 (HARSH) CORRIDORS OUTSIDE ECCS PUMP ROOMS (EL.599'-0")									
NORMAL MAX MIN AVERAGE	NORMAL FULL POWER OPERATION	1	8407 HRS 3503 HRS 338.390 HRS	108 78 89	90 20 50	ATMOSPHERE ATMOSPHERE ATMOSPHERE	2.5×10^{-3}	8.8×10^2	(4) (9) (10) (12) (13)
ABNORMAL MAX MIN	LOSS OF HVAC	1	100 HRS	121	90 20	ATMOSPHERE ATMOSPHERE			(5) (6)
ACCIDENT MAX AVERAGE (180 DAYS)	LOCA INSIDE CONTAINMENT	1		128 123	90 MAX 20 MIN	ATMOSPHERE ATMOSPHERE			(7)
ACCIDENT	RWCU BREAK IN RWCU PUMP ROOM IN ZONE AB-9	1	0.0 SEC 15 SEC 30 SEC 40 SEC 1 MIN 6 MIN 30 MIN 82 MIN 136 MIN 1 DAY 180 DAYS	108 217 196 192 189 163 150 128 108 108 108	90 100 100 90 90 90 90 90 90 90 90	0.0 PSIG 1.6 PSIG 0.4 PSIG 0.0 PSIG 0.0 PSIG 0.0 PSIG 0.0 PSIG 0.0 PSIG 0.0 PSIG 0.0 PSIG 0.0 PSIG			ENVIRONMENTAL MEDIUM AIR STEAM STEAM STEAM/AIR AIR AIR AIR AIR AIR AIR AIR
ACCIDENT	LOCA INSIDE CONTAINMENT	1	0.5 HR 8 HRS 24 HRS 5 DAYS 10 DAYS 30 DAYS 60 DAYS 180 DAYS				1.61×10^4	7.24×10^3 6.53×10^4 9.73×10^4 1.82×10^5 2.35×10^5 3.80×10^5 5.30×10^5 1.03×10^5	(8) (11)
ACCIDENT	RCIC LINE BREAK IN ZONE AB-3	1	0.0 SEC 1.0 SEC 6 SEC 10 SEC 15 SEC 20 SEC 30 SEC 40 SEC 62 SEC 90 SEC 180 SEC 300 SEC 10 MIN 15 MIN 75 MIN 1 DAY 180 DAYS	108 115 139 160 181 200 223 222 207 193 171 158 142 135 108 108 108	90 100 100 100 90 90 90 90 90 90 90 90 90 90 90 90 90	0.0 PSIG 0.4 PSIG 0.1 PSIG 0.1 PSIG 0.0 PSIG 0.0 PSIG 0.0 PSIG 0.0 PSIG 0.0 PSIG 0.0 PSIG 0.0 PSIG 0.0 PSIG 0.0 PSIG 0.0 PSIG 0.0 PSIG 0.0 PSIG 0.0 PSIG			ENVIRONMENTAL MEDIUM AIR STEAM STEAM STEAM STEAM/AIR AIR AIR AIR AIR AIR AIR AIR AIR AIR AIR AIR

NOTES:

- TIME DURATION SHOWN IS FOR EACH OCCURRENCE OF THE LISTED SIGNIFICANT EVENT. FOR NORMAL FULL POWER OPERATION, HOURS REPRESENT THE TIME FOR WHICH THE MAXIMUM, MINIMUM, AND NORMAL WEIGHTED AVERAGE TEMPERATURE OCCUR OVER THE POSTULATED 40 YEAR PLANT LIFE. THE ONE CYCLE LISTED FOR THE NORMAL FULL POWER OPERATION REPRESENTS THIS 40 YEAR DURATION MINUS ANY SIGNIFICANT TRANSIENTS. THE SUM OF THE NORMAL AND THE ABNORMAL DURATIONS SHOULD THEREFORE EQUAL 40 YEARS (350.400 HOURS).
- CONDITION DURATION DOES NOT APPLY TO PERCENT RELATIVE HUMIDITY. PERCENT RELATIVE HUMIDITY IN RELATION TO SPECIFIED TIME DURATIONS HAS NOT BEEN POSTULATED EXCEPT FOR HIGH ENERGY LINE BREAK TRANSIENTS.
- INTEGRATED GAMMA RADIATION IS OVER 40 YEARS FOR NORMAL PLANT OPERATION, AND 180 DAYS FOR ACCIDENT CONDITIONS. FOR ACCIDENT CONDITIONS, RADIATION DOSES ARE BASED ON RELEASES INSIDE CONTAINMENT ONLY, UNLESS OTHERWISE NOTED.
- TEMPERATURES SHOWN OCCUR DURING NORMAL PLANT OPERATING MODES. THESE NORMAL PLANT OPERATING MODES INCLUDED THE FOLLOWING:
 - NORMAL FULL POWER OPERATION
 - HOT STANDBY (OCCURS APPROXIMATELY 5.5 TIMES PER YEAR FOR 5 DAYS)
 - NORMAL SHUTDOWN (OCCURS APPROXIMATELY 2.7 TIMES PER YEAR FOR 10 DAYS)
 - CONTINUATION OF SHUTDOWN (OCCURS APPROXIMATELY 1 TIME PER YEAR FOR 30 DAYS)
 - TESTING (DURATIONS VARY)
 MINIMUM TEMPERATURES SHOWN ARE BASED ON SYSTEM OPERATION DURING THE ABOVE NORMAL PLANT OPERATING MODES. MINIMUM TEMPERATURES FOR THE "PLANT OFF", OR TOTAL SHUTDOWN CONDITION ARE NOT SHOWN. DURING THE PLANT OFF CONDITION, (OR THOSE TIMES WHEN A SYSTEM OR EQUIPMENT IS NOT IN OPERATION WITHIN A ZONE), THE PLANT HEATING SYSTEMS ARE DESIGNED TO MAINTAIN A MINIMUM TEMPERATURE OF 60° F.
- MODERATE ENERGY PIPE BREAKS IN THIS ZONE COULD CAUSE LOCALIZED WETTING AND 100 PERCENT RELATIVE HUMIDITY FOR A DURATION OF 24 HOURS MAXIMUM. FLUID TEMPERATURES IN LOCAL MODERATE ENERGY LINES MAY EXCEED THE LISTED MAXIMUM AMBIENT TEMPERATURE FOR THIS ZONE AND SHOULD BE ADDRESSED IF THE EQUIPMENT TO BE QUALIFIED IS WETTED BY SPRAY FROM MODERATE ENERGY BREAKS.
- LOSS OF HVAC IN THE CONTEXT OF THESE TABLES MEANS LOSS OF NON-SAFETY HVAC DUE TO A LOSS OF OFFSITE POWER(LOOP). THE TEMPERATURES SHOWN ARE BASED ON AN ASSUMED INITIAL TEMPERATURE EQUAL TO THE NORMAL PLANT OPERATING CONDITION MAXIMUM TEMPERATURE.
- ACCIDENT TEMPERATURES SHOWN ARE BASED ON HEAT LOADS FROM SYSTEMS OPERATING IN THE DESIGNATED AREA WHICH ARE ESSENTIAL TO BRINGING THE PLANT TO SHUTDOWN CONDITION FOLLOWING AN ACCIDENT.
- FOR QUALIFICATION OF EQUIPMENT TO AN ATWS EVENT, A RADIATION ENVIRONMENT EQUIVALENT TO 10% OF THE GIVEN LOCA DOSES MAY BE USED.
- FOR TYPICAL NORMAL OPERATION RADIATION SOURCES REFER TO USAR SECTION 3.11.5.2.1.
- A RELATIVE HUMIDITY (RH) OF 20% IS THE AVERAGE MINIMUM RH GENERIC TO BWR6/MARK III PLANTS. THIS IS NOT A REQUIREMENT SINCE THE MINIMUM RH DOES NOT NEED TO BE CONTROLLED. THE RH MAY DROP BELOW 20% WITH NO ADVERSE AFFECT ON PLANT EQUIPMENT.
- REFERENCE ECP 05-0238.
- DUCT AND PIPING PENETRATION IN THE LEAD BLANKET SHIELDING ADJACENT TO THE CONCRETE WALL SEPARATING AB-9 AND AB-10 PROVIDE STREAMING PATHWAYS IN THE OVERHEAD AREAS IN AB-9. THE AREA IMPACTED BY THE STREAMING EXTENDS 20' NORTH OF THE 8' CONCRETE WALL FROM EL. 608'-0" TO THE OVERHEAD SLAB AS SHOWN IN THE FOLLOWING TABLE:

DESCRIPTION	MAXIMUM DOSE RATE (rads/hr)	INTEGRATED DOSE (rad)
FROM BLANKETS TO NORTH FACE OF CONCRETE WALL	7.0×10^{-2}	2.5×10^4
0-10' NORTH OF WALL	2.0×10^{-2}	7.0×10^3
10-20' NORTH OF WALL	6.0×10^{-3}	2.1×10^3
>20' NORTH OF WALL	2.5×10^{-3}	8.8×10^2

 THESE DOSE RATES AND DOSES CONSERVATIVELY APPLY IN THE SPECIFIED AREA NORTH OF THE BLANKETS FROM EL. 608'-0" UP TO THE OVERHEAD SLAB AND FROM COLUMN LINE AX-8 WEST TO THE INSIDE BUILDING WALL (COLUMN LINE AX-7).
- INSIDE THE LEAD BLANKET SHIELD AROUND THE 1M38B0008 DUCT:

MAXIMUM DOSE RATE = 2.5×10^{-2} RADS/HR
INTEGRATED DOSE = 8.8×10^3 RADS

(REV. 19 10/2015)

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

ENVIRONMENTAL CONDITIONS
FOR AUXILIARY BUILDING
FIGURE 3.11-16
(DWG. B-022-0007-00000)

REFERENCE DRAWINGS:
B-022-001

PLANT OPERATING CONDITION	SIGNIFICANT EVENT	CYCLES	CONDITION DURATION (1)	TEMPERATURE	RELATIVE HUMIDITY (2) % T FINAL (%)	PRESSURE	GAMMA RADIATION (3)		SUPPLEMENTARY DATA
				F*			MAX DOSE RATE RADS/HR	DOSE INTEGRATED RADS	
ZONE AB-10(HARSH) ADHR HEAT EXCHANGER AREA (EL. 599'-0")									
NORMAL MAX MIN AVERAGE	NORMAL FULL POWER OPERATION	1	8407 HRS 3503 HRS 338,390 HRS	108 78 89	90 20 50	ATMOSPHERE ATMOSPHERE ATMOSPHERE	2.2x10 ⁰	7.7x10 ⁵	(4) (9) (10)
ABNORMAL MAX MIN	LOSS OF HVAC	1	100 HRS	121	90 20	ATMOSPHERE ATMOSPHERE			(5) (6)
ACCIDENT MAX AVERAGE (180 DAYS)	LOCA INSIDE CONTAINMENT	1		128 123	90 MAX 20 MIN	ATMOSPHERE ATMOSPHERE			(7)
ACCIDENT	RWCU BREAK IN RWCU PUMP ROOM IN ZONE AB-9	1	0.0 SEC 15 SEC 30 SEC 40 SEC 1 MIN 6 MIN 30 MIN 82 MIN 136 MIN 1 DAY 180 DAYS	108 217 196 192 189 163 150 128 108 108 108	90 100 100 90 90 90 90 90 90 90 90	0.0 PSIG 1.6 PSIG 0.4 PSIG 0.0 PSIG 0.0 PSIG 0.0 PSIG 0.0 PSIG 0.0 PSIG 0.0 PSIG 0.0 PSIG 0.0 PSIG			ENVIRONMENTAL MEDIUM AIR STEAM STEAM STEAM/AIR AIR AIR AIR AIR AIR AIR
ACCIDENT	LOCA INSIDE CONTAINMENT	1	0.5 HR 8 HRS 24 HRS 5 DAYS 10 DAYS 30 DAYS 60 DAYS 180 DAYS				1.61x10 ⁴	7.24x10 ³ 6.53x10 ⁴ 9.73x10 ⁴ 1.82x10 ⁵ 2.35x10 ⁵ 3.80x10 ⁵ 5.30x10 ⁵ 1.03x10 ⁶	(8) (11)
ACCIDENT	RCIC LINE BREAK IN ZONE AB-3	1	0.0 SEC 1.0 SEC 6 SEC 10 SEC 15 SEC 20 SEC 30 SEC 40 SEC 62 SEC 90 SEC 180 SEC 300 SEC 10 MIN 15 MIN 75 MIN 1 DAY 180 DAYS	108 115 139 160 181 200 223 222 207 193 171 158 142 135 108 108 108	90 100 100 90 90 90 90 90 90 90 90 90 90 90 90 90 90	0.0 PSIG 0.4 PSIG 0.1 PSIG 0.1 PSIG 0.0 PSIG 0.0 PSIG 0.0 PSIG 0.0 PSIG 0.0 PSIG 0.0 PSIG 0.0 PSIG 0.0 PSIG 0.0 PSIG 0.0 PSIG 0.0 PSIG 0.0 PSIG 0.0 PSIG			ENVIRONMENTAL MEDIUM AIR STEAM STEAM STEAM STEAM/AIR AIR AIR AIR AIR AIR AIR AIR AIR AIR AIR AIR

NOTES:

1. TIME DURATION SHOWN IS FOR EACH OCCURRENCE OF THE LISTED SIGNIFICANT EVENT. FOR NORMAL FULL POWER OPERATION, HOURS REPRESENT THE TIME FOR WHICH THE MAXIMUM, MINIMUM, AND NORMAL WEIGHTED AVERAGE TEMPERATURE OCCUR OVER THE PASTULATED 40 YEAR PLANT LIFE. THE ONE CYCLE LISTED FOR THE NORMAL FULL POWER OPERATION REPRESENTS THIS 40 YEAR DURATION MINUS ANY SIGNIFICANT TRANSIENTS. THE SUM OF THE NORMAL AND THE ABNORMAL DURATIONS SHOULD THEREFORE EQUAL 40 YEARS (350,400 HOURS).
2. CONDITION DURATION DOES NOT APPLY TO PERCENT RELATIVE HUMIDITY. PERCENT RELATIVE HUMIDITY IN RELATION TO SPECIFIED TIME DURATIONS HAS NOT BEEN POSTULATED EXCEPT FOR HIGH ENERGY LINE BREAK TRANSIENTS.
3. INTEGRATED GAMMA RADIATION IS OVER 40 YEARS FOR NORMAL PLANT OPERATION, AND 180 DAYS FOR ACCIDENT CONDITIONS. FOR ACCIDENT CONDITIONS, RADIATION DOSES ARE BASED ON RELEASES INSIDE CONTAINMENT ONLY, UNLESS OTHERWISE NOTED.
4. TEMPERATURES SHOWN OCCUR DURING NORMAL PLANT OPERATING MODES. THESE NORMAL PLANT OPERATING MODES INCLUDED THE FOLLOWING:
 - a. NORMAL FULL POWER OPERATION
 - b. HOT STANDBY (OCCURS APPROXIMATELY 5.5 TIMES PER YEAR FOR 5 DAYS)
 - c. NORMAL SHUTDOWN (OCCURS APPROXIMATELY 2.7 TIMES PER YEAR FOR 10 DAYS)
 - d. CONTINUATION OF SHUTDOWN (OCCURS APPROXIMATELY 1 TIME PER YEAR FOR 30 DAYS)
 - e. TESTING (DURATIONS VARY)
 MINIMUM TEMPERATURES SHOWN ARE BASED ON SYSTEM OPERATION DURING THE ABOVE NORMAL PLANT OPERATING MODES. MINIMUM TEMPERATURES FOR THE "PLANT OFF", OR TOTAL SHUTDOWN CONDITION ARE NOT SHOWN. DURING THE PLANT OFF CONDITION, (OR THOSE TIMES WHEN A SYSTEM OR EQUIPMENT IS NOT IN OPERATION WITHIN A ZONE), THE PLANT HEATING SYSTEMS ARE DESIGNED TO MAINTAIN A MINIMUM TEMPERATURE OF 60° F.
5. MODERATE ENERGY PIPE BREAKS IN THIS ZONE COULD CAUSE LOCALIZED WETTING AND 100 PERCENT RELATIVE HUMIDITY FOR A DURATION OF 24 HOURS MAXIMUM. FLUID TEMPERATURES IN LOCAL MODERATE ENERGY LINES MAY EXCEED THE LISTED MAXIMUM AMBIENT TEMPERATURE FOR THIS ZONE AND SHOULD BE ADDRESSED IF THE EQUIPMENT TO BE QUALIFIED IS WETTED BY SPRAY FROM MODERATE ENERGY BREAKS.
6. LOSS OF HVAC IN THE CONTEXT OF THESE TABLES MEANS LOSS OF NON-SAFETY HVAC DUE TO A LOSS OF OFFSITE POWER (LOOP). THE TEMPERATURES SHOWN ARE BASED ON AN ASSUMED INITIAL TEMPERATURE EQUAL TO THE NORMAL PLANT OPERATING CONDITION MAXIMUM TEMPERATURE.
7. ACCIDENT TEMPERATURES SHOWN ARE BASED ON HEAT LOADS FROM SYSTEMS OPERATING IN THE DESIGNATED AREA WHICH ARE ESSENTIAL TO BRINGING THE PLANT TO SHUTDOWN CONDITION FOLLOWING AN ACCIDENT.
8. FOR QUALIFICATION OF EQUIPMENT TO AN ATWS EVENT, A RADIATION ENVIRONMENT EQUIVALENT TO 10% OF THE GIVEN LOCA DOSES MAY BE USED.
9. FOR TYPICAL NORMAL OPERATION RADIATION SOURCES REFER TO USAR SECTION 3.11.5.2.1.
10. A RELATIVE HUMIDITY (RH) OF 20% IS THE AVERAGE MINIMUM RH GENERIC TO BWR6/MARK III PLANTS. THIS IS NOT A REQUIREMENT SINCE THE MINIMUM RH DOES NOT NEED TO BE CONTROLLED. THE RH MAY DROP BELOW 20% WITH NO ADVERSE AFFECT ON PLANT EQUIPMENT.
11. REFERENCE ECP 04-0239.

REFERENCE DRAWINGS:

B-022-001

(REV. 19 10/2015)

PERRY NUCLEAR POWER PLANT 10 CENTER RD., PERRY, OHIO 44081
ENVIRONMENTAL CONDITIONS FOR AUXILIARY BUILDING FIGURE 3.11-16A (DWG. B-022-0008-00000)

PLANT OPERATING CONDITION	SIGNIFICANT EVENT	CYCLES	CONDITION DURATION (1)	TEMPERATURE	RELATIVE HUMIDITY(2) @ T FINAL (%)	PRESSURE	GAMMA RADIATION(3)		SUPPLEMENTARY DATA
				'F			MAX DOSE RATE RADS/HR	DOSE INTEGRATED RADS	
ZONE CB-1 (MILD) CONTROL ROOM									
NORMAL MAX MIN AVERAGE	NORMAL FULL POWER OPERATION	1	8410 HRS 3504 HRS 338,486 HRS	75 69 75	90 20 50	ATMOSPHERE ATMOSPHERE ATMOSPHERE	5.0x10 ⁻⁴	1.8x10 ²	(4) (5) (8)
ACCIDENT MAX AVERAGE (180 DAYS)	LOCA INSIDE CONTAINMENT	1		89 88	90 max 20 min	ATMOSPHERE ATMOSPHERE			(7)
ACCIDENT	LOCA INSIDE CONTAINMENT	1	0 HR 6 HR 24 HRS 30 DAYS 100 DAYS 180 DAYS				5.8x10 ⁻¹	2.6x10 ⁻¹ 1.4x10 ⁰ 1.97x10 ⁰ 7.5x10 ⁰ 7.5x10 ⁰ 7.5x10 ⁰	
ZONE CB-2-B (MILD) DIV.1/DIV.2 AND HPCS BATTERY ROOMS									
NORMAL MAX MIN AVERAGE	NORMAL FULL POWER OPERATION	1	8410 HRS 3504 HRS 338,486 HRS	80 72 77	90 20 50	ATMOSPHERE ATMOSPHERE ATMOSPHERE	5.0x10 ⁻⁴	1.8x10 ²	(4) (8)
ABNORMAL MAX MIN	LOSS OF HVAC	1	100 HRS	81	90 20	ATMOSPHERE			(5) (6)
ACCIDENT MAX AVERAGE (180 DAYS)	LOCA INSIDE CONTAINMENT	1		81	90 max 20 min	ATMOSPHERE ATMOSPHERE			(7)
ACCIDENT	LOCA INSIDE CONTAINMENT	1	1 HR 6 HR 24 HRS 30 DAYS 100 DAYS 180 DAYS				2.9x10 ¹	2.70x10 ¹ 2.03x10 ² 3.09x10 ² 3.63x10 ² 3.69x10 ² 3.76x10 ²	
ZONE CB-2-620 (MILD) FLR. ELEV. 620'-6", MCC, SWITCHGEAR & MISC EQUIPMENT AREA (EXCLUDING HPCS BATTERY ROOMS)									
NORMAL MAX MIN AVERAGE	NORMAL FULL POWER OPERATION	1	8410 HRS 3504 HRS 338,486 HRS	85 65 74	90 20 50	ATMOSPHERE ATMOSPHERE ATMOSPHERE	5.0x10 ⁻⁴	1.8x10 ²	(4) (8)
ABNORMAL MAX MIN	LOSS OF HVAC	1	100 HRS	85 85	90 20	ATMOSPHERE			(5) (6)
ACCIDENT MAX AVERAGE (180 DAYS)	LOCA INSIDE CONTAINMENT	1		85 85	90 max 20 min	ATMOSPHERE ATMOSPHERE			(7)
ACCIDENT	LOCA INSIDE CONTAINMENT	1	1 HR 6 HR 24 HRS 30 DAYS 100 DAYS 180 DAYS				2.9x10 ¹	2.70x10 ¹ 2.03x10 ² 3.09x10 ² 3.63x10 ² 3.69x10 ² 3.76x10 ²	
ZONE CB-2-638 (MILD) FLR. ELEV. 638'-6", MCC, SWITCHGEAR & MISC EQUIP. AREA (EXCLUDING DIV.1/DIV.2 BATTERY ROOMS)									
NORMAL MAX MIN AVERAGE	NORMAL FULL POWER OPERATION	1	8410 HRS 3504 HRS 338,486 HRS	85 65 79	90 20 50	ATMOSPHERE ATMOSPHERE ATMOSPHERE	5.0x10 ⁻⁴	1.8x10 ²	(4) (8)
ABNORMAL MAX MIN	LOSS OF HVAC	1	100 HRS	92	90 20	ATMOSPHERE			(5) (6)
ACCIDENT MAX AVERAGE (180 DAYS)	LOCA INSIDE CONTAINMENT	1		85 85	90 max 20 min	ATMOSPHERE ATMOSPHERE			(7)
ACCIDENT	LOCA INSIDE CONTAINMENT	1	1 HR 6 HR 24 HRS 30 DAYS 100 DAYS 180 DAYS				2.9x10 ¹	2.70x10 ¹ 2.03x10 ² 3.09x10 ² 3.63x10 ² 3.69x10 ² 3.76x10 ²	
ZONE CB-3 (MILD) HVAC EQUIPMENT AREA									
NORMAL MAX MIN AVERAGE	NORMAL FULL POWER OPERATION	1	8410 HRS 3504 HRS 338,486 HRS	86 74 81	90 20 50	ATMOSPHERE ATMOSPHERE ATMOSPHERE	2.5x10 ⁻³	8.8x10 ²	(4) (5) (8)
ACCIDENT MAX AVERAGE (180 DAYS)	LOCA INSIDE CONTAINMENT	1		86 85	90 20	ATMOSPHERE ATMOSPHERE			(7)
ACCIDENT	LOCA INSIDE CONTAINMENT	1	1 HR 6 HR 24 HRS 30 DAYS 100 DAYS 180 DAYS				2.9x10 ¹	2.70x10 ¹ 2.03x10 ² 3.09x10 ² 3.63x10 ² 3.69x10 ² 3.76x10 ²	

NOTES:

1. TIME DURATION SHOWN IS FOR EACH OCCURRENCE OF THE LISTED SIGNIFICANT EVENT. FOR NORMAL FULL POWER OPERATION, HOURS REPRESENT THE TIME FOR WHICH THE MAXIMUM, MINIMUM, AND NORMAL WEIGHTED AVERAGE TEMPERATURE OCCUR OVER THE POSTULATED 40 YEAR PLANT LIFE. THE ONE CYCLE LISTED FOR THE NORMAL FULL POWER OPERATION REPRESENTS THIS 40 YEAR DURATION MINUS ANY SIGNIFICANT TRANSIENTS. THE SUM OF THE NORMAL AND THE ABNORMAL DURATIONS SHOULD THEREFORE EQUAL 40 YEARS (350,400 HOURS).
 2. CONDITION DURATION DOES NOT APPLY TO PERCENT RELATIVE HUMIDITY. PERCENT RELATIVE HUMIDITY IN RELATION TO SPECIFIED TIME DURATIONS HAS NOT BEEN POSTULATED EXCEPT FOR HIGH ENERGY LINE BREAK TRANSIENTS.
 3. INTEGRATED GAMMA RADIATION IS OVER 40 YEARS FOR NORMAL PLANT OPERATION AND 180 DAYS FOR ACCIDENT CONDITIONS. FOR ACCIDENT CONDITIONS, RADIATION DOSES ARE BASED ON RELEASES INSIDE CONTAINMENT ONLY, UNLESS OTHERWISE NOTED.
 4. TEMPERATURES SHOWN OCCUR DURING NORMAL PLANT OPERATING MODES. THESE NORMAL PLANT OPERATING MODES INCLUDED THE FOLLOWING:
 - a. NORMAL FULL POWER OPERATION
 - b. HOT STANDBY (OCCURS APPROXIMATELY 5.5 TIMES PER YEAR FOR 5 DAYS)
 - c. NORMAL SHUTDOWN (OCCURS APPROXIMATELY 2.7 TIMES PER YEAR FOR 10 DAYS)
 - d. CONTINUATION OF SHUTDOWN (OCCURS APPROXIMATELY 1 TIME PER YEAR FOR 30 DAYS)
 - e. TESTING (DURATIONS VARY)

MINIMUM TEMPERATURES SHOWN ARE BASED ON SYSTEM OPERATION DURING THE ABOVE NORMAL PLANT OPERATING MODES. MINIMUM TEMPERATURES FOR THE 'PLANT OFF' OR TOTAL SHUTDOWN CONDITION ARE NOT SHOWN. DURING THE PLANT OFF CONDITION, (OR THOSE TIMES WHEN A SYSTEM OR EQUIPMENT IS NOT IN OPERATION WITHIN A ZONE), THE PLANT HEATING SYSTEMS ARE DESIGNED TO MAINTAIN A MINIMUM TEMPERATURE OF 60° F.
 5. MODERATE ENERGY PIPE BREAKS IN THIS ZONE COULD CAUSE LOCALIZED WETTING AND 100 PERCENT RELATIVE HUMIDITY FOR A DURATION OF 24 HOURS MAXIMUM. FLUID TEMPERATURES IN LOCAL MODERATE ENERGY LINES MAY EXCEED THE LISTED MAXIMUM AMBIENT TEMPERATURE FOR THIS ZONE AND SHOULD BE ADDRESSED IF THE EQUIPMENT TO BE QUALIFIED IS WETTED BY SPRAY FROM MODERATE ENERGY BREAKS.
 6. LOSS OF HVAC IN THE CONTEXT OF THESE TABLES MEANS LOSS OF NON-SAFETY HVAC DUE TO A LOSS OF OFFSITE POWER (LOFP). THE TEMPERATURES SHOWN ARE BASED ON AN ASSUMED INITIAL TEMPERATURE EQUAL TO THE NORMAL PLANT OPERATING CONDITION MAXIMUM TEMPERATURE.
 7. ACCIDENT TEMPERATURES SHOWN ARE BASED ON HEAT LOADS FROM SYSTEMS OPERATING IN THE DESIGNATED AREA WHICH ARE ESSENTIAL TO BRINGING THE PLANT TO SHUTDOWN CONDITION FOLLOWING AN ACCIDENT.
 8. FOR TYPICAL NORMAL OPERATION RADIATION SOURCES REFER TO USAR SECTION 3.11.5.2.1.
- [9] LOSS OF HVAC TEMPERATURE IN THE UNIT 2 TELEPHONE EQUIPMENT ROOM (FORMERLY THE UNIT 2 REMOTE SHUTDOWN ROOM) WILL EXCEED 85 F. THE HIGHER 90 F TEMPERATURE DETERMINED FOR THIS ROOM IS ACCEPTABLE SINCE THIS ROOM DOES NOT CONTAIN SAFETY RELATED EQUIPMENT.

REFERENCE DRAWINGS:

B-022-0001

(REV. 19 10/2015)

<p>PERRY NUCLEAR POWER PLANT 10 CENTER RD., PERRY, OHIO 44081</p>
<p>ENVIRONMENTAL CONDITIONS FOR CONTROL BUILDINGS FIGURE 3.11-17 (DWG. D-022-0010-00000)</p>

PLANT OPERATING CONDITION	SIGNIFICANT EVENT	CYCLES	CONDITION DURATION (1)	TEMPERATURE	RELATIVE HUMIDITY(2) • T FINAL (%)	PRESSURE	GAMMA RADIATION(3)		SUPPLEMENTARY DATA
				°F			MAX DOSE RATE RADS/HR	DOSE INTEGRATED RADS	
ZONE CB-4 (MILD) NUCLEAR CLOSED COOLING HEAT EXCHANGER ROOM									
NORMAL MAX MIN AVERAGE	NORMAL FULL POWER OPERATION	1	8407 HRS 3503 HRS 338,390 HRS	95 92 94	90 20 50	ATMOSPHERE ATMOSPHERE ATMOSPHERE	5.0×10^{-4}	1.80×10^2	(4) (8) (9)
ABNORMAL MAX MIN	LOSS OF HVAC	1	100 HRS	100	90 20	ATMOSPHERE ATMOSPHERE			(5) (6)
ACCIDENT MAX AVERAGE (180 DAYS)	LOCA INSIDE CONTAINMENT	1		86 86	90 max 20 min	ATMOSPHERE ATMOSPHERE			(7)
ACCIDENT	LOCA INSIDE CONTAINMENT	1	1 HR 6 HRS 24 HRS 30 DAYS 100 DAYS 180 DAYS				2.9×10^1	2.70×10^1 2.03×10^2 3.09×10^2 3.63×10^2 3.69×10^2 3.76×10^2	
ZONE CB-4 (MILD) NUCLEAR CLOSED COOLING PUMP ROOM									
NORMAL MAX MIN AVERAGE	NORMAL FULL POWER OPERATION	1	8407 HRS 3503 HRS 338,390 HRS	84 82 84	90 20 50	ATMOSPHERE ATMOSPHERE ATMOSPHERE	5.0×10^{-4}	1.80×10^2	(4) (8) (9)
ABNORMAL MAX MIN	LOSS OF HVAC	1	100 HRS	179	90 20	ATMOSPHERE ATMOSPHERE			(5) (6)
ACCIDENT MAX AVERAGE (180 DAYS)	LOCA INSIDE CONTAINMENT	1		86 86	90 max 20 min	ATMOSPHERE ATMOSPHERE			(7)
ACCIDENT	LOCA INSIDE CONTAINMENT	1	1 HR 6 HRS 24 HRS 30 DAYS 100 DAYS 180 DAYS				2.9×10^1	2.70×10^1 2.03×10^2 3.09×10^2 3.63×10^2 3.69×10^2 3.76×10^2	
ZONE CB-4 (MILD) WEST END, FLOOR ELEVATION 599'-0"									
NORMAL MAX MIN AVERAGE	NORMAL FULL POWER OPERATION	1	8407 HRS 3503 HRS 338,390 HRS	75 73 74	90 20 50	ATMOSPHERE ATMOSPHERE ATMOSPHERE	5.0×10^{-4}	1.80×10^2	(4) (8) (9)
ABNORMAL MAX MIN	LOSS OF HVAC	1	100 HRS	92	90 20	ATMOSPHERE ATMOSPHERE			(5) (6)
ACCIDENT MAX AVERAGE (180 DAYS)	LOCA INSIDE CONTAINMENT	1		83 83	90 max 20 min	ATMOSPHERE ATMOSPHERE			(7)
ACCIDENT	LOCA INSIDE CONTAINMENT	1	1 HR 6 HRS 24 HRS 30 DAYS 100 DAYS 180 DAYS				2.9×10^1	2.70×10^1 2.03×10^2 3.09×10^2 3.63×10^2 3.69×10^2 3.76×10^2	

NOTES:

1. TIME DURATION SHOWN IS FOR EACH OCCURRENCE OF THE LISTED SIGNIFICANT EVENT, FOR NORMAL FULL POWER OPERATION, HOURS REPRESENT THE TIME FOR WHICH THE MAXIMUM, MINIMUM, AND NORMAL WEIGHTED AVERAGE TEMPERATURE OCCUR OVER THE POSTULATED 40 YEAR PLANT LIFE. THE ONE CYCLE LISTED FOR THE NORMAL FULL POWER OPERATION REPRESENTS THIS 40 YEAR DURATION MINUS ANY SIGNIFICANT TRANSIENTS. THE SUM OF THE NORMAL AND THE ABNORMAL DURATIONS SHOULD THEREFORE EQUAL 40 YEARS (350,400 HOURS).
 2. CONDITION DURATION DOES NOT APPLY TO PERCENT RELATIVE HUMIDITY. PERCENT RELATIVE HUMIDITY IN RELATION TO SPECIFIED TIME DURATIONS HAS NOT BEEN POSTULATED EXCEPT FOR HIGH ENERGY LINE BREAK TRANSIENTS.
 3. INTEGRATED GAMMA RADIATION IS OVER 40 YEARS FOR NORMAL PLANT OPERATION, AND 180 DAYS FOR ACCIDENT CONDITIONS. FOR ACCIDENT CONDITIONS, RADIATION DOSES ARE BASED ON RELEASES INSIDE CONTAINMENT ONLY, UNLESS OTHERWISE NOTED.
 4. TEMPERATURES SHOWN OCCUR DURING NORMAL PLANT OPERATING MODES. THESE NORMAL PLANT OPERATING MODES INCLUDED THE FOLLOWING:
 - a. NORMAL FULL POWER OPERATION
 - b. HOT STANDBY (OCCURS APPROXIMATELY 5.5 TIMES PER YEAR FOR 5 DAYS)
 - c. NORMAL SHUTDOWN (OCCURS APPROXIMATELY 2.7 TIMES PER YEAR FOR 10 DAYS)
 - d. CONTINUATION OF SHUTDOWN (OCCURS APPROXIMATELY 1 TIME PER YEAR FOR 30 DAYS)
 - e. TESTING (DURATIONS VARY)
- MINIMUM TEMPERATURES SHOWN ARE BASED ON SYSTEM OPERATION DURING THE ABOVE NORMAL PLANT OPERATING MODES. MINIMUM TEMPERATURES FOR THE 'PLANT OFF', OR TOTAL SHUTDOWN CONDITION ARE NOT SHOWN. DURING THE PLANT OFF CONDITION, (OR THOSE TIMES WHEN A SYSTEM OR EQUIPMENT IS NOT IN OPERATION WITHIN A ZONE), THE PLANT HEATING SYSTEMS ARE DESIGNED TO MAINTAIN A MINIMUM TEMPERATURE OF 60° F.
5. MODERATE ENERGY PIPE BREAKS IN THIS ZONE COULD CAUSE LOCALIZED WETTING AND 100 PERCENT RELATIVE HUMIDITY FOR A DURATION OF 24 HOURS MAXIMUM. FLUID TEMPERATURES IN LOCAL MODERATE ENERGY LINES MAY EXCEED THE LISTED MAXIMUM AMBIENT TEMPERATURE FOR THIS ZONE AND SHOULD BE ADDRESSED IF THE EQUIPMENT TO BE QUALIFIED IS WETTED BY SPRAY FROM MODERATE ENERGY BREAKS.
 6. LOSS OF HVAC IN THE CONTEXT OF THESE TABLES MEANS LOSS OF NON-SAFETY HVAC DUE TO A LOSS OF OFFSITE POWER(LOOP). THE TEMPERATURES SHOWN ARE BASED ON AN ASSUMED INITIAL TEMPERATURE EQUAL TO THE NORMAL PLANT OPERATING CONDITION MAXIMUM TEMPERATURE.
 7. ACCIDENT TEMPERATURES SHOWN ARE BASED ON HEAT LOADS FROM SYSTEMS OPERATING IN THE DESIGNATED AREA WHICH ARE ESSENTIAL TO BRINGING THE PLANT TO SHUTDOWN CONDITION FOLLOWING AN ACCIDENT.
 8. FOR TYPICAL NORMAL OPERATION RADIATION SOURCES REFER TO USAR SECTION 3.11.5.2.1.
 9. A RELATIVE HUMIDITY (RH) OF 20% IS THE AVERAGE MINIMUM RH GENERIC TO BWR6/MARK III PLANTS. THIS IS NOT A REQUIREMENT SINCE THE MINIMUM RH DOES NOT NEED TO BE CONTROLLED. THE RH MAY DROP BELOW 20% WITH NO ADVERSE AFFECT ON PLANT EQUIPMENT.

REFERENCE DRAWINGS:

B-022-001

(REV. 19 10/2015)

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

ENVIRONMENTAL CONDITIONS
FOR CONTROL BUILDINGS
FIGURE 3.11-18
(DWG. B-022-0011-00000)

PLANT OPERATING CONDITION	SIGNIFICANT EVENT	CYCLES	CONDITION DURATION (1)	TEMPERATURE	RELATIVE HUMIDITY(2) @ T FINAL (%)	PRESSURE	GAMMA RADIATION(3)		SUPPLEMENTARY DATA
				*F			MAX DOSE RATE RADS/HR	DOSE INTEGRATED RADS	
ZONE CB-5 (MILD) EMERGENCY CLOSED COOLING PUMP AREA									
NORMAL MAX MIN AVERAGE	NORMAL FULL POWER OPERATION	1	8410 HRS 3504 HRS 338,486 HRS	89 86 88	90 20 50	ATMOSPHERE ATMOSPHERE ATMOSPHERE	5.0x10 ⁻⁴	1.80x10 ²	(4) (5) (8) (9)
ACCIDENT MAX AVERAGE (180 DAYS)	LOCA INSIDE CONTAINMENT	1		80 80	90 max 20 min	ATMOSPHERE ATMOSPHERE			(7)
ACCIDENT	LOCA INSIDE CONTAINMENT	1	1 HR 6 HR 24 HRS 30 DAYS 100 DAYS 180 DAYS				2.9x10 ¹	2.70x10 ¹ ₂ 2.03x10 ² ₂ 3.09x10 ² ₂ 3.63x10 ² ₂ 3.69x10 ² ₂ 3.76x10 ² ₂	

NOTES:

1. TIME DURATION SHOWN IS FOR EACH OCCURRENCE OF THE LISTED SIGNIFICANT EVENT. FOR NORMAL FULL POWER OPERATION, HOURS REPRESENT THE TIME FOR WHICH THE MAXIMUM, MINIMUM, AND NORMAL WEIGHTED AVERAGE TEMPERATURE OCCUR OVER THE POSTULATED 40 YEAR PLANT LIFE. THE ONE CYCLE LISTED FOR THE NORMAL FULL POWER OPERATION REPRESENTS THIS 40 YEAR DURATION MINUS ANY SIGNIFICANT TRANSIENTS. THE SUM OF THE NORMAL AND THE ABNORMAL DURATIONS SHOULD THEREFORE EQUAL 40 YEARS (350,400 HOURS).
 2. CONDITION DURATION DOES NOT APPLY TO PERCENT RELATIVE HUMIDITY. PERCENT RELATIVE HUMIDITY IN RELATION TO SPECIFIED TIME DURATIONS HAS NOT BEEN POSTULATED EXCEPT FOR HIGH ENERGY LINE BREAK TRANSIENTS.
 3. INTEGRATED GAMMA RADIATION IS OVER 40 YEARS FOR NORMAL PLANT OPERATION, AND 180 DAYS FOR ACCIDENT CONDITIONS. FOR ACCIDENT CONDITIONS, RADIATION DOSES ARE BASED ON RELEASES INSIDE CONTAINMENT ONLY, UNLESS OTHERWISE NOTED.
 4. TEMPERATURES SHOWN OCCUR DURING NORMAL PLANT OPERATING MODES. THESE NORMAL PLANT OPERATING MODES INCLUDED THE FOLLOWING:
 - A. NORMAL FULL POWER OPERATION
 - B. HOT STANDBY (OCCURS APPROXIMATELY 5.5 TIMES PER YEAR FOR 5 DAYS)
 - C. NORMAL SHUTDOWN (OCCURS APPROXIMATELY 2.7 TIMES PER YEAR FOR 10 DAYS)
 - D. CONTINUATION OF SHUTDOWN (OCCURS APPROXIMATELY 1 TIME PER YEAR FOR 30 DAYS)
 - E. TESTING (DURATIONS VARY)
- MINIMUM TEMPERATURES SHOWN ARE BASED ON SYSTEM OPERATION DURING THE ABOVE NORMAL PLANT OPERATING MODES. MINIMUM TEMPERATURES FOR THE "PLANT OFF", OR TOTAL SHUTDOWN CONDITION ARE NOT SHOWN. DURING THE PLANT OFF CONDITION, (OR THOSE TIMES WHEN A SYSTEM OR EQUIPMENT IS NOT IN OPERATION WITHIN A ZONE), THE PLANT HEATING SYSTEMS ARE DESIGNED TO MAINTAIN A MINIMUM TEMPERATURE OF 60° F.
5. MODERATE ENERGY PIPE BREAKS IN THIS ZONE COULD CAUSE LOCALIZED WETTING AND 100 PERCENT RELATIVE HUMIDITY FOR A DURATION OF 24 HOURS MAXIMUM. FLUID TEMPERATURES IN LOCAL MODERATE ENERGY LINES MAY EXCEED THE LISTED MAXIMUM AMBIENT TEMPERATURE FOR THIS ZONE AND SHOULD BE ADDRESSED IF THE EQUIPMENT TO BE QUALIFIED IS WETTED BY SPRAY FROM MODERATE ENERGY BREAKS.
 6. LOSS OF HVAC IN THE CONTEXT OF THESE TABLES MEANS LOSS OF NON-SAFETY HVAC DUE TO A LOSS OF OFFSITE POWER(LOOP). THE TEMPERATURES SHOWN ARE BASED ON AN ASSUMED INITIAL TEMPERATURE EQUAL TO THE NORMAL PLANT OPERATING CONDITION MAXIMUM TEMPERATURE.
 7. ACCIDENT TEMPERATURES SHOWN ARE BASED ON HEAT LOADS FROM SYSTEMS OPERATING IN THE DESIGNATED AREA WHICH ARE ESSENTIAL TO BRINGING THE PLANT TO SHUTDOWN CONDITION FOLLOWING AN ACCIDENT.
 8. FOR TYPICAL NORMAL OPERATION RADIATION SOURCES REFER TO USAR SECTION 3.11.5.2.1.
 9. A RELATIVE HUMIDITY (RH) OF 20% IS THE AVERAGE MINIMUM RH GENERIC TO BWR6/MARK III PLANTS. THIS IS NOT A REQUIREMENT SINCE THE MINIMUM RH DOES NOT NEED TO BE CONTROLLED. THE RH MAY DROP BELOW 20% WITH NO ADVERSE AFFECT ON PLANT EQUIPMENT.

REFERENCE DRAWINGS:

B-022-001

(REV. 19 10/2015)

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

ENVIRONMENTAL CONDITIONS
FOR CONTROL BUILDINGS
FIGURE 3.11-19
(DWG. B-022-0012-00000)

PLANT OPERATING CONDITION	SIGNIFICANT EVENT	CYCLES	CONDITION DURATION (1)	TEMPERATURE °F	RELATIVE HUMIDITY(2) % T FINAL (%)	PRESSURE	GAMMA RADIATION(3)		BETA RADIATION		SUPPLEMENTARY DATA
							MAX DOSE RATE RADS/HR	DOSE INTEGRATED RADS	MAX DOSE RATE RADS/HR	DOSE INTEGRATED RADS	
ZONE CT-0 (HARSH) CONTAINMENT ANNULUS											
NORMAL MAX MIN AVERAGE	NORMAL FULL POWER OPERATION	1	8407 HRS 3503 HRS 338,390 HRS	105 66 87	90 20 50	ATMOSPHERE ATMOSPHERE ATMOSPHERE	2.5x10 ⁻³	8.8x10 ²			(4) (9)
ABNORMAL MAX MIN	LOSS OF HVAC	1	100 HRS	128	90 20	ATMOSPHERE ATMOSPHERE					(6)
ACCIDENT	LOCA INSIDE CONTAINMENT	1	0 MIN 16.6 MIN 50 MIN 83.3 MIN 2.8 HRS 4.1 HRS 5.5 HRS 6.9 HRS 8.3 HRS 11.1 HRS 16.6 HRS 19.4 HRS 1 DAY 100 DAYS 180 DAYS	105 108 114 119 129 135 139 141 143 145 148 149 150 105 105	90 MAX 20 MIN	ATMOSPHERE VARIES OVER 0.1 PSI RANGE FOR 180 DAYS DURATION					
ACCIDENT	LOCA INSIDE CONTAINMENT	1	1 HR 6 HRS 24 HRS 30 DAYS 100 DAYS 180 DAYS				1.63x10 ⁶	6.18x10 ⁵ 2.07x10 ⁶ 4.33x10 ⁷ 1.41x10 ⁷ 2.02x10 ⁷ 2.53x10 ⁷	1.28x10 ³	7.76x10 ² 6.89x10 ⁴ 2.15x10 ⁴ 7.48x10 ⁴ 9.77x10 ⁵ 1.13x10 ⁵	(10) (8)
ZONE CT-1 (HARSH) AREA ABOVE REFUELING FLOOR											
NORMAL MAX MIN AVERAGE	NORMAL FULL POWER OPERATION	1	8363 HRS 3485 HRS 336,616 HRS	104 80 91	90 20 50	ATMOSPHERE ATMOSPHERE ATMOSPHERE	2.5x10 ⁻³	8.8x10 ²	NEGLIGIBLE	NEGLIGIBLE	(4) (9)
ABNORMAL MAX MIN	LOSS OF HVAC	1	100 HRS	137	90 20	ATMOSPHERE ATMOSPHERE					(6)
ABNORMAL	SAFETY RELIEF VALVE DISCHARGE	08	0 MIN 30 MIN 90 MIN 2 HRS 3 HRS 4 HRS 5 HRS 6 HRS 7 HRS 8 HRS 9 HRS 10 HRS 11 HRS 12 HRS 13 HRS 17 HRS	90.0 96.6 109.0 112.7 117.7 119.7 120.0 118.1 116.9 115.9 115.1 114.7 114.2 105.0 101.7 90.0	90 100 100 100 100 100 100 100 100 100 100 100 100 100 100 100	ATMOSPHERE 0.4 PSIG 1.1 PSIG 1.4 PSIG 1.7 PSIG 1.9 PSIG 1.9 PSIG 1.8 PSIG 1.7 PSIG 1.6 PSIG 1.6 PSIG 1.6 PSIG 1.2 PSIG 1.0 PSIG 0.8 PSIG 0.0 PSIG	2.1x10 ¹	2.5x10 ³	NEGLIGIBLE	NEGLIGIBLE	
ABNORMAL	TOTAL NON-ACCIDENT INTEGRATED DOSE							2.71x10 ⁵			SUM OF SRVD TRANSIENTS PLUS NORMAL PLANT OPERATION RADIATION DOSES
ACCIDENT	LOCA INSIDE CONTAINMENT	1	0 SEC 3 SEC 10 SEC 30 SEC 100 SEC 1 HR 7 HR 18 HR 27.8 HR 11.6 DAYS 100 DAYS 180 DAYS	104 100 150 150 150 135 140 135 133 120 95 95	90 100 100 100 100 100 100 100 100 100 100 100	1.0 5.3 5.8 6.8 5.8 5.8 6.5 6.4 6.2 2.5 0.0 0.0					ACCIDENT ENVIRONMENTAL MEDIUM AIR, SPRAY (7) (13) AIR, SPRAY (7) (13) AIR, SPRAY (7) (13) AIR, SPRAY (7) (13) AIR, SPRAY (7) (13) AIR, SPRAY (7) (13) AIR, SPRAY (7) (13) AIR, SPRAY (7) (13) AIR, SPRAY (7) (13) AIR, SPRAY (7) (13) AIR, SPRAY (7) (13) AIR, SPRAY (7) (13)

ZONE CT-1 CONTINUED ON B-022-021

NOTES:

1. TIME DURATION SHOWN IS FOR EACH OCCURRENCE OF THE LISTED SIGNIFICANT EVENT. FOR NORMAL FULL POWER OPERATION, HOURS REPRESENT THE TIME FOR WHICH THE MAXIMUM, MINIMUM, AND NORMAL WEIGHTED AVERAGE TEMPERATURE OCCUR OVER THE POSTULATED 40 YEAR PLANT LIFE. THE ONE CYCLE LISTED FOR THE NORMAL FULL POWER OPERATION REPRESENTS THIS 40 YEAR DURATION MINUS ANY SIGNIFICANT TRANSIENTS. THE SUM OF THE NORMAL AND THE ABNORMAL DURATIONS SHOULD THEREFORE EQUAL 40 YEARS (350,400 HOURS).
2. CONDITION DURATION DOES NOT APPLY TO PERCENT RELATIVE HUMIDITY. PERCENT RELATIVE HUMIDITY IN RELATION TO SPECIFIED TIME DURATIONS HAS NOT BEEN POSTULATED EXCEPT FOR HIGH ENERGY LINE BREAK TRANSIENTS.
3. INTEGRATED GAMMA RADIATION IS OVER 40 YEARS FOR NORMAL PLANT OPERATION, AND 180 DAYS FOR ACCIDENT CONDITIONS. FOR ACCIDENT CONDITIONS, RADIATION DOSES ARE BASED ON RELEASES INSIDE CONTAINMENT ONLY, UNLESS OTHERWISE NOTED.
4. TEMPERATURES SHOWN OCCUR DURING NORMAL PLANT OPERATING MODES. THESE NORMAL PLANT OPERATING MODES INCLUDED THE FOLLOWING:
 - a. NORMAL FULL POWER OPERATION
 - b. HOT STANDBY (OCCURS APPROXIMATELY 5.5 TIMES PER YEAR FOR 5 DAYS)
 - c. NORMAL SHUTDOWN (OCCURS APPROXIMATELY 2.7 TIMES PER YEAR FOR 10 DAYS)
 - d. CONTINUATION OF SHUTDOWN (OCCURS APPROXIMATELY 1 TIME PER YEAR FOR 30 DAYS)
 - e. TESTING (DURATIONS VARY)

MINIMUM TEMPERATURES SHOWN ARE BASED ON SYSTEM OPERATION DURING THE ABOVE NORMAL PLANT OPERATING MODES. MINIMUM TEMPERATURES FOR THE PLANT OF WHEN M-14 PURGE AND VENT SYSTEM OPERATING OR TOTAL SHUTDOWN CONDITION ARE NOT SHOWN. DURING THE PLANT OFF CONDITION, DURING THOSE TIMES WHEN A SYSTEM OR EQUIPMENT IS NOT IN OPERATION WITHIN A ZONE, OR WHEN M-14 SYSTEM OPERATING THE PLANT HEATING SYSTEM ARE DESIGNED TO MAINTAIN A MINIMUM TEMPERATURE OF 60° F.
5. DELETED
6. LOSS OF HVAC IN THE CONTEXT OF THESE TABLES MEANS LOSS OF NON-SAFETY HVAC DUE TO A LOSS OF OFFSITE POWER(LOOP). THE TEMPERATURES SHOWN ARE BASED ON AN ASSUMED INITIAL TEMPERATURE EQUAL TO THE NORMAL PLANT OPERATING CONDITION MAXIMUM TEMPERATURE.
7. THIS AREA IS SUBJECT TO WATER SPRAY FROM THE CONTAINMENT SPRAY SYSTEM. THE WATER CHEMISTRY OF THE SPRAY IS AS NOTED IN SECTION 3.11.5.1.2 OF THE FSAR. DURATION OF THE CONTAINMENT SPRAYS IS CONTROLLED ADMINISTRATIVELY, HOWEVER PLANT TECHNICAL SPECIFICATIONS SHALL STATE THAT THE SPRAYS SHALL BE TERMINATED AT A MAXIMUM OF 30 HOURS POST ACCIDENT. SPRAYS MAY BE TURNED ON AGAIN IF REQUIRED TO LIMIT CONTAINMENT AIRSPACE TEMPERATURE 185° F. REACTIVATION OF SPRAYS COULD BE REQUIRED ANY TIME DURING THE POSTULATED 180 DAY ACCIDENT.
8. FOR QUALIFICATION OF EQUIPMENT TO AN ATWS EVENT, A RADIATION ENVIRONMENT EQUIVALENT TO 10% OF THE GIVEN LOCA DOSES MAY BE USED.
9. FOR TYPICAL NORMAL OPERATION RADIATION SOURCES REFER TO USAR SECTION 3.11.5.2.1.
10. AREAS WITHIN THE ANNULUS WHICH ARE BELOW EL.598'-4" NEED NOT CONSIDER BETA RADIATION. THESE AREAS ARE SHIELDED WITH CONCRETE BY THE CONTAINMENT FIX AS SHOWN ON DWG E-015-012.
11. EQUIPMENT IS SUBJECT TO SUBMERGENCE BETWEEN ELEVATIONS 593'-6" AND 612'-6". FROTH AND SPRAY OCCUR FROM ELEVATIONS 612'-6" TO 623'-4". TIME DURATION IS 5 SECONDS.
12. PORTIONS OF ZONES CT-3 AND CT-4 DIRECTLY BELOW OPEN GRATING ON ZONES CT-7 AND CT-8 ELEVATIONS MAY BE SUBJECT TO RUN-OFF DRIPPING FROM CONTAINMENT SPRAYS.
13. ABOVE CONTAINMENT ELEVATION 730'-0" THE STRATIFIED TEMPERATURES FOLLOWING A RWCU LINE BREAK WILL BE 220° F FROM 0 TO 3 HOURS POST LOCA.

REFERENCE DRAWINGS:

- B-022-001
- B-022-021

(REV. 19 10/2015)

<p>PERRY NUCLEAR POWER PLANT 10 CENTER RD., PERRY, OHIO 44081</p>
<p>ENVIRONMENTAL CONDITIONS FOR CONTAINMENT BUILDING FIGURE 3.11-20 (DWG. B-020-0020-00000)</p>

PLANT OPERATING CONDITION	SIGNIFICANT EVENT	CYCLES	CONDITION DURATION (1)	TEMPERATURE 'F	RELATIVE HUMIDITY(2) % T FINAL (%)	PRESSURE	GAMMA RADIATION(3)		BETA RADIATION		SUPPLEMENTARY DATA
							MAX DOSE RATE RADS/HR	DOSE INTEGRATED RADS	MAX DOSE RATE RADS/HR	DOSE INTEGRATED RADS	
ZONE CT-1 (HARSH) AREA ABOVE REFUELING FLOOR (CONTINUED FROM B-022-020)											
ACCIDENT	LOCA INSIDE CONTAINMENT	1	1 HR 6 HRS 24 HRS 30 DAYS 100 DAYS 180 DAYS				4.14x10 ⁶	1.69x10 ⁶ 5.96x10 ⁶ 1.31x10 ⁷ 3.19x10 ⁷ 3.34x10 ⁷ 3.39x10 ⁷	2.46x10 ⁷	5.81x10 ⁶ 1.46x10 ⁷ 2.69x10 ⁷ 7.15x10 ⁷ 9.53x10 ⁷ 1.17x10 ⁸	(8)
ZONE CT-2 (HARSH) AREA ABOVE SUPPRESSION POOL											
NORMAL MAX MIN AVERAGE	NORMAL FULL POWER OPERATION	1	8363 HRS 3485 HRS 336.616 HRS	104 80 91	90 20 50	ATMOSPHERE ATMOSPHERE ATMOSPHERE	2.5x10 ⁻³	8.8x10 ²	NEGLIGIBLE	NEGLIGIBLE	(4) (9) (14)
ABNORMAL MAX MIN	LOSS OF HVAC	1	100 HRS	137	90 20	ATMOSPHERE ATMOSPHERE					(6)
ABNORMAL	SAFETY RELIEF VALVE DISCHARGE	008	0 MIN 30 MIN 90 MIN 2 HRS 3 HRS 4 HRS 5 HRS 6 HRS 7 HRS 8 HRS 9 HRS 10 HRS 11 HRS 12 HRS 13 HRS 17 HRS	90.0 96.6 109.0 112.7 117.7 119.7 120.0 118.1 116.9 115.9 114.7 109.2 105.0 101.7 90.0	90 100 100 100 100 100 100 100 100 100 100 100 100 100 100 100	ATMOSPHERE 0.4 PSIG 1.1 PSIG 1.4 PSIG 1.7 PSIG 1.9 PSIG 1.9 PSIG 1.8 PSIG 1.7 PSIG 1.6 PSIG 1.6 PSIG 1.6 PSIG 1.2 PSIG 1.0 PSIG 0.8 PSIG 0.0 PSIG	2.1x10 ¹	2.5x10 ³	NEGLIGIBLE	NEGLIGIBLE	
ABNORMAL	TOTAL NON-ACCIDENT INTEGRATED DOSE							2.71x10 ⁵			SUM OF SRVD TRANSIENTS PLUS NORMAL PLANT OPERATION RADIATION DOSES
ACCIDENT	LOCA INSIDE CONTAINMENT	1	0 SEC 2 SEC 10 SEC 30 SEC 100 SEC 1 HR 7 HR 18 HR 27.8 HR 11.6 DAYS 100 DAYS 180 DAYS	104 100 150 150 150 135 140 135 133 120 95 95		1.0 11.4 5.8 6.9 5.8 5.8 6.5 6.4 6.2 2.5 0.0 0.0					ACCIDENT ENVIRONMENTAL MEDIUM AIR, SPRAY (11), SUBMERGENCE AIR, SPRAY (11), SUBMERGENCE AIR, SPRAY (11), SUBMERGENCE AIR, SPRAY (11), SUBMERGENCE AIR, SPRAY (11), SUBMERGENCE AIR, SPRAY (11), SUBMERGENCE AIR, SPRAY (11), SUBMERGENCE AIR, SPRAY (11), SUBMERGENCE AIR, SPRAY (11), SUBMERGENCE AIR, SPRAY (11), SUBMERGENCE AIR, SPRAY (11), SUBMERGENCE AIR, SPRAY (11), SUBMERGENCE AIR, SPRAY (11), SUBMERGENCE AIR, SPRAY (11), SUBMERGENCE AIR, SPRAY (11), SUBMERGENCE
ACCIDENT	LOCA INSIDE CONTAINMENT	1	1 HR 6 HRS 24 HRS 30 DAYS 100 DAYS 180 DAYS				1.62x10 ⁶	7.49x10 ⁵ 3.21x10 ⁶ 7.32x10 ⁶ 2.66x10 ⁷ 3.50x10 ⁷ 3.98x10 ⁷	2.46x10 ⁷	5.81x10 ⁶ 1.46x10 ⁷ 2.69x10 ⁷ 7.15x10 ⁷ 9.53x10 ⁷ 1.17x10 ⁸	(8)

NOTES:

1. TIME DURATION SHOWN IS FOR EACH OCCURRENCE OF THE LISTED SIGNIFICANT EVENT. FOR NORMAL FULL POWER OPERATION, HOURS REPRESENT THE TIME FOR WHICH THE MAXIMUM, MINIMUM, AND NORMAL WEIGHTED AVERAGE TEMPERATURE OCCUR OVER THE POSTULATED 40 YEAR PLANT LIFE. THE ONE CYCLE LISTED FOR THE NORMAL FULL POWER OPERATION REPRESENTS THIS 40 YEAR DURATION MINUS ANY SIGNIFICANT TRANSIENTS. THE SUM OF THE NORMAL AND THE ABNORMAL DURATIONS SHOULD THEREFORE EQUAL 40 YEARS (350,400 HOURS).
2. CONDITION DURATION DOES NOT APPLY TO PERCENT RELATIVE HUMIDITY. PERCENT RELATIVE HUMIDITY IN RELATION TO SPECIFIED TIME DURATIONS HAS NOT BEEN POSTULATED EXCEPT FOR HIGH ENERGY LINE BREAK TRANSIENTS.
3. INTEGRATED GAMMA RADIATION IS OVER 40 YEARS FOR NORMAL PLANT OPERATION, AND 180 DAYS FOR ACCIDENT CONDITIONS. FOR ACCIDENT CONDITIONS, RADIATION DOSES ARE BASED ON RELEASES INSIDE CONTAINMENT ONLY, UNLESS OTHERWISE NOTED.
4. TEMPERATURES SHOWN OCCUR DURING NORMAL PLANT OPERATING MODES. THESE NORMAL PLANT OPERATING MODES INCLUDED THE FOLLOWING:
 - a. NORMAL FULL POWER OPERATION
 - b. HOT STANDBY (OCCURS APPROXIMATELY 5.5 TIMES PER YEAR FOR 5 DAYS)
 - c. NORMAL SHUTDOWN (OCCURS APPROXIMATELY 2.7 TIMES PER YEAR FOR 10 DAYS)
 - d. CONTINUATION OF SHUTDOWN (OCCURS APPROXIMATELY 1 TIME PER YEAR FOR 30 DAYS)
 - e. TESTING (DURATIONS VARY)
 MINIMUM TEMPERATURES SHOWN ARE BASED ON SYSTEM OPERATION DURING THE ABOVE NORMAL PLANT OPERATING MODES. MINIMUM TEMPERATURES FOR THE PLANT OFF, WHEN M-14 PURGE AND VENT SYSTEM OPERATING OR TOTAL SHUTDOWN CONDITION ARE NOT SHOWN. DURING THE PLANT OFF CONDITION, DURING THOSE TIMES WHEN A SYSTEM OR EQUIPMENT IS NOT IN OPERATION WITHIN A ZONE, OR WHEN M-14 SYSTEM OPERATING THE PLANT HEATING SYSTEMS ARE DESIGNED TO MAINTAIN A MINIMUM TEMPERATURE OF 60° F.
5. DELETED
6. LOSS OF HVAC IN THE CONTEXT OF THESE TABLES MEANS LOSS OF NON-SAFETY HVAC DUE TO A LOSS OF OFFSITE POWER(LOOP). THE TEMPERATURES SHOWN ARE BASED ON AN ASSUMED INITIAL TEMPERATURE EQUAL TO THE NORMAL PLANT OPERATING CONDITION MAXIMUM TEMPERATURE.
7. THIS AREA IS SUBJECT TO WATER SPRAY FROM THE CONTAINMENT SPRAY SYSTEM. THE WATER CHEMISTRY OF THE SPRAY IS AS NOTED IN SECTION 3.11.5.1.2 OF THE FSAR. DURATION OF THE CONTAINMENT SPRAYS IS CONTROLLED ADMINISTRATIVELY, HOWEVER PLANT TECHNICAL SPECIFICATIONS SHALL STATE THAT THE SPRAYS SHALL BE TERMINATED AT A MAXIMUM OF 30 HOURS POST ACCIDENT. SPRAYS MAY BE TURNED ON AGAIN IF REQUIRED TO LIMIT CONTAINMENT AIRSPACE TEMPERATURE 185° F. REACTIVATION OF SPRAYS COULD BE REQUIRED ANY TIME DURING THE POSTULATED 180 DAY ACCIDENT.
8. FOR QUALIFICATION OF EQUIPMENT TO AN ATWS EVENT, A RADIATION ENVIRONMENT EQUIVALENT TO 10% OF THE GIVEN LOCA DOSES MAY BE USED.
9. FOR TYPICAL NORMAL OPERATION RADIATION SOURCES REFER TO USAR SECTION 3.11.5.2.1.
10. AREAS WITHIN THE ANNULUS WHICH ARE BELOW EL.598'-4" NEED NOT CONSIDER BETA RADIATION. THESE AREAS ARE SHIELDED WITH CONCRETE BY THE CONTAINMENT FIX AS SHOWN ON DWG E-015-012.
11. EQUIPMENT IS SUBJECT TO SUBMERGENCE BETWEEN ELEVATIONS 593'-6" AND 612'-6". FROTH AND SPRAY OCCUR FROM ELEVATIONS 612'-6" TO 623'-4". TIME DURATION IS 5 SECONDS.
12. PORTIONS OF ZONES CT-3 AND CT-4 DIRECTLY BELOW OPEN GRATING ON ZONES CT-7 AND CT-8 ELEVATIONS MAY BE SUBJECT TO RUN-OFF DRIPPING FROM CONTAINMENT SPRAYS.
13. ABOVE CONTAINMENT ELEVATION 730'-0" THE STRATIFIED TEMPERATURES FOLLOWING A RWCU LINE BREAK WILL BE 220° F FROM 0 TO 3 HOURS POST LOCA.
14. AS REACTOR POWER INCREASES, DOSE RATES AT THE DRYWELL PERSONNEL AIRLOCK SHIELD DOORS WILL INCREASE. IF ANY EQUIPMENT IS TO BE ADDED IN THE VICINITY OF THE SHIELD DOORS, CONSIDERATION SHOULD BE GIVEN TO THE INCREASED RADIATION LEVELS DUE TO STREAMING FROM OPEN SHIELD DOORS.

REFERENCE DRAWINGS:

B-022-001
B-022-020

(REV. 19 10/2015)

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

ENVIRONMENTAL CONDITIONS
FOR CONTAINMENT BUILDING
FIGURE 3.11-21
(DWG. B-022-0021-00000)

PLANT OPERATING CONDITION	SIGNIFICANT EVENT	CYCLES	CONDITION DURATION (1)	TEMPERATURE °F	RELATIVE HUMIDITY(2) T FINAL (%)	PRESSURE	GAMMA RADIATION(3)		BETA RADIATION		SUPPLEMENTARY DATA
							MAX DOSE RATE RADS/HR	DOSE INTEGRATED RADS	MAX DOSE RATE RADS/HR	DOSE INTEGRATED RADS	
ZONE CT-3 (HARSH) HCU FLOOR											
NORMAL MAX MIN AVERAGE	NORMAL FULL POWER OPERATION	1	8363 HRS 3485 HRS 336,616 HRS	104 80 91	90 20 50	ATMOSPHERE ATMOSPHERE ATMOSPHERE	2.5x10 ⁻³	8.8x10 ²	NEGLIGIBLE	NEGLIGIBLE	(4) (9)
ABNORMAL MAX MIN	LOSS OF HVAC	1	100 HRS	137	90 20	ATMOSPHERE ATMOSPHERE					(6)
ABNORMAL	SAFETY RELIEF VALVE DISCHARGE	108	0 MIN 30 MIN 90 MIN 2 HRS 3 HRS 4 HRS 5 HRS 6 HRS 7 HRS 8 HRS 9 HRS 10 HRS 11 HRS 12 HRS 13 HRS 17 HRS	90.0 96.6 109.0 112.7 117.7 119.7 120.0 118.1 116.9 115.9 115.1 114.7 109.2 105.0 101.7 90.0	90 100 100 100 100 100 100 100 100 100 100 100 100 100 100 100	ATMOSPHERE 0.4 PSIG 1.1 PSIG 1.4 PSIG 1.7 PSIG 1.9 PSIG 1.9 PSIG 1.8 PSIG 1.7 PSIG 1.6 PSIG 1.6 PSIG 1.2 PSIG 1.0 PSIG 0.8 PSIG 0.0 PSIG	2.1x10 ¹	2.5x10 ³	NEGLIGIBLE	NEGLIGIBLE	
ABNORMAL	TOTAL NON- ACCIDENT INTEGRATED DOSE							2.71x10 ⁵			SUM OF SRVD TRANSIENTS PLUS NORMAL PLANT OPERATION RADIATION DOSES
ACCIDENT	LOCA INSIDE CONTAINMENT	1	0 SEC 3 SEC 10 SEC 30 SEC 100 SEC 1 HR 7 HR 18 HR 27.8 HR 11.6 DAYS 100 DAYS 180 DAYS	104 100 150 150 150 135 140 135 133 120 95 95	90 100 100 100 100 100 100 100 100 100 100 100 100	1.0 5.3 5.8 6.8 5.8 5.8 6.5 6.4 6.2 2.5 0.0 0.0					ACCIDENT ENVIRONMENTAL MEDIUM AIR, SPRAY (11.12), SUBMERGENCE AIR, SPRAY (11.12), SUBMERGENCE AIR, SPRAY (11.12), SUBMERGENCE AIR, SPRAY (11.12), SUBMERGENCE AIR, SPRAY (11.12), SUBMERGENCE AIR, SPRAY (11.12), SUBMERGENCE AIR, SPRAY (11.12), SUBMERGENCE AIR, SPRAY (11.12), SUBMERGENCE AIR, SPRAY (11.12), SUBMERGENCE AIR, SPRAY (11.12), SUBMERGENCE AIR, SPRAY (11.12), SUBMERGENCE AIR, SPRAY (11.12), SUBMERGENCE AIR, SPRAY (11.12), SUBMERGENCE AIR, SPRAY (11.12), SUBMERGENCE AIR, SPRAY (11.12), SUBMERGENCE
ACCIDENT	LOCA INSIDE CONTAINMENT	1	1 HR 6 HRS 24 HRS 30 DAYS 100 DAYS 180 DAYS				1.62x10 ⁶	7.49x10 ⁵ 3.21x10 ⁶ 7.32x10 ⁷ 2.66x10 ⁷ 3.50x10 ⁷ 3.98x10 ⁷	2.46x10 ⁷	5.81x10 ⁶ 1.46x10 ⁷ 2.69x10 ⁷ 7.15x10 ⁷ 9.53x10 ⁸ 1.17x10 ⁸	(8)
ZONE CT-4 (HARSH) SLCS FLOOR											
NORMAL MAX MIN AVERAGE	NORMAL FULL POWER OPERATION	1	8363 HRS 3485 HRS 336,616 HRS	104 80 91	90 20 50	ATMOSPHERE ATMOSPHERE ATMOSPHERE	2.5x10 ⁻³	8.8x10 ²	NEGLIGIBLE	NEGLIGIBLE	(4) (9)
ABNORMAL MAX MIN	LOSS OF HVAC	1	100 HRS	137	90 20	ATMOSPHERE ATMOSPHERE					(6)

ZONE CT-4 CONTINUED ON B-022-023

NOTES:

1. TIME DURATION SHOWN IS FOR EACH OCCURRENCE OF THE LISTED SIGNIFICANT EVENT, FOR NORMAL FULL POWER OPERATION, HOURS REPRESENT THE TIME FOR WHICH THE MAXIMUM, MINIMUM, AND NORMAL WEIGHTED AVERAGE TEMPERATURE OCCUR OVER THE POSTULATED 40 YEAR PLANT LIFE. THE ONE CYCLE LISTED FOR THE NORMAL FULL POWER OPERATION REPRESENTS THIS 40 YEAR DURATION MINUS ANY SIGNIFICANT TRANSIENTS. THE SUM OF THE NORMAL AND THE ABNORMAL DURATIONS SHOULD THEREFORE EQUAL 40 YEARS (350,400 HOURS).
2. CONDITION DURATION DOES NOT APPLY TO PERCENT RELATIVE HUMIDITY. PERCENT RELATIVE HUMIDITY IN RELATION TO SPECIFIED TIME DURATIONS HAS NOT BEEN POSTULATED EXCEPT FOR HIGH ENERGY LINE BREAK TRANSIENTS.
3. INTEGRATED GAMMA RADIATION IS OVER 40 YEARS FOR NORMAL PLANT OPERATION, AND 180 DAYS FOR ACCIDENT CONDITIONS. FOR ACCIDENT CONDITIONS, RADIATION DOSES ARE BASED ON RELEASES INSIDE CONTAINMENT ONLY, UNLESS OTHERWISE NOTED.
4. TEMPERATURES SHOWN OCCUR DURING NORMAL PLANT OPERATING MODES. THESE NORMAL PLANT OPERATING MODES INCLUDED THE FOLLOWING:
 - a. NORMAL FULL POWER OPERATION
 - b. HOT STANDBY (OCCURS APPROXIMATELY 5.5 TIMES PER YEAR FOR 5 DAYS)
 - c. NORMAL SHUTDOWN (OCCURS APPROXIMATELY 2.7 TIMES PER YEAR FOR 10 DAYS)
 - d. CONTINUATION OF SHUTDOWN (OCCURS APPROXIMATELY 1 TIME PER YEAR FOR 30 DAYS)
 - e. TESTING (DURATIONS VARY)
 MINIMUM TEMPERATURES SHOWN ARE BASED ON SYSTEM OPERATION DURING THE ABOVE NORMAL PLANT OPERATING MODES. MINIMUM TEMPERATURES FOR THE "PLANT OFF" WHEN M-14 PURGE AND VENT SYSTEM OPERATING OR TOTAL SHUTDOWN CONDITION ARE NOT SHOWN. DURING THE PLANT OFF CONDITION, DURING THOSE TIMES WHEN A SYSTEM OR EQUIPMENT IS NOT IN OPERATION WITHIN A ZONE, OR WHEN M-14 SYSTEM OPERATING THE PLANT HEATING SYSTEM ARE DESIGNED TO MAINTAIN A MINIMUM TEMPERATURE OF 60° F.
5. DELETED
6. LOSS OF HVAC IN THE CONTEXT OF THESE TABLES MEANS LOSS OF NON-SAFETY HVAC DUE TO A LOSS OF OFFSITE POWER(LOOP). THE TEMPERATURES SHOWN ARE BASED ON AN ASSUMED INITIAL TEMPERATURE EQUAL TO THE NORMAL PLANT OPERATING CONDITION MAXIMUM TEMPERATURE.
7. THIS AREA IS SUBJECT TO WATER SPRAY FROM THE CONTAINMENT SPRAY SYSTEM. THE WATER CHEMISTRY OF THE SPRAY IS AS NOTED IN SECTION 3.11.5.1.2 OF THE FSAR. DURATION OF THE CONTAINMENT SPRAYS IS CONTROLLED ADMINISTRATIVELY. HOWEVER PLANT TECHNICAL SPECIFICATIONS SHALL STATE THAT THE SPRAYS SHALL BE TERMINATED AT A MAXIMUM OF 30 HOURS POST ACCIDENT. SPRAYS MAY BE TURNED ON AGAIN IF REQUIRED TO LIMIT CONTAINMENT AIRSPACE TEMPERATURE 185° F. REACTIVATION OF SPRAYS COULD BE REQUIRED ANY TIME DURING THE POSTULATED 180 DAY ACCIDENT.
8. FOR QUALIFICATION OF EQUIPMENT TO AN ATWS EVENT, A RADIATION ENVIRONMENT EQUIVALENT TO 10% OF THE GIVEN LOCA DOSES MAY BE USED.
9. FOR TYPICAL NORMAL OPERATION RADIATION SOURCES REFER TO USAR SECTION 3.11.5.2.1.
10. AREAS WITHIN THE ANNULUS WHICH ARE BELOW EL.598'-4" NEED NOT CONSIDER BETA RADIATION. THESE AREAS ARE SHIELDED WITH CONCRETE BY THE CONTAINMENT FIX AS SHOWN ON DWG E-015-012.
11. EQUIPMENT IS SUBJECT TO SUBMERGENCE BETWEEN ELEVATIONS 593'-6" AND 612'-6". FROTH AND SPRAY OCCUR FROM ELEVATIONS 612'-6" TO 623'-4". TIME DURATION IS 5 SECONDS.
12. PORTIONS OF ZONES CT-3 AND CT-4 DIRECTLY BELOW OPEN GRATING ON ZONES CT-7 AND CT-8 ELEVATIONS MAY BE SUBJECT TO RUN-OFF DRIPPING FROM CONTAINMENT SPRAYS.
13. ABOVE CONTAINMENT ELEVATION 730'-0" THE STRATIFIED TEMPERATURES FOLLOWING A RWCU LINE BREAK WILL BE 220° F FROM 0 TO 3 HOURS POST LOCA.

REFERENCE DRAWINGS:

B-022-001
B-022-023

(REV. 19 10/2015)

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

ENVIRONMENTAL CONDITIONS
FOR CONTAINMENT BUILDING
FIGURE 3.11-22
(DWG. B-022-0022-00000)

PLANT OPERATING CONDITION	SIGNIFICANT EVENT	CYCLES	CONDITION DURATION (1)	TEMPERATURE °F	RELATIVE HUMIDITY(2) @ T FINAL (%)	PRESSURE	GAMMA RADIATION(3)		BETA RADIATION		SUPPLEMENTARY DATA
							MAX DOSE RATE RADS/HR	DOSE INTEGRATED RADS	MAX DOSE RATE RADS/HR	DOSE INTEGRATED RADS	
ZONE CT-4 (HARSH) SLCS FLOOR (CONTINUED FROM B-022-022)											
ABNORMAL	SAFETY RELIEF VALVE DISCHARGE	100	0 MIN 30 MIN 90 MIN 2 HRS 3 HRS 4 HRS 5 HRS 6 HRS 7 HRS 8 HRS 9 HRS 10 HRS 11 HRS 12 HRS 13 HRS 17 HRS	90.0 96.6 109.0 112.7 117.7 119.7 120.0 118.1 116.9 115.9 115.1 114.7 109.2 105.0 101.7 90.0	90 100 100 100 100 100 100 100 100 100 100 100 100 100 100 100	ATMOSPHERE 0.4 PSIG 1.1 PSIG 1.4 PSIG 1.7 PSIG 1.9 PSIG 1.9 PSIG 1.8 PSIG 1.7 PSIG 1.6 PSIG 1.6 PSIG 1.6 PSIG 1.2 PSIG 1.0 PSIG 0.8 PSIG 0.0 PSIG	2.1x10 ¹	2.5x10 ³	NEGLIGIBLE	NEGLIGIBLE	
ABNORMAL	TOTAL NON-ACCIDENT INTEGRATED DOSE							2.71x10 ⁵			SUM OF SRVD TRANSIENTS PLUS NORMAL PLANT OPERATION RADIATION DOSES
ACCIDENT	LOCA INSIDE CONTAINMENT	1	0 SEC 3 SEC 10 SEC 30 SEC 100 SEC 1 HR 7 HR 18 HR 27.8 HR 11.6 DAYS 100 DAYS 180 DAYS	104 100 150 150 150 135 140 135 133 120 95 95	90 100 100 100 100 100 100 100 100 100 100 100	1.0 5.3 5.8 6.8 5.8 5.8 6.5 6.4 6.2 2.5 0.0 0.0					ACCIDENT ENVIRONMENTAL MEDIUM AIR, SPRAY (12) AIR, SPRAY (12) AIR, SPRAY (12) AIR, SPRAY (12) AIR, SPRAY (12) AIR, SPRAY (12) AIR, SPRAY (12) AIR, SPRAY (12) AIR, SPRAY (12) AIR, SPRAY (12) AIR, SPRAY (12) AIR, SPRAY (12)
ACCIDENT	LOCA INSIDE CONTAINMENT	1	1 HR 6 HRS 24 HRS 30 DAYS 100 DAYS 180 DAYS				1.62x10 ⁶	7.49x10 ⁵ 3.21x10 ⁶ 7.32x10 ⁶ 2.66x10 ⁷ 3.50x10 ⁷ 3.98x10 ⁷	2.46x10 ⁷	5.81x10 ⁶ 1.46x10 ⁷ 2.69x10 ⁷ 7.15x10 ⁷ 9.53x10 ⁷ 1.17x10 ⁸	(8)
ZONE CT-5 (HARSH) RWCU ROOMS											
NORMAL	NORMAL FULL POWER OPERATION	1	8363 HRS 3485 HRS 336,616 HRS	110 99 105	90 20 50	ATMOSPHERE ATMOSPHERE ATMOSPHERE	100	2.8x10 ⁷	NEGLIGIBLE	NEGLIGIBLE	(4) (9)
ABNORMAL	LOSS OF HVAC	1	100 HRS	151	90 20	ATMOSPHERE ATMOSPHERE					(6)
ABNORMAL	SAFETY RELIEF VALVE DISCHARGE	100	0.0 MIN 30.0 MIN 90 MIN 2 HRS 3 HRS 4 HRS 5 HRS 6 HRS 7 HRS 8 HRS 9 HRS 10 HRS 11 HRS 12 HRS 13 HRS 17 HRS	90.0 96.6 109.0 112.7 117.7 119.7 120.0 118.1 116.9 115.9 115.1 114.7 109.2 105.0 101.7 90	90 100 100 100 100 100 100 100 100 100 100 100 100 100 100 100	ATMOSPHERE 0.4 PSIG 1.1 PSIG 1.4 PSIG 1.7 PSIG 1.9 PSIG 1.9 PSIG 1.8 PSIG 1.7 PSIG 1.6 PSIG 1.6 PSIG 1.6 PSIG 1.2 PSIG 1.0 PSIG 0.8 PSIG 0.0 PSIG	2.1x10 ¹	2.5x10 ³	NEGLIGIBLE	NEGLIGIBLE	
ABNORMAL	TOTAL NON-ACCIDENT INTEGRATED DOSE							2.8x10 ⁷			2.8x10 ⁷ IS THE SUM OF SRVD TRANSIENTS PLUS NORMAL PLANT OPERATION RADIATION DOSES

NOTES:

1. TIME DURATION SHOWN IS FOR EACH OCCURRENCE OF THE LISTED SIGNIFICANT EVENT. FOR NORMAL FULL POWER OPERATION, HOURS REPRESENT THE TIME FOR WHICH THE MAXIMUM, MINIMUM, AND NORMAL WEIGHTED AVERAGE TEMPERATURE OCCUR OVER THE POSTULATED 40 YEAR PLANT LIFE. THE ONE CYCLE LISTED FOR THE NORMAL FULL POWER OPERATION REPRESENTS THIS 40 YEAR DURATION MINUS ANY SIGNIFICANT TRANSIENTS. THE SUM OF THE NORMAL AND THE ABNORMAL DURATIONS SHOULD THEREFORE EQUAL 40 YEARS (350,400 HOURS).
2. CONDITION DURATION DOES NOT APPLY TO PERCENT RELATIVE HUMIDITY. PERCENT RELATIVE HUMIDITY IN RELATION TO SPECIFIED TIME DURATIONS HAS NOT BEEN POSTULATED EXCEPT FOR HIGH ENERGY LINE BREAK TRANSIENTS.
3. INTEGRATED GAMMA RADIATION IS OVER 40 YEARS FOR NORMAL PLANT OPERATION, AND 180 DAYS FOR ACCIDENT CONDITIONS. FOR ACCIDENT CONDITIONS, RADIATION DOSES ARE BASED ON RELEASES INSIDE CONTAINMENT ONLY, UNLESS OTHERWISE NOTED.
4. TEMPERATURES SHOWN OCCUR DURING NORMAL PLANT OPERATING MODES. THESE NORMAL PLANT OPERATING MODES INCLUDED THE FOLLOWING:
 - a. NORMAL FULL POWER OPERATION
 - b. HOT STANDBY (OCCURS APPROXIMATELY 5.5 TIMES PER YEAR FOR 5 DAYS)
 - c. NORMAL SHUTDOWN (OCCURS APPROXIMATELY 2.7 TIMES PER YEAR FOR 10 DAYS)
 - d. CONTINUATION OF SHUTDOWN (OCCURS APPROXIMATELY 1 TIME PER YEAR FOR 30 DAYS)
 - e. TESTING (DURATIONS VARY)
 MINIMUM TEMPERATURES SHOWN ARE BASED ON SYSTEM OPERATION DURING THE ABOVE NORMAL PLANT OPERATING MODES. MINIMUM TEMPERATURES FOR THE "PLANT OFF", WHEN M-14 PURGE AND VENT SYSTEM OPERATING OR TOTAL SHUTDOWN CONDITION ARE NOT SHOWN. DURING THE PLANT OFF CONDITION, DURING THOSE TIMES WHEN A SYSTEM OR EQUIPMENT IS NOT IN OPERATION WITHIN A ZONE, OR WHEN M-14 SYSTEM OPERATING THE PLANT HEATING SYSTEM ARE DESIGNED TO MAINTAIN A MINIMUM TEMPERATURE OF 60° F.
5. DELETED
6. LOSS OF HVAC IN THE CONTEXT OF THESE TABLES MEANS LOSS OF NON-SAFETY HVAC DUE TO A LOSS OF OFFSITE POWER(LOOP). THE TEMPERATURES SHOWN ARE BASED ON AN ASSUMED INITIAL TEMPERATURE EQUAL TO THE NORMAL PLANT OPERATING CONDITION MAXIMUM TEMPERATURE.
7. THIS AREA IS SUBJECT TO WATER SPRAY FROM THE CONTAINMENT SPRAY SYSTEM. THE WATER CHEMISTRY OF THE SPRAY IS AS NOTED IN SECTION 3.11.5.1.2 OF THE FSAR. DURATION OF THE CONTAINMENT SPRAYS IS CONTROLLED ADMINISTRATIVELY, HOWEVER PLANT TECHNICAL SPECIFICATIONS SHALL STATE THAT THE SPRAYS SHALL BE TERMINATED AT A MAXIMUM OF 30 HOURS POST ACCIDENT. SPRAYS MAY BE TURNED ON AGAIN IF REQUIRED TO LIMIT CONTAINMENT AIRSPACE TEMPERATURE 185° F. REACTIVATION OF SPRAYS COULD BE REQUIRED ANY TIME DURING THE POSTULATED 180 DAY ACCIDENT.
8. FOR QUALIFICATION OF EQUIPMENT TO AN ATWS EVENT, A RADIATION ENVIRONMENT EQUIVALENT TO 10% OF THE GIVEN LOCA DOSES MAY BE USED.
9. FOR TYPICAL NORMAL OPERATION RADIATION SOURCES REFER TO USAR SECTION 3.11.5.2.1.
10. AREAS WITHIN THE ANNULUS WHICH ARE BELOW EL.598'-4" NEED NOT CONSIDER BETA RADIATION. THESE AREAS ARE SHIELDED WITH CONCRETE BY THE CONTAINMENT FIX AS SHOWN ON DWG E-015-012.
11. EQUIPMENT IS SUBJECT TO SUBMERGENCE BETWEEN ELEVATIONS 593'-6" AND 612'-6". FROTH AND SPRAY OCCUR FROM ELEVATIONS 612'-6" TO 623'-4". TIME DURATION IS 5 SECONDS.
12. PORTIONS OF ZONES CT-3 AND CT-4 DIRECTLY BELOW OPEN GRATING ON ZONES CT-7 AND CT-8 ELEVATIONS MAY BE SUBJECT TO RUN-OFF DRIPPING FROM CONTAINMENT SPRAYS.
13. ABOVE CONTAINMENT ELEVATION 730'-0" THE STRATIFIED TEMPERATURES FOLLOWING A RWCU LINE BREAK WILL BE 220° F FROM 0 TO 3 HOURS POST LOCA.

REFERENCE DRAWINGS:

B-022-001
B-022-022
B-022-024

(REV. 19 10/2015)

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

ENVIRONMENTAL CONDITIONS
FOR CONTAINMENT BUILDING
FIGURE 3.11-23
(DWG. B-022-0023-00000)

ZONE CT-5 CONTINUED ON B-022-024

PLANT OPERATING CONDITION	SIGNIFICANT EVENT	CYCLES	CONDITION DURATION (1)	TEMPERATURE °F	RELATIVE HUMIDITY(2) % T FINAL (%)	PRESSURE	GAMMA RADIATION(3)		BETA RADIATION		SUPPLEMENTARY DATA
							MAX DOSE RATE RADS/HR	DOSE INTEGRATED RADS	MAX DOSE RATE RADS/HR	DOSE INTEGRATED RADS	
ZONE CT-5 (HARSH) RWCU ROOMS (CONTINUED FROM B-022-023)											
ACCIDENT	RWCU BREAK INSIDE CONTAINMENT	1	0 SEC 1.3 SEC 18.5 SEC 34 SEC 1.5 HR 2.5 HR 3.5 HR 5.0 HR 12.0 HR 24 HR 48 HR 180 DAYS	140 215 240 230 160 150 140 125 110 98 98	90 100 100 100 100 100 100 100 100 100 100 100	0.0 3.0 10.3 5.3 0.0 0.0 0.0 0.0 0.0 0.0 0.0					ACCIDENT ENVIRONMENTAL MEDIUM AIR STEAM STEAM STEAM STEAM AIR AIR AIR AIR AIR AIR AIR
ACCIDENT	LOCA INSIDE CONTAINMENT	1	1 HR 6 HRS 24 HRS 30 DAYS 100 DAYS 180 DAYS				1.62x10 ⁶	7.49x10 ⁵ 3.21x10 ⁶ 7.32x10 ⁶ 2.66x10 ⁷ 3.50x10 ⁷ 3.98x10 ⁷	2.46x10 ⁷	5.81x10 ⁶ 1.46x10 ⁷ 2.69x10 ⁷ 7.15x10 ⁷ 9.53x10 ⁷ 1.17x10 ⁸	(8)
ZONE CT-6 (HARSH) STEAM TUNNEL INSIDE CONTAINMENT											
NORMAL	NORMAL FULL POWER OPERATION	1	8363 HRS 3485 HRS 336,616 HRS	144 119 132	90 20 50	ATMOSPHERE ATMOSPHERE ATMOSPHERE	10.7	3.0x10 ⁶	NEGLIGIBLE	NEGLIGIBLE	(4) (9) (14)
ABNORMAL	LOSS OF HVAC	1	100 HRS	137	90 20	ATMOSPHERE ATMOSPHERE					(6)
ABNORMAL	SAFETY RELIEF VALVE DISCHARGE	100	0 MIN 30 MIN 90 MIN 2 HRS 3 HRS 4 HRS 5 HRS 6 HRS 7 HRS 8 HRS 9 HRS 10 HRS 11 HRS 12 HRS 13 HRS 17 HRS	90.0 96.6 109.0 112.7 117.7 119.7 120.0 118.1 116.9 115.9 115.1 114.7 109.2 105.0 101.7 90.0	90 100 100 100 100 100 100 100 100 100 100 100 100 100 100 100	ATMOSPHERE 0.4 PSIG 1.1 PSIG 1.4 PSIG 1.7 PSIG 1.9 PSIG 1.9 PSIG 1.8 PSIG 1.7 PSIG 1.6 PSIG 1.6 PSIG 1.6 PSIG 1.2 PSIG 1.0 PSIG 0.8 PSIG 0.0 PSIG	2.1x10 ¹	2.5x10 ³			
ABNORMAL	TOTAL NON-ACCIDENT INTEGRATED DOSE							3.3x10 ⁶			3.3x10 ⁶ IS THE SUM OF SRVD TRANSIENTS PLUS NORMAL PLANT OPERATION RADIATION DOSES
ACCIDENT	LOCA & RWCU LINE BREAK COMPOSITE	1	0 SEC 3 SEC 10 SEC 30 SEC 100 SEC 1 HR 7 HR 18 HR 27.8 HR 11.6 DAYS 100 DAYS 180 DAYS	144 213 220 227 150 135 140 135 133 119 95 95							ACCIDENT ENVIRONMENTAL MEDIUM AIR STEAM STEAM STEAM AIR AIR AIR AIR AIR AIR AIR AIR
ACCIDENT	LOCA INSIDE CONTAINMENT	1	1 HR 6 HRS 24 HRS 30 DAYS 100 DAYS 180 DAYS				1.62x10 ⁶	7.49x10 ⁵ 3.21x10 ⁶ 7.32x10 ⁶ 2.66x10 ⁷ 3.50x10 ⁷ 3.98x10 ⁷	2.46x10 ⁷	5.81x10 ⁶ 1.46x10 ⁷ 2.69x10 ⁷ 7.15x10 ⁷ 9.53x10 ⁷ 1.17x10 ⁸	(8)

NOTES:

1. TIME DURATION SHOWN IS FOR EACH OCCURRENCE OF THE LISTED SIGNIFICANT EVENT. FOR NORMAL FULL POWER OPERATION, HOURS REPRESENT THE TIME FOR WHICH THE MAXIMUM, MINIMUM, AND NORMAL WEIGHTED AVERAGE TEMPERATURE OCCUR OVER THE POSTULATED 40 YEAR PLANT LIFE. THE ONE CYCLE LISTED FOR THE NORMAL FULL POWER OPERATION REPRESENTS THIS 40 YEAR DURATION MINUS ANY SIGNIFICANT TRANSIENTS. THE SUM OF THE NORMAL AND THE ABNORMAL DURATIONS SHOULD THEREFORE EQUAL 40 YEARS (350,400 HOURS).
2. CONDITION DURATION DOES NOT APPLY TO PERCENT RELATIVE HUMIDITY. PERCENT RELATIVE HUMIDITY IN RELATION TO SPECIFIED TIME DURATIONS HAS NOT BEEN POSTULATED EXCEPT FOR HIGH ENERGY LINE BREAK TRANSIENTS.
3. INTEGRATED GAMMA RADIATION IS OVER 40 YEARS FOR NORMAL PLANT OPERATION, AND 180 DAYS FOR ACCIDENT CONDITIONS. FOR ACCIDENT CONDITIONS, RADIATION DOSES ARE BASED ON RELEASES INSIDE CONTAINMENT ONLY, UNLESS OTHERWISE NOTED.
4. TEMPERATURES SHOWN OCCUR DURING NORMAL PLANT OPERATING MODES. THESE NORMAL PLANT OPERATING MODES INCLUDED THE FOLLOWING:
 - a. NORMAL FULL POWER OPERATION
 - b. HOT STANDBY (OCCURS APPROXIMATELY 5.5 TIMES PER YEAR FOR 5 DAYS)
 - c. NORMAL SHUTDOWN (OCCURS APPROXIMATELY 2.7 TIMES PER YEAR FOR 10 DAYS)
 - d. CONTINUATION OF SHUTDOWN (OCCURS APPROXIMATELY 1 TIME PER YEAR FOR 30 DAYS)
 - e. TESTING (DURATIONS VARY)
 MINIMUM TEMPERATURES SHOWN ARE BASED ON SYSTEM OPERATION DURING THE ABOVE NORMAL PLANT OPERATING MODES. MINIMUM TEMPERATURES FOR THE "PLANT OFF", WHEN M-14 PURGE AND VENT SYSTEM OPERATING OR TOTAL SHUTDOWN CONDITION ARE NOT SHOWN. DURING THE PLANT OFF CONDITION, DURING THOSE TIMES WHEN A SYSTEM OR EQUIPMENT IS NOT IN OPERATION WITHIN A ZONE, OR WHEN M-14 SYSTEM OPERATING THE PLANT HEATING SYSTEM ARE DESIGNED TO MAINTAIN A MINIMUM TEMPERATURE OF 60° F.
5. DELETED
6. LOSS OF HVAC IN THE CONTEXT OF THESE TABLES MEANS LOSS OF NON-SAFETY HVAC DUE TO A LOSS OF OFFSITE POWER(LOOP). THE TEMPERATURES SHOWN ARE BASED ON AN ASSUMED INITIAL TEMPERATURE EQUAL TO THE NORMAL PLANT OPERATING CONDITION MAXIMUM TEMPERATURE.
7. THIS AREA IS SUBJECT TO WATER SPRAY FROM THE CONTAINMENT SPRAY SYSTEM. THE WATER CHEMISTRY OF THE SPRAY IS AS NOTED IN SECTION 3.11.5.1.2 OF THE FSAR. DURATION OF THE CONTAINMENT SPRAYS IS CONTROLLED ADMINISTRATIVELY, HOWEVER PLANT TECHNICAL SPECIFICATIONS SHALL STATE THAT THE SPRAYS SHALL BE TERMINATED AT A MAXIMUM OF 30 HOURS POST ACCIDENT. SPRAYS MAY BE TURNED ON AGAIN IF REQUIRED TO LIMIT CONTAINMENT AIRSPACE TEMPERATURE 185° F. REACTIVATION OF SPRAYS COULD BE REQUIRED ANY TIME DURING THE POSTULATED 180 DAY ACCIDENT.
8. FOR QUALIFICATION OF EQUIPMENT TO AN ATWS EVENT, A RADIATION ENVIRONMENT EQUIVALENT TO 10% OF THE GIVEN LOCA DOSES MAY BE USED.
9. FOR TYPICAL NORMAL OPERATION RADIATION SOURCES REFER TO USAR SECTION 3.11.5.2.1.
10. AREAS WITHIN THE ANNULUS WHICH ARE BELOW EL 598'-4" NEED NOT CONSIDER BETA RADIATION. THESE AREAS ARE SHIELDED WITH CONCRETE BY THE CONTAINMENT FIX AS SHOWN ON DWG E-015-012.
11. EQUIPMENT IS SUBJECT TO SUBMERGENCE BETWEEN ELEVATIONS 593'-6" AND 612'-6". FROTH AND SPRAY OCCUR FROM ELEVATIONS 612'-6" TO 623'-4". TIME DURATION IS 5 SECONDS.
12. PORTIONS OF ZONES CT-3 AND CT-4 DIRECTLY BELOW OPEN GRATING ON ZONES CT-7 AND CT-8 ELEVATIONS MAY BE SUBJECT TO RUN-OFF DRIPPING FROM CONTAINMENT SPRAYS.
13. ABOVE CONTAINMENT ELEVATION 730'-0" THE STRATIFIED TEMPERATURES FOLLOWING A RWCU LINE BREAK WILL BE 220° F FROM 0 TO 3 HOURS POST LOCA.
14. THIS AREA, CT-6, IS SUBJECT TO THE POSSIBILITY OF SPRAY DURING NORMAL OPERATIONS DUE TO THE INSTALLATION OF RELIEF VALVES ON THE 4" PIPE INTO PENETRATION #424.

REFERENCE DRAWINGS:
B-022-001
B-022-023

(REV. 19 10/2015)

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

ENVIRONMENTAL CONDITIONS
FOR CONTAINMENT BUILDING
FIGURE 3.11-24
(DWG. B-022-0024-00000)

PLANT OPERATING CONDITION	SIGNIFICANT EVENT	CYCLES	CONDITION DURATION (1)	TEMPERATURE °F	RELATIVE HUMIDITY(2) @ T FINAL (%)	PRESSURE	GAMMA RADIATION(3)		BETA RADIATION		SUPPLEMENTARY DATA
							MAX DOSE RATE RADS/HR	DOSE INTEGRATED RADS	MAX DOSE RATE RADS/HR	DOSE INTEGRATED RADS	
ZONE CT-7 (HARSH) FLOOR ELEVATIONS 652'-0" THROUGH 670'-6"											
NORMAL MAX MIN AVERAGE	NORMAL FULL POWER OPERATION	1	8363 HRS 3485 HRS 336,616 HRS	104 80 91	90 20 50	ATMOSPHERE ATMOSPHERE ATMOSPHERE	2.5x10 ⁻³	8.8x10 ²	NEGLIGIBLE	NEGLIGIBLE	(4) (9)
ABNORMAL MAX MIN	LOSS OF HVAC	1	100 HRS	137	90 20	ATMOSPHERE ATMOSPHERE					(6)
ABNORMAL	SAFETY RELIEF VALVE DISCHARGE	100	0 MIN 30 MIN 90 MIN 2 HRS 3 HRS 4 HRS 5 HRS 6 HRS 7 HRS 8 HRS 9 HRS 10 HRS 11 HRS 12 HRS 13 HRS 17 HRS	90.0 96.6 109.0 112.7 117.7 119.7 120.0 118.1 116.9 115.9 115.1 114.7 109.2 105.0 101.7 90.0	90 100 100 100 100 100 100 100 100 100 100 100 100 100 100 100	ATMOSPHERE 0.4 PSIG 1.1 PSIG 1.4 PSIG 1.7 PSIG 1.9 PSIG 1.9 PSIG 1.8 PSIG 1.7 PSIG 1.6 PSIG 1.6 PSIG 1.6 PSIG 1.2 PSIG 1.0 PSIG 0.8 PSIG 0.0 PSIG	2.1x10 ¹	2.5x10 ³	NEGLIGIBLE	NEGLIGIBLE	
ABNORMAL	TOTAL NON-ACCIDENT INTEGRATED DOSE							2.71x10 ⁵			SUM OF SRVD TRANSIENTS PLUS NORMAL PLANT OPERATION RADIATION DOSES
ACCIDENT	LOCA INSIDE CONTAINMENT	1	0 SEC 3 SEC 10 SEC 30 SEC 100 SEC 1 HR 7 HR 18 HR 27.8 HR 11.6 DAYS 100 DAYS 180 DAYS	104 100 150 150 150 135 140 135 133 120 95 95	90 100 100 100 100 100 100 100 100 100 100 100	1.0 5.3 5.8 6.8 5.8 5.8 6.5 6.4 6.2 2.5 0.0 0.0					(7)
ACCIDENT	LOCA INSIDE CONTAINMENT	1	1 HR 6 HRS 24 HRS 30 DAYS 100 DAYS 180 DAYS				1.62x10 ⁶	7.49x10 ⁵ 3.21x10 ⁶ 7.32x10 ⁷ 2.66x10 ⁷ 3.50x10 ⁷ 3.98x10 ⁷	2.46x10 ⁷	5.81x10 ⁶ 1.46x10 ⁷ 2.69x10 ⁷ 7.15x10 ⁷ 9.53x10 ⁷ 1.17x10 ⁸	(8)
ZONE CT-8 (HARSH) FLOOR ELEVATIONS 652'-0" THROUGH 670'-6"											
NORMAL MAX MIN AVERAGE	NORMAL FULL POWER OPERATION	1	8363 HRS 3485 HRS 336,616 HRS	104 80 91	90 20 50	ATMOSPHERE ATMOSPHERE ATMOSPHERE	2.5x10 ⁻³	8.8x10 ²	NEGLIGIBLE	NEGLIGIBLE	(4) (9)
ABNORMAL MAX MIN	LOSS OF HVAC	1	100 HRS	137	90 20	ATMOSPHERE ATMOSPHERE					(6)
ABNORMAL	SAFETY RELIEF VALVE DISCHARGE	100	0 MIN 30 MIN 90 MIN 2 HRS 3 HRS 4 HRS 5 HRS 6 HRS 7 HRS 8 HRS 9 HRS 10 HRS 11 HRS 12 HRS 13 HRS 17 HRS	90.0 96.6 109.0 112.7 117.7 119.7 120.0 118.1 116.9 115.9 115.1 114.7 109.2 105.0 101.7 90.0	90 100 100 100 100 100 100 100 100 100 100 100 100 100 100 100	ATMOSPHERE 0.4 PSIG 1.1 PSIG 1.4 PSIG 1.7 PSIG 1.9 PSIG 1.9 PSIG 1.8 PSIG 1.7 PSIG 1.6 PSIG 1.6 PSIG 1.6 PSIG 1.2 PSIG 1.0 PSIG 0.8 PSIG 0.0 PSIG	2.1x10 ¹	2.5x10 ³	NEGLIGIBLE	NEGLIGIBLE	

NOTES:

- TIME DURATION SHOWN IS FOR EACH OCCURRENCE OF THE LISTED SIGNIFICANT EVENT. FOR NORMAL FULL POWER OPERATION, HOURS REPRESENT THE TIME FOR WHICH THE MAXIMUM, MINIMUM, AND NORMAL WEIGHTED AVERAGE TEMPERATURE OCCUR OVER THE POSTULATED 40 YEAR PLANT LIFE. THE ONE CYCLE LISTED FOR THE NORMAL FULL POWER OPERATION REPRESENTS THIS 40 YEAR DURATION MINUS ANY SIGNIFICANT TRANSIENTS. THE SUM OF THE NORMAL AND THE ABNORMAL DURATIONS SHOULD THEREFORE EQUAL 40 YEARS (350,400 HOURS).
- CONDITION DURATION DOES NOT APPLY TO PERCENT RELATIVE HUMIDITY. PERCENT RELATIVE HUMIDITY IN RELATION TO SPECIFIED TIME DURATIONS HAS NOT BEEN POSTULATED EXCEPT FOR HIGH ENERGY LINE BREAK TRANSIENTS.
- INTEGRATED GAMMA RADIATION IS OVER 40 YEARS FOR NORMAL PLANT OPERATION, AND 180 DAYS FOR ACCIDENT CONDITIONS. FOR ACCIDENT CONDITIONS, RADIATION DOSES ARE BASED ON RELEASES INSIDE CONTAINMENT ONLY, UNLESS OTHERWISE NOTED.
- TEMPERATURES SHOWN OCCUR DURING NORMAL PLANT OPERATING MODES. THESE NORMAL PLANT OPERATING MODES INCLUDED THE FOLLOWING:
 - NORMAL FULL POWER OPERATION
 - HOT STANDBY (OCCURS APPROXIMATELY 5.5 TIMES PER YEAR FOR 5 DAYS)
 - NORMAL SHUTDOWN (OCCURS APPROXIMATELY 2.7 TIMES PER YEAR FOR 10 DAYS)
 - CONTINUATION OF SHUTDOWN (OCCURS APPROXIMATELY 1 TIME PER YEAR FOR 30 DAYS)
 - TESTING (DURATIONS VARY)
 MINIMUM TEMPERATURES SHOWN ARE BASED ON SYSTEM OPERATION DURING THE ABOVE NORMAL PLANT OPERATING MODES. MINIMUM TEMPERATURES FOR THE "PLANT OFF", WHEN M-14 PURGE AND VENT SYSTEM OPERATING OR TOTAL SHUTDOWN CONDITION ARE NOT SHOWN, DURING THE PLANT OFF CONDITION, DURING THOSE TIMES WHEN A SYSTEM OR EQUIPMENT IS NOT IN OPERATION WITHIN A ZONE, OR WHEN M-14 SYSTEM OPERATING THE PLANT HEATING SYSTEM ARE DESIGNED TO MAINTAIN A MINIMUM TEMPERATURE OF 60° F.
- DELETED
- LOSS OF HVAC IN THE CONTEXT OF THESE TABLES MEANS LOSS OF NON-SAFETY HVAC DUE TO A LOSS OF OFFSITE POWER(LOOP). THE TEMPERATURES SHOWN ARE BASED ON AN ASSUMED INITIAL TEMPERATURE EQUAL TO THE NORMAL PLANT OPERATING CONDITION MAXIMUM TEMPERATURE.
- THIS AREA IS SUBJECT TO WATER SPRAY FROM THE CONTAINMENT SPRAY SYSTEM. THE WATER CHEMISTRY OF THE SPRAY IS AS NOTED IN SECTION 3.11.5.1.2 OF THE FSAR. DURATION OF THE CONTAINMENT SPRAYS IS CONTROLLED ADMINISTRATIVELY, HOWEVER PLANT TECHNICAL SPECIFICATIONS SHALL STATE THAT THE SPRAYS SHALL BE TERMINATED AT A MAXIMUM OF 30 HOURS POST ACCIDENT. SPRAYS MAY BE TURNED ON AGAIN IF REQUIRED TO LIMIT CONTAINMENT AIRSPACE TEMPERATURE 185° F. REACTIVATION OF SPRAYS COULD BE REQUIRED ANY TIME DURING THE POSTULATED 180 DAY ACCIDENT.
- FOR QUALIFICATION OF EQUIPMENT TO AN ATWS EVENT, A RADIATION ENVIRONMENT EQUIVALENT TO 10% OF THE GIVEN LOCA DOSES MAY BE USED.
- FOR TYPICAL NORMAL OPERATION RADIATION SOURCES REFER TO USAR SECTION 3.11.5.2.1.
- AREAS WITHIN THE ANNULUS WHICH ARE BELOW EL.598'-4" NEED NOT CONSIDER BETA RADIATION. THESE AREAS ARE SHIELDED WITH CONCRETE BY THE CONTAINMENT FIX AS SHOWN ON DWG E-015-012.
- EQUIPMENT IS SUBJECT TO SUBMERGENCE BETWEEN ELEVATIONS 593'-6" AND 612'-6". FROTH AND SPRAY OCCUR FROM ELEVATIONS 612'-6" TO 623'-4". TIME DURATION IS 5 SECONDS.
- PORTIONS OF ZONES CT-3 AND CT-4 DIRECTLY BELOW OPEN GRATING ON ZONES CT-7 AND CT-8 ELEVATIONS MAY BE SUBJECT TO RUN-OFF DRIPPING FROM CONTAINMENT SPRAYS.
- ABOVE CONTAINMENT ELEVATION 730'-0" THE STRATIFIED TEMPERATURES FOLLOWING A RWCU LINE BREAK WILL BE 220° F FROM 0 TO 3 HOURS POST LOCA.

REFERENCE DRAWINGS:

B-022-001
B-022-026

(REV. 19 10/2015)

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

ENVIRONMENTAL CONDITIONS
FOR CONTAINMENT BUILDING
FIGURE 3.11-25
(DWG. B-022-0025-00000)

ZONE CT-8 CONTINUED ON B-022-026

PLANT OPERATING CONDITION	SIGNIFICANT EVENT	CYCLES	CONDITION DURATION (1)	TEMPERATURE °F	RELATIVE HUMIDITY(2) % T FINAL (%)	PRESSURE	GAMMA RADIATION(3)		BETA RADIATION		SUPPLEMENTARY DATA	
							MAX DOSE RATE RADS/HR	DOSE INTEGRATED RADS	MAX DOSE RATE RADS/HR	DOSE INTEGRATED RADS		
ZONE CT-8 (HARSH) FLOOR ELEVATIONS 652'-0" THROUGH 670'-6" (CONTINUED FROM B-022-025)												
ABNORMAL	TOTAL NON-ACCIDENT INTEGRATED DOSE							2.71x10 ⁵			SUM OF SRVD TRANSIENTS PLUS NORMAL PLANT OPERATION RADIATION DOSES	
ACCIDENT	LOCA INSIDE CONTAINMENT	1	0 SEC 3 SEC 10 SEC 30 SEC 100 SEC 1 HR 7 HR 18 HR 27.8 HR 11.6 DAYS 100 DAYS 180 DAYS	104 100 150 150 150 135 140 135 133 120 95 95	90 100 100 100 100 100 100 100 100 100 100 100	1.0 5.3 5.8 6.8 5.8 5.8 6.5 6.4 6.2 2.5 0.0 0.0					(7)	
ACCIDENT	LOCA INSIDE CONTAINMENT	1	1 HR 6 HRS 24 HRS 30 DAYS 100 DAYS 180 DAYS				1.62x10 ⁶	7.49x10 ⁵ 3.21x10 ⁶ 7.32x10 ⁶ 2.66x10 ⁷ 3.50x10 ⁷ 3.98x10 ⁷	2.46x10 ⁷	5.81x10 ⁶ 1.46x10 ⁷ 2.69x10 ⁷ 7.15x10 ⁷ 9.53x10 ⁷ 1.17x10 ⁸		(8)

NOTES:

1. TIME DURATION SHOWN IS FOR EACH OCCURRENCE OF THE LISTED SIGNIFICANT EVENT. FOR NORMAL FULL POWER OPERATION, HOURS REPRESENT THE TIME FOR WHICH THE MAXIMUM, MINIMUM, AND NORMAL WEIGHTED AVERAGE TEMPERATURE OCCUR OVER THE POSTULATED 40 YEAR PLANT LIFE. THE ONE CYCLE LISTED FOR THE NORMAL FULL POWER OPERATION REPRESENTS THIS 40 YEAR DURATION MINUS ANY SIGNIFICANT TRANSIENTS. THE SUM OF THE NORMAL AND THE ABNORMAL DURATIONS SHOULD THEREFORE EQUAL 40 YEARS (350,400 HOURS).
2. CONDITION DURATION DOES NOT APPLY TO PERCENT RELATIVE HUMIDITY. PERCENT RELATIVE HUMIDITY IN RELATION TO SPECIFIED TIME DURATIONS HAS NOT BEEN POSTULATED EXCEPT FOR HIGH ENERGY LINE BREAK TRANSIENTS.
3. INTEGRATED GAMMA RADIATION IS OVER 40 YEARS FOR NORMAL PLANT OPERATION, AND 180 DAYS FOR ACCIDENT CONDITIONS. FOR ACCIDENT CONDITIONS, RADIATION DOSES ARE BASED ON RELEASES INSIDE CONTAINMENT ONLY, UNLESS OTHERWISE NOTED.
4. TEMPERATURES SHOWN OCCUR DURING NORMAL PLANT OPERATING MODES. THESE NORMAL PLANT OPERATING MODES INCLUDED THE FOLLOWING:
 - a. NORMAL FULL POWER OPERATION
 - b. HOT STANDBY (OCCURS APPROXIMATELY 5.5 TIMES PER YEAR FOR 5 DAYS)
 - c. NORMAL SHUTDOWN (OCCURS APPROXIMATELY 2.7 TIMES PER YEAR FOR 10 DAYS)
 - d. CONTINUATION OF SHUTDOWN (OCCURS APPROXIMATELY 1 TIME PER YEAR FOR 30 DAYS)
 - e. TESTING (DURATIONS VARY)
 MINIMUM TEMPERATURES SHOWN ARE BASED ON SYSTEM OPERATION DURING THE ABOVE NORMAL PLANT OPERATING MODES. MINIMUM TEMPERATURES FOR THE 'PLANT OFF', WHEN M-14 PURGE AND VENT SYSTEM OPERATING OR TOTAL SHUTDOWN CONDITION ARE NOT SHOWN. DURING THE PLANT OFF CONDITION, DURING THOSE TIMES WHEN A SYSTEM OR EQUIPMENT IS NOT IN OPERATION WITHIN A ZONE, OR WHEN M-14 SYSTEM OPERATING THE PLANT HEATING SYSTEM ARE DESIGNED TO MAINTAIN A MINIMUM TEMPERATURE OF 60° F.
5. DELETED
6. LOSS OF HVAC IN THE CONTEXT OF THESE TABLES MEANS LOSS OF NON-SAFETY HVAC DUE TO A LOSS OF OFFSITE POWER(LOOP). THE TEMPERATURES SHOWN ARE BASED ON AN ASSUMED INITIAL TEMPERATURE EQUAL TO THE NORMAL PLANT OPERATING CONDITION MAXIMUM TEMPERATURE.
7. THIS AREA IS SUBJECT TO WATER SPRAY FROM THE CONTAINMENT SPRAY SYSTEM. THE WATER CHEMISTRY OF THE SPRAY IS AS NOTED IN SECTION 3.11.5.1.2 OF THE FSAR. DURATION OF THE CONTAINMENT SPRAYS IS CONTROLLED ADMINISTRATIVELY, HOWEVER PLANT TECHNICAL SPECIFICATIONS SHALL STATE THAT THE SPRAYS SHALL BE TERMINATED AT A MAXIMUM OF 30 HOURS POST ACCIDENT. SPRAYS MAY BE TURNED ON AGAIN IF REQUIRED TO LIMIT CONTAINMENT AIRSPACE TEMPERATURE 185° F. REACTIVATION OF SPRAYS COULD BE REQUIRED ANY TIME DURING THE POSTULATED 180 DAY ACCIDENT.
8. FOR QUALIFICATION OF EQUIPMENT TO AN ATWS EVENT, A RADIATION ENVIRONMENT EQUIVALENT TO 10% OF THE GIVEN LOCA DOSES MAY BE USED.
9. FOR TYPICAL NORMAL OPERATION RADIATION SOURCES REFER TO USAR SECTION 3.11.5.2.1.
10. AREAS WITHIN THE ANNULUS WHICH ARE BELOW EL. 598'-4" NEED NOT CONSIDER BETA RADIATION. THESE AREAS ARE SHIELDED WITH CONCRETE BY THE CONTAINMENT FIX AS SHOWN ON DWG E-015-012.
11. EQUIPMENT IS SUBJECT TO SUBMERGENCE BETWEEN ELEVATIONS 593'-6" AND 612'-6". FROTH AND SPRAY OCCUR FROM ELEVATIONS 612'-6" TO 623'-4". TIME DURATION IS 5 SECONDS.
12. PORTIONS OF ZONES CT-3 AND CT-4 DIRECTLY BELOW OPEN GRATING ON ZONES CT-7 AND CT-8 ELEVATIONS MAY BE SUBJECT TO RUN-OFF DRIPPING FROM CONTAINMENT SPRAYS.
13. ABOVE CONTAINMENT ELEVATION 730'-0" THE STRATIFIED TEMPERATURES FOLLOWING A RWCU LINE BREAK WILL BE 220° F FROM 0 TO 3 HOURS POST LOCA.

(REV. 19 10/2015)

REFERENCE DRAWINGS:

B-022-001
B-022-025

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

ENVIRONMENTAL CONDITIONS
FOR CONTAINMENT BUILDING
FIGURE 3.11-26
(DWG. B-022-0026-00000)

PLANT OPERATING CONDITION	SIGNIFICANT EVENT	CYCLES	CONDITION DURATION (1)	TEMPERATURE	RELATIVE HUMIDITY(2) @ T FINAL (%)	PRESSURE	GAMMA RADIATION(3)		SUPPLEMENTARY DATA
				°F			MAX DOSE RATE RADS/HR	DOSE INTEGRATED RADS	
ZONE DG-1 (MILD) GENERAL AREAS - DIV. 1 / 2 DG BAYS									
NORMAL MAX MIN AVERAGE	NORMAL FULL POWER OPERATION	1	8398 HRS 3499 HRS 338.023 HRS	109 60 90	90 20 50	ATMOSPHERE ATMOSPHERE ATMOSPHERE	5.0×10^{-4}	1.8×10^2	(4) (5) (8) (9)
NORMAL MAX MIN	TESTING	480	1 HR	122 109	90 20	ATMOSPHERE ATMOSPHERE			
ABNORMAL MAX MIN	LOSS OF HVAC	1	100 HRS	122	90 20	ATMOSPHERE ATMOSPHERE			(5) (6)
ACCIDENT	LOCA INSIDE CONTAINMENT	1	0 HR 15 MIN 180 DAYS	109 122 122	90 max 20 min	ATMOSPHERE ATMOSPHERE ATMOSPHERE			(7)
ACCIDENT	LOCA INSIDE CONTAINMENT	1	1 HR 6 HRS 24 HRS 30 DAYS 100 DAYS 180 DAYS				2.9×10^1	2.70×10^1 2.03×10^2 3.09×10^2 3.63×10^2 3.69×10^2 3.76×10^2	

ZONE DG-2 (MILD) GENERAL AREAS - HPCS DG BAY

NORMAL MAX MIN AVERAGE	NORMAL FULL POWER OPERATION	1	8398 HRS 3499 HRS 338.023 HRS	102 60 95	90 20 50	ATMOSPHERE ATMOSPHERE ATMOSPHERE	5.0×10^{-4}	1.8×10^2	(4) (5) (8) (9)
NORMAL MAX MIN	TESTING	480	1 HR	106 102	90 20	ATMOSPHERE ATMOSPHERE			
ABNORMAL MAX MIN	LOSS OF HVAC	1	100 HRS	106	90 20	ATMOSPHERE ATMOSPHERE			(5) (6)
ACCIDENT	LOCA INSIDE CONTAINMENT	1	0 HR 15 MIN 180 DAYS	102 106 106	90 max 20 min	ATMOSPHERE ATMOSPHERE ATMOSPHERE			(7)
ACCIDENT	LOCA INSIDE CONTAINMENT	1	1 HR 6 HRS 24 HRS 30 DAYS 100 DAYS 180 DAYS				2.9×10^1	2.70×10^1 2.03×10^2 3.09×10^2 3.63×10^2 3.69×10^2 3.76×10^2	

NOTES:

1. TIME DURATION SHOWN IS FOR EACH OCCURRENCE OF THE LISTED SIGNIFICANT EVENT. FOR NORMAL FULL POWER OPERATION, HOURS REPRESENT THE TIME FOR WHICH THE MAXIMUM, MINIMUM, AND NORMAL WEIGHTED AVERAGE TEMPERATURE OCCUR OVER THE POSTULATED 40 YEAR PLANT LIFE. THE ONE CYCLE LISTED FOR THE NORMAL FULL POWER OPERATION REPRESENTS THIS 40 YEAR DURATION MINUS ANY SIGNIFICANT TRANSIENTS. THE SUM OF THE NORMAL AND THE ABNORMAL DURATIONS SHOULD THEREFORE EQUAL 40 YEARS (350,400 HOURS).
2. CONDITION DURATION DOES NOT APPLY TO PERCENT RELATIVE HUMIDITY. PERCENT RELATIVE HUMIDITY IN RELATION TO SPECIFIED TIME DURATIONS HAS NOT BEEN POSTULATED EXCEPT FOR HIGH ENERGY LINE BREAK TRANSIENTS.
3. INTEGRATED GAMMA RADIATION IS OVER 40 YEARS FOR NORMAL PLANT OPERATION, AND 180 DAYS FOR ACCIDENT CONDITIONS. FOR ACCIDENT CONDITIONS, RADIATION DOSES ARE BASED ON RELEASES INSIDE CONTAINMENT ONLY, UNLESS OTHERWISE NOTED.
4. TEMPERATURES SHOWN OCCUR DURING NORMAL PLANT OPERATING MODES. THESE NORMAL PLANT OPERATING MODES INCLUDED THE FOLLOWING:
 - A. NORMAL FULL POWER OPERATION
 - B. HOT STANDBY (OCCURS APPROXIMATELY 5.5 TIMES PER YEAR FOR 5 DAYS)
 - C. NORMAL SHUTDOWN (OCCURS APPROXIMATELY 2.7 TIMES PER YEAR FOR 10 DAYS)
 - D. CONTINUATION OF SHUTDOWN (OCCURS APPROXIMATELY 1 TIME PER YEAR FOR 30 DAYS)
 - E. TESTING (DURATIONS VARY)
 MINIMUM TEMPERATURES SHOWN ARE BASED ON SYSTEM OPERATION DURING THE ABOVE NORMAL PLANT OPERATING MODES. MINIMUM TEMPERATURES FOR THE "PLANT OFF", OR TOTAL SHUTDOWN CONDITION ARE NOT SHOWN. DURING THE PLANT OFF CONDITION, (OR THOSE TIMES WHEN A SYSTEM OR EQUIPMENT IS NOT IN OPERATION WITHIN A ZONE), THE PLANT HEATING SYSTEMS ARE DESIGNED TO MAINTAIN A MINIMUM TEMPERATURE OF 60° F.
5. MODERATE ENERGY PIPE BREAKS IN THIS ZONE COULD CAUSE LOCALIZED WETTING AND 100 PERCENT RELATIVE HUMIDITY FOR A DURATION OF 24 HOURS MAXIMUM. FLUID TEMPERATURES IN LOCAL MODERATE ENERGY LINES MAY EXCEED THE LISTED MAXIMUM AMBIENT TEMPERATURE FOR THIS ZONE AND SHOULD BE ADDRESSED IF THE EQUIPMENT TO BE QUALIFIED IS WETTED BY SPRAY FROM MODERATE ENERGY BREAKS.
6. LOSS OF HVAC IN THE CONTEXT OF THESE TABLES MEANS LOSS OF NON-SAFETY HVAC DUE TO A LOSS OF OFFSITE POWER (LOOP). THE TEMPERATURES SHOWN ARE BASED ON AN ASSUMED INITIAL TEMPERATURE EQUAL TO THE NORMAL OPERATING CONDITION MAXIMUM TEMPERATURE.
7. ACCIDENT TEMPERATURES ARE BASED ON HEAT LOADS FROM SYSTEMS OPERATING IN THE DESIGNATED AREA WHICH ARE ESSENTIAL TO BRINGING THE PLANT TO SHUTDOWN CONDITION FOLLOWING AN ACCIDENT.
8. FOR TYPICAL NORMAL OPERATION RADIATION SOURCES REFER TO USAR SECTION 3.11.5.2.1.
9. A RELATIVE HUMIDITY (RH) OF 20% IS THE AVERAGE MINIMUM RH GENERIC TO BWR6/MARK III PLANTS. THIS IS NOT A REQUIREMENT SINCE THE MINIMUM RH DOES NOT NEED TO BE CONTROLLED. THE RH MAY DROP BELOW 20% WITH NO ADVERSE AFFECT ON PLANT EQUIPMENT.

(REV. 19 10/2015)

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

ENVIRONMENTAL CONDITIONS
FOR DIESEL GENERATOR AREAS
FIGURE 3.11-27
(DWG. B-022-0027-00000)

REFERENCE DRAWINGS:
B-022-0001-00000

PLANT OPERATING CONDITION	SIGNIFICANT EVENT	CYCLES	CONDITION DURATION (1)	TEMPERATURE °F	RELATIVE HUMIDITY(2) • T FINAL (%)	PRESSURE	GAMMA RADIATION(3)		BETA RADIATION		SUPPLEMENTARY DATA
							MAX DOSE RATE RADS/HR	DOSE INTEGRATED RADS	MAX DOSE RATE RADS/HR	DOSE INTEGRATED RADS	
ZONE DW-1 (HARSH) DRYWELL OUTSIDE RPV SHIELD WALL (NOT AT CORE MIDPLANE)											
NORMAL MAX MIN AVERAGE	NORMAL FULL POWER OPERATION	1	8400 HRS 3500 HRS 338,100 HRS	145 122 134	90 20 50	0.0 PSIG -.1' WG	1.0x10 ²	2.8x10 ⁷	NEGLIGIBLE	NEGLIGIBLE	(4) (5) (10) (16)
ABNORMAL MAX MIN	SCRAM	600	30 MIN	148	90 20	0.0 PSIG -.1' WG					(16)
ABNORMAL MAX MIN	LOSS OF HVAC	1	100 HRS	149	90 20	0.0 PSIG -.1' WG					(6) (16)
ACCIDENT	LOCA INSIDE CONTAINMENT DRYWELL (LARGE LINE BREAK)	1	0.0 SEC 0.8 SEC 6.0 SEC 6.1 SEC 25 SEC 30 SEC 100 SEC 9.7 MIN 10 MIN 30 MIN 38 MIN 5.6 HR 27.8 HR 11.6 DAYS 100 DAYS 180 DAYS	145 329 329 329 329 329 320 265 265 260 260 250 250 129 100 100	90 STEAM STEAM STEAM STEAM STEAM STEAM STEAM STEAM STEAM STEAM STEAM STEAM 100 100 100	1.0 23.5 23.5 16.6 13.6 9.1 9.1 10.8 10.8 12.8 14.3 13.6 9.2 0.0 0.0					ACCIDENT ENVIRONMENTAL MEDIUM SPRAY, SUBMERGENCE IMPACT, AND DRAG DURING NEGATIVE PRESSURE TRANSIENT ABOVE WEIR (7) (8)
ACCIDENT	LOCA INSIDE CONTAINMENT DRYWELL (SMALL LINE BREAK)	1	0 SEC 45 SEC 3 HRS 6 HRS 30 HRS 2 DAYS 100 DAYS	145 330 330 310 250 238 90	90 STEAM STEAM STEAM STEAM STEAM STEAM 100	0.0 PSIG 15 PSIG 15 PSIG 14 PSIG 10 PSIG 9 PSIG 0.0 PSIG					
ACCIDENT	LOCA INSIDE CONTAINMENT DRYWELL	1	1 HR 6 HRS 24 HRS 30 DAYS 100 DAYS 180 DAYS				9.84x10 ⁶	2.87x10 ⁶ 1.37x10 ⁷ 2.93x10 ⁷ 6.06x10 ⁷ 6.96x10 ⁷ 7.51x10 ⁷	1.30x10 ⁸	2.80x10 ⁷ 6.83x10 ⁸ 1.24x10 ⁹ 1.93x10 ⁹ 2.15x10 ⁹ 2.35x10 ⁹	(9)
ZONE DW-2 (HARSH) DRYWELL OUTSIDE RPV SHIELD WALL (AT CORE MIDPLANE)											
NORMAL MAX MIN AVERAGE	NORMAL FULL POWER OPERATION	1	8400 HRS 3500 HRS 338,100 HRS	145 122 134	90 20 50	0.0 PSIG -.1' WG	1.6x10 ²	4.5x10 ⁷	NEGLIGIBLE	NEGLIGIBLE	(4) (10) (13)
ABNORMAL MAX MIN	SCRAM	600	30 MIN	148	90 20	0.0 PSIG -.1' WG					
ABNORMAL MAX MIN	LOSS OF HVAC	1	100 HRS	149	90 20	0.0 PSIG -.1' WG					(6)

ZONE DW-2 CONTINUED ON B-022-031

NOTES:

- TIME DURATION SHOWN IS FOR EACH OCCURRENCE OF THE LISTED SIGNIFICANT EVENT. FOR NORMAL FULL POWER OPERATION, HOURS REPRESENT THE TIME FOR WHICH THE MAXIMUM, MINIMUM, AND NORMAL WEIGHTED AVERAGE TEMPERATURE OCCUR OVER THE POSTULATED 40 YEAR PLANT LIFE. THE ONE CYCLE LISTED FOR THE NORMAL FULL POWER OPERATION REPRESENTS THIS 40 YEAR DURATION MINUS ANY SIGNIFICANT TRANSIENTS. THE SUM OF THE NORMAL AND THE ABNORMAL DURATIONS SHOULD THEREFORE EQUAL 40 YEARS (350,400 HOURS).
- CONDITION DURATION DOES NOT APPLY TO PERCENT RELATIVE HUMIDITY. PERCENT RELATIVE HUMIDITY IN RELATION TO SPECIFIED TIME DURATIONS HAS NOT BEEN POSTULATED EXCEPT FOR HIGH ENERGY LINE BREAK TRANSIENTS.
- INTEGRATED GAMMA RADIATION IS OVER 40 YEARS FOR NORMAL PLANT OPERATION, AND 180 DAYS FOR ACCIDENT CONDITIONS. FOR ACCIDENT CONDITIONS, RADIATION DOSES ARE BASED ON RELEASES INSIDE CONTAINMENT ONLY, UNLESS OTHERWISE NOTED.
- TEMPERATURES SHOWN OCCUR DURING NORMAL PLANT OPERATING MODES. THESE NORMAL PLANT OPERATING MODES INCLUDED THE FOLLOWING:
 - NORMAL FULL POWER OPERATION
 - HOT STANDBY (OCCURS APPROXIMATELY 5.5 TIMES PER YEAR FOR 5 DAYS)
 - NORMAL SHUTDOWN (OCCURS APPROXIMATELY 2.7 TIMES PER YEAR FOR 10 DAYS)
 - CONTINUATION OF SHUTDOWN (OCCURS APPROXIMATELY 1 TIME PER YEAR FOR 30 DAYS)
 - TESTING (DURATIONS VARY)
 MINIMUM TEMPERATURES SHOWN ARE BASED ON SYSTEM OPERATION DURING THE ABOVE NORMAL PLANT OPERATING MODES. MINIMUM TEMPERATURES FOR THE 'PLANT OFF', OR TOTAL SHUTDOWN CONDITION ARE NOT SHOWN. DURING THE PLANT OFF CONDITION, OR THOSE TIMES WHEN A SYSTEM OR EQUIPMENT IS NOT IN OPERATION WITHIN A ZONE, THE PLANT HEATING SYSTEMS ARE DESIGNED TO MAINTAIN A MINIMUM TEMPERATURE OF 60° F.
- NEUTRON FLUENCE IS 1.1x10⁶ NTN/CM²/SEC FOR NORMAL OPERATION MAX DOSE RATE AND 1.12x10⁵ NTN/CM² FOR NORMAL 40 YEAR PLANT OPERATION INTEGRATED DOSE.
- LOSS OF HVAC IN THE CONTEXT OF THESE TABLES MEANS LOSS OF NON-SAFETY HVAC DUE TO A LOSS OF OFFSITE POWER(LOOP). THE TEMPERATURES SHOWN ARE BASED ON AN ASSUMED INITIAL TEMPERATURE EQUAL TO THE NORMAL PLANT OPERATING CONDITION MAXIMUM TEMPERATURE.
- EQUIPMENT LOCATED IN ZONE DW-1 IS SUBJECT TO WEIR SWELL SUBMERGENCE EFFECTS FROM ELEVATION 599'-0" TO ELEVATIONS 613'-0". ADDITIONALLY, WEIR SWELL SUBMERGENCE WILL OCCUR BELOW ELEVATION 599'-0" IN THE REGION OF ZONE DW-1 OUTSIDE THE WEIR WALL BUT STILL WITHIN THE DRYWELL. THE TOTAL DURATION OF THE WEIR SWELL EVENT IS 5 SECONDS.
- ALTHOUGH NOT SHOWN HERE, THE COMPOSITE PRESSURE ENVELOPE INCLUDES A PRESSURE DECAY AT A RATE OF 20 PSI PER SECOND TO -14 PSIG. THE PRESSURE REMAINS AT -14 PSIG FOR 2 SECONDS AND THEN INCREASES AT 4.5 PSI PER SECOND. THE TOTAL TIME PRESSURE REMAINS BELOW 0 PSIG IS 7 SECONDS.
- FOR QUALIFICATION OF EQUIPMENT TO AN ATWS EVENT, A RADIATION ENVIRONMENT EQUIVALENT TO 10% OF THE GIVEN LOCA DOSES MAY BE USED.
- FOR TYPICAL NORMAL OPERATION RADIATION SOURCES REFER TO USAR SECTION 3.11.5.2.1.
- DW-2 IS NOT AFFECTED BY WEIR SWELL.
- FOLLOWING A LOCA, THE ENTIRE AREA WITHIN THE DRYWELL BELOW ELEVATION 599'-0" SHOULD BE ASSUMED TO BE FLOODED.
- NEUTRON FLUENCE IS 2.02x10⁶ NTN/CM²/SEC FOR NORMAL OPERATION MAX. DOSE RATE AND 2.02x10⁵ NTN/CM² FOR NORMAL 40 YEAR PLANT OPERATION INTEGRATED DOSE.
- NEUTRON FLUENCE IS 1.12x10⁵ NTN/CM²/SEC FOR NORMAL OPERATION MAX DOSE RATE AND 1.12x10⁴ NTN/CM² FOR NORMAL 40 YEAR PLANT OPERATION INTEGRATED DOSE.
- NEUTRON FLUENCE IS 1.23x10⁶ NTN/CM²/SEC FOR NORMAL OPERATION MAX DOSE RATE AND 1.23x10⁵ NTN/CM² FOR NORMAL 40 YEAR PLANT OPERATION INTEGRATED DOSE.
- LOCALIZED HOT SPOTS EXIST IN AREAS OF THIS ZONE (REFERENCE CR 89-0118). REFER TO TAF 81620 FOR ADDITIONAL INFORMATION.

REFERENCE DRAWINGS: B-022-001
B-022-031

(REV. 19 10/2015)

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

ENVIRONMENTAL CONDITIONS
FOR DRYWELL AREA
FIGURE 3.11-28
(DWG. B-022-0030-00000)

PLANT OPERATING CONDITION	SIGNIFICANT EVENT	CYCLES	CONDITION DURATION (1)	TEMPERATURE °F	RELATIVE HUMIDITY(2) % T FINAL (%)	PRESSURE	GAMMA RADIATION(3)		BETA RADIATION		SUPPLEMENTARY DATA
							MAX DOSE RATE RADS/HR	DOSE INTEGRATED RADS	MAX DOSE RATE RADS/HR	DOSE INTEGRATED RADS	
ZONE DW-2 (HARSH) DRYWELL OUTSIDE RPV SHIELD WALL AT CORE MIDPOINT (CONTINUED FROM B-022-030)											
ACCIDENT	LOCA INSIDE CONTAINMENT DRYWELL (LARGE LINE BREAK)	1	0.0 SEC 0.8 SEC 6.0 SEC 6.1 SEC 25 SEC 30 SEC 100 SEC 9.7 MIN 10 MIN 30 MIN 38 MIN 5.6 HR 27.8 HR 11.6 DAYS 100 DAYS 180 DAYS	145 329 329 329 329 329 320 265 265 260 260 250 250 129 100 100	90 STEAM STEAM STEAM STEAM STEAM STEAM STEAM STEAM STEAM STEAM STEAM STEAM 100 100 100	1.0 23.5 23.5 16.6 15.3 13.6 9.1 9.1 10.8 10.8 12.8 14.3 13.6 9.2 0.0 0.0					ACCIDENT ENVIRONMENTAL MEDIUM STEAM & AIR ONLY (11) (8)
ACCIDENT	LOCA INSIDE CONTAINMENT DRYWELL (SMALL LINE BREAK)	1	0 SEC 45 SEC 3 HRS 6 HRS 30 HRS 2 DAYS 100 DAYS	145 330 330 310 250 238 90	90 STEAM STEAM STEAM STEAM STEAM STEAM 100	0.0 PSIG 15 PSIG 15 PSIG 14 PSIG 10 PSIG 9 PSIG 0.0 PSIG					
ACCIDENT	LOCA INSIDE CONTAINMENT DRYWELL	1	1 HR 6 HRS 24 HRS 30 DAYS 100 DAYS 180 DAYS				9.84x10 ⁶	2.87x10 ⁶ 1.37x10 ⁷ 2.93x10 ⁷ 6.06x10 ⁷ 6.96x10 ⁷ 7.51x10 ⁷	1.30x10 ⁸	2.80x10 ⁷ 6.83x10 ⁷ 1.24x10 ⁸ 1.93x10 ⁸ 2.15x10 ⁸ 2.35x10 ⁸	(9)
ZONE DW-3 (HARSH) DRYWELL UNDER PRESSURE VESSEL											
NORMAL MAX MIN AVERAGE	NORMAL FULL POWER OPERATION	1	8402 HRS 3501 HRS 338,197 HRS	127 80 127	90 20 50	0.0 PSIG -.1" WG	7.0x10 ⁸	2.0x10 ⁶	NEGLIGIBLE	NEGLIGIBLE	(4) (10) (14)
ABNORMAL MAX MIN	SCRAM	600	30 MIN	141	90 20	0.0 PSIG -.1" WG					
ACCIDENT	LOCA INSIDE CONTAINMENT DRYWELL (LARGE LINE BREAK)	1	0.0 SEC 0.8 SEC 6.0 SEC 6.1 SEC 25 SEC 30 SEC 100 SEC 9.7 MIN 10 MIN 30 MIN 38 MIN 5.6 HR 27.8 HR 11.6 DAYS 100 DAYS 180 DAYS	145 329 329 329 329 329 320 265 265 260 260 250 250 129 100 100	90 STEAM STEAM STEAM STEAM STEAM STEAM STEAM STEAM STEAM STEAM STEAM STEAM 100 100 100	1.0 23.5 23.5 16.6 15.3 13.6 9.1 9.1 10.8 10.8 12.8 14.3 13.6 9.2 0.0 0.0				ACCIDENT ENVIRONMENTAL MEDIUM INCLUDES AIR, STEAM, AND FLOODING (8) (12)	
ACCIDENT	LOCA INSIDE CONTAINMENT DRYWELL (SMALL LINE BREAK)	1	0 SEC 45 SEC 3 HRS 6 HRS 30 HRS 2 DAYS 100 DAYS 180 DAYS	145 330 330 310 250 238 90	90 STEAM STEAM STEAM STEAM STEAM STEAM 100	0.0 PSIG 15 PSIG 15 PSIG 14 PSIG 10 PSIG 9 PSIG 0.0 PSIG 0.0 PSIG					
ACCIDENT	LOCA INSIDE CONTAINMENT DRYWELL	1	1 HR 6 HRS 24 HRS 30 DAYS 100 DAYS 180 DAYS				9.84x10 ⁶	2.87x10 ⁶ 1.37x10 ⁷ 2.93x10 ⁷ 6.06x10 ⁷ 6.96x10 ⁷ 7.51x10 ⁷	1.30x10 ⁸	2.80x10 ⁷ 6.83x10 ⁷ 1.24x10 ⁸ 1.93x10 ⁸ 2.15x10 ⁸ 2.35x10 ⁸	(9)

NOTES:

- TIME DURATION SHOWN IS FOR EACH OCCURRENCE OF THE LISTED SIGNIFICANT EVENT. FOR NORMAL FULL POWER OPERATION, HOURS REPRESENT THE TIME FOR WHICH THE MAXIMUM, MINIMUM, AND NORMAL WEIGHTED AVERAGE TEMPERATURE OCCUR OVER THE POSTULATED 40 YEAR PLANT LIFE. THE ONE CYCLE LISTED FOR THE NORMAL FULL POWER OPERATION REPRESENTS THIS 40 YEAR DURATION MINUS ANY SIGNIFICANT TRANSIENTS. THE SUM OF THE NORMAL AND THE ABNORMAL DURATIONS SHOULD THEREFORE EQUAL 40 YEARS (350,400 HOURS).
- CONDITION DURATION DOES NOT APPLY TO PERCENT RELATIVE HUMIDITY. PERCENT RELATIVE HUMIDITY IN RELATION TO SPECIFIED TIME DURATIONS HAS NOT BEEN POSTULATED EXCEPT FOR HIGH ENERGY LINE BREAK TRANSIENTS.
- INTEGRATED GAMMA RADIATION IS OVER 40 YEARS FOR NORMAL PLANT OPERATION, AND 180 DAYS FOR ACCIDENT CONDITIONS. FOR ACCIDENT CONDITIONS, RADIATION DOSES ARE BASED ON RELEASES INSIDE CONTAINMENT ONLY, UNLESS OTHERWISE NOTED.
- TEMPERATURES SHOWN OCCUR DURING NORMAL PLANT OPERATING MODES. THESE NORMAL PLANT OPERATING MODES INCLUDED THE FOLLOWING:
 - NORMAL FULL POWER OPERATION
 - HOT STANDBY (OCCURS APPROXIMATELY 5.5 TIMES PER YEAR FOR 5 DAYS)
 - NORMAL SHUTDOWN (OCCURS APPROXIMATELY 2.7 TIMES PER YEAR FOR 10 DAYS)
 - CONTINUATION OF SHUTDOWN (OCCURS APPROXIMATELY 1 TIME PER YEAR FOR 30 DAYS)
 - TESTING (DURATIONS VARY)
 MINIMUM TEMPERATURES SHOWN ARE BASED ON SYSTEM OPERATION DURING THE ABOVE NORMAL PLANT OPERATING MODES. MINIMUM TEMPERATURES FOR THE "PLANT OFF" OR TOTAL SHUTDOWN CONDITION ARE NOT SHOWN. DURING THE PLANT OFF CONDITION, OR THOSE TIMES WHEN A SYSTEM OR EQUIPMENT IS NOT IN OPERATION WITHIN A ZONE, THE PLANT HEATING SYSTEMS ARE DESIGNED TO MAINTAIN A MINIMUM TEMPERATURE OF 60° F.
- NEUTRON FLUENCE IS 1.11x10¹⁵ NTN/CM²/SEC FOR NORMAL OPERATION MAX DOSE RATE AND 1.12x10¹⁵ NTN/CM² FOR NORMAL 40 YEAR PLANT OPERATION INTEGRATED DOSE.
- LOSS OF HVAC IN THE CONTEXT OF THESE TABLES MEANS LOSS OF NON-SAFETY HVAC DUE TO A LOSS OF OFFSITE POWER(LOOP). THE TEMPERATURES SHOWN ARE BASED ON AN ASSUMED INITIAL TEMPERATURE EQUAL TO THE NORMAL PLANT OPERATING CONDITION MAXIMUM TEMPERATURE.
- EQUIPMENT LOCATED IN ZONE DW-1 IS SUBJECT TO WEIR SWELL SUBMERGENCE EFFECTS FROM ELEVATION 599'-0" TO ELEVATIONS 613'-0". ADDITIONALLY, WEIR SWELL SUBMERGENCE WILL OCCUR BELOW ELEVATION 599'-0" IN THE REGION OF ZONE DW-1 OUTSIDE THE WEIR WALL BUT STILL WITHIN THE DRYWELL. THE TOTAL DURATION OF THE WEIR SWELL EVENT IS 5 SECONDS.
- ALTHOUGH NOT SHOWN HERE, THE COMPOSITE PRESSURE ENVELOPE INCLUDES A PRESSURE DECAY AT A RATE OF 20 PSI PER SECOND TO -14 PSIG. THE PRESSURE REMAINS AT -14 PSIG FOR 2 SECONDS AND THEN INCREASES AT 4.5 PSI PER SECOND. THE TOTAL TIME PRESSURE REMAINS BELOW 0 PSIG IS 7 SECONDS.
- FOR QUALIFICATION OF EQUIPMENT TO AN ATWS EVENT, A RADIATION ENVIRONMENT EQUIVALENT TO 10% OF THE GIVEN LOCA DOSES MAY BE USED.
- FOR TYPICAL NORMAL OPERATION RADIATION SOURCES REFER TO USAR SECTION 3.11.5.2.1.
- DW-2 IS NOT AFFECTED BY WEIR SWELL.
- FOLLOWING A LOCA, THE ENTIRE AREA WITHIN THE DRYWELL BELOW ELEVATION 599'-0" SHOULD BE ASSUMED TO BE FLOODED.
- NEUTRON FLUENCE IS 2.02x10¹⁵ NTN/CM²/SEC FOR NORMAL OPERATION MAX. DOSE RATE AND 2.02x10¹⁵ NTN/CM² FOR NORMAL 40 YEAR PLANT OPERATION INTEGRATED DOSE.
- NEUTRON FLUENCE IS 1.12x10¹⁵ NTN/CM²/SEC FOR NORMAL OPERATION MAX DOSE RATE AND 1.12x10¹⁵ NTN/CM² FOR NORMAL 40 YEAR PLANT OPERATION INTEGRATED DOSE.
- NEUTRON FLUENCE IS 1.23x10¹⁵ NTN/CM²/SEC FOR NORMAL OPERATION MAX DOSE RATE AND 1.23x10¹⁵ NTN/CM² FOR NORMAL 40 YEAR PLANT OPERATION INTEGRATED DOSE.

REFERENCE DRAWINGS: B-022-001
B-022-030

(REV. 19 10/2015)

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

ENVIRONMENTAL CONDITIONS
FOR DRYWELL AREA
FIGURE 3.11-29
(DWG. B-022-0031-00000)

PLANT OPERATING CONDITION	SIGNIFICANT EVENT	CYCLES	CONDITION DURATION (1)	TEMPERATURE °F	RELATIVE HUMIDITY(2) @ T FINAL (%)	PRESSURE	GAMMA RADIATION(3)		BETA RADIATION		SUPPLEMENTARY DATA
							MAX DOSE RATE RADS/HR	DOSE INTEGRATED RADS	MAX DOSE RATE RADS/HR	DOSE INTEGRATED RADS	
ZONE DW-4 (HARSH) DRYWELL DOME											
NORMAL MAX MIN AVERAGE	NORMAL FULL POWER OPERATION	1	8410 HRS 3504 HRS 338,486 HRS	145 130 134	90 20 50	0.0 PSIG -1.1" WG	1.0x10 ²	2.8x10 ⁷	NEGLIGIBLE	NEGLIGIBLE	(4) (10) (15)
ACCIDENT	LOCA INSIDE CONTAINMENT DRYWELL (LARGE LINE BREAK)	1	0.0 SEC 0.8 SEC 6.0 SEC 6.1 SEC 25 SEC 30 SEC 100 SEC 9.7 MIN 10 MIN 30 MIN 38 MIN 5.6 HR 27.8 HR 11.6 DAYS 100 DAYS 180 DAYS	145 329 329 329 329 329 320 265 265 260 260 250 250 129 100 100	90 STEAM STEAM STEAM STEAM STEAM STEAM STEAM STEAM STEAM STEAM STEAM STEAM 100 100 100	1.0 23.5 23.5 16.6 15.3 13.6 9.1 9.1 10.8 10.8 12.8 14.3 13.6 9.2 0.0 0.0					ACCIDENT ENVIRONMENTAL MEDIUM INCLUDES STEAM & AIR ONLY (8)
ACCIDENT	LOCA INSIDE CONTAINMENT DRYWELL (SMALL LINE BREAK)	1	0 SEC 45 SEC 3 HRS 6 HRS 30 HRS 2 DAYS 100 DAYS 180 DAYS	145 330 330 310 250 238 90 90	90 STEAM STEAM STEAM STEAM STEAM STEAM 100 100	0.0 PSIG 15 PSIG 15 PSIG 14 PSIG 10 PSIG 9 PSIG 0.0 PSIG 0.0 PSIG					
ACCIDENT	LOCA INSIDE CONTAINMENT	1	1 HR 6 HRS 24 HRS 30 DAYS 100 DAYS 180 DAYS				9.84x10 ⁶	2.87x10 ⁶ 1.37x10 ⁷ 2.93x10 ⁷ 6.06x10 ⁷ 6.96x10 ⁷ 7.51x10 ⁷	1.30x10 ⁸	2.80x10 ⁷ 6.83x10 ⁷ 1.24x10 ⁸ 1.93x10 ⁸ 2.15x10 ⁸ 2.35x10 ⁸	(9)
ZONE DW-5 (HARSH) REACTOR PRESSURE VESSEL SKIRT											
NORMAL MAX MIN AVERAGE	NORMAL FULL POWER OPERATION	1	8410 HRS 3504 HRS 338,486 HRS	120 80 119	90 20 50	0.0 PSIG -1.1" WG	1.0x10 ²	2.8x10 ⁷	NEGLIGIBLE	NEGLIGIBLE	(4) (10) (15)
ACCIDENT	LOCA INSIDE CONTAINMENT DRYWELL (LARGE LINE BREAK)	1	0.0 SEC 0.8 SEC 6.0 SEC 6.1 SEC 25 SEC 30 SEC 100 SEC 9.7 MIN 10 MIN 30 MIN 38 MIN 5.6 HR 27.8 HR 11.6 DAYS 100 DAYS 180 DAYS	145 329 329 329 329 329 320 265 265 260 260 250 250 129 100 100	90 STEAM STEAM STEAM STEAM STEAM STEAM STEAM STEAM STEAM STEAM STEAM STEAM 100 100 100	1.0 23.5 23.5 16.6 15.3 13.6 9.1 9.1 10.8 10.8 12.8 14.3 13.6 9.2 0.0 0.0					ACCIDENT ENVIRONMENTAL MEDIUM INCLUDES STEAM & AIR ONLY (8)
ACCIDENT	LOCA INSIDE CONTAINMENT DRYWELL (SMALL LINE BREAK)	1	0 SEC 45 SEC 3 HRS 6 HRS 30 HRS 2 DAYS 100 DAYS 180 DAYS	145 330 330 310 250 238 90 90	90 STEAM STEAM STEAM STEAM STEAM STEAM 100 100	0.0 PSIG 15 PSIG 15 PSIG 14 PSIG 10 PSIG 9 PSIG 0.0 PSIG 0.0 PSIG					
ACCIDENT	LOCA INSIDE CONTAINMENT DRYWELL	1	1 HR 6 HRS 24 HRS 30 DAYS 100 DAYS 180 DAYS				9.84x10 ⁶	2.87x10 ⁶ 1.37x10 ⁷ 2.93x10 ⁷ 6.06x10 ⁷ 6.96x10 ⁷ 7.51x10 ⁷	1.30x10 ⁸	2.80x10 ⁷ 6.83x10 ⁷ 1.24x10 ⁸ 1.93x10 ⁸ 2.15x10 ⁸ 2.35x10 ⁸	(9)

NOTES:

1. TIME DURATION SHOWN IS FOR EACH OCCURRENCE OF THE LISTED SIGNIFICANT EVENT. FOR NORMAL FULL POWER OPERATION, HOURS REPRESENT THE TIME FOR WHICH THE MAXIMUM, MINIMUM, AND NORMAL WEIGHTED AVERAGE TEMPERATURE OCCUR OVER THE POSTULATED 40 YEAR PLANT LIFE. THE ONE CYCLE LISTED FOR THE NORMAL FULL POWER OPERATION REPRESENTS THIS 40 YEAR DURATION MINUS ANY SIGNIFICANT TRANSIENTS. THE SUM OF THE NORMAL AND THE ABNORMAL DURATIONS SHOULD THEREFORE EQUAL 40 YEARS (350,400 HOURS).
2. CONDITION DURATION DOES NOT APPLY TO PERCENT RELATIVE HUMIDITY. PERCENT RELATIVE HUMIDITY IN RELATION TO SPECIFIED TIME DURATIONS HAS NOT BEEN POSTULATED EXCEPT FOR HIGH ENERGY LINE BREAK TRANSIENTS.
3. INTEGRATED GAMMA RADIATION IS OVER 40 YEARS FOR NORMAL PLANT OPERATION, AND 180 DAYS FOR ACCIDENT CONDITIONS. FOR ACCIDENT CONDITIONS, RADIATION DOSES ARE BASED ON RELEASES INSIDE CONTAINMENT ONLY, UNLESS OTHERWISE NOTED.
4. TEMPERATURES SHOWN OCCUR DURING NORMAL PLANT OPERATING MODES. THESE NORMAL PLANT OPERATING MODES INCLUDED THE FOLLOWING:
 - a. NORMAL FULL POWER OPERATION
 - b. HOT STANDBY (OCCURS APPROXIMATELY 5.5 TIMES PER YEAR FOR 5 DAYS)
 - c. NORMAL SHUTDOWN (OCCURS APPROXIMATELY 2.7 TIMES PER YEAR FOR 10 DAYS)
 - d. CONTINUATION OF SHUTDOWN (OCCURS APPROXIMATELY 1 TIME PER YEAR FOR 30 DAYS)
 - e. TESTING (DURATIONS VARY)
 MINIMUM TEMPERATURES SHOWN ARE BASED ON SYSTEM OPERATION DURING THE ABOVE NORMAL PLANT OPERATING MODES. MINIMUM TEMPERATURES FOR THE 'PLANT OFF', OR TOTAL SHUTDOWN CONDITION ARE NOT SHOWN. DURING THE PLANT OFF CONDITION, (OR THOSE TIMES WHEN A SYSTEM OR EQUIPMENT IS NOT IN OPERATION WITHIN A ZONE), THE PLANT HEATING SYSTEMS ARE DESIGNED TO MAINTAIN A MINIMUM TEMPERATURE OF 60° F.
5. NEUTRON FLUENCE IS 1.11x10⁶ NTN/CM²/SEC FOR NORMAL OPERATION MAX DOSE RATE AND 1.12x10¹⁵ NTN/CM² FOR NORMAL 40 YEAR PLANT OPERATION INTEGRATED DOSE.
6. LOSS OF HVAC IN THE CONTEXT OF THESE TABLES MEANS LOSS OF NON-SAFETY HVAC DUE TO A LOSS OF OFFSITE POWERLOOP). THE TEMPERATURES SHOWN ARE BASED ON AN ASSUMED INITIAL TEMPERATURE EQUAL TO THE NORMAL PLANT OPERATING CONDITION MAXIMUM TEMPERATURE.
7. EQUIPMENT LOCATED IN ZONE DW-1 IS SUBJECT TO WEIR SWELL SUBMERGENCE EFFECTS FROM ELEVATION 599'-0" TO ELEVATIONS 613'-0". ADDITIONALLY, WEIR SWELL SUBMERGENCE WILL OCCUR BELOW ELEVATION 599'-0" IN THE REGION OF ZONE DW-1 OUTSIDE THE WEIR WALL BUT STILL WITHIN THE DRYWELL. THE TOTAL DURATION OF THE WEIR SWELL EVENT IS 5 SECONDS.
8. ALTHOUGH NOT SHOWN HERE, THE COMPOSITE PRESSURE ENVELOPE INCLUDES A PRESSURE DECAY AT A RATE OF 20 PSI PER SECOND TO -14 PSIG. THE PRESSURE REMAINS AT -14 PSIG FOR 2 SECONDS AND THEN INCREASES AT 4.5 PSI PER SECOND. THE TOTAL TIME PRESSURE REMAINS BELOW 0 PSIG IS 7 SECONDS.
9. FOR QUALIFICATION OF EQUIPMENT TO AN ATWS EVENT, A RADIATION ENVIRONMENT EQUIVALENT TO 10% OF THE GIVEN LOCA DOSES MAY BE USED.
10. FOR TYPICAL NORMAL OPERATION RADIATION SOURCES REFER TO USAR SECTION 3.11.5.2.1.
11. DW-2 IS NOT AFFECTED BY WEIR SWELL.
12. FOLLOWING A LOCA, THE ENTIRE AREA WITHIN THE DRYWELL BELOW ELEVATION 599'-0" SHOULD BE ASSUMED TO BE FLOODED.
13. NEUTRON FLUENCE IS 2.02x10⁶ NTN/CM²/SEC FOR NORMAL OPERATION MAX. DOSE RATE AND 2.02x10¹⁵ NTN/CM² FOR NORMAL 40 YEAR PLANT OPERATION INTEGRATED DOSE.
14. NEUTRON FLUENCE IS 1.12x10⁵ NTN/CM²/SEC FOR NORMAL OPERATION MAX DOSE RATE AND 1.12x10¹⁴ NTN/CM² FOR NORMAL 40 YEAR PLANT OPERATION INTEGRATED DOSE.
15. NEUTRON FLUENCE IS 1.23x10⁶ NTN/CM²/SEC FOR NORMAL OPERATION MAX DOSE RATE AND 1.23x10¹⁵ NTN/CM² FOR NORMAL 40 YEAR PLANT OPERATION INTEGRATED DOSE.

REFERENCE DRAWINGS: B-022-001

(REV. 19 10/2015)

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

ENVIRONMENTAL CONDITIONS
FOR DRYWELL AREA
FIGURE 3.11-30
(DWG. B-022-0032-00000)

PLANT OPERATING CONDITION	SIGNIFICANT EVENT	CYCLES	CONDITION DURATION (1)	TEMPERATURE	RELATIVE HUMIDITY(2) % T FINAL (%)	PRESSURE	GAMMA RADIATION(3)		SUPPLEMENTARY DATA
				*F			MAX DOSE RATE RADS/HR	DOSE INTEGRATED RADS	
ZONE ESW (MILD) EMERGENCY SERVICE WATER PUMPHOUSE									
NORMAL MAX MIN AVERAGE	NORMAL FULL POWER OPERATION	1	6463 HRS 2693 HRS 260,124 HRS	99 60 81	90 20 50	ATMOSPHERE ATMOSPHERE ATMOSPHERE	5.0x10 ⁻⁴	1.8x10 ²	(4) (5) (8)
NORMAL MAX MIN	SHUTDOWN	111	234 HRS	104 99	90 20	ATMOSPHERE ATMOSPHERE ATMOSPHERE			(6)
NORMAL MAX MIN	CONTINUATION OF SHUTDOWN	40	720 HRS	104 99	90 20	ATMOSPHERE ATMOSPHERE ATMOSPHERE			(6)
NORMAL MAX MIN	HOT STANDBY	220	120 HRS	104 99	90 20	ATMOSPHERE ATMOSPHERE ATMOSPHERE			(6)
ACCIDENT	LOCA INSIDE CONTAINMENT	1	0 HR 1 HR 180 DAYS	99 104 104	90 max 20 min	ATMOSPHERE ATMOSPHERE ATMOSPHERE			(7)
ACCIDENT	LOCA INSIDE CONTAINMENT	1	1 HR 6 HRS 24 HRS 30 DAYS 100 DAYS 180 DAYS				2.9x10 ¹	2.70x10 ¹ 2.03x10 ² 3.09x10 ² 3.63x10 ² 3.69x10 ² 3.76x10 ²	

NOTES:

1. TIME DURATION SHOWN IS FOR EACH OCCURRENCE OF THE LISTED SIGNIFICANT EVENT. FOR NORMAL FULL POWER OPERATION, HOURS REPRESENT THE TIME FOR WHICH THE MAXIMUM, MINIMUM, AND NORMAL WEIGHTED AVERAGE TEMPERATURE OCCUR OVER THE POSTULATED 40 YEAR PLANT LIFE. THE ONE CYCLE LISTED FOR THE NORMAL FULL POWER OPERATION REPRESENTS THIS 40 YEAR DURATION MINUS ANY SIGNIFICANT TRANSIENTS. THE SUM OF THE NORMAL AND THE ABNORMAL DURATIONS SHOULD THEREFORE EQUAL 40 YEARS (350,400 HOURS).
2. CONDITION DURATION DOES NOT APPLY TO PERCENT RELATIVE HUMIDITY. PERCENT RELATIVE HUMIDITY IN RELATION TO SPECIFIED TIME DURATIONS HAS NOT BEEN POSTULATED EXCEPT FOR HIGH ENERGY LINE BREAK TRANSIENTS.
3. INTEGRATED GAMMA RADIATION IS OVER 40 YEARS FOR NORMAL PLANT OPERATION, AND 180 DAYS FOR ACCIDENT CONDITIONS. FOR ACCIDENT CONDITIONS, RADIATION DOSES ARE BASED ON RELEASES INSIDE CONTAINMENT ONLY, UNLESS OTHERWISE NOTED.
4. TEMPERATURES SHOWN OCCUR DURING NORMAL PLANT OPERATING MODES. THESE NORMAL PLANT OPERATING MODES INCLUDED THE FOLLOWING:
 - a. NORMAL FULL POWER OPERATION
 - b. HOT STANDBY (OCCURS APPROXIMATELY 5.5 TIMES PER YEAR FOR 5 DAYS)
 - c. NORMAL SHUTDOWN (OCCURS APPROXIMATELY 2.7 TIMES PER YEAR FOR 10 DAYS)
 - d. CONTINUATION OF SHUTDOWN (OCCURS APPROXIMATELY 1 TIME PER YEAR FOR 30 DAYS)
 - e. TESTING (DURATIONS VARY)

MINIMUM TEMPERATURES SHOWN ARE BASED ON SYSTEM OPERATION DURING THE ABOVE NORMAL PLANT OPERATING MODES. MINIMUM TEMPERATURES FOR THE EMERGENCY SERVICE WATER SYSTEM SHUTDOWN CONDITION. THE PLANT HEATING SYSTEMS ARE DESIGNED TO MAINTAIN A MINIMUM TEMPERATURE OF 40° F.
5. MODERATE ENERGY PIPE BREAKS IN THIS ZONE COULD CAUSE LOCALIZED WETTING AND 100 PERCENT RELATIVE HUMIDITY FOR A DURATION OF 24 HOURS MAXIMUM. FLUID TEMPERATURES IN LOCAL MODERATE ENERGY LINES MAY EXCEED THE LISTED MAXIMUM AMBIENT TEMPERATURE FOR THIS ZONE AND SHOULD BE ADDRESSED IF THE EQUIPMENT TO BE QUALIFIED IS WETTED BY SPRAY FROM MODERATE ENERGY BREAKS.
6. THIS OPERATING MODE IS CONSIDERED PART OF NORMAL PLANT OPERATION. IT IS SHOWN SEPARATELY HERE BECAUSE IT REPRESENTS A SIGNIFICANT TRANSIENT ABOVE THE NORMAL AVERAGE TEMPERATURE.
7. ACCIDENT TEMPERATURES ARE BASED ON HEAT LOADS FROM SYSTEMS OPERATING IN THE DESIGNATED AREA WHICH ARE ESSENTIAL TO BRINGING THE PLANT TO SHUTDOWN CONDITION FOLLOWING AN ACCIDENT.
8. FOR TYPICAL NORMAL OPERATION RADIATION SOURCES REFER TO USAR SECTION 3.11.5.2.1.

REFERENCE DRAWINGS: B-022-001

(REV. 19 10/2015)

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

ENVIRONMENTAL CONDITIONS FOR
EMERGENCY SERVICE WATER PUMPHOUSE
FIGURE 3.11-31
(DWG. B-022-0035-00000)

PLANT OPERATING CONDITION	SIGNIFICANT EVENT	CYCLES	CONDITION DURATION (1)	TEMPERATURE	RELATIVE HUMIDITY(2) • T FINAL (%)	PRESSURE	GAMMA RADIATION(3)		SUPPLEMENTARY DATA
				'F			MAX DOSE RATE RADS/HR	DOSE INTEGRATED RADS	
ZONE FB-1 (MILD) INTERMEDIATE BLDG: FUEL POOL PUMP AREA (ELEVATION 574'-10", 599'-0")									
NORMAL MAX MIN AVERAGE	NORMAL FULL POWER OPERATION	1	8407 HRS 3503 HRS 338,390 HRS	127 96 113	90 20 50	ATMOSPHERE ATMOSPHERE ATMOSPHERE	2.5x10 ⁻³	8.8x10 ²	(4) (10) (12)
ABNORMAL MAX MIN	LOSS OF HVAC	1	100 HRS	125	90 20	ATMOSPHERE ATMOSPHERE			(6) (7)
ACCIDENT MAX AVERAGE (180 DAYS)	LOCA INSIDE CONTAINMENT	1		133 121	90 max 20 min	ATMOSPHERE ATMOSPHERE			(8)
ACCIDENT	LOCA INSIDE CONTAINMENT	1	1 HR 6 HRS 24 HRS 30 DAYS 100 DAYS 180 DAYS				4.9x10 ¹	4.0x10 ¹ 2.43x10 ² 3.86x10 ² 5.59x10 ² 9.50x10 ² 1.03x10 ³	
ZONE FB-2 (MILD) FUEL HANDLING AREA OPERATING FLOOR									
NORMAL MAX MIN AVERAGE	NORMAL FULL POWER OPERATION	1	8407 HRS 3503 HRS 338,390 HRS	102 51 74	90 20 50	ATMOSPHERE ATMOSPHERE ATMOSPHERE	2.5x10 ⁻³	8.8x10 ²	(4) (10)
ABNORMAL MAX MIN	LOSS OF HVAC	1	100 HRS	107	90 20	ATMOSPHERE ATMOSPHERE			(6) (7)
ACCIDENT MAX AVERAGE (180 DAYS)	LOCA INSIDE CONTAINMENT	1		108 94	90 max 20 min	ATMOSPHERE ATMOSPHERE			(8)
ACCIDENT	LOCA INSIDE CONTAINMENT	1	1 HR 6 HRS 24 HRS 30 DAYS 100 DAYS 180 DAYS				6.0x10 ¹	4.0x10 ¹ 2.43x10 ² 3.86x10 ² 5.59x10 ² 9.50x10 ² 1.03x10 ³	(11)
ZONE FB-3-574 (HARSH) FUEL HANDLING AREA AT 574'-10" ELEVATION									
NORMAL MAX MIN AVERAGE	NORMAL FULL POWER OPERATION	1	8407 HRS 3503 HRS 338,390 HRS	115 89 95	90 20 50	ATMOSPHERE ATMOSPHERE ATMOSPHERE	2.5x10 ⁻³	8.8x10 ²	(4) (10) (12)
ABNORMAL MAX MIN	LOSS OF HVAC	1	100 HRS	115	90 20	ATMOSPHERE ATMOSPHERE			(6) (7)
ACCIDENT MAX AVERAGE (180 DAYS)	LOCA INSIDE CONTAINMENT	1		108 91	90 max 20 min	ATMOSPHERE ATMOSPHERE			(8) (9)
ACCIDENT	LOCA INSIDE CONTAINMENT	1	1 HR 6 HRS 24 HRS 30 DAYS 100 DAYS 180 DAYS				6.0x10 ¹	4.0x10 ¹ 2.43x10 ² 3.86x10 ² 5.59x10 ² 9.50x10 ² 1.03x10 ³	

NOTES:

1. TIME DURATION SHOWN IS FOR EACH OCCURRENCE OF THE LISTED SIGNIFICANT EVENT. FOR NORMAL FULL POWER OPERATION, HOURS REPRESENT THE TIME FOR WHICH THE MAXIMUM, MINIMUM, AND NORMAL WEIGHTED AVERAGE TEMPERATURE OCCUR OVER THE POSTULATED 40 YEAR PLANT LIFE. THE ONE CYCLE LISTED FOR THE NORMAL FULL POWER OPERATION REPRESENTS THIS 40 YEAR DURATION MINUS ANY SIGNIFICANT TRANSIENTS. THE SUM OF THE NORMAL AND THE ABNORMAL DURATIONS SHOULD THEREFORE EQUAL 40 YEARS (350,400 HOURS).
2. CONDITION DURATION DOES NOT APPLY TO PERCENT RELATIVE HUMIDITY. PERCENT RELATIVE HUMIDITY IN RELATION TO SPECIFIED TIME DURATIONS HAS NOT BEEN POSTULATED EXCEPT FOR HIGH ENERGY LINE BREAK TRANSIENTS.
3. INTEGRATED GAMMA RADIATION IS OVER 40 YEARS FOR NORMAL PLANT OPERATION, AND 180 DAYS FOR ACCIDENT CONDITIONS. FOR ACCIDENT CONDITIONS, RADIATION DOSES ARE BASED ON RELEASES INSIDE CONTAINMENT ONLY, UNLESS OTHERWISE NOTED.
4. TEMPERATURES SHOWN OCCUR DURING NORMAL PLANT OPERATING MODES. THESE NORMAL PLANT OPERATING MODES INCLUDED THE FOLLOWING:
 - a. NORMAL FULL POWER OPERATION
 - b. HOT STANDBY (OCCURS APPROXIMATELY 5.5 TIMES PER YEAR FOR 5 DAYS)
 - c. NORMAL SHUTDOWN (OCCURS APPROXIMATELY 2.7 TIMES PER YEAR FOR 10 DAYS)
 - d. CONTINUATION OF SHUTDOWN (OCCURS APPROXIMATELY 1 TIME PER YEAR FOR 30 DAYS)
 - e. TESTING (DURATIONS VARY)
 MINIMUM TEMPERATURES SHOWN ARE BASED ON SYSTEM OPERATION DURING THE ABOVE NORMAL PLANT OPERATING MODES. MINIMUM TEMPERATURES FOR THE 'PLANT OFF', OR TOTAL SHUTDOWN CONDITION ARE NOT SHOWN. DURING THE PLANT OFF CONDITION, (OR THOSE TIMES WHEN A SYSTEM OR EQUIPMENT IS NOT IN OPERATION WITHIN A ZONE), THE PLANT HEATING SYSTEMS ARE DESIGNED TO MAINTAIN A MINIMUM TEMPERATURE OF 60° F.
5. DELETED
6. MODERATE ENERGY PIPE BREAKS IN THIS ZONE COULD CAUSE LOCALIZED WETTING AND 100 PERCENT RELATIVE HUMIDITY FOR A DURATION OF 24 HOURS MAXIMUM. FLUID TEMPERATURES IN LOCAL MODERATE ENERGY LINES MAY EXCEED THE LISTED MAXIMUM AMBIENT TEMPERATURE FOR THIS ZONE AND SHOULD BE ADDRESSED IF THE EQUIPMENT TO BE QUALIFIED IS WETTED BY SPRAY FROM MODERATE ENERGY BREAKS.
7. LOSS OF HVAC IN THE CONTEXT OF THESE TABLES MEANS LOSS OF NON-SAFETY HVAC DUE TO A LOSS OF OFFSITE POWER(LOOP). THE TEMPERATURES SHOWN ARE BASED ON AN ASSUMED INITIAL TEMPERATURE EQUAL TO THE NORMAL PLANT OPERATING CONDITION MAXIMUM TEMPERATURE.
8. ACCIDENT TEMPERATURES SHOWN ARE BASED ON HEAT LOADS FROM SYSTEMS OPERATING IN THE DESIGNATED AREA WHICH ARE ESSENTIAL TO BRINGING THE PLANT TO SHUTDOWN CONDITION FOLLOWING AN ACCIDENT.
9. FOR QUALIFICATION OF EQUIPMENT TO AN ATWS EVENT, A RADIATION ENVIRONMENT EQUIVALENT TO 10% OF THE GIVEN LOCA DOSES MAY BE USED.
10. FOR TYPICAL NORMAL OPERATION RADIATION SOURCES REFER TO USAR SECTION 3.11.5.2.1.
11. DURING A SEISMIC EVENT, SLOSHING OF WATER WITHIN THE FUEL POOL WALLS WILL CAUSE LOCALIZED WETTING/SPRAY. THE PREDICTED SLOSH HEIGHT IS 8.74 FEET ABOVE THE NORMAL POOL WATER SURFACE OF 619'-6". FLOODING IN THE POOL AREA IS ANTICIPATED SINCE ONLY 1 FOOT OF FREEBOARD IS PROVIDED BY THE FUEL POOL WALLS, WITH TOP OF WALL ELEVATION AT 620'-6". SPRAY UP TO ELEVATION 628'-3" ABOVE THE POOL IS ANTICIPATED.
12. A RELATIVE HUMIDITY (RH) OF 20% IS THE AVERAGE MINIMUM RH GENERIC TO BWR6/MARK III PLANTS. THIS IS NOT A REQUIREMENT SINCE THE MINIMUM RH DOES NOT NEED TO BE CONTROLLED. THE RH MAY DROP BELOW 20% WITH NO ADVERSE AFFECT ON PLANT EQUIPMENT.

REFERENCE DRAWINGS:

B-022-001

(REV. 19 10/2015)

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

ENVIRONMENTAL CONDITIONS
FOR INTERMEDIATE BUILDING
FIGURE 3.11-32 (SHEET 1 OF 2)
(DWG. B-022-0040-00001)

PLANT OPERATING CONDITION	SIGNIFICANT EVENT	CYCLES	CONDITION DURATION (1)	TEMPERATURE °F	RELATIVE HUMIDITY(2) % T FINAL (%)	PRESSURE	GAMMA RADIATION(3)		SUPPLEMENTARY DATA
							MAX DOSE RATE RADS/HR	DOSE INTEGRATED RADS	
ZONE FB-3-N (HARSH) FUEL HANDLING AREA-NORTHERN HALF AT 599'-0" ELEVATION									
NORMAL MAX MIN AVERAGE	NORMAL FULL POWER OPERATION	1	8407 HRS 3503 HRS 338,390 HRS	102 65 80	90 20 50	ATMOSPHERE ATMOSPHERE ATMOSPHERE	2.5×10^{-3}	8.8×10^2	(4) (10) (12)
ABNORMAL MAX MIN	LOSS OF HVAC	1	100 HRS	123	90 20	ATMOSPHERE ATMOSPHERE			(6) (7)
ACCIDENT MAX AVERAGE (180 DAYS)	LOCA INSIDE CONTAINMENT	1		124 114	90 max 20 min	ATMOSPHERE ATMOSPHERE			(8) (9)
ACCIDENT	LOCA INSIDE CONTAINMENT	1	1 HR 6 HRS 24 HRS 30 DAYS 100 DAYS 180 DAYS				6.0×10^1	4.0×10^1 2.43×10^2 3.86×10^2 5.59×10^2 9.50×10^2 1.03×10^3	
ZONE FB-3-S (HARSH) FUEL HANDLING AREA-SOUTHERN HALF AT 599'-0" ELEVATION									
NORMAL MAX MIN AVERAGE	NORMAL FULL POWER OPERATION	1	8407 HRS 3503 HRS 338,390 HRS	108 78 86	90 20 50	ATMOSPHERE ATMOSPHERE ATMOSPHERE	2.5×10^{-3}	8.8×10^2	(4) (10) (12)
ABNORMAL MAX MIN	LOSS OF HVAC	1	100 HRS	120	90 20	ATMOSPHERE ATMOSPHERE			(6) (7)
ACCIDENT MAX AVERAGE (180 DAYS)	LOCA INSIDE CONTAINMENT	1		121 107	90 max 20 min	ATMOSPHERE ATMOSPHERE			(8) (9)
ACCIDENT	LOCA INSIDE CONTAINMENT	1	1 HR 6 HRS 24 HRS 30 DAYS 100 DAYS 180 DAYS				6.0×10^1	4.0×10^1 2.43×10^2 3.86×10^2 5.59×10^2 9.50×10^2 1.03×10^3	

NOTES:

1. TIME DURATION SHOWN IS FOR EACH OCCURRENCE OF THE LISTED SIGNIFICANT EVENT. FOR NORMAL FULL POWER OPERATION, HOURS REPRESENT THE TIME FOR WHICH THE MAXIMUM, MINIMUM, AND NORMAL WEIGHTED AVERAGE TEMPERATURE OCCUR OVER THE POSTULATED 40 YEAR PLANT LIFE. THE ONE CYCLE LISTED FOR THE NORMAL FULL POWER OPERATION REPRESENTS THIS 40 YEAR DURATION MINUS ANY SIGNIFICANT TRANSIENTS. THE SUM OF THE NORMAL AND THE ABNORMAL DURATIONS SHOULD THEREFORE EQUAL 40 YEARS (350,400 HOURS).
2. CONDITION DURATION DOES NOT APPLY TO PERCENT RELATIVE HUMIDITY. PERCENT RELATIVE HUMIDITY IN RELATION TO SPECIFIED TIME DURATIONS HAS NOT BEEN POSTULATED EXCEPT FOR HIGH ENERGY LINE BREAK TRANSIENTS.
3. INTEGRATED GAMMA RADIATION IS OVER 40 YEARS FOR NORMAL PLANT OPERATION, AND 180 DAYS FOR ACCIDENT CONDITIONS. FOR ACCIDENT CONDITIONS, RADIATION DOSES ARE BASED ON RELEASES INSIDE CONTAINMENT ONLY, UNLESS OTHERWISE NOTED.
4. TEMPERATURES SHOWN OCCUR DURING NORMAL PLANT OPERATING MODES. THESE NORMAL PLANT OPERATING MODES INCLUDED THE FOLLOWING:
 - a. NORMAL FULL POWER OPERATION
 - b. HOT STANDBY (OCCURS APPROXIMATELY 5.5 TIMES PER YEAR FOR 5 DAYS)
 - c. NORMAL SHUTDOWN (OCCURS APPROXIMATELY 2.7 TIMES PER YEAR FOR 10 DAYS)
 - d. CONTINUATION OF SHUTDOWN (OCCURS APPROXIMATELY 1 TIME PER YEAR FOR 30 DAYS)
 - e. TESTING (DURATIONS VARY)
 MINIMUM TEMPERATURES SHOWN ARE BASED ON SYSTEM OPERATION DURING THE ABOVE NORMAL PLANT OPERATING MODES. MINIMUM TEMPERATURES FOR THE 'PLANT OFF' OR TOTAL SHUTDOWN CONDITION ARE NOT SHOWN. DURING THE PLANT OFF CONDITION, OR THOSE TIMES WHEN A SYSTEM OR EQUIPMENT IS NOT IN OPERATION WITHIN A ZONE, THE PLANT HEATING SYSTEMS ARE DESIGNED TO MAINTAIN A MINIMUM TEMPERATURE OF 60° F.
5. DELETED
6. MODERATE ENERGY PIPE BREAKS IN THIS ZONE COULD CAUSE LOCALIZED WETTING AND 100 PERCENT RELATIVE HUMIDITY FOR A DURATION OF 24 HOURS MAXIMUM. FLUID TEMPERATURES IN LOCAL MODERATE ENERGY LINES MAY EXCEED THE LISTED MAXIMUM AMBIENT TEMPERATURE FOR THIS ZONE AND SHOULD BE ADDRESSED IF THE EQUIPMENT TO BE QUALIFIED IS WETTED BY SPRAY FROM MODERATE ENERGY BREAKS.
7. LOSS OF HVAC IN THE CONTEXT OF THESE TABLES MEANS LOSS OF NON-SAFETY HVAC DUE TO A LOSS OF OFFSITE POWER(LOOP). THE TEMPERATURES SHOWN ARE BASED ON AN ASSUMED INITIAL TEMPERATURE EQUAL TO THE NORMAL PLANT OPERATING CONDITION MAXIMUM TEMPERATURE.
8. ACCIDENT TEMPERATURES SHOWN ARE BASED ON HEAT LOADS FROM SYSTEMS OPERATING IN THE DESIGNATED AREA WHICH ARE ESSENTIAL TO BRINGING THE PLANT TO SHUTDOWN CONDITION FOLLOWING AN ACCIDENT.
9. FOR QUALIFICATION OF EQUIPMENT TO AN ATWS EVENT, A RADIATION ENVIRONMENT EQUIVALENT TO 10% OF THE GIVEN LOCA DOSES MAY BE USED.
10. FOR TYPICAL NORMAL OPERATION RADIATION SOURCES REFER TO USAR SECTION 3.11.5.2.1.
11. DURING A SEISMIC EVENT, SLOSHING OF WATER WITHIN THE FUEL POOL WALLS WILL CAUSE LOCALIZED WETTING/SPRAY. THE PREDICTED SLOSH HEIGHT IS 8.74 FEET ABOVE THE NORMAL POOL WATER SURFACE OF 619'-6". FLOODING IN THE POOL AREA IS ANTICIPATED SINCE ONLY 1 FOOT OF FREEBOARD IS PROVIDED BY THE FUEL POOL WALLS, WITH TOP OF WALL ELEVATION AT 620'-6". SPRAY UP TO ELEVATION 628'-3" ABOVE THE POOL IS ANTICIPATED.
12. A RELATIVE HUMIDITY (RH) OF 20% IS THE AVERAGE MINIMUM RH GENERIC TO BWR6/MARK III PLANTS. THIS IS NOT A REQUIREMENT SINCE THE MINIMUM RH DOES NOT NEED TO BE CONTROLLED. THE RH MAY DROP BELOW 20% WITH NO ADVERSE EFFECT ON PLANT EQUIPMENT.

REFERENCE DRAWINGS:

B-022-001

(REV. 19 10/2015)

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

ENVIRONMENTAL CONDITIONS
FOR INTERMEDIATE BUILDING
FIGURE 3.11-32 (SHEET 2 OF 2)
(DWG. B-022-0040-00002)

PLANT OPERATING CONDITION	SIGNIFICANT EVENT	CYCLES	CONDITION DURATION (1)	TEMPERATURE	RELATIVE HUMIDITY(2) @ T FINAL (%)	PRESSURE	GAMMA RADIATION(3)		SUPPLEMENTARY DATA
				*F			MAX DOSE RATE RADS/HR	DOSE INTEGRATED RADS	
ZONE FB-4 (MILD) HVAC EQUIPMENT AREA									
NORMAL MAX MIN AVERAGE	NORMAL FULL POWER OPERATION	1	8407 HRS 3503 HRS 338,390 HRS	116 60 94	90 20 50	ATMOSPHERE ATMOSPHERE ATMOSPHERE	2.5×10^{-3}	8.8×10^2	(4) (10) (12) (13)
ABNORMAL MAX MIN	LOSS OF HVAC	1	100 HRS	130	90 20	ATMOSPHERE ATMOSPHERE			(6) (7) (13)
ACCIDENT MAX AVERAGE (180 DAYS)	LOCA INSIDE CONTAINMENT	1		133 123	90 max 20 min	ATMOSPHERE ATMOSPHERE			(8) (13)
ACCIDENT	LOCA INSIDE CONTAINMENT	1	1 HR 6 HRS 24 HRS 30 DAYS 100 DAYS 180 DAYS				3.65×10^1	4.10×10^1 ¹ 2.53×10^2 ² 4.19×10^2 ² 6.08×10^2 ² 6.22×10^2 ² 6.34×10^2 ²	
ZONE FB-5 (MILD) ELECTRICAL PENETRATION AREA									
NORMAL MAX MIN AVERAGE	NORMAL FULL POWER OPERATION	1	8409 HRS 3504 HRS 338,486 HRS	118 83 98	90 20 50	ATMOSPHERE ATMOSPHERE ATMOSPHERE	2.5×10^{-3}	8.8×10^2	(4) (6) (10) (12)
ABNORMAL MAX MIN	LOSS OF HVAC	1	100 HRS	130	90 20	ATMOSPHERE ATMOSPHERE			(6) (7)
ACCIDENT MAX AVERAGE (180 DAYS)	LOCA INSIDE CONTAINMENT	1		135 122	90 max 20 min	ATMOSPHERE ATMOSPHERE			(8)
ACCIDENT	LOCA INSIDE CONTAINMENT	1	1 HR 6 HRS 24 HRS 30 DAYS 100 DAYS 180 DAYS				3.65×10^1	4.10×10^1 ¹ 2.53×10^2 ² 4.19×10^2 ² 6.08×10^2 ² 6.22×10^2 ² 6.34×10^2 ²	
ZONE FB-6 (HARSH) PIPE CHASE, ELEVATIONS 585'-0"									
NORMAL MAX MIN AVERAGE	NORMAL FULL POWER OPERATION	1	8407 HRS 3503 HRS 338,390 HRS	122 114 116	90 20 50	ATMOSPHERE ATMOSPHERE ATMOSPHERE	2.7×10^1	9.4×10^6	(4) (10) (12)
ABNORMAL MAX MIN	LOSS OF HVAC	1	100 HRS	125	90 20	ATMOSPHERE ATMOSPHERE			(6) (7)
ACCIDENT MAX AVERAGE (180 DAYS)	LOCA INSIDE CONTAINMENT	1		119 115	90 max 20 min	ATMOSPHERE ATMOSPHERE			(8)
ACCIDENT	LOCA INSIDE CONTAINMENT	1	1 HR 6 HRS 24 HRS 30 DAYS 100 DAYS 180 DAYS				8.4×10^3	6.51×10^3 ³ 2.63×10^4 ⁴ 6.69×10^4 ⁴ 5.43×10^5 ⁵ 1.01×10^6 ⁶ 1.48×10^6 ⁶	(9)

NOTES:

1. TIME DURATION SHOWN IS FOR EACH OCCURRENCE OF THE LISTED SIGNIFICANT EVENT. FOR NORMAL FULL POWER OPERATION, HOURS REPRESENT THE TIME FOR WHICH THE MAXIMUM, MINIMUM, AND NORMAL WEIGHTED AVERAGE TEMPERATURE OCCUR OVER THE POSTULATED 40 YEAR PLANT LIFE. THE ONE CYCLE LISTED FOR THE NORMAL FULL POWER OPERATION REPRESENTS THIS 40 YEAR DURATION MINUS ANY SIGNIFICANT TRANSIENTS. THE SUM OF THE NORMAL AND THE ABNORMAL DURATIONS SHOULD THEREFORE EQUAL 40 YEARS (350,400 HOURS).
2. CONDITION DURATION DOES NOT APPLY TO PERCENT RELATIVE HUMIDITY. PERCENT RELATIVE HUMIDITY IN RELATION TO SPECIFIED TIME DURATIONS HAS NOT BEEN POSTULATED EXCEPT FOR HIGH ENERGY LINE BREAK TRANSIENTS.
3. INTEGRATED GAMMA RADIATION IS OVER 40 YEARS FOR NORMAL PLANT OPERATION, AND 180 DAYS FOR ACCIDENT CONDITIONS. FOR ACCIDENT CONDITIONS, RADIATION DOSES ARE BASED ON RELEASES INSIDE CONTAINMENT ONLY, UNLESS OTHERWISE NOTED.
4. TEMPERATURES SHOWN OCCUR DURING NORMAL PLANT OPERATING MODES. THESE NORMAL PLANT OPERATING MODES INCLUDED THE FOLLOWING:
 - a. NORMAL FULL POWER OPERATION
 - b. HOT STANDBY (OCCURS APPROXIMATELY 5.5 TIMES PER YEAR FOR 5 DAYS)
 - c. NORMAL SHUTDOWN (OCCURS APPROXIMATELY 2.7 TIMES PER YEAR FOR 10 DAYS)
 - d. CONTINUATION OF SHUTDOWN (OCCURS APPROXIMATELY 1 TIME PER YEAR FOR 30 DAYS)
 - e. TESTING (DURATIONS VARY)
 MINIMUM TEMPERATURES SHOWN ARE BASED ON SYSTEM OPERATION DURING THE ABOVE NORMAL PLANT OPERATING MODES. MINIMUM TEMPERATURES FOR THE 'PLANT OFF', OR TOTAL SHUTDOWN CONDITION ARE NOT SHOWN. DURING THE PLANT OFF CONDITION, (OR THOSE TIMES WHEN A SYSTEM OR EQUIPMENT IS NOT IN OPERATION WITHIN A ZONE), THE PLANT HEATING SYSTEMS ARE DESIGNED TO MAINTAIN A MINIMUM TEMPERATURE OF 60° F.
5. DELETED
6. MODERATE ENERGY PIPE BREAKS IN THIS ZONE COULD CAUSE LOCALIZED WETTING AND 100 PERCENT RELATIVE HUMIDITY FOR A DURATION OF 24 HOURS MAXIMUM. FLUID TEMPERATURES IN LOCAL MODERATE ENERGY LINES MAY EXCEED THE LISTED MAXIMUM AMBIENT TEMPERATURE FOR THIS ZONE AND SHOULD BE ADDRESSED IF THE EQUIPMENT TO BE QUALIFIED IS WETTED BY SPRAY FROM MODERATE ENERGY BREAKS.
7. LOSS OF HVAC IN THE CONTEXT OF THESE TABLES MEANS LOSS OF NON-SAFETY HVAC DUE TO A LOSS OF OFFSITE POWER(LOOP). THE TEMPERATURES SHOWN ARE BASED ON AN ASSUMED INITIAL TEMPERATURE EQUAL TO THE NORMAL PLANT OPERATING CONDITION MAXIMUM TEMPERATURE.
8. ACCIDENT TEMPERATURES SHOWN ARE BASED ON HEAT LOADS FROM SYSTEMS OPERATING IN THE DESIGNATED AREA WHICH ARE ESSENTIAL TO BRINGING THE PLANT TO SHUTDOWN CONDITION FOLLOWING AN ACCIDENT.
9. FOR QUALIFICATION OF EQUIPMENT TO AN ATWS EVENT, A RADIATION ENVIRONMENT EQUIVALENT TO 10% OF THE GIVEN LOCA DOSES MAY BE USED.
10. FOR TYPICAL NORMAL OPERATION RADIATION SOURCES REFER TO USAR SECTION 3.11.5.2.1.
11. DURING A SEISMIC EVENT, SLOSHING OF WATER WITHIN THE FUEL POOL WALLS WILL CAUSE LOCALIZED WETTING/SPRAY. THE PREDICTED SLOSH HEIGHT IS 8.74 FEET ABOVE THE NORMAL POOL WATER SURFACE OF 619'-6". FLOODING IN THE POOL AREA IS ANTICIPATED SINCE ONLY 1 FOOT OF FREEBOARD IS PROVIDED BY THE FUEL POOL WALLS, WITH TOP OF WALL ELEVATION AT 620'-6". SPRAY UP TO ELEVATION 628'-3" ABOVE THE POOL IS ANTICIPATED.
12. A RELATIVE HUMIDITY (RH) OF 20% IS THE AVERAGE MINIMUM RH GENERIC TO BWR6/MARK III PLANTS. THIS IS NOT A REQUIREMENT SINCE THE MINIMUM RH DOES NOT NEED TO BE CONTROLLED. THE RH MAY DROP BELOW 20% WITH NO ADVERSE AFFECT ON PLANT EQUIPMENT.
13. PER ECP 14-0564, CALCULATION ECA-007 WAS UPDATED TO GENERATE NEW OPERATING CONDITION TEMPERATURES FOR ROOM IB-620-10 DUE TO THE NEW ROOM CONFIGURATION. THIS ROOM WAS PREVIOUSLY CLASSIFIED AS ZONE FB-7, BUT IS NOW CLASSIFIED AS ZONE FB-4. THESE NEW OPERATING CONDITION TEMPERATURES CAN BE SEEN IN CALCULATION ECA-007. THE TEMPERATURES IDENTIFIED IN THIS CALCULATION WILL NOT AFFECT THE CURRENT OPERATING CONDITION TEMPERATURES OF ZONE FB-4. ROOM IB-620-8 IS ALSO CLASSIFIED AS ZONE FB-4. THE TEMPERATURES IN THIS ROOM WILL BE THE SAME AS THE TEMPERATURES OF ZONE FB-4 DURING ALL PLANT OPERATING CONDITIONS.

REFERENCE DRAWINGS:
B-022-001

(REV. 19 10/2015)

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

ENVIRONMENTAL CONDITIONS
FOR INTERMEDIATE BUILDING
FIGURE 3.11-33
(DWG. B-022-0041-00000)

PLANT OPERATING CONDITION	SIGNIFICANT EVENT	CYCLES	CONDITION DURATION (1)	TEMPERATURE	RELATIVE HUMIDITY(2) T FINAL (%)	PRESSURE	GAMMA RADIATION(3)		SUPPLEMENTARY DATA
				*F			MAX DOSE RATE RADS/HR	DOSE INTEGRATED RADS	
ZONE FB-7 (HARSH) ANNULUS EXHAUST GAS TREATMENT AREA									
NORMAL MAX MIN AVERAGE	NORMAL FULL POWER OPERATION	1	8407 HRS 3503 HRS 338,390 HRS	124 90 103	90 20 50	ATMOSPHERE ATMOSPHERE ATMOSPHERE	2.5×10^{-3}	8.8×10^2	(4) (10) (12)
ABNORMAL MAX MIN	LOSS OF HVAC	1	100 HRS	142	90 20	ATMOSPHERE ATMOSPHERE			(6) (7)
ACCIDENT MAX AVERAGE (180 DAYS)	LOCA INSIDE CONTAINMENT	1		144 135	90 max 20 min	ATMOSPHERE ATMOSPHERE			(8)
ACCIDENT	LOCA INSIDE CONTAINMENT	1	1 HR 6 HRS 24 HRS 30 DAYS 100 DAYS 180 DAYS				4.9×10^3	4.69×10^3 2.62×10^4 9.36×10^4 7.52×10^5 8.17×10^5 8.29×10^5	(9)
ZONE FB-8 (HARSH) FUEL HANDLING AREA EXHAUST FILTER AREA									
NORMAL MAX MIN AVERAGE	NORMAL FULL POWER OPERATION	1	8407 HRS 3503 HRS 338,390 HRS	114 60 86	90 20 50	ATMOSPHERE ATMOSPHERE ATMOSPHERE	2.5×10^{-2}	8.8×10^3	(4) (10) (12)
ABNORMAL MAX MIN	LOSS OF HVAC	1	100 HRS	119	90 20	ATMOSPHERE ATMOSPHERE			(6) (7)
ACCIDENT MAX AVERAGE (180 DAYS)	LOCA INSIDE CONTAINMENT	1		120 103	90 max 20 min	ATMOSPHERE ATMOSPHERE			(8)
ACCIDENT	FUEL HANDLING ACCIDENT	1	1 HR 6 HRS 24 HRS 30 DAYS 100 DAYS 180 DAYS				3.66×10^2	4.03×10^2 2.42×10^3 9.66×10^3 9.66×10^4 1.00×10^5 1.00×10^5	(9)

NOTES:

1. TIME DURATION SHOWN IS FOR EACH OCCURRENCE OF THE LISTED SIGNIFICANT EVENT. FOR NORMAL FULL POWER OPERATION, HOURS REPRESENT THE TIME FOR WHICH THE MAXIMUM, MINIMUM, AND NORMAL WEIGHTED AVERAGE TEMPERATURE OCCUR OVER THE POSTULATED 40 YEAR PLANT LIFE. THE ONE CYCLE LISTED FOR THE NORMAL FULL POWER OPERATION REPRESENTS THIS 40 YEAR DURATION MINUS ANY SIGNIFICANT TRANSIENTS. THE SUM OF THE NORMAL AND THE ABNORMAL DURATIONS SHOULD THEREFORE EQUAL 40 YEARS (350,400 HOURS).
2. CONDITION DURATION DOES NOT APPLY TO PERCENT RELATIVE HUMIDITY. PERCENT RELATIVE HUMIDITY IN RELATION TO SPECIFIED TIME DURATIONS HAS NOT BEEN POSTULATED EXCEPT FOR HIGH ENERGY LINE BREAK TRANSIENTS.
3. INTEGRATED GAMMA RADIATION IS OVER 40 YEARS FOR NORMAL PLANT OPERATION, AND 180 DAYS FOR ACCIDENT CONDITIONS. FOR ACCIDENT CONDITIONS, RADIATION DOSES ARE BASED ON RELEASES INSIDE CONTAINMENT ONLY, UNLESS OTHERWISE NOTED.
4. TEMPERATURES SHOWN OCCUR DURING NORMAL PLANT OPERATING MODES. THESE NORMAL PLANT OPERATING MODES INCLUDED THE FOLLOWING:
 - a. NORMAL FULL POWER OPERATION
 - b. HOT STANDBY (OCCURS APPROXIMATELY 5.5 TIMES PER YEAR FOR 5 DAYS)
 - c. NORMAL SHUTDOWN (OCCURS APPROXIMATELY 2.7 TIMES PER YEAR FOR 10 DAYS)
 - d. CONTINUATION OF SHUTDOWN (OCCURS APPROXIMATELY 1 TIME PER YEAR FOR 30 DAYS)
 - e. TESTING (DURATIONS VARY)
 MINIMUM TEMPERATURES SHOWN ARE BASED ON SYSTEM OPERATION DURING THE ABOVE NORMAL PLANT OPERATING MODES. MINIMUM TEMPERATURES FOR THE 'PLANT OFF', OR TOTAL SHUTDOWN CONDITION ARE NOT SHOWN. DURING THE PLANT OFF CONDITION, (OR THOSE TIMES WHEN A SYSTEM OR EQUIPMENT IS NOT IN OPERATION WITHIN A ZONE), THE PLANT HEATING SYSTEMS ARE DESIGNED TO MAINTAIN A MINIMUM TEMPERATURE OF 60° F.
5. DELETED
6. MODERATE ENERGY PIPE BREAKS IN THIS ZONE COULD CAUSE LOCALIZED WETTING AND 100 PERCENT RELATIVE HUMIDITY FOR A DURATION OF 24 HOURS MAXIMUM. FLUID TEMPERATURES IN LOCAL MODERATE ENERGY LINES MAY EXCEED THE LISTED MAXIMUM AMBIENT TEMPERATURE FOR THIS ZONE AND SHOULD BE ADDRESSED IF THE EQUIPMENT TO BE QUALIFIED IS WETTED BY SPRAY FROM MODERATE ENERGY BREAKS.
7. LOSS OF HVAC IN THE CONTEXT OF THESE TABLES MEANS LOSS OF NON-SAFETY HVAC DUE TO A LOSS OF OFFSITE POWER(LOOP). THE TEMPERATURES SHOWN ARE BASED ON AN ASSUMED INITIAL TEMPERATURE EQUAL TO THE NORMAL PLANT OPERATING CONDITION MAXIMUM TEMPERATURE.
8. ACCIDENT TEMPERATURES SHOWN ARE BASED ON HEAT LOADS FROM SYSTEMS OPERATING IN THE DESIGNATED AREA WHICH ARE ESSENTIAL TO BRINGING THE PLANT TO SHUTDOWN CONDITION FOLLOWING AN ACCIDENT.
9. FOR QUALIFICATION OF EQUIPMENT TO AN ATWS EVENT, A RADIATION ENVIRONMENT EQUIVALENT TO 10% OF THE GIVEN LOCA DOSES MAY BE USED.
10. FOR TYPICAL NORMAL OPERATION RADIATION SOURCES REFER TO USAR SECTION 3.11.5.2.1.
11. DURING A SEISMIC EVENT, SLOSHING OF WATER WITHIN THE FUEL POOL WALLS WILL CAUSE LOCALIZED WETTING/SPRAY. THE PREDICTED SLOSH HEIGHT IS 8.74 FEET ABOVE THE NORMAL POOL WATER SURFACE OF 619'-6". FLOODING IN THE POOL AREA IS ANTICIPATED SINCE ONLY 1 FOOT OF FREEBOARD IS PROVIDED BY THE FUEL POOL WALLS, WITH TOP OF WALL ELEVATION AT 620'-6". SPRAY UP TO ELEVATION 628'-3" ABOVE THE POOL IS ANTICIPATED.
12. A RELATIVE HUMIDITY (RH) OF 20% IS THE AVERAGE MINIMUM RH GENERIC TO BWR6/MARK III PLANTS. THIS IS NOT A REQUIREMENT SINCE THE MINIMUM RH DOES NOT NEED TO BE CONTROLLED. THE RH MAY DROP BELOW 20% WITH NO ADVERSE AFFECT ON PLANT EQUIPMENT.

REFERENCE DRAWINGS: B-022-001

(REV. 22 10/2021)

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

ENVIRONMENTAL CONDITIONS
FOR INTERMEDIATE BUILDING
FIGURE 3.11-34
(DWG. B-022-0042-00000)

PLANT OPERATING CONDITION	SIGNIFICANT EVENT	CYCLES	CONDITION DURATION (1)	TEMPERATURE	RELATIVE HUMIDITY(2) • T FINAL (%)	PRESSURE	GAMMA RADIATION(3)		SUPPLEMENTARY DATA
				°F			MAX DOSE RATE RADS/HR	DOSE INTEGRATED RADS	
ZONE OG-B (MILD) GENERAL AREAS									
NORMAL MAX MIN AVERAGE	NORMAL FULL POWER OPERATION	1	8407 HRS 3503 HRS 338,390 HRS	97 60 81	90 20 50	ATMOSPHERE ATMOSPHERE ATMOSPHERE	1.0×10^{-1}	3.5×10^4	(4) (5) (6) (10)
ABNORMAL MAX MIN	LOSS OF HVAC	1	100 HRS	91	90 20	ATMOSPHERE ATMOSPHERE			(7)
ACCIDENT MAX AVERAGE (180 DAYS)	LOCA INSIDE CONTAINMENT	1		91 75	90 max 20 min	ATMOSPHERE ATMOSPHERE			(8) (9)
ACCIDENT	LOCA INSIDE CONTAINMENT	1	1 HR 6 HRS 24 HRS 30 DAYS 100 DAYS 180 DAYS				2.9×10^1	2.70×10^1 2.03×10^2 3.09×10^2 3.63×10^2 3.69×10^2 3.76×10^2	

NOTES:

1. TIME DURATION SHOWN IS FOR EACH OCCURRENCE OF THE LISTED SIGNIFICANT EVENT. FOR NORMAL FULL POWER OPERATION, HOURS REPRESENT THE TIME FOR WHICH THE MAXIMUM, MINIMUM, AND NORMAL WEIGHTED AVERAGE TEMPERATURE OCCUR OVER THE POSTULATED 40 YEAR PLANT LIFE. THE ONE CYCLE LISTED FOR THE NORMAL FULL POWER OPERATION REPRESENTS THIS 40 YEAR DURATION MINUS ANY SIGNIFICANT TRANSIENTS. THE SUM OF THE NORMAL AND THE ABNORMAL DURATIONS SHOULD THEREFORE EQUAL 40 YEARS (350,400 HOURS).
2. CONDITION DURATION DOES NOT APPLY TO PERCENT RELATIVE HUMIDITY. PERCENT RELATIVE HUMIDITY IN RELATION TO SPECIFIED TIME DURATIONS HAS NOT BEEN POSTULATED EXCEPT FOR HIGH ENERGY LINE BREAK TRANSIENTS.
3. INTEGRATED GAMMA RADIATION IS OVER 40 YEARS FOR NORMAL PLANT OPERATION, AND 180 DAYS FOR ACCIDENT CONDITIONS. FOR ACCIDENT CONDITIONS, RADIATION DOSES ARE BASED ON RELEASES INSIDE CONTAINMENT ONLY, UNLESS OTHERWISE NOTED.
4. TEMPERATURES SHOWN OCCUR DURING NORMAL PLANT OPERATING MODES. THESE NORMAL PLANT OPERATING MODES INCLUDED THE FOLLOWING:
 - a. NORMAL FULL POWER OPERATION
 - b. HOT STANDBY (OCCURS APPROXIMATELY 5.5 TIMES PER YEAR FOR 5 DAYS)
 - c. NORMAL SHUTDOWN (OCCURS APPROXIMATELY 2.7 TIMES PER YEAR FOR 10 DAYS)
 - d. CONTINUATION OF SHUTDOWN (OCCURS APPROXIMATELY 1 TIME PER YEAR FOR 30 DAYS)
 - e. TESTING (DURATIONS VARY)
5. FOR TYPICAL NORMAL OPERATION RADIATION SOURCES REFER TO USAR SECTION 3.11.5.2.1.
6. UNDER LOSS OF HVAC, THE ZONE MINIMUM TEMPERATURE COULD REACH 35° F ON A -5° F DAY. THE LOSS OF HVAC TEMPERATURE SHOWN UNDER ABNORMAL EVENT IS BASED ON AN ASSUMED INITIAL TEMPERATURE EQUAL TO THE NORMAL PLANT OPERATING CONDITION MAXIMUM TEMPERATURE.
7. LOSS OF HVAC IN THE CONTEXT OF THESE TABLES MEANS LOSS OF NON-SAFETY HVAC DUE TO A LOSS OF OFFSITE POWER(LOOP). THE TEMPERATURES SHOWN ARE BASED ON AN ASSUMED INITIAL TEMPERATURE EQUAL TO THE NORMAL PLANT OPERATING CONDITION MAXIMUM TEMPERATURE.
8. ACCIDENT TEMPERATURES SHOWN ARE BASED ON HEAT LOADS FROM SYSTEMS OPERATING IN THE DESIGNATED AREA WHICH ARE ESSENTIAL TO BRINGING THE PLANT TO SHUTDOWN CONDITION FOLLOWING AN ACCIDENT.
9. FOR QUALIFICATION OF EQUIPMENT TO AN ATWS EVENT, A RADIATION ENVIRONMENT EQUIVALENT TO 10% OF THE GIVEN LOCA DOSES MAY BE USED.
10. A RELATIVE HUMIDITY (RH) OF 20% IS THE AVERAGE MINIMUM RH GENERIC TO BWR6/MARK III PLANTS. THIS IS NOT A REQUIREMENT SINCE THE MINIMUM RH DOES NOT NEED TO BE CONTROLLED. THE RH MAY DROP BELOW 20% WITH NO ADVERSE AFFECT ON PLANT EQUIPMENT.

REFERENCE DRAWINGS: B-022-001

(REV. 19 10/2015)

<p>PERRY NUCLEAR POWER PLANT 10 CENTER RD., PERRY, OHIO 44081</p>
<p>ENVIRONMENTAL CONDITIONS FOR GENERAL AREAS OF THE OFFGAS BUILDING FIGURE 3.11-35 (DWG. B-022-0046-00000)</p>

PLANT OPERATING CONDITION	SIGNIFICANT EVENT	CYCLES	CONDITION DURATION (1)	TEMPERATURE	RELATIVE HUMIDITY(2) • T FINAL (%)	PRESSURE	GAMMA RADIATION(3)		SUPPLEMENTARY DATA
				*F			MAX DOSE RATE RADS/HR	DOSE INTEGRATED RADS	
ZONE OU-T (MILD) OUTSIDE - AROUND CONDENSATE STORAGE TANK									
NORMAL MAX MIN AVERAGE	NONE			104 -10 58	100 20	ATMOSPHERE ATMOSPHERE ATMOSPHERE		7.4x10 ⁻³	(5) (6)
ACCIDENT	LOCA INSIDE CONTAINMENT	1						7.78x10 ⁻³	
ZONE HB-1 (MILD) HEATER BAY FAN ROOMS									
NORMAL MAX MIN AVERAGE	NORMAL FULL POWER OPERATION	1	8410 HRS 3504 HRS 338,486 HRS	118 60 93	90 20 50	ATMOSPHERE ATMOSPHERE ATMOSPHERE	2.5x10 ⁻³	8.77x10 ⁻²	(4) (5) (6)
ACCIDENT	LOCA INSIDE CONTAINMENT	1	0 HR 1 HR 180 DAYS	118 122 122	90 max 20 max	ATMOSPHERE ATMOSPHERE ATMOSPHERE			
ACCIDENT	LOCA INSIDE CONTAINMENT	1	1 HR 6 HRS 24 HRS 30 DAYS 100 DAYS 180 DAYS				2.9x10 ⁻¹	2.70x10 ⁻¹ 2.03x10 ⁻² 3.09x10 ⁻² 3.63x10 ⁻² 3.69x10 ⁻² 3.76x10 ⁻²	

NOTES:

1. TIME DURATION SHOWN IS FOR EACH OCCURRENCE OF THE LISTED SIGNIFICANT EVENT. FOR NORMAL FULL POWER OPERATION, HOURS REPRESENT THE TIME FOR WHICH THE MAXIMUM, MINIMUM, AND NORMAL WEIGHTED AVERAGE TEMPERATURE OCCUR OVER THE POSTULATED 40 YEAR PLANT LIFE. THE ONE CYCLE LISTED FOR THE NORMAL FULL POWER OPERATION REPRESENTS THIS 40 YEAR DURATION MINUS ANY SIGNIFICANT TRANSIENTS. THE SUM OF THE NORMAL AND THE ABNORMAL DURATIONS SHOULD THEREFORE EQUAL 40 YEARS (350,400 HOURS).
2. CONDITION DURATION DOES NOT APPLY TO PERCENT RELATIVE HUMIDITY. PERCENT RELATIVE HUMIDITY IN RELATION TO SPECIFIED TIME DURATIONS HAS NOT BEEN POSTULATED EXCEPT FOR HIGH ENERGY LINE BREAK TRANSIENTS.
3. INTEGRATED GAMMA RADIATION IS OVER 40 YEARS FOR NORMAL PLANT OPERATION, AND 180 DAYS FOR ACCIDENT CONDITIONS. FOR ACCIDENT CONDITIONS, RADIATION DOSES ARE BASED ON RELEASES INSIDE CONTAINMENT ONLY, UNLESS OTHERWISE NOTED.
4. TEMPERATURES SHOWN OCCUR DURING NORMAL PLANT OPERATING MODES. THESE NORMAL PLANT OPERATING MODES INCLUDED THE FOLLOWING:
 - a. NORMAL FULL POWER OPERATION
 - b. HOT STANDBY (OCCURS APPROXIMATELY 5.5 TIMES PER YEAR FOR 5 DAYS)
 - c. NORMAL SHUTDOWN (OCCURS APPROXIMATELY 2.7 TIMES PER YEAR FOR 10 DAYS)
 - d. CONTINUATION OF SHUTDOWN (OCCURS APPROXIMATELY 1 TIME PER YEAR FOR 30 DAYS)
 - e. TESTING (DURATIONS VARY)
 MINIMUM TEMPERATURES SHOWN ARE BASED ON SYSTEM OPERATION DURING THE ABOVE NORMAL PLANT OPERATING MODES. MINIMUM TEMPERATURES FOR THE 'PLANT OFF', OR TOTAL SHUTDOWN CONDITION ARE NOT SHOWN. DURING THE PLANT OFF CONDITION, OR THOSE TIMES WHEN A SYSTEM OR EQUIPMENT IS NOT IN OPERATION WITHIN A ZONE, THE PLANT HEATING SYSTEMS ARE DESIGNED TO MAINTAIN A MINIMUM TEMPERATURE OF 60° F.
5. FOR TYPICAL NORMAL OPERATION RADIATION SOURCES REFER TO USAR SECTION 3.11.5.2.1.
6. A RELATIVE HUMIDITY (RH) OF 20% IS THE AVERAGE MINIMUM RH GENERIC TO BWR6/MARK III PLANTS. THIS IS NOT A REQUIREMENT SINCE THE MINIMUM RH DOES NOT NEED TO BE CONTROLLED. THE RH MAY DROP BELOW 20% WITH NO ADVERSE AFFECT ON PLANT EQUIPMENT.

REFERENCE DRAWINGS: B-022-001

(REV. 19 10/2015)

PERRY NUCLEAR POWER PLANT
 10 CENTER RD., PERRY, OHIO 44081

 ENVIRONMENTAL CONDITIONS
 HEATER BAY FAN ROOM & OUTSIDE
 AROUND CONDENSATE STORAGE TANK
 FIGURE 3.11-36
 (DWG. B-022-0047-00000)

PLANT OPERATING CONDITION	SIGNIFICANT EVENT	CYCLES	CONDITION DURATION (1)	TEMPERATURE	RELATIVE HUMIDITY(2) @ T FINAL (%)	PRESSURE	GAMMA RADIATION(3)		SUPPLEMENTARY DATA
				*F			MAX DOSE RATE RADS/HR	DOSE INTEGRATED RADS	
ZONE TB-1 (HARSH) BELOW TURBINE OPERATING FLOOR									
NORMAL MAX MIN AVERAGE	NORMAL FULL POWER OPERATION	1	8407 HRS 3503 HRS 338,390 HRS	130°F 113°F 122°F	90 20 50	ATMOSPHERE ATMOSPHERE ATMOSPHERE	1.07x10 ¹	3.0x10 ⁶	(4) (8) (12)
ABNORMAL MAX MIN	LOSS OF HVAC	1	100 HRS	168	90 20	ATMOSPHERE ATMOSPHERE			(5) (6)
ACCIDENT	MAIN STEAM LINE BREAK	1	0.0 SEC 1.0 SEC 6.2 SEC 1.5 HRS 2.0 HRS 2.5 HRS 3.5 HRS 5.0 HRS 9.0 HRS 12.0 HRS 24 HRS 48 HRS 180 DAYS	130 310 310 310 212 160 150 140 130 125 110 98	90 100 100 100 100 100 100 100 100 100 90 90 90	0.0 PSIG 7.0 PSIG 1.0 PSIG 1.0 PSIG 0.0 PSIG 0.0 PSIG 0.0 PSIG 0.0 PSIG 0.0 PSIG 0.0 PSIG 0.0 PSIG 0.0 PSIG 0.0 PSIG			ENVIRONMENTAL MEDIUM AIR STEAM STEAM STEAM STEAM STEAM STEAM STEAM STEAM AIR AIR AIR
ACCIDENT MAX AVERAGE (180 DAYS)	LOCA INSIDE CONTAINMENT	1		168 167	90 max 20 min	ATMOSPHERE ATMOSPHERE			
ACCIDENT	LOCA INSIDE CONTAINMENT	1	1 HR 6 HRS 24 HRS 30 DAYS 100 DAYS 180 DAYS				2.9x10 ¹	2.70x10 ¹ 2.03x10 ² 3.09x10 ² 3.63x10 ² 3.69x10 ² 3.76x10 ²	(7)
ZONE TB-2 (HARSH) HEATER BAY (EAST SIDE)									
NORMAL MAX MIN AVERAGE	NORMAL FULL POWER OPERATION	1	8407 HRS 3503 HRS 338,390 HRS	124 60 103	90 20 50	ATMOSPHERE ATMOSPHERE ATMOSPHERE	2.5x10 ⁻³	8.8x10 ²	(4) (8) (12)
ABNORMAL MAX MIN	LOSS OF HVAC	1	100 HRS	157	90 20	ATMOSPHERE ATMOSPHERE ATMOSPHERE			(9) (6)
ACCIDENT	MAIN STEAM LINE BREAK	1	0.0 SEC 1.0 SEC 3.0 SEC 6.2 SEC 7 DAYS	124 212 212 212 212	90 100 100 100 100	0.0 PSIG 1.6 PSIG 1.6 PSIG 0.5 PSIG 0.5 PSIG			ENVIRONMENTAL MEDIUM AIR STEAM STEAM STEAM STEAM
ACCIDENT MAX AVERAGE (180 DAYS)	LOCA INSIDE CONTAINMENT	1		157 144	90 max 20 min	ATMOSPHERE ATMOSPHERE			
ACCIDENT	LOCA INSIDE CONTAINMENT	1	1 HR 6 HRS 24 HRS 30 DAYS 100 DAYS 180 DAYS				2.9x10 ¹	2.70x10 ¹ 2.03x10 ² 3.09x10 ² 3.63x10 ² 3.69x10 ² 3.76x10 ²	(7)
ZONE TB-2 (HARSH) HEATER BAY (WEST SIDE)									
NORMAL MAX MIN AVERAGE	NORMAL FULL POWER OPERATION	1	8407 HRS 3503 HRS 338,390 HRS	115 65 92	90 20 50	ATMOSPHERE ATMOSPHERE ATMOSPHERE	2.5x10 ⁻³	8.8x10 ²	(4) (8) (12)

ZONE TB-2 CONTINUED ON DWG. B-022-051

NOTES:

1. TIME DURATION SHOWN IS FOR EACH OCCURRENCE OF THE LISTED SIGNIFICANT EVENT. FOR NORMAL FULL POWER OPERATION, HOURS REPRESENT THE TIME FOR WHICH THE MAXIMUM, MINIMUM, AND NORMAL WEIGHTED AVERAGE TEMPERATURE OCCUR OVER THE POSTULATED 40 YEAR PLANT LIFE. THE ONE CYCLE LISTED FOR THE NORMAL FULL POWER OPERATION REPRESENTS THIS 40 YEAR DURATION MINUS ANY SIGNIFICANT TRANSIENTS. THE SUM OF THE NORMAL AND THE ABNORMAL DURATIONS SHOULD THEREFORE EQUAL 40 YEARS (350,400 HOURS).
2. CONDITION DURATION DOES NOT APPLY TO PERCENT RELATIVE HUMIDITY. PERCENT RELATIVE HUMIDITY IN RELATION TO SPECIFIED TIME DURATIONS HAS NOT BEEN POSTULATED EXCEPT FOR HIGH ENERGY LINE BREAK TRANSIENTS.
3. INTEGRATED GAMMA RADIATION IS OVER 40 YEARS FOR NORMAL PLANT OPERATION, AND 180 DAYS FOR ACCIDENT CONDITIONS. FOR ACCIDENT CONDITIONS, RADIATION DOSES ARE BASED ON RELEASES INSIDE CONTAINMENT ONLY, UNLESS OTHERWISE NOTED.
4. TEMPERATURES SHOWN OCCUR DURING NORMAL PLANT OPERATING MODES. THESE NORMAL PLANT OPERATING MODES INCLUDED THE FOLLOWING:
 - a. NORMAL FULL POWER OPERATION
 - b. HOT STANDBY (OCCURS APPROXIMATELY 5.5 TIMES PER YEAR FOR 5 DAYS)
 - c. NORMAL SHUTDOWN (OCCURS APPROXIMATELY 2.7 TIMES PER YEAR FOR 10 DAYS)
 - d. CONTINUATION OF SHUTDOWN (OCCURS APPROXIMATELY 1 TIME PER YEAR FOR 30 DAYS)
 - e. TESTING (DURATIONS VARY)
 MINIMUM TEMPERATURES SHOWN ARE BASED ON SYSTEM OPERATION DURING THE ABOVE NORMAL PLANT OPERATING MODES. MINIMUM TEMPERATURES FOR THE 'PLANT OFF', OR TOTAL SHUTDOWN CONDITION ARE NOT SHOWN. DURING THE PLANT OFF CONDITION, (OR THOSE TIMES WHEN A SYSTEM OR EQUIPMENT IS NOT IN OPERATION WITHIN A ZONE), THE PLANT HEATING SYSTEMS ARE DESIGNED TO MAINTAIN A MINIMUM TEMPERATURE OF 60° F.
5. UNDER LOSS OF HVAC, THE ZONE MINIMUM TEMPERATURE COULD REACH 35° F ON A -5° F DAY. THE LOSS OF HVAC TEMPERATURE SHOWN UNDER THE ABNORMAL EVENT IS BASED ON A INITIAL TEMPERATURE EQUAL TO THE NORMAL PLANT OPERATING CONDITION MAXIMUM TEMPERATURE.
6. LOSS OF HVAC IN THE CONTEXT OF THESE TABLES MEANS LOSS OF NON-SAFETY HVAC DUE TO A LOSS OF OFFSITE POWER(LOOP). THE TEMPERATURES SHOWN ARE BASED ON AN ASSUMED INITIAL TEMPERATURE EQUAL TO THE NORMAL PLANT OPERATING CONDITION MAXIMUM TEMPERATURE.
7. FOR QUALIFICATION OF EQUIPMENT TO AN ATWS EVENT, A RADIATION ENVIRONMENT EQUIVALENT TO 10% OF THE GIVEN LOCA DOSES MAY BE USED.
8. FOR TYPICAL NORMAL OPERATION RADIATION SOURCES REFER TO USAR SECTION 3.11.5.2.1.
9. MODERATE ENERGY PIPE BREAKS IN THIS ZONE COULD CAUSE LOCALIZED WETTING AND 100 PERCENT RELATIVE HUMIDITY FOR A DURATION OF 24 HOURS MAXIMUM. FLUID TEMPERATURES IN LOCAL MODERATE ENERGY LINES MAY EXCEED THE LISTED MAXIMUM AMBIENT TEMPERATURE FOR THIS ZONE AND SHOULD BE ADDRESSED IF THE EQUIPMENT TO BE QUALIFIED IS WETTED BY SPRAY FROM MODERATE ENERGY BREAKS. FOR MODERATE ENERGY PIPE BREAK ANALYSIS SEE SECTION 3.6.0 OF THE FSAR.
10. ENVIRONMENT SHOWN DOES NOT INCLUDE STEAM LINE BREAKS WHICH COULD OCCUR IN OR ADJACENT TO THIS ZONE.
11. ENVIRONMENTAL CONDITIONS SHOWN FOR MAIN STEAM LINE BREAK ARE THE SAME AS FOR TB-2 WHICH IS PART OF THE SAME FLOOR. THERE ARE NO INTERMEDIATE WALLS AND THIS IS CONSIDERED THE WORST POSSIBLE CONDITION.
12. A RELATIVE HUMIDITY (RH) OF 20% IS THE AVERAGE MINIMUM RH GENERIC TO BWR6/MARK III PLANTS. THIS IS NOT A REQUIREMENT SINCE THE MINIMUM RH DOES NOT NEED TO BE CONTROLLED. THE RH MAY DROP BELOW 20% WITH NO ADVERSE AFFECT ON PLANT EQUIPMENT.

REFERENCE DRAWINGS: B-022-001 B-022-051

(REV. 20 10/2017)

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

ENVIRONMENTAL CONDITIONS
FOR TURBINE BUILDING
FIGURE 3.11-37
(DWG. B-022-0050-00000)

PLANT OPERATING CONDITION	SIGNIFICANT EVENT	CYCLES	CONDITION DURATION (1)	TEMPERATURE	RELATIVE HUMIDITY(2) @ T FINAL (%)	PRESSURE	GAMMA RADIATION(3)		SUPPLEMENTARY DATA
				*F			MAX DOSE RATE RADS/HR	DOSE INTEGRATED RADS	
ZONE TB-2 (HARSH) HEATER BAY (WEST SIDE, CONTINUED FROM B-022-050)									
ABNORMAL MAX MIN	LOSS OF HVAC	1	100 HRS	127	90 20	ATMOSPHERE ATMOSPHERE			(9) (6)
ACCIDENT MAX AVERAGE (180 DAYS)	LOCA INSIDE CONTAINMENT	1		127 109	90 max 20 min	ATMOSPHERE ATMOSPHERE			
ACCIDENT	MAIN STEAM LINE BREAK	1	0.0 SEC 1.0 SEC 3.0 SEC 6.2 SEC 7 DAYS	124 212 212 212 212	90 100 100 100 100	0.0 PSIG 1.6 PSIG 1.6 PSIG 0.5 PSIG 0.5 PSIG			ENVIRONMENTAL MEDIUM AIR STEAM STEAM STEAM STEAM
ACCIDENT	LOCA INSIDE CONTAINMENT	1	1 HR 6 HRS 24 HRS 30 DAYS 100 DAYS 180 DAYS				2.9x10 ¹	2.70x10 ¹ 2.03x10 ² 3.09x10 ² 3.63x10 ² 3.69x10 ² 3.76x10 ²	(7)
ZONE TB-3 (HARSH) TURBINE BUILDING WEST END EL. 620'-6"									
NORMAL MAX MIN AVERAGE	NORMAL FULL POWER OPERATION	1	8407 HRS 3504 HRS 338,390 HRS	109 60 105	90 20 50	ATMOSPHERE ATMOSPHERE ATMOSPHERE	5x10 ⁻⁴	1.75x10 ²	(4) (8) (12)
ABNORMAL	LOSS OF HVAC	1	100 HRS	122	90 20	ATMOSPHERE ATMOSPHERE			(10)
ACCIDENT MAX AVERAGE (180 DAYS)	LOCA INSIDE CONTAINMENT	1		122 109	90 max 20 min	ATMOSPHERE ATMOSPHERE			
ACCIDENT	MAIN STEAM LINE BREAK	1	0.0 SEC 1.0 SEC 3.0 SEC 6.2 SEC 7 DAYS	124 212 212 212 212	90 100 100 100 100	0.0 PSIG 1.6 PSIG 1.6 PSIG 0.5 PSIG 0.5 PSIG			ENVIRONMENTAL MEDIUM AIR (1) STEAM STEAM STEAM STEAM
ACCIDENT	LOCA INSIDE CONTAINMENT	1	1 HR 6 HRS 24 HRS 30 DAYS 100 DAYS 180 DAYS				2.9x10 ¹	2.70x10 ¹ 2.03x10 ² 3.09x10 ² 3.63x10 ² 3.69x10 ² 3.76x10 ²	(7)

NOTES:


1. TIME DURATION SHOWN IS FOR EACH OCCURRENCE OF THE LISTED SIGNIFICANT EVENT, FOR NORMAL FULL POWER OPERATION, HOURS REPRESENT THE TIME FOR WHICH THE MAXIMUM, MINIMUM, AND NORMAL WEIGHTED AVERAGE TEMPERATURE OCCUR OVER THE POSTULATED 40 YEAR PLANT LIFE. THE ONE CYCLE LISTED FOR THE NORMAL FULL POWER OPERATION REPRESENTS THIS 40 YEAR DURATION MINUS ANY SIGNIFICANT TRANSIENTS. THE SUM OF THE NORMAL AND THE ABNORMAL DURATIONS SHOULD THEREFORE EQUAL 40 YEARS (350,400 HOURS).
2. CONDITION DURATION DOES NOT APPLY TO PERCENT RELATIVE HUMIDITY. PERCENT RELATIVE HUMIDITY IN RELATION TO SPECIFIED TIME DURATIONS HAS NOT BEEN POSTULATED EXCEPT FOR HIGH ENERGY LINE BREAK TRANSIENTS.
3. INTEGRATED GAMMA RADIATION IS OVER 40 YEARS FOR NORMAL PLANT OPERATION, AND 180 DAYS FOR ACCIDENT CONDITIONS. FOR ACCIDENT CONDITIONS, RADIATION DOSES ARE BASED ON RELEASES INSIDE CONTAINMENT ONLY, UNLESS OTHERWISE NOTED.
4. TEMPERATURES SHOWN OCCUR DURING NORMAL PLANT OPERATING MODES. THESE NORMAL PLANT OPERATING MODES INCLUDED THE FOLLOWING:
 - a. NORMAL FULL POWER OPERATION
 - b. HOT STANDBY (OCCURS APPROXIMATELY 5.5 TIMES PER YEAR FOR 5 DAYS)
 - c. NORMAL SHUTDOWN (OCCURS APPROXIMATELY 2.7 TIMES PER YEAR FOR 10 DAYS)
 - d. CONTINUATION OF SHUTDOWN (OCCURS APPROXIMATELY 1 TIME PER YEAR FOR 30 DAYS)
 - e. TESTING (DURATIONS VARY)
 MINIMUM TEMPERATURES SHOWN ARE BASED ON SYSTEM OPERATION DURING THE ABOVE NORMAL PLANT OPERATING MODES. MINIMUM TEMPERATURES FOR THE "PLANT OFF" OR TOTAL SHUTDOWN CONDITION ARE NOT SHOWN. DURING THE PLANT OFF CONDITION, (OR THOSE TIMES WHEN A SYSTEM OR EQUIPMENT IS NOT IN OPERATION WITHIN A ZONE), THE PLANT HEATING SYSTEMS ARE DESIGNED TO MAINTAIN A MINIMUM TEMPERATURE OF 60° F.
5. UNDER LOSS OF HVAC, THE ZONE MINIMUM TEMPERATURE COULD REACH 35° F ON A -5° F DAY. THE LOSS OF HVAC TEMPERATURE SHOWN UNDER THE ABNORMAL EVENT IS BASED ON A INITIAL TEMPERATURE EQUAL TO THE NORMAL PLANT OPERATING CONDITION MAXIMUM TEMPERATURE.
6. LOSS OF HVAC IN THE CONTEXT OF THESE TABLES MEANS LOSS OF NON-SAFETY HVAC DUE TO A LOSS OF OFFSITE POWER(LOOP). THE TEMPERATURES SHOWN ARE BASED ON AN ASSUMED INITIAL TEMPERATURE EQUAL TO THE NORMAL PLANT OPERATING CONDITION MAXIMUM TEMPERATURE.
7. FOR QUALIFICATION OF EQUIPMENT TO AN ATWS EVENT, A RADIATION ENVIRONMENT EQUIVALENT TO 10% OF THE GIVEN LOCA DOSES MAY BE USED.
8. FOR TYPICAL NORMAL OPERATION RADIATION SOURCES REFER TO USAR SECTION 3.11.5.2.1.
9. MODERATE ENERGY PIPE BREAKS IN THIS ZONE COULD CAUSE LOCALIZED WETTING AND 100 PERCENT RELATIVE HUMIDITY FOR A DURATION OF 24 HOURS MAXIMUM. FLUID TEMPERATURES IN LOCAL MODERATE ENERGY LINES MAY EXCEED THE LISTED MAXIMUM AMBIENT TEMPERATURE FOR THIS ZONE AND SHOULD BE ADDRESSED IF THE EQUIPMENT TO BE QUALIFIED IS WETTED BY SPRAY FROM MODERATE ENERGY BREAKS. FOR MODERATE ENERGY PIPE BREAK ANALYSIS SEE SECTION 3.6.0 OF THE FSAR.
10. ENVIRONMENT SHOWN DOES NOT INCLUDE STEAM LINE BREAKS WHICH COULD OCCUR IN OR ADJACENT TO THIS ZONE.
11. ENVIRONMENTAL CONDITIONS SHOWN FOR MAIN STEAM LINE BREAK ARE THE SAME AS FOR TB-2 WHICH IS PART OF THE SAME FLOOR. THERE ARE NO INTERMEDIATE WALLS AND THIS IS CONSIDERED THE WORST POSSIBLE CONDITION.
12. A RELATIVE HUMIDITY (RH) OF 20% IS THE AVERAGE MINIMUM RH GENERIC TO BWR6/MARK III PLANTS. THIS IS NOT A REQUIREMENT SINCE THE MINIMUM RH DOES NOT NEED TO BE CONTROLLED. THE RH MAY DROP BELOW 20% WITH NO ADVERSE AFFECT ON PLANT EQUIPMENT.

REFERENCE DRAWINGS: B-022-001
B-022-050

(REV. 20 10/2017)

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

ENVIRONMENTAL CONDITIONS
FOR TURBINE BUILDING
FIGURE 3.11-38
(DWG. B-022-0051-00000)



DW-1 OUTSIDE RPV SHIELDWALL, NOT AT CORE MIDPLANE

DW-2 OUTSIDE RPV SHIELDWALL, AT CORE MIDPLANE EXTENDING TO A RADIUS OF 24 FT. FROM RPV CENTERLINE, TO A HEIGHT 22 FT. ABOVE FUEL CORE MIDPLANE AND 16 FT. BELOW FUEL CORE MIDPLANE AND INCLUDING MAJOR RPV SHIELDWALL PENETRATIONS.

DW-3 AREA UNDER RPV INSIDE PEDESTAL

DW-4 WITHIN DRYWELL HEAD

DW-5 OUTSIDE RPV SHIRT

CT-7, CT-8 AREAS SUBJECT TO CONTAINMENT SPRAY

(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Drywell and Containment
Environmental Zones

Figure 3.11-39
(Dwg. B-022-068)

Removed in Accordance with RIS 2015-17

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

ENVIRONMENTAL ZONE MAP PLAN A
ABOVE EL. 568'-6" EL. 574'-10", EL. 577'-6"
& EL. 580'-6" PLANT COMPLEX
FIGURE 3.11-40
(DWG. E-022-0060-00000)

Removed in Accordance with RIS 2015-17

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

ENVIRONMENTAL ZONE MAP,
PLAN B ABOVE EL 593-6, 599-0,
600-6, 602-6 & 605-6 PLANT COMPLEX
FIGURE 3.11-41
(DWG. E-022-0061-00000)

Removed in Accordance with RIS 2015-17

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

ENVIRONMENTAL ZONE MAP PLAN "C"
ABOVE ELEVS. 620'-6", 623'-6", AND
624'-6", PLANT COMPLEX
FIGURE 3.11-42
(DWG. E-022-0062-00000)

Removed in Accordance with RIS 2015-17

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

ENVIRONMENTAL ZONE MAP PLAN "D"
ABOVE ELEVS. 638'-6", 642'-0"
AND 647'-6", PLANT COMPLEX
FIGURE 3.11-43
(DWG. E-022-0063-00000)

Removed in Accordance with RIS 2015-17

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

ENVIRONMENTAL ZONE MAP
PLAN "E" ABOVE ELEVS.
652'-0" AND 654'-6", PLANT COMPLEX
FIGURE 3.11-44
(DWG. E-022-0064-00000)

Removed in Accordance with RIS 2015-17

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

ENVIRONMENTAL ZONE MAP PLAN
"F" ABOVE ELEVS. 664'-6",
665'-0" AND 670'-6" PLANT COMPLEX
FIGURE 3.11-45
(DWG. E-022-0065-00000)

Removed in Accordance with RIS 2015-17


PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

ENVIRONMENTAL ZONE MAP
PLAN "G" ABOVE EL. 689'-6"
PLANT COMPLEX
FIGURE 3.11-46
(DWG. 022-0066-00000)

Removed in Accordance with RIS 2015-17

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

ENVIRONMENTAL ZONE MAP EMERGENCY
SERVICE WATER PUMPHOUSE
PLANS AND ELEVATIONS
FIGURE 3.11-47
(DWG. E-022-0067-00000)




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Reactor Building Model for
Hydrodynamic Analysis
Soil Elements

Figure 3A-1




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Containment Vessel Model for
Hydrodynamic Analysis

Figure 3A-2




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

RPV Horizontal Model

Figure 3A-3




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

RPV Vertical Model

Figure 3A-4



<i>f</i>	4	8	12	16	20	24	28	40	50	CPS
<i>L_s</i>	1225	613	408	306	245	204	175	123	98	FT
<i>L_c</i>	2019	1010	673	504	404	336	289	203	162	FT

(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Chagrin Shale Dynamic
Characteristics

Figure 3A-5

See Figure 3A-7




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Reactor Building Model for
Hydrodynamic Analysis

Figure 3A-6




(Rev. 12 1/03)

PERRY NUCLEAR POWER PLANT

Reactor Building Model for
Hydrodynamic Analysis

Figure 3A-7




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Plan at Elevation 599'-9"

Figure 3B-1




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Section 1-1 Through Sump

Figure 3B-2




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Section 2-2 Through TIP Platform

Figure 3B-3




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Plan at Elevation 620'-6"

Figure 3B-4




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Suppression Pool Cross Section

Figure 3B-5




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Condensation Oscillation Load
 Spatial Distribution on the
 Drywell Wall Containment Wall
 and Basemat

Figure 3B-6




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Suppression Pool Chugging
Normalized Peak Underpressure
Attenuation

Figure 3B-7




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Suppression Pool Chugging
Normalized Spike Attenuation

Figure 3B-8




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Suppression Pool Chugging Spike
Duration d as a Function of
Location in the Pool

Figure 3B-9




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Suppression Pool Chugging
 Normalized Peak Post-Chug
 Oscillations

Figure 3B-10




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Suppression Pool Chugging
 Normalized Mean Underpressure
 Attenuation

Figure 3B-11





(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Suppression Pool Chugging
 Normalized Post-Chug Oscillation
 Attenuation

Figure 3B-12



SECTION A-A


(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Quencher Arrangement Elevation
Perry Nuclear Power Plant

Figure 3BA-1




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Typical Quencher Plan View F

Figure 3BA-2



LEGEND: ADS =

(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Safety/Relief Valve
Discharge Locations

Figure 3BA-3

- NOTES
1. EQUAL DISTRIBUTION OF DISCHARGERS IN THE SUPPRESSION POOL IS REQUIRED FOR PROPER SUPPRESSION FUNCTION.
 2. NON-VERTICAL LENGTHS OF DISCHARGE PIPE ARE LOCATED AS HIGH ABOVE THE SUPPRESSION POOL AS IS PRACTICAL.
 3. ALL DISCHARGE PIPES TOWARD THE SUPPRESSION POOL ARE LOCATED AS CLOSE TO THE MAIN WALL AS IS PRACTICAL.
 4. ALL DISCHARGE PIPES TOWARD THE SUPPRESSION POOL ARE LOCATED AS CLOSE TO THE SAFETY RELIEF VALVE AS PRACTICAL.
 5. VXX IDENTIFIES RELATIVE VALVE LOCATION ON MAIN STEAM LINES.




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Safety/Relief Valve Discharge
Piping Arrangement

Figure 3BA-4




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

One Safety/Relief Valve Normalized
Wall Pressure at 4.5°

Figure 3BA-5




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Two Safety/Relief Valves Normalized
Wall Pressure at 355.5°

Figure 3BA-6




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Eight Safety/Relief Valves Normalized
Wall Pressure at
346.5° Azimuth

Figure 3BA-7




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Eight Safety/Relief Valves
Reference Point 4
(Circumferential Distribution)

Figure 3BA-8




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Eight Safety/Relief Valves
Reference Point 10
(Circumferential Distribution)

Figure 3BA-9




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Nineteen Safety/Relief Valves
 Normalized Wall Pressure
 At 130.5° Azimuth

Figure 3BA-10




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Suppression Pool Chugging
 Normalized Mean Underpressure
 Attenuation

Figure 3BA-11



(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Nineteen Safety/Relief Valves
Reference Point 10
(Circumferential Distribution)

Figure 3BA-12

INITIAL POOL TEMP.	95°F
TOTAL POOL MASS	7.12×10^6 LB
POOL DEPTH	18.5 FT.
TOTAL ENERGY RELEASE	4.0×10^8 BTU
FINAL BULK POOL TEMP.	146°F



(Rev. 12 1/03)

PERRY NUCLEAR POWER PLANT

Suppression Pool Temperature
Profile for Large Breaks
(DBA)

Figure 3BI-1