


- EXPLANATION**
- FAULT ZONE WITH PLASTIC CLAY SOFTENING WITH ASSOCIATE OF RANDOMLY ORIENTED SILTSTONE AND SHALE FRAGMENTS.
 - FAULT ZONE STRONGER AND THICK. ARROWS INDICATE DIRECTION OF RELATIVE MOVEMENT.
 - JOINT/FRACTURE PATTERN.
 - SILTSTONE.
 - SILTSTONE LAMINA, DAMAGED WHERE BEDDING PLANE CONTINUOUSLY MAPPED BUT SILTSTONE LITHOLOGY FINISHED OUT.
 - SHALE.
 - SHALE LAMINA AS LABELED.
 - IRONSTONE CONCRETIONS.
 - MICRO-CRACK SAMPLE LOCATION NUMBER GIVEN.




(Rev. 12 1/03)

PERRY NUCLEAR POWER PLANT


Intake Tunnel Fault Map

Figure 2.5-50



EXPLANATION


- FAULT ZONE ZONE, BRAY, PLASTIC CLAY-SILTSTONE MATRIX WITH AGGREGATE OF RANDOMLY ORIENTED SILTSTONE AND SHALE FRAGMENTS.
- FAULT ZONE ZONE, SILTSTONE MATRIX WITH AGGREGATE OF RANDOMLY ORIENTED SILTSTONE AND SHALE FRAGMENTS.
- JOINT/FRACTURE PATTERN.
- SILTSTONE.
- SILTSTONE LAMINA, DASHED WHERE BEDDING PLANE CONTINUOUSLY MAPPED BUT SILTSTONE LITHOLOGY PINCHED OUT.
- SHALE.
- SHALE LAMINA, AS LABELED.
- CONCRETE.
- MICRO-GRAIN SAMPLE LOCATION NUMBER GIVEN.



(Rev. 12/1/63)


PERRY NUCLEAR POWER PLANT

Discharge Tunnel Fault Map
Figure 2.5-51



EXPLANATION

- FAULT SOUSE ZONE. GRAY, PLASTIC CLAY GOUGE MATRIX WITH AGGREGATE OF RANDOMLY ORIENTED SILTSTONE AND SHALE FRAGMENTS.
- FAULT SOUSE STRINGER 4-6 FT. THICK. ARROWS INDICATE DIRECTION OF RELATIVE MOVEMENT.
- JOINT/FRACTURE PATTERN.
- SILTSTONE.
- SILTSTONE LAMINA, DASHED WHERE BEDDING PLANE CONTINUOUSLY MAPPED BUT SILTSTONE LITHOLOGY FINISHED OUT.
- SHALE.
- SHALE LAMINA, AS LABELED.
- IRONSTONE CONCRETIONS.
- MICRO-CRACK SAMPLE LOCATION NUMBER GIVEN.





(Rev. 12-1-63)

PERRY NUCLEAR POWER PLANT

Discharge Tunnel Fracture Zone Map


Figure 2.5-52



LEGEND

- ⊙ GAS TESTING
- TOP OF BEDROCK PROBE LOCATIONS
- BORING LOCATIONS
- OBSERVATION WELLS
- ⊙ PERMEABILITY TEST BORINGS
- ⊙ DEEP WELL (PUMP WELL)
- ⊙ SPECIAL TESTING TEST BORINGS (PRESSUREMETER)
- ⊙ PERZOMETER TEST BORINGS
- ⊙ SEISMIC SURVEY TEST BORINGS
- ⊙ RECHARGE TEST BORINGS
- ▲ TEST CHASSISONS
- ⊙ T-X SERIES-FAULT STUDY
- ⊙ MONITORING WELLS
- TEST PITS

- NOTES:
1. THE ELEVATION OF THE SURFACE OF THE WATER DURING THE PROBE READINGS WAS EL. 574.0 (U.S.S. DATUM).
 2. THE ELEVATIONS USED ON THIS DRAWING REFERENCED TO THE U.S.C.S. DATUM.
 3. BORING LOCATION 1-18 NOT SHOWN - OFF DRAWING (N. 777,769; E. 2,368,517)
1. REACTOR COORDINATES:
- | | GRID 6813 | PLANT GRID |
|--------|------------------|------------|
| UNIT 1 | N. 780,545 | N. 49,468 |
| | E. 2,369,815 | E. 9,510 |
| UNIT 2 | N. 780,546,725 | N. 49,255 |
| | E. 2,369,941,166 | E. 9,510 |









(Rev. 12 1/03)

PERRY NUCLEAR POWER PLANT

Site Exploration Plot Plan
Figure 2.5-53


LEGEND

-  SHALE
-  LOWER TILL
-  UPPER TILL / LACUSTRINE



NOTE:
 EACH COOLING TOWER RESTS ON
 498 PILES. THE PILES ARE SEATED
 IN SHALE.



(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Plant Structures Foundation
 Grade Materials




Figure 2.5-54



KEY

AMOUNT OVEREXCAVATED

	0 - 3 FT.
	3 - 10 FT.
	10 - 15 FT.




(Rev. 12 1/03)

PERRY NUCLEAR POWER PLANT

Foundation Overexcavation
Plan

Figure 2.5-55



REGIONAL TECTONIC PROVINCES


- Province Boundary
- Michigan Basin Tectonic Province Boundary constructed from Midland ASLB LBP-85-2 (72, 271)

EARTHQUAKES

TIME WINDOW BEING 1966-1986
 1986-1991

MAGNITUDE	INTENSITY


(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Tectonic Provinces and Earthquakes

Figure 2.3-56



Sources:







Fritz, Herman R., *A Series of Population Maps of the Colonies and the United States 1625-1790*. American Geographical Society, *Re-imagined and Other Maps*, No. 2, *Parade*, New York (1966).

National Atlas of the United States of America. The United States Department of the Interior, Geological Survey, Washington D.C. (1970) 154-139p.


Wells, Nicholas. *Atlas of Historical Settlements in the Colonies*. Historical Society, *Parade*, New York (1978).



Extent of Settled Area

-  Prior to 1650
-  1650 to 1699
-  1700 to 1769
-  1770 to 1799
-  1800 to 1849
-  1850 to 1890


(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT


Expansion and Settlement in
the Colonies and Eastern
United States

Figure 2.5-57



LEGEND


MAGNITUDE RANGES FROM 1.0 TO 10.0
 INTENSITY RANGES FROM I TO XII
 TIME WINDOW BEGINS 1500 ENDS 2000



- | | |
|--|---|
| <p>A</p> <ul style="list-style-type: none"> 1/31/86 2/01/86 2/03/86 2/06/86 2/07/86 3/24/86 2/12/87 12/28/88 9/01/90 | <p>B</p> <ul style="list-style-type: none"> 7/13/87 (12) 7/14/87 (2) 7/16/87 (5) 8/13/87 12/19/87 12/25/87 8/01/89 (5) 8/02/89 (4) 8/03/89 8/04/89 1/01/90 7/13/90 7/24/90 9/25/90 9/26/90 (4) 11/18/90 5/02/91 |
|--|---|

For further details on aftershock sequence, see Figure 2.5-67 and Table 2.5-18.

This earthquake sequence of more than 60 tremors is probably induced. (Armbruster et al., 1987)




(Rev. 12 1/03)

PERRY NUCLEAR POWER PLANT


Seismicity Within 50 Mile Radius
 M > 1.0 I₀ ≥ 1.0

Figure 2.5-58



- ### REGIONAL TECTONIC ELEMENTS
- Great Lakes Basins - Ages around 990 million years (Stable, Expansive, Non-patterned, Boreas)
 - Appalachian Basins - Ages around 1000 million years
 - Eastern Basins - Ages around 1450 million years

- Structure continues to feet from surface of Proterozoic basement surface
 - Thrust fault - both on upper plate
 - Normal fault - both on upper plate
 - High angle fault
 - Strike-slip fault
 - Intensely deformed "Synorogenic" structure
- (Major faults: 1971, 1972; 1973; 1974; 1975; 1976; 1977)



- ### REGIONAL TECTONIC PROVINCES
- Province Boundary
 - Michigan Basin Tectonic Province Boundary constructed from Midland ASLB LBP-85-2 (72, 271)

EARTHQUAKES

TIME WINDOW BEGINS DEC. 1796,
ENDS SEPT. 1991





MAGNITUDE	INTENSITY
	III
	V
	VI
	VII
	VIII

(Rev. 12 1/83)

PERRY NUCLEAR POWER PLANT

Regional Tectonics
Earthquake Tectonic Provinces

Figure 2.5-39




(Rev. 12 1/63)


PERRY NUCLEAR POWER PLANT

Regional Tectonics and Earthquakes


Figure 2.3-60




- ▲ Station
- ⊙ Injection Well
- ▨ Epicenter of Mainshock
January 31, 1986



(Rev. 12 1/03)

	PERRY NUCLEAR POWER PLANT
Telemetered Network Station Configuration	
Figure 2.5-61	




(Source: Christensen, et al., March 1987)(2)

(Rev. 12 1/03)

PERRY NUCLEAR POWER PLANT


The Anna, Ohio Seismic Zone,
Historical Seismicity,
Proposed Faults, and
Observed LANDSAT Lineaments

Figure 2.5-62




Source: C. W. Stover, U.S.G.S. in (2)

(Rev. 12 1/03)

	PERRY NUCLEAR POWER PLANT
Isoseismal Map of the July 12, 1986 St. Marys' Earthquake	
Figure 2.5-63	

ST MARYS EVENT
7/12/86



Focal Mechanism for the July 12, 1986, St. Marys, Ohio Earthquake. Compressional arrivals are shown as solid symbols and tensional as open symbols. The P and T axes are also shown.

(Source: Christensen, et al., March 1987) (2)


(Rev. 12 1/03)





PERRY NUCLEAR POWER PLANT

Focal Mechanism for the
July 12, 1986 Earthquake

Figure 2.5-64




 Epicenter of Mainshock January 31, 1986



ND = FELT, NO DAMAGE

Source: (4)


(Rev. 12 1/03)





PERRY NUCLEAR POWER PLANT

Isoseismal Map for
Northeastern Ohio for
Earthquake of January 31, 1986

Figure 2.5-65



 Epicenter of Mainshock
January 31, 1986



(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Typical Portable Network
Configuration from
March to October 1986

Figure 2.5-66


81.17W
+

81.14W
+ 41.67N



Magnitude

- 2
- 3
- 4
- 5



Note: See Table 2.5-18 for identification of events.

(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

January 31, 1986
Aftershock Sequence

Figure 2.5-67

PERRY EARTHQUAKE 01/31/86



Focal Mechanism for the January 31, 1986 Perry Earthquake Near Cleveland, Ohio (from the Harvard group as found in the PDE monthly listing). The compressional (P) and tensional (T) axes are shown.

(Source: Christensen, et al., March 1987)(2)


(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Focal Mechanism for the
January 31, 1986 Earthquake

Figure 2.5-68



CENTER POINT COORDS = 41.646 -81.156
CENTER POINT ELEV = -4.5 km
VIEW POINT COORDS = 41.623 -81.070
VIEW POINT ELEV = -4.5 km
SURF. DISTANCE (km) = 8.
AZIMUTH = 110.



CENTER POINT COORDS = 41.646 -81.156
CENTER POINT ELEV = -4.5 km
VIEW POINT COORDS = 41.590 -81.200
VIEW POINT ELEV = -4.5 km
SURF. DISTANCE (km) = 7.
AZIMUTH = 211.


(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT


Stereo View of the
Aftershock Sequence

Figure 2.5-69



(Source: Stover and von Hake, 1982)(276)


(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Isoseismal Map for the
 Sharpsburg, Kentucky Earthquake
 of July 27, 1980

Figure 2.5-70




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Dates of Settlement in
Eastern Canada

Figure 2.5-71




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Intensity Attenuation Curves
for Eastern North America

Figure 2.5-73




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Comparison of Attenuation
Models Used to Estimate Site
Intensities for Historical Events

Figure 2.5-74



Generalized isoseismal map of the earthquake of December 16, 1811 at 08^h15^m GMT. MM intensity values at individual points are given in Arabic numerals. The isoseisms, labeled with Roman numerals, indicate the outer bound of the region of specified intensity.

REFERENCE 280


(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Isoseismal Map - Mississippi
Valley Earthquake of
1811 and 1812

Figure 2.5-75



Isoseismal map of the Eastern United States contoured to show the broad regional patterns of the reported intensities for the 1886 Charleston earthquake. Contoured intensity levels are shown in Roman numerals.

REFERENCE 281


(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Isoseismal Map - 1886
Charleston Earthquake

Figure 2.5-76



Earthquake of May 31, 1897

REFERENCE 150


(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Isoseismal Map - Virginia
Earthquake of May 31, 1897


Figure 2.5-77




ST. LAWRENCE EARTHQUAKE
MARCH 1, 1925

REFERENCE 282

(Rev. 12 1/03)

	PERRY NUCLEAR POWER PLANT
Isoseismal Map - St. Lawrence Earthquake, March 1, 1925	
Figure 2.5-78	



Areas affected by shocks of February 5 and August 12


REFERENCE 283

(Rev. 12 1/03)

PERRY NUCLEAR POWER PLANT

Isoseismal Map - United States
(Eastern, Attica, New York)
Earthquakes, 1929

Figure 2.5-79



The Attica, New York, Earthquake of
August 12, 1929.

A Modification of REFERENCE 283
(Figure 3):
125,000 square miles.

REFERENCE 147


(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Isoseismal Map - Attica, New York
Earthquake of August 12, 1929

Figure 2.5-80



Area affected by Anna, Ohio, shock of September 20

REFERENCE 284


(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Isoseismal Map - Area Affected by
Anna, Ohio Earthquake
September 20, 1931

Figure 2.5-81



The Anna, Ohio, Earthquake of
September, 1931.

A Modification of REFERENCE 215
(Figure 3):
45,000 square miles.

REFERENCE 147, Page 135


(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Isoseismal Map - Area Affected by
Anna, Ohio Earthquake
September 20, 1931

Figure 2.5-82



REFERENCE 1, P.12 (AFTER REFERENCE 160)


(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Isoseismal Map - Area Affected by
 Anna, Ohio Earthquake,
 March 2, 1937

Figure 2.5-83



REFERENCE 285 (AFTER REFERENCE 160)


(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT


Isoseismal Map - Area Affected by
Anna, Ohio Earthquake,
March 2, 1937

Figure 2.5-84



Area affected by the Lake Erie earthquake of March 8, 1943.

REFERENCE 286





The Lake Erie Earthquake March 8, 1943.

A Modification REFERENCE 217 (Figure 4):
85,000 square miles.

REFERENCE 147, page 135.

(Rev. 12 1/03)

	PERRY NUCLEAR POWER PLANT
Isoseismal Map - The Lake Erie Earthquake of March 8, 1943	
Figure 2.5-85	



REFERENCE 147, page 135.


(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Isoseismal Map - Cornwall
Massena Earthquake of
September 5, 1944

Figure 2.5-86




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Intensities at the PNPP Site
for the
January 31, 1986, Earthquake

Figure 2.5-87



(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT


Comparison of PNPP-1 OBE and
SSE Horizontal Spectra with
January 31, 1986, Horizontal
Spectra at Reactor Foundation

Figure 2.5-88


ACCELERATION TIME HISTORY MOTION - H1




JANUARY 31, 1986 EARTHQUAKE ACCELEROGRAM
HORIZONTAL (N-S)



ACCELERATION TIME HISTORY MOTION - H2



JANUARY 31, 1986 EARTHQUAKE ACCELEROGRAM
HORIZONTAL (E-W)




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Comparison of Design Time History -
H1 and January 31, 1986 - (N-S)
H2 and January 31, 1986 - (E-W)

Figure 2.5-89



R1651S.L10
R1651W.L10

Mean, upper and lower
bounds for V MM
after O'Brien (1980)


(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Comparison of January 31, 1986,
Low Frequency Horizontal Response
Spectra with Response Spectra
for MM Intensity V

Figure 2.5-90



(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Intensity Acceleration Relationships

Figure 2.5-91

ACCELEROGRAM - H1



(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Acceleration Time History -
Motion H1

Figure 2.5-92

ACCELEROGRAM - H 2



(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Acceleration Time History -
Motion H2

Figure 2.5-93

ACCELEROGRAM - V



(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Acceleration Time History -
Vertical Motion

Figure 2.5-94

VELOCITY TIME HISTORY - H 1



(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Vertical Time History -
Motion H1

Figure 2.5-95

DISPLACEMENT TIME HISTORY - H 1



(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Displacement Time History -
Motion H1

Figure 2.5-96

VELOCITY TIME HISTORY - H2



(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Vertical Time History -
Motion H2

Figure 2.5-97

DISPLACEMENT TIME HISTORY - H2



(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Displacement Time History -
Motion H2

Figure 2.5-98

VELOCITY TIME HISTORY - V



(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Velocity Time History -
Vertical Motion

Figure 2.5-99

DISPLACEMENT TIME HISTORY - V




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Displacement Time History -
Vertical Motion

Figure 2.5-100




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Safe Shutdown Earthquake Design
Response Spectra -
Horizontal Motion

Figure 2.5-101



(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Safe Shutdown Earthquake
Design Response Spectra -
Vertical Motion

Figure 2.5-102

RESPONSE SPECTRUM - H1



(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Response Spectra - Horizontal
Motion H1 (2% and 5% Damping)

Figure 2.5-103

RESPONSE SPECTRUM - H1



(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Response Spectra - Horizontal Motion H1 (7% and 10% Damping)

Figure 2.5-104

RESPONSE SPECTRUM - H2



(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Response Spectra - Horizontal
Motion H2 (2% and 5% Damping)

Figure 2.5-105

RESPONSE SPECTRUM - H2



(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Response Spectra - Horizontal
Motion H2 (7% and 10% Damping)

Figure 2.5-106

RESPONSE SPECTRUM - V



(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Response Spectra - Vertical
Motion (2% and 5% Damping)

Figure 2.5-107

RESPONSE SPECTRUM - V




(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Response Spectra - Vertical
Motion (7% and 10% Damping)


Figure 2.5-108



 **PERRY NUCLEAR POWER PLANT**

Observed Response Spectra for Intensity VIII Effects vs. Design Response Spectra

Figure 2.5-109



AVERAGE MAGNITUDE OF 5.7
 AVERAGE DISTANCE OF 13 KM
 ROCK FOUNDATIONS
 (BASIC SUBSET, MAGNITUDE RANGE
 EXTENDED TO INCLUDE THREE EVENTS
 WITH MAGNITUDE M_L - 6.0, 6.0 AND
 6.1, 5% DAMPING)


(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Site Specific Response Spectra
 for the Perry Site
 (5% Damping)

Figure 2.5-110




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Operating Basis Earthquake Design
Response Spectra - Horizontal
Motion

Figure 2.5-111




(Rev. 13 12/03)



PERRY NUCLEAR POWER PLANT

Operating Basis Earthquake Design
Response Spectra - Vertical
Motion

Figure 2.5-112



NOTE:

Numbers next to solid lineaments referred to in Section 2.5.3.2.

Dashed lineaments from Synthetic Aperture Radar Imagery, Cleveland 2^o sheet, 1984.


(Rev. 12 1/03)






PERRY NUCLEAR POWER PLANT

ERTS and SAR Lineaments

Figure 2.5-113




EXPLANATION

 Anticline
 Syncline
 Fault with displacement indicated

Note: All structures dashed where inferred.



Source: (52 and 212)

(Rev. 12 1/03)


PERRY NUCLEAR POWER PLANT

Structure Map of Northeastern Ohio

Figure 2.5-114



(Rev. 12 1/03)





PERRY NUCLEAR POWER PLANT



Grain Size Distribution Curves -
Lacustrine Sediments

Figure 2.5-115 (Sheet 1 of 6)


MECHANICAL ANALYSIS



MECHANICAL ANALYSIS




(Rev. 12-1/03)



PERRY NUCLEAR POWER PLANT

Grain Size Distribution Curves -
 Lacustrine Sediments

Figure 2.5-115 (Sheet 2 of 6)



(Tested by Herron Testing Laboratories)





(Rev. 12 1/03)

PERRY NUCLEAR POWER PLANT

Grain Size Distribution Curves -
Lacustrine Sediments

Figure 2.5-115 (Sheet 3 of 6)





(Tested by Herron Testing Laboratories)

(Rev. 12 1/03)

PERRY NUCLEAR POWER PLANT

Grain Size Distribution Curves -
Lacustrine Sediments

Figure 2.5-115 (Sheet 4 of 6)



(Tested by Herron Testing Laboratories)



(Rev. 12 1/03)

PERRY NUCLEAR POWER PLANT



Grain Size Distribution Curves -
Lacustrine Sediments

Figure 2.5-115 (Sheet 5 of 6)

MECHANICAL ANALYSIS



MECHANICAL ANALYSIS



(Tested by Herron Testing Laboratories)



(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Grain Size Distribution Curves -
Lacustrine Sediments

Figure 2.5-115 (Sheet 6 of 6)





(Rev. 12 1/03)

PERRY NUCLEAR POWER PLANT

Grain Size Distribution Curves -
Upper Till

Figure 2.5-116 (Sheet 1 of 5)







(Rev. 12 1/03)

PERRY NUCLEAR POWER PLANT

Grain Size Distribution Curves -
Upper Till

Figure 2.5-116 (Sheet 2 of 5)





(Tested by Herron Testing Laboratories)

(Rev. 12 1/03)

PERRY NUCLEAR POWER PLANT

Grain Size Distribution Curves -
Upper Till

Figure 2.5-116 (Sheet 3 of 5)



(Tested by Herron Testing Laboratories)

(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT


Grain Size Distribution Curves -
Upper Till

Figure 2.5-116 (Sheet 4 of 5)

MECHANICAL ANALYSIS



BORING	SAMPLE	DEPTH	SYMBOL	CLASSIFICATION	MC	LL	PL
1-52	10	29.5-31	•	UT CL	19.7	27	16
1-52	11	32.5-34	•	UT CL	18.2	25	17
1-52	12	35.5-37	•	UT CL-ML	14.5	23	16



BORING	SAMPLE	DEPTH	SYMBOL	CLASSIFICATION	MC	LL	PL

(Tested by Herron Testing Laboratories)



(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Grain Size Distribution Curves -
Upper Till

Figure 2.5-116 (Sheet 5 of 5)





(Rev. 12 1/03)

PERRY NUCLEAR POWER PLANT

Grain Size Distribution Curves -
Lower Till

Figure 2.5-117 (Sheet 1 of 6)







(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Grain Size Distribution Curves -
Lower Till

Figure 2.5-117 (Sheet 2 of 6)





(Tested by Heron Testing Laboratories)

(Rev. 12 1/03)

PERRY NUCLEAR POWER PLANT

Grain Size Distribution Curves -
Lower Till

Figure 2.5-117 (Sheet 3 of 6)



(Tested by Herron Testing Laboratories)



(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Grain Size Distribution Curves -
Lower Till

Figure 2.5-117 (Sheet 4 of 6)



(Tested by Herron Testing Laboratories)


(Rev. 12 1/03)

PERRY NUCLEAR POWER PLANT


Grain Size Distribution Curves -
Lower Till

Figure 2.5-117 (Sheet 5 of 6)

MECHANICAL ANALYSIS



BORING	SAMPLE	DEPTH	SYMBOL	CLASSIFICATION	MC	LL	PL
1-52	13	38.5-40	•	LT CL	11.5	23	14
1-52	14	41.5-43	◦	LT CL-ML	11.9	21	15
1-52	15	44.5-46	x	LT CL	10.9	24	16



BORING	SAMPLE	DEPTH	SYMBOL	CLASSIFICATION	MC	LL	PL
1-52	16	47.5-49	◦	LT CL	8.0	20	12
1-52	17	50.5-52	•	LT CL	8.3	22	13

(Tested by Herron Testing Laboratories)


(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Grain Size Distribution Curves -
Lower Till

Figure 2.5-117 (Sheet 6 of 6)



NOTE: RANGE REPRESENTS THE RESULTS OF 44 TESTS


(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT


Range of Grain Size Distribution
Test Results for Upper Till



Figure 2.5-118



NOTE: RANGE REPRESENTS THE RESULTS OF 56 TESTS


(Rev. 12 1/03)

	PERRY NUCLEAR POWER PLANT
Range of Grain Size Distribution Test Results for Lower Till	
Figure 2.5-119	



CURVE No.	PRESSURE INCREMENT FROM (lb)	TIME IN MINUTES	COEFFICIENT OF COM. (P/P ₀) ^{1/2}	DESCRIPTION OF SPECIMEN	TEST SPECIMEN PROPERTIES		INITIAL		FINAL	
					CONSOLIDATION PROPERTIES	TEST SPECIMEN PROPERTIES	INITIAL	FINAL		
1	1 lb	2 hr		Firm gray clayey silt, trace fine sand (LAC) CL-ME COMPRESSION INDEX RECOMPRESSION INDEX SWELLING INDEX PRECONSOLIDATION STRESS, lbf EXISTING OVERBURDEN STRESS, lbf	0.095	28.7	28.7	22.7		
2	2 lb	4 hr			0.008	0.710	0.710	0.583		
3	4 lb	8 hr			0.015	100	100	100		
4	8 lb	15			1.70	0.9166	0.9166	0.851		
5	16	30			0.65	2.495	2.495	2.452		
TIME COMPRESSION CURVES					UNIT DRY WEIGHT, pcf	27.0	27.0			
PRESSURE INCREMENTS OF					PLASTIC LIMIT, %	21.0	21.0			
					FLUIDITY, %	23.0	23.0			
					SPECIFIC GRAVITY	2.68	2.68			
					FROM VOLUMETRIC STRAIN					

(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Typical Consolidation Test
Curves - Lacustrine Sediments

Figure 2.5-120





(Rev. 12 1/03)

PERRY NUCLEAR POWER PLANT

Typical Consolidation Test
Curves - Upper Till

Figure 2.5-121







(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Schematic Representation of
Pressuremeter

Figure 2.5-123




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Typical Pressuremeter Test
 Curves - Lower Till

Figure 2.5-124




PERRY NUCLEAR POWER PLANT

Typical Plate Loading Test
Curve - Lower Till

Figure 2.5-126

TEST No.	MOHNO No.	SAMPLE DEPTH (feet)	T_d (pcf)	M_v (%)	\bar{u}_v (pcf)	$(\bar{u}_v - \bar{u}_s)$ max (pcf)	E_v (%)	A_v	M_v (%)	\bar{c} (pcf)	β degrees
17	1-23		106.0	20.0	1.92	9.97	6.0	-.212	20.8		
18	1-22A	15 - 17	99.7	22.0	0.86	1.06	13.5	.003	22.0		
19			104.2	19.7	2.59	1.90	17.8	-.222	19.7		

NOTE: $\sin \beta = \tan \alpha \bar{c} = \frac{\bar{c}}{\cos \beta}$




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Typical Effective Stress Paths -
Lacustrine Sediments

Figure 2.5-127



TEST No.	SAMPLE No.	SAMPLE DEPTH (feet)	V_d (%)	V_v (%)	$\frac{V_v}{V_d}$	$\frac{(V_v - V_d)}{V_d}$	$\frac{V_v}{V_d}$ max	$\frac{V_v}{V_d}$ (10)	$\frac{V_v}{V_d}$ (5)	$\frac{V_v}{V_d}$ (1)	$\frac{V_v}{V_d}$ (0.5)
10	8-1-26	94-95.5	128.0	11.9	1.5	0.70			11.5	-12	11.0
11	8-1-26	94-95.5	128.0	11.9	3.0	0.90			9.0	-27	10.0
12	8-1-26	94-95.5	128.0	8.5	7.2	10.00			6.5	-32	8.0

NOTE: $\sin \phi = \tan \alpha$, $\epsilon = \frac{1}{\cos \phi}$


104 (10 - 10) †

(Rev. 12 1/03)

PERRY NUCLEAR POWER PLANT

Typical Effective Stress Paths -
Lower Till

Figure 2.5-129






(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Typical Effective Stress -
Strength Characteristics of
Lacustrine Sediments

Figure 2.5-130




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Typical Effective Stress -
 Strength Characteristics of
 Lower Till

Figure 2.5-131





(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Typical Effective Stress -
Strength Characteristics of
Upper Till

Figure 2.5-132





(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Dynamic Properties of
Lacustrine Sediments

Figure 2.5-133





(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Dynamic Properties of Upper Till

Figure 2.5-134




(Rev. 12 1/03)

PERRY NUCLEAR POWER PLANT


Dynamic Properties of Lower Till

Figure 2.5-135

MECHANICAL ANALYSIS



BORING	SAMPLE	DEPTH	SYMBOL	CLASSIFICATION	MC	LL	PL
S-1			○	Standard Grain Size Distribution - Entire Sample	10.0	21	14
S-1			●	Standard Grain Size Distribution - Minus No. 10			
S-1			□	Grain Size Distribution - Minus No. 10 without Deflocculation			



BORING	SAMPLE	DEPTH	SYMBOL	CLASSIFICATION	MC	LL	PL
S-2			○	Standard Grain Size Distribution - Entire Sample	9.9	20	15
S-2			●	Standard Grain Size Distribution - Minus No. 10			
S-2			□	Grain Size Distribution - Minus No. 10 without Deflocculation			

(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT


Soil Conservation Service
Tests on Lower Till

Figure 2.5-136 (Sheet 1 of 3)

MECHANICAL ANALYSIS



BORING	SAMPLE	DEPTH	SYMBOL	CLASSIFICATION	MC	LL	PL
	S-3		○	Standard Grain Size Distribution - Entire Sample	10.2	21	15
	S-3		●	Standard Grain Size Distribution - Minus No. 10			
	S-3		□	Grain Size Distribution - Minus No. 10 without Deflocculation			



BORING	SAMPLE	DEPTH	SYMBOL	CLASSIFICATION	MC	LL	PL
	S-4		○	Standard Grain Size Distribution - Entire Sample	10.1	20	16
	S-4		●	Standard Grain Size Distribution - Minus No. 10			
	S-4		□	Grain Size Distribution - Minus No. 10 without Deflocculation			

(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT


Soil Conservation Service
Tests on Lower Till

Figure 2.5-136 (Sheet 2 of 3)

MECHANICAL ANALYSIS



BORING	SAMPLE	DEPTH	SYMBOL	CLASSIFICATION	MC	LL	PL
	S-5		○	Standard Grain Size Distribution - Entire Sample	9.8	20	17
	S-5		●	Standard Grain Size Distribution - Minus No. 10			
	S-5		□	Grain Size Distribution - Minus No. 10 without Deflocculation			



BORING	SAMPLE	DEPTH	SYMBOL	CLASSIFICATION	MC	LL	PL


(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Soil Conservation Service
Tests on Lower Till

Figure 2.5-136 (Sheet 3 of 3)





(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Dissolved Salts in
Saturation Extract

Figure 2.5-137





(Rev. 12 1/03)

PERRY NUCLEAR POWER PLANT

Grain Size Distribution Curves -
Chagrin Shale

Figure 2.5-138 (Sheet 1 of 2)





(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Grain Size Distribution Curves -
Chagrin Shale

Figure 2.5-138 (Sheet 2 of 2)




(Rev. 12 1/03)

	PERRY NUCLEAR POWER PLANT
Wet-Dry Cycle Slaking Durability Test on Chagrin Shale	
Figure 2.5-139	

TYPICAL STRESS - STRAIN CHARACTERISTICS OF SHALE IN UNIAXIAL COMPRESSION

SYMBOL	BORING No.	SAMPLE DEPTH (Ft)	γ_d (pcf)	w_n (%)	ULTIMATE STRESS (tsf)	ULTIMATE STRAIN (%)	E_s (tsf x 10 ³)
•	1 - 33	152	156.0	4.5	302	0.50	67
◦	1 - 33	161	150.0	4.7	442	0.50	102
+	1 - 1	124	164.7	2.1	542	0.91	53

ALL SAMPLES EXHIBITED AN ABRUPT BRITTLE FAILURE




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Typical Stress - Strain
Characteristics of Shale in
Uniaxial Compression

Figure 2.5-140





(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Deere-Miller Strength -
Modulus Classification of
Chagrin Shale

Figure 2.5-141




(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Typical Pressuremeter Test
Results in Chagrin Shale


Figure 2.5-142




SECTION 1-1




INDEX MAP



SECTION 2-2



SECTION 3-3



SECTION 4-4


(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Subsurface Stratigraphy and
Excavation Sections
(Preconstruction)


Figure 2.5-143 (Sheet 1 of 2)




SECTION 5-5




SECTION 6-6



SECTION 7-7



INDEX MAP




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Subsurface Stratigraphy and
Excavation Sections
(Preconstruction)


Figure 2.5-143 (Sheet 2 of 2)



● I-30 TEST BORINGS USED FOR SEISMIC VELOCITY MEASUREMENTS

0 100 200 300 400 500 FEET

(Rev. 12 1/03)

	PERRY NUCLEAR POWER PLANT
	Site Seismic Survey
	Figure 2.5-144



Anticlinal fold and overthrust fault in Bedford formation on Bates Creek, southeast of Painesville.
(Reference 289)


(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Warners Creek Thrust
Fault from Prosser

Figure 2.5-145



Anticline produced by buckling of the shales at the base of the landslide at Cleveland, Ohio. (Reference 289)

(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Anticline Produced by Sliding
from Van Horn

Figure 2.5-146



UNSYMMETRICAL ANTICLINE

This shows 5 feet of disturbed shale overlain by 2 feet of glacial drift. (Reference 290)

(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Anticline in Shale from
Van Horn

Figure 2.5-147



UNSYMMETRICAL ANTICLINE WITH BOTTOM LAYERS HORIZONTAL

Eight feet of shale are covered by 2 feet of glacial drift. (Reference 290)

(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Anticline in Shale from
Van Horn

Figure 2.5-148



This view shows 3 feet of glacial sand and 5 feet of folded iron-stained shale having 3 well defined concretionary ironstone bands, 3 feet of blue shale with less folding, and 3 feet of horizontal shale. (Reference 290)

(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Anticline in Shale from
Van Horn

Figure 2.5-149



(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Aerial Photograph of Warners
(Bates) Creek Fault

Figure 2.5-150




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT


Aerial Photograph of Hell
Hollow Faults

Figure 2.5-151



(APPROXIMATELY TO SCALE)

NOTE: WARNERS CREEK FAULT IS 8 MILES SOUTH OF PNPP SITE




PERRY NUCLEAR POWER PLANT

Sketch of Excavated Rock Slope
Showing Warners Creek Thrust Fault

Figure 2.5-152

(Rev. 12 1/03)



(APPROXIMATELY TO SCALE)

NOTE: FAULT #1 IS 7 MILES SE OF PERRY SITE

FEET


(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Sketch of Excavated Rock Slope
Showing Hell Hollow Fault #1

Figure 2.5-153



(APPROXIMATELY TO SCALE)


(Rev. 12 1/03)

NOTE: FAULT #2 IS 40 FT SOUTH OF FAULT #1

PERRY NUCLEAR POWER PLANT

Sketch of Excavated Rock Slope
Showing Hell Hollow Fault #2

Figure 2.5-154



(Rev. 12 1/03)


PERRY NUCLEAR POWER PLANT

Sketch of Excavated Rock Slope
Showing Hell Hollow Fault #3

Figure 2.5-155

(APPROXIMATELY TO SCALE)

NOTE: FAULT #3 IS 60 FT SOUTH OF FAULT #2 AND 100 FT SOUTH OF FAULT #1




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Interpretative Sketch of
Hell Hollow Faults
Related to Slumping

Figure 2.5-156




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Photograph of Warners
(Bates) Creek Exposure

Figure 2.5-157



(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Photographic Enlargement of Fault
of Warners (Bates) Creek

Figure 2.5-158




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Photographic Enlargement of Fault
of Warners (Bates) Creek

Figure 2.5-159



(Rev. 12 1/03)


NOTE: See Figure 2.5-152 for Location.



PERRY NUCLEAR POWER PLANT

Photographic Enlargement of
Tightly Folded Strata at
Warners (Bates)

Figure 2.5-160



Note: See Figure 2.5-152 for Location.


(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Photograph of Minor Thrust Fault,
20 ft North of Warners
(Bates) Creek Fault

Figure 2.5-161




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Photograph of Hell Hollow
Fault #1 Prior to Excavation

Figure 2.5-162




(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Photograph of Hell Hollow
Fault #1 After Excavation

Figure 2.5-163



(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Photographic Enlargement of
Hell Hollow Fault #1
After Excavation

Figure 2.5-164




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Photograph of Hell Hollow
Fault #2 After Excavation

Figure 2.5-165



(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Photograph of Hell Hollow
Fault #3 Prior to Excavation

Figure 2.5-166




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Photograph of Hell Hollow
Fault #3 After Excavation

Figure 2.5-167



NOTE: SCARP IN FOREGROUND


(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Photograph of Hell Hollow Slump
Area Facing South

Figure 2.5-168



NOTE: SCARP IN BACKGROUND



(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Photograph of Hell Hollow Slump
Area Facing East


Figure 2.5-169



PERRY NUCLEAR POWER PLANT

Representative Records of
Pressure vs. Shut-in Time

Figure 2.5-170





(Rev. 12 1/03)


PRESSURE
(PSIG)


PERRY NUCLEAR POWER PLANT

Pressure vs. Depth
Figure 2.5-171



(Rev. 12 1/03)

	PERRY NUCLEAR POWER PLANT
<p>Arrival Time vs. Distance</p> <p>Figure 2.5-172</p>	




NOTE: See Figure 2.5-144 for Survey Line Traces.

(Rev. 12 1/03)


PERRY NUCLEAR POWER PLANT

Seismic Survey Profile

Figure 2.5-173



Note: As per section 2.5.4.5.5 the backfill materials shown in this figure may be replaced with Controlled Low Strength Material (CLSM).




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT


Typical Backfill Section

Figure 2.5-174



Test No.	Unit Dry Wgt. (pcf)	Relative Density (%)	Effective Consol. Pressure (ksf) $\bar{\sigma}_c$	Max. Stress Difference (ksf) $(\sigma_1 - \sigma_3)_f$	Failure Strain ϵ_f (%)
①	120.7	85.0	2	31.3	12.9
②	120.6	85.0	4	37.4	9.0
③	120.9	86.0	6	42.0	8.3

NOTES: Maximum Density = 125 pcf
Minimum Density = 101 pcf





(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Triaxial Compression
Test Results, Class A
Fill Design Investigation

Figure 2.5-176




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Typical Results of High
Amplitude Cyclic Torsion Tests,
Class A Fill Design Investigations

Figure 2.5-177




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Maximum Shear Modulus vs.
Confining Pressure, Class A
Fill Design Investigation

Figure 2.5-178



NOTE: RANGE IS ESTIMATED BASED ON A RANDOM SAMPLING OF APPROXIMATELY 675 TESTS


(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Range of Grain Size Distribution
 Test Results for Class A Fill
 (Bestone Quarry)

Figure 2.5-179



NOTE: RANGE IS ESTIMATED BASED ON A RANDOM SAMPLING OF APPROXIMATELY 5500 TESTS


(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Range of Grain Size Distribution
 Test Results for Class A Fill
 (Sidley Quarry)

Figure 2.5-180




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Class A Fill - Field
 Density Tests

Figure 2.5-181



(Rev. 12 1/03)


Maximum Dry Density: 133.7 pcf
 Optimum Moisture: 8.9 %



PERRY NUCLEAR POWER PLANT

Typical Compaction Curve,
 Class B Fill

Figure 2.5-182



NOTE: RANGE IS ESTIMATED BASED ON A RANDOM SAMPLING
OF APPROXIMATELY 200 TESTS


(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Range of Grain Size Distribution
Test Results for Class B Fill

Figure 2.5-183




(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Class B Fill - Field
Density Tests

Figure 2.5-184



(Rev. 12 1/03)





PERRY NUCLEAR POWER PLANT

Class B Fill - Field
Moisture Tests

Figure 2.5-185

PIEZOMETER LOCATION SCHEDULE		
PIEZOMETER	LOCATION	
	N. COORD	E. COORD
N-1-BS	49,880 63	9,459 89
N-2-BS	49,939 81	9,460 63
N-3-BS	49,999 13	9,460 39
N-4-BS	50,059 45	9,460 15
N-5-BS	50,119 77	9,460 00
N-6-BS	50,179 09	9,459 76
S-1-BS	48,848 30	9,500 16
S-2-BS	48,790 46	9,505 26
S-3-BS	48,732 62	9,510 36
S-4-BS	48,674 78	9,515 46
S-5-BS	48,616 94	9,520 56
S-6-BS	48,559 10	9,525 66
S-7	48,501 26	9,530 76
S-7A	48,501 26	9,498 51
S-7B	48,187 0	9,501 9
S-8	47,880 4	9,500 7
S-1-BS	49,308 33	9,708 23
S-2-BS	49,360 22	9,719 30
S-3-BS	49,412 11	9,730 37
S-4-BS	49,464 0	9,741 44
S-5-BS	49,516 0	9,752 51
S-6-BS	49,568 0	9,763 58
S-7-BS	49,620 0	9,774 65
S-8-BS	49,672 0	9,785 72
S-9-BS	49,724 0	9,796 79
S-10-BS	49,776 0	9,807 86
S-11-BS	49,828 0	9,818 93
S-12-BS	49,880 0	9,830 00
S-13-BS	49,932 0	9,841 07
S-14-BS	49,984 0	9,852 14
S-15-BS	50,036 0	9,863 21
S-16-BS	50,088 0	9,874 28
S-17-BS	50,140 0	9,885 35
S-18-BS	50,192 0	9,896 42
S-19-BS	50,244 0	9,907 49
S-20-BS	50,296 0	9,918 56
S-21-BS	50,348 0	9,929 63
S-22-BS	50,400 0	9,940 70
S-23-BS	50,452 0	9,951 77
S-24-BS	50,504 0	9,962 84
S-25-BS	50,556 0	9,973 91
S-26-BS	50,608 0	9,985 00
S-27-BS	50,660 0	9,996 07
S-28-BS	50,712 0	10,007 14
S-29-BS	50,764 0	10,018 21
S-30-BS	50,816 0	10,029 28
S-31-BS	50,868 0	10,040 35
S-32-BS	50,920 0	10,051 42
S-33-BS	50,972 0	10,062 49
S-34-BS	51,024 0	10,073 56
S-35-BS	51,076 0	10,084 63
S-36-BS	51,128 0	10,095 70
S-37-BS	51,180 0	10,106 77
S-38-BS	51,232 0	10,117 84
S-39-BS	51,284 0	10,128 91
S-40-BS	51,336 0	10,140 00
S-41-BS	51,388 0	10,151 07
S-42-BS	51,440 0	10,162 14
S-43-BS	51,492 0	10,173 21
S-44-BS	51,544 0	10,184 28
S-45-BS	51,596 0	10,195 35
S-46-BS	51,648 0	10,206 42
S-47-BS	51,700 0	10,217 49
S-48-BS	51,752 0	10,228 56
S-49-BS	51,804 0	10,239 63
S-50-BS	51,856 0	10,250 70
S-51-BS	51,908 0	10,261 77
S-52-BS	51,960 0	10,272 84
S-53-BS	52,012 0	10,283 91
S-54-BS	52,064 0	10,295 00
S-55-BS	52,116 0	10,306 07
S-56-BS	52,168 0	10,317 14
S-57-BS	52,220 0	10,328 21
S-58-BS	52,272 0	10,339 28
S-59-BS	52,324 0	10,350 35
S-60-BS	52,376 0	10,361 42
S-61-BS	52,428 0	10,372 49
S-62-BS	52,480 0	10,383 56
S-63-BS	52,532 0	10,394 63
S-64-BS	52,584 0	10,405 70
S-65-BS	52,636 0	10,416 77
S-66-BS	52,688 0	10,427 84
S-67-BS	52,740 0	10,438 91
S-68-BS	52,792 0	10,450 00
S-69-BS	52,844 0	10,461 07
S-70-BS	52,896 0	10,472 14
S-71-BS	52,948 0	10,483 21
S-72-BS	53,000 0	10,494 28
S-73-BS	53,052 0	10,505 35
S-74-BS	53,104 0	10,516 42
S-75-BS	53,156 0	10,527 49
S-76-BS	53,208 0	10,538 56
S-77-BS	53,260 0	10,549 63
S-78-BS	53,312 0	10,560 70
S-79-BS	53,364 0	10,571 77
S-80-BS	53,416 0	10,582 84
S-81-BS	53,468 0	10,593 91
S-82-BS	53,520 0	10,605 00
S-83-BS	53,572 0	10,616 07
S-84-BS	53,624 0	10,627 14
S-85-BS	53,676 0	10,638 21
S-86-BS	53,728 0	10,649 28
S-87-BS	53,780 0	10,660 35
S-88-BS	53,832 0	10,671 42
S-89-BS	53,884 0	10,682 49
S-90-BS	53,936 0	10,693 56
S-91-BS	53,988 0	10,704 63
S-92-BS	54,040 0	10,715 70
S-93-BS	54,092 0	10,726 77
S-94-BS	54,144 0	10,737 84
S-95-BS	54,196 0	10,748 91
S-96-BS	54,248 0	10,760 00
S-97-BS	54,300 0	10,771 07
S-98-BS	54,352 0	10,782 14
S-99-BS	54,404 0	10,793 21
S-100-BS	54,456 0	10,804 28



LEGEND

- ◆ AS BUILT PIEZOMETER LOCATIONS
- ◆ PROPOSED PIEZOMETER LOCATIONS

REFERENCES

- E-744-004 PLANT PLAN - IMMEDIATE PLANT AREA
- E-744-005 PLANT FOUNDATION AND SERVICE CANALS
- E-744-006 PLANT FOUNDATION SYSTEM - NUCLEAR ISLAND PIEZOMETER LOCATIONS
- E-744-008 TYPICAL SECTION - TYPICAL SECTION AND PARKING AREAS


THIS DRAWING SUPERSEDES DRAWING E-746-011

(Rev. 12 1/03)


PERRY NUCLEAR POWER PLANT

Locations of Permanent
Groundwater Observation Piezometers


Figure 2.5-186



(Rev. 12 1/03)

	PERRY NUCLEAR POWER PLANT
Groundwater Observation Piezometric Readings	
Figure 2.5-187 (Sheet 1 of 34)	

PIEZOMETER E-3A



(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Groundwater Observation
Piezometric Readings

Figure 2.5-187 (Sheet 2 of 34)

PIEZOMETER E-3B



(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Groundwater Observation
Piezometric Readings

Figure 2.5-187 (Sheet 3 of 34)

PIEZOMETER E-4



(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Groundwater Observation
Piezometric Readings

Figure 2.5-187 (Sheet 4 of 34)

PIEZOMETER E-5



(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Groundwater Observation
Piezometric Readings

Figure 2.5-187 (Sheet 5 of 34)

PIEZOMETER E-6



(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Groundwater Observation
Piezometric Readings

Figure 2.5-187 (Sheet 6 of 34)

PIEZOMETER E-7




(Rev. 12 1/03)

PERRY NUCLEAR POWER PLANT

Groundwater Observation
Piezometric Readings

Figure 2.5-187 (Sheet 7 of 34)

PIEZOMETER E-7A



(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Groundwater Observation
Piezometric Readings

Figure 2.5-187 (Sheet 8 of 34)

PIEZOMETER E-7B



(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Groundwater Observation
Piezometric Readings

Figure 2.5-187 (Sheet 9 of 34)

PIEZOMETER E-8



(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Groundwater Observation
Piezometric Readings

Figure 2.5-187 (Sheet 10 of 34)

PIEZOMETER W-4




(Rev. 12 1/03)

PERRY NUCLEAR POWER PLANT

Groundwater Observation
Piezometric Readings

Figure 2.5-187 (Sheet 11 of 34)

PIEZOMETER W-5



(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Groundwater Observation
Piezometric Readings

Figure 2.5-187 (Sheet 12 of 34)

PIEZOMETER W-6



(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT


Groundwater Observation
Piezometric Readings

Figure 2.5-187 (Sheet 13 of 34)

PIEZOMETER W-6A




(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Groundwater Observation
Piezometric Readings


Figure 2.5-187 (Sheet 14 of 34)




(Rev. 12 1/03)

	PERRY NUCLEAR POWER PLANT
Groundwater Observation Piezometric Readings	
Figure 2.5-187 (Sheet 15 of 34)	


PIEZOMETER W-7



(Rev. 12 1/03)

 PERRY NUCLEAR POWER PLANT
Groundwater Observation Piezometric Readings Figure 2.5-187 (Sheet 16 of 34)

PIEZOMETER W-8



(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Groundwater Observation
Piezometric Readings

Figure 2.5-187 (Sheet 17 of 34)

PIEZOMETER S-3



(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Groundwater Observation
Piezometric Readings

Figure 2.5-187 (Sheet 18 of 34)

PIEZOMETER S-4




(Rev. 12 1/03)

PERRY NUCLEAR POWER PLANT

Groundwater Observation
Piezometric Readings

Figure 2.5-187 (Sheet 19 of 34)

PIEZOMETER S-4A



(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT


Groundwater Observation
Piezometric Readings

Figure 2.5-187 (Sheet 20 of 34)


PIEZOMETER S-48




(Rev. 12 1/03)

	PERRY NUCLEAR POWER PLANT
Groundwater Observation Piezometric Readings	
Figure 2.5-187 (Sheet 21 of 34)	


PIEZOMETER S-5



(Rev. 12 1/03)

	PERRY NUCLEAR POWER PLANT
Groundwater Observation Piezometric Readings	
Figure 2.5-187 (Sheet 22 of 34)	

PIEZOMETER S-6



(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT


Groundwater Observation
Piezometric Readings

Figure 2.5-187 (Sheet 23 of 34)

PIEZOMETER S-7



(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Groundwater Observation
Piezometric Readings

Figure 2.5-187 (Sheet 24 of 34)

PIEZOMETER S-7A



(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Groundwater Observation
Piezometric Readings

Figure 2.5-187 (Sheet 25 of 34)

PIEZOMETER S-7B



(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT


Groundwater Observation
Piezometric Readings

Figure 2.5-187 (Sheet 26 of 34)

PIEZOMETER S-8



(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Groundwater Observation
Piezometric Readings

Figure 2.5-187 (Sheet 27 of 34)

PIEZOMETER N-3



(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Groundwater Observation
Piezometric Readings

Figure 2.5-187 (Sheet 28 of 34)

PIEZOMETER N-4



(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Groundwater Observation
Piezometric Readings

Figure 2.5-187 (Sheet 29 of 34)

PIEZOMETER N-4A



(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Groundwater Observation
Piezometric Readings

Figure 2.5-187 (Sheet 30 of 34)

PIEZOMETER N-48



(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Groundwater Observation
Piezometric Readings

Figure 2.5-187 (Sheet 31 of 34)

PIEZOMETER N-8




(Rev. 12 1/03)

PERRY NUCLEAR POWER PLANT

Groundwater Observation
Piezometric Readings

Figure 2.5-187 (Sheet 32 of 34)

PIEZOMETER N-8A



(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Groundwater Observation
Piezometric Readings

Figure 2.5-187 (Sheet 33 of 34)

PIEZOMETER N-88




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Groundwater Observation
Piezometric Readings

Figure 2.5-187 (Sheet 34 of 34)




(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT


Groundwater Profiles

Figure 2.5-188 (Sheet 1 of 4)



(Rev. 12 1/03)

 PERRY NUCLEAR POWER PLANT
<p>Groundwater Profiles</p> <p>Figure 2.5-188 (Sheet 2 of 4)</p>




(Rev. 12 1/03)

PERRY NUCLEAR POWER PLANT

Groundwater Profiles

Figure 2.5-188 (Sheet 3 of 4)




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Groundwater Profiles

Figure 2.5-188 (Sheet 4 of 4)




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Number of Cycles Required
for Initial Liquefaction

Figure 2.5-189




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Cycle Stress Developed and
 Required for Initial
 Liquefaction in 10 Stress Cycles

Figure 2.5-190




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Liquefaction Potential Analysis
of Lacustrine Sediments

Figure 2.5-191




Subgrade Deformation - Inches (Rev. 12 1/03)

PERRY NUCLEAR POWER PLANT

Time-Deformation Analysis for
Reactor Building Complex

Figure 2.5-192



NOTES:

- (1) K_0 (SHALE) = 2.0
- (2) K_0 (FILL) = 1.0
- (3) ANALYSIS ASSUMES 33% OF TOTAL SHALE SWELL OCCURS BEFORE MAT PLACEMENT.
- (4) DEFLECTION SHOWN IS FOR END OF CONSTRUCTION CONDITION PRIOR TO SERVICE LOADING.


(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Deformation Analysis for
Emergency Service Water Pumphouse

Figure 2.5-193




- NOTE:
1. DYNAMIC INCREMENT ADDED TO NORMAL OPERATING CONDITIONS FOR SSE EVENT
 2. ADDITIONAL LOADINGS DUE TO SURCHARGE FROM CRANES, RAILROADS OR ADJACENT FOUNDATIONS ADDED AS REQUIRED
 3. FOR LOADS APPLICABLE TO EMERGENCY SERVICE WATER PUMPHOUSE SEE FIGURE 2.5-195

(Rev. 12 1/03)

PERRY NUCLEAR POWER PLANT

Earth Pressure Diagrams for
Rigid Subsurface Walls


Figure 2.5-194




NOTE: DYNAMIC INCREMENTS ADDED TO NORMAL OPERATIONS CONDITIONS FOR SSE EVENT

ELEVATION IN FEET

(Rev. 12 1/03)

	PERRY NUCLEAR POWER PLANT
Earth Pressure Diagrams for Emergency Service Water Pumphouse Subsurface Walls	
Figure 2.5-195	



LEGEND:

- CASE 1; $K_0(\text{SHALE})=2, K_0(\text{FILL})=1$ INCREMENTAL WALL CONSTRUCTION
- △ CASE 2; $K_0(\text{SHALE})=2, K_0(\text{FILL})=1$
- CASE 3; $K_0(\text{SHALE})=1, K_0(\text{FILL})=0.5$


(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Lateral Pressure - Emergency
Service Water Pumphouse

Figure 2.5-196




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Shale Heave Gauge
Location Plan

Figure 2.5-197



NOTE: # 8 BAR PLACED WITH AND DRIVEN INTO 1 1/4 INCH WELL POINT
 ELEVATION OF TOP OF BAR ESTABLISHED FROM SURFACE


(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Shale Heave Gauge Detail

Figure 2.5-198




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Shale Heave Gauge Monitoring Data

Figure 2.5-199 (Sheet 1 of 2)




(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Shale Heave Gauge Monitoring Data


Figure 2.5-199 (Sheet 2 of 2)



(Rev. 12 1/03)

	PERRY NUCLEAR POWER PLANT
Shale Extensometer Locations in Emergency Service Water Pumphouse Excavation	
Figure 2.5-200	

EXTENSOMETER EX-1



RELATIVE DEFORMATION (INCHES)
(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Shale Extensometers Monitoring
Data

Figure 2.5-202 (Sheet 1 of 6)

EXTENSOMETER EX-2



RELATIVE DEFORMATION (INCHES)
 (Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Shale Extensometers Monitoring
 Data

Figure 2.5-202 (Sheet 2 of 6)

EXTENSOMETER EX-3



RELATIVE DEFORMATION (INCHES)
(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Shale Extensometers Monitoring
Data

Figure 2.5-202 (Sheet 3 of 6)

EXTENSOMETER EX-4




RELATIVE DEFORMATION (INCHES)
 (Rev. 12 1/03)

PERRY NUCLEAR POWER PLANT


Shale Extensometers Monitoring
Data

Figure 2.5-202 (Sheet 4 of 6)


EXTENSOMETER EX-5



RELATIVE DEFORMATION (INCHES)
 (Rev. 12 1/03)

	PERRY NUCLEAR POWER PLANT
Shale Extensometers Monitoring Data	
Figure 2.5-202 (Sheet 5 of 6)	

EXTENSOMETER EX-6




RELATIVE DEFORMATION (INCHES)
(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Shale Extensometers Monitoring
Data

Figure 2.5-202 (Sheet 6 of 6)





(REV. 19 10/2015)

PERRY NUCLEAR POWER PLANT
10 CENTER RD., PERRY, OHIO 44081

SETTLEMENT MONUMENT
LOCATION PLAN

FIGURE 2.5-203



NOTE: MEASURED DEFORMATION IS RELATIVE TO MONUMENT WITHIN CONTROL COMPLEX



(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Reactor Mat Deformation

Figure 2.5-204 (Sheet 1 of 2)



NOTE: MEASURED DEFORMATION IS RELATIVE TO MONUMENT WITHIN CONTROL COMPLEX



(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Reactor Mat Deformation

Figure 2.5-204 (Sheet 2 of 2)





(Rev. 12 1/03)

PERRY NUCLEAR POWER PLANT

Settlement Observation Data

Figure 2.5-205 (Sheet 1 of 6)





(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Settlement Observation Data

Figure 2.5-205 (Sheet 2 of 6)





(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Settlement Observation Data

Figure 2.5-205 (Sheet 3 of 6)





(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Settlement Observation Data

Figure 2.5-205 (Sheet 4 of 6)





(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Settlement Observation Data

Figure 2.5-205 (Sheet 5 of 6)




(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Settlement Observation Data
Figure 2.5-205 (Sheet 6 of 6)



BRASS DISK DIMENSIONS



TYPICAL DISK INSTALLATION



(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Building Settlement
Monitoring Disks

Figure 2.5-206





(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Settlement Observation Data

Figure 2.5-207



NOTE: STRUCTURAL CONCRETE PLACEMENT
COMPLETED PRIOR TO SETTLEMENT
MONITORING.

(Rev. 12 1/03)




PERRY NUCLEAR POWER PLANT

Settlement Observation Data

Figure 2.5-208


NOTE: β = ANGLE OF INCLINATION OF THE BLUFF SLOPE WITH THE HORIZONTAL



SYMBOL	AVERAGE SLOPE	FACTOR OF SAFETY		MAX. ②-③ DISTANCE (FT.)
		STATIC	DYNAMIC*	
●	1:1	0.73	0.56	46
○	2:1	1.32	0.94	88
+	3:1	1.68	1.09	136

* $k_s = 0.15$

- ① EXISTING TOE OF BLUFF SLOPE
- ② FUTURE BLUFF TOE
- ③ MAX. LIMIT OF CRITICAL SLIP SURFACE



(Rev. 12 1/03)


PERRY NUCLEAR POWER PLANT

Bluff Stability Analysis

Figure 2.5-209

FAILURE SURFACE NO.	METHOD	SEISMIC COEFFICIENT	FACTOR OF SAFETY
①	B	0.00	1.68
①	B	0.15q	1.09
②	M-P	0.00	1.69
②	M-P	0.15q	1.18
③	M-P	0.00	2.16
④	M-P	0.15q	1.45

NOTE: B = BISHOP METHOD
M-P = MORGENSTERN - PRICE METHOD




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Stability Analysis of
Lake Erie Bluff

Figure 2.5-210



15th, 50th, 85th fractiles and mean annual probability of exceedance of peak ground acceleration from EPRI Report RP 101-53 ⁽³⁰⁸⁾


(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

EPRI Seismic Hazard
Calculations Results
for PNPP

Figure 2.5-211



Median uniform hazard spectra at the
 1.0E-3, 1.0E4 and 1.0E5 annual probability
 of exceedance from EPRI Report RP 101-53⁽³⁰⁸⁾


(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT


EPRI Seismic Hazard
 Calculations Results
 for PNPP

Figure 2.5-212




Base map: Official Transportation Map, Ohio Department of Transportation, 1987.



 Felt report location
 (per police/sheriff, newspapers or
 phone calls to area residents)

Note: Epicentral symbol equivalent
 to uncertainty.

(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Distribution of Felt Reports
 1/26/1991 Earthquake

Figure 2.5-213




(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Total Felt Area of
 Dec. 28, 1989 (23:29 UT)
 Microearthquake Mc=2.8

Figure 2.5-214



(Rev. 12 1/03)



PERRY NUCLEAR POWER PLANT

Isoseismal Map
Saguenay Earthquake
November 25, 1988

Figure 2.5-215