

3.1 SFSC INTEGRITY

3.1.2 SFSC Heat Removal System

LCO 3.1.2 The SFSC Heat Removal System shall be operable

-----NOTE-----  
The SFSC Heat Removal System is operable when 50% or more of each of the inlet and outlet vent areas are unblocked and available for flow or when air temperature requirements are met.  
-----

APPLICABILITY: During STORAGE OPERATIONS.

ACTIONS

-----NOTE-----  
Separate Condition entry is allowed for each SFSC.  
-----

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. SFSC Heat Removal System operable, but partially ( $\leq 50\%$ ) blocked.	A.1 Remove blockage.	N/A
B. SFSC Heat Removal System inoperable.	B.1 Restore SFSC Heat Removal System to operable status.	8 hours

(continued)