

Official Transcript of Proceedings
NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguards
 Kairos Power Licensing Subcommittee
 Open Session

Docket Number: (n/a)

Location: teleconference

Date: Friday, November 19, 2021

Work Order No.: NRC-1754

Pages 1-41

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1716 14th Street, N.W., Suite 200
Washington, D.C. 20009
(202) 234-4433

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, as reported herein, is a record of the discussions recorded at the meeting.

This transcript has not been reviewed, corrected, and edited, and it may contain inaccuracies.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

UNITED STATES OF AMERICA

NUCLEAR REGULATORY COMMISSION

+ + + + +

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

(ACRS)

+ + + + +

KAIROS POWER LICENSING SUBCOMMITTEE

+ + + + +

FRIDAY

NOVEMBER 19, 2021

+ + + + +

The Subcommittee met via Teleconference,
at 9:00 a.m. EST, David A. Petti, Chair, presiding.

COMMITTEE MEMBERS:

- DAVID A. PETTI, Chair
- RONALD G. BALLINGER, Member
- VICKI M. BIER, Member
- DENNIS BLEY, Member
- CHARLES H. BROWN, JR., Member
- VESNA B. DIMITRIJEVIC, Member
- JOSE MARCH-LEUBA, Member
- JOY L. REMPE, Member

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

ACRS CONSULTANT:

STEPHEN SCHULTZ

DESIGNATED FEDERAL OFFICIAL:

WEIDONG WANG

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

T-A-B-L-E O-F C-O-N-T-E-N-T-S

ACRS Chairman Introductory Remarks 4

NRC Staff Introductory Remarks 6

Kairos Power Introductory Remarks 10

Overview of Kairos Power Mechanistic Source Term
(MST) Methodology 13

Public Comment 41

Adjournment 41

P-R-O-C-E-E-D-I-N-G-S

9:00 a.m.

CHAIR PETTI: Well, good morning, everyone. The meeting will now come to order.

This is a meeting of the Kairos Power Licensing Subcommittee of the Advisory Committee on Reactor Safeguards. I am David Petti, Chairman of today's Subcommittee meeting.

ACRS members in attendance are Vicki Bier, Charles Brown, Jose March-Leuba, Joy Rempe, Ron Ballinger, Vesna Dimitrijevic. And I don't see anybody else.

Our consultants. Let's see. I don't see any of our consultants either at this point, but they may be in by phone.

Weidong Wang of the ACRS staff is the designated federal official for this meeting.

During today's meeting the Subcommittee will review staff Safety Evaluation Report on the KP-FHR Mechanistic Source Term Methodology, Revision 1. The Subcommittee will hear presentations by and hold discussions with the NRC staff, Kairos Power representatives, and other interested persons regarding this matter, but part of the presentations by the applicant and the NRC staff may be closed in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 order to discuss information that is proprietary to
2 the licensee and its contractors pursuant to 5 U.S.C.
3 552(b)(C)(4).

4 Attendance at the meeting that deals with
5 such information will be limited to the NRC staff and
6 its consultants, Kairos Power, and those individuals
7 and organizations who have entered into an appropriate
8 confidentiality agreement with them. Consequently we
9 will need to confirm that we have only eligible
10 observers and participants in the closed part of the
11 meeting.

12 The rules for participation in all ACRS
13 meetings including today's were announced in the
14 Federal Register on June 13th, 2019. The ACRS section
15 of the U.S. NRC public website provides our charter,
16 bylaws, agendas, letter reports, and full transcripts
17 of all Full and Subcommittee meetings including slides
18 presented there. The meeting notice and agenda for
19 this meeting were posted there. We have received no
20 written statements or requests to make an oral
21 statement from the public.

22 The Subcommittee will gather information,
23 analyze relevant issues and facts, and formulate
24 proposed positions and actions as appropriate for
25 deliberation by the Full Committee.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 The rules for participation in today's
2 meetings have been announced as part of the notice of
3 this meeting previously published in the Federal
4 Register.

5 A transcript of the meeting is being kept
6 and will be made available as stated in the Federal
7 Register notice.

8 Due to the COVID pandemic today's meeting
9 is being held over Microsoft Teams for ACRS, NRC
10 staff, and the licensee attendees. There is also a
11 telephone bridge line allowing participation of the
12 public over the phone.

13 When addressing the Subcommittee that
14 participant should first identify themselves and speak
15 with sufficient clarity and volume so that they may be
16 readily heard. When not speaking we request that
17 participants mute your computer microphone or phone.

18 We'll now proceed with the meeting. And
19 I'd like to start by calling on William Kennedy, NRR
20 management.

21 MR. KENNEDY: Well, good morning, Mr.
22 Chairman and distinguished members of the Advisory
23 Committee on Reactor Safeguards. My name is William
24 Kennedy. I'm the Acting Chief of the Advanced Reactor
25 Licensing Branch in NRR's Division of Advanced

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 reactors and Non-Power Production and Utilization
2 Facilities.

3 It's my pleasure to be here today to
4 provide introductory remarks on behalf of the
5 division. With me today are Ms. Michelle Hart, who is
6 the lead technical reviewer. Mr. Alex Chereskin.
7 They are both from the Advanced Reactor Technical
8 Branch No. 2 in DANU. Mr. Jason White is here from
9 the External Hazards Branch in the Division of
10 Engineering and External Hazards. And all of them
11 will be providing the staff presentation. We also
12 have Mr. Samuel Cuadrado de Jesus who is providing
13 project management support for the review of this
14 topical report.

15 The staff is looking forward to
16 discussions with and feedback from ACRS members today
17 on the Draft Safety Evaluation of the Kairos Power
18 topical report that's titled KP-FHR Mechanistic Source
19 Term Methodology. So as you will hear this topical
20 report is important for Kairos' development of
21 accident source terms and atmospheric dispersion
22 values for use in radiological consequence analysis
23 for siting and safety analysis for Kairos Power's
24 fluoride salt-cooled high-temperature reactor designs,
25 also known as the KP-FHR designs.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 The report also describes development of
2 source terms for estimation of dose for anticipated
3 operational occurrences in design-basis events to be
4 used in the endorsed NEI 18-04 methodology for
5 applicants to categorize events, classify and describe
6 special treatment of structures, systems, and
7 components, and assess defense-in-depth for non-light
8 water reactors.

9 This topical report is related to other
10 Kairos topical reports such as the Fuel Performance
11 Methodology Report. Limitations and conditions on the
12 use of the topical report are identified to ensure
13 that the methods and underlying assumptions are
14 applicable to the specific design in future KP-FHR
15 license applications.

16 So I'd just like to note that this is the
17 fourth time the staff and Kairos Power have had the
18 opportunity to brief ACRS on Kairos' topical reports
19 and so the staff appreciated the helpful comments from
20 the ACRS on the recent topical report evaluation
21 covering reactor coolant scaling methodologies,
22 licensing modernization project implementation, and
23 most recently the Fuel Performance Methodology Report.

24 Staff looks forward to continuing to work
25 with Chairman Petti and the rest of the ACRS members

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 and staff as we complete reviews of more Kairos Power
2 topical reports and review license applications for
3 facilities that will use the Kairos Power design.

4 In September we received a construction
5 permit application for the Kairos Power Hermes test
6 reactor, and that is currently being reviewed for
7 acceptance.

8 I'd also like to highlight the working
9 relationship between the NRC staff and Kairos Power
10 has been excellent. Similar to previous reviews of
11 Kairos Power topical reports the staff and Kairos have
12 used public meetings as an efficient means for
13 addressing technical issues without the need for
14 significant formal requests for additional
15 information.

16 And then finally I'd like to give a big
17 thanks to the technical staff for their efforts to
18 produce a high-quality Draft Safety Evaluation Report
19 and also for project management of this review.

20 So that concludes my opening remarks.
21 Thank you very much.

22 CHAIR PETTI: Thank you. Before we turn
23 it over to Kairos I just want to note for the record
24 that our consultant Steve Schultz has joined us.

25 So, Kairos, the floor is yours.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MEMBER BROWN: Dave, are they showing
2 their slides?

3 CHAIR PETTI: Not yet.

4 Kairos, are you out there?

5 MEMBER BROWN: Just wanted to make sure I
6 wasn't the only one.

7 MR. PEEBLES: Okay. Sorry. We were
8 having some technical difficulties with the conference
9 room.

10 Thank you, Mr. Chairman, and good morning,
11 everyone. My name is Drew Peebles. I'm the Manager
12 of Licensing and Safety Integration here at Kairos
13 Power. Before we get started I would like to thank
14 the ACRS members (audio interference).

15 CHAIR PETTI: Okay. I don't hear them
16 anymore. Do other people have that problem?

17 MEMBER BROWN: It sounds like we've lost
18 them, Dave.

19 MEMBER MARCH-LEUBA: Yes, like -- yes,
20 they were having -- we were trying to test their
21 conference room yesterday. They were having some
22 technical issues.

23 CHAIR PETTI: Okay.

24 (Pause.)

25 CHAIR PETTI: Okay. I hear you guys

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 again.

2 MR. PEEBLES: Sorry about that. So I was
3 saying we would like to thank the ACRS members for
4 your continued interest in Kairos Power. William
5 Kennedy mentioned that we've had four briefings in
6 front of the ACRS to date. I believe this is the
7 fifth topical that we will bring to you on.

8 (Audio interference.)

9 CHAIR PETTI: And they've faded out again.

10 So some of the -- I'm assuming some of the
11 Kairos folks that I see listed that may not be in the
12 conference room are texting them and telling them.

13 (Pause.)

14 MR. PEEBLES: Sorry about this. So I
15 think I mentioned that William Kennedy also mentioned
16 that we were -- that we've briefed the ACRS four times
17 to date and I believe this is the fifth topical that
18 we get a chance (audio interference).

19 CHAIR PETTI: Okay. We're continuing to
20 have problems. I'm wondering if I should go out and
21 come back in, if that would help.

22 MR. PEEBLES: Okay. Can you hear us now?

23 CHAIR PETTI: A little echo, but yes. Oh,
24 a big echo.

25 MR. PEEBLES: Okay. We've joined with a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 different laptop. Sorry about the conference room
2 issues.

3 So as I was mentioning, we have recently
4 submitted our construction permit application for our
5 non-power reactor that we refer to as Hermes and we
6 look forward to engaging with the ACRS in the review
7 of that application as well.

8 I would also like to thank the NRC staff
9 for a thorough and efficient review of the topical
10 report. I think all of the feedback and discussions
11 made sure that we had a complete product.

12 So I'm joined here by the lead technical
13 contributor to the topical report, Dr. Matthew Denman,
14 who will be giving the presentation today. We are
15 also joined by several subject matter experts that
16 will be available to answer detailed questions in
17 their areas of expertise.

18 Just as a reminder to the Kairos
19 attendees, if you do come off mute, please remember to
20 introduce yourselves.

21 And with that I will turn it over to Matt.
22 And let me make sure I can share my slides on this
23 computer.

24 DR. DENMAN: Yes. So while Drew is
25 pulling the slides up I'll begin my introductions.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Mr. Chairman, members of the Committee,
2 thank you very much for your time today. My name is
3 Matthew Denman and I am a principal reliability
4 engineer at Kairos Power and it is going to be my
5 pleasure today to brief you on Kairos Power's
6 Mechanistic Source Term Methodology Topical Report.

7 And, Weidong, can you make sure that I'm
8 a presenter so I can share my screen?

9 MR. WANG: I think you are. You are the
10 presenter.

11 DR. DENMAN: The --

12 MR. WANG: Maybe you -- a different --
13 okay. Now it's because --

14 DR. DENMAN: Yes.

15 MR. WANG: -- you changed it up. Okay.
16 Let me just go and make -- yes, it's changed.

17 (Pause.)

18 MR. WANG: We can see your screen now.

19 DR. DENMAN: Thank you so much.

20 Okay. So with that Kairos Powers' mission
21 is to enable the world's transition to clean energy
22 with the ultimate goal of dramatically improving
23 people's quality of life while protecting the
24 environment.

25 In order to achieve this mission we must

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 prioritize that our efforts focus on a clean energy
2 technology that is both affordable and safe. Today's
3 topic, mechanistic source term, is key to allowing
4 Kairos Power to demonstrate the safety of our design
5 which will enable the affordability of that design.

6 At a high level our approach to source
7 term is to decompose the problem into a series of
8 material-at-risk throughout the plant and barrier
9 release fractions that will separate that material at
10 risk from our receptor at the site boundary.

11 For each barrier radionuclides are grouped
12 and then we model the release of that group of
13 radionuclides through the barrier using a
14 representative element. Barriers for radionuclide
15 release are the TRISO fuel and the FLiBe coolant.
16 These form our functional containment for
17 radionuclides.

18 Again radionuclide groupings are used to
19 facilitate transport of radionuclides through the
20 barriers and unique grouping structures will exist for
21 various release models. So for say the fuel you might
22 have a different grouping structure for mechanical
23 grinding of the fuel verse a diffusion of
24 radionuclides through the TRISO barriers.

25 At steady --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 CHAIR PETTI: Matthew?

2 DR. DENMAN: Yes, sir.

3 CHAIR PETTI: I just have a real high-
4 level question here on the methodology.

5 DR. DENMAN: Sure.

6 CHAIR PETTI: I understand it's to be used
7 really for accidents, but do you guys plan to use this
8 same methodology to support the worker dose
9 evaluations, shielding needs, or are you guys thinking
10 about a completely different approach there?

11 DR. DENMAN: That is a very good question
12 and thank you very much for it. The approach in the
13 topical is limited to off-site dose calculations and
14 explicitly excludes worker doses or control room dose.
15 Similar methods may be used to quantify those dose
16 metrics, but the complete strategy of how to drive a
17 conservative consequence estimate has not been
18 included in this topical report.

19 CHAIR PETTI: Okay. Thanks.

20 DR. DENMAN: So for sources of steady
21 state material at risk in the system the overwhelming
22 majority of our material at risk is contained within
23 our TRISO fuel. That TRISO fuel can exist in multiple
24 configurations. Most of our TRISO fuel will exist as
25 either completely intact particles or with a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 compromised inner or outer PyC layer and all of these
2 configurations are expected to retain an overwhelming
3 majority of the fission products and heavy metals
4 contained within those particles.

5 There will be -- due to manufacturing and
6 in-service, steady state in-service failures there
7 will be some TRISO particles that will have
8 compromised silicon carbide layers, and these
9 particles are expected to release a certain quantity
10 of their fission products into the FLiBe coolant
11 during steady state irradiation.

12 Additionally, as part of the manufacturing
13 process there is a very small fraction of dispersed
14 uranium that is expected throughout the fuel form and
15 the fission products from this dispersed uranium have
16 no credited fission product or heavy metal retention
17 capabilities within the fuel.

18 These fission products and heavy metals
19 will move into the circulating activity where they
20 will be combined with impurities that are expected
21 within the salt including sodium, uranium, thorium,
22 various other corrosion products.

23 The circulating activity will continue to
24 generate radionuclides via transmutation. There will
25 be some tritium production within the FLiBe coolant.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 The tritium primarily will either be absorbed into
2 graphite pebbles and structural materials or will move
3 into various off-gas cleanup systems.

4 When we talk about how we're going to
5 quantify the material at risk throughout the plant,
6 for the fuel we will focus on our manufacturing
7 specifications. We will utilize the KP-BISON Fuel
8 Performance Code to estimate the depletion of
9 radionuclides from the fuel and we will use our Core
10 Design Topical Report methodology in order to
11 calculate the burnup and buildup of fission products
12 within the fuel.

13 The circulating activity material at risk
14 will be limited by technical specifications that will
15 be set as limiting conditions of operations for our
16 plant.

17 The holdup of tritium in structures and
18 graphite pebbles will be calculated via the tritium
19 source term methodology discussed in the next few
20 slides. And various material at risks outside of our
21 functional containment will be limited by its
22 technical specifications, specifically the FLiBe
23 cleanup and -- one sec.

24 (Pause.)

25 DR. DENMAN: Sorry. My apologies for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 those technical difficulties.

2 The material at risk within the various
3 cleanup systems will be limited by technical
4 specifications.

5 For steady state tritium inventory
6 evaluations, tritium will be -- or tritium modeling
7 will include transport and holdup in the fuel pebbles
8 and core moderator and graphite structures in the
9 vessel and primary piping and intermediate heat
10 exchange steel. Tritium is produced in the KP-FHR
11 through the reactions listed below. The top two
12 reactions are the primary reactions that contribute to
13 tritium production in the system and the bottom two
14 reactions are the primary reactions contributing to
15 lithium-6 buildup, which will subsequently be sources
16 of tritium production.

17 CHAIR PETTI: So, Matt, just another
18 question. So you're not explicitly modeling tritium
19 production in the graphite from lithium impurities nor
20 ternary fission in the particles?

21 DR. DENMAN: So, well, we are --

22 CHAIR PETTI: I mean they may be
23 significantly smaller here but --

24 DR. DENMAN: Yes.

25 CHAIR PETTI: -- it's probably worth just

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 a -- I think they'll be smaller given the capability
2 to make good graphite today. Years ago impurities
3 were higher and you had to worry about those things.

4 DR. DENMAN: Understand. Yes, we are not
5 explicitly modeling the lithium and the graphite, nor
6 the ternary fission within the fuel due to the fact
7 that an overwhelming majority of the tritium that is
8 expected to be produced in the system will be produced
9 via the FLiBe reactions shown on the slide.

10 CHAIR PETTI: Okay. Thanks.

11 DR. DENMAN: The KP-FHR is uniquely suited
12 to retain radionuclides due to the large margins to
13 fuel damage from our operating range. Our core inlet
14 and outlet temperatures are in the 550 to 650 range.
15 Our FLiBe freezing temperatures and our -- sorry, our
16 FLiBe boiling temperatures are not until 1,430 degrees
17 C. And our peak fuel temperatures above which we
18 would potentially expect silicon carbide-induced
19 failures aren't until 1,600 degrees C. So there is a
20 large margin to the functional failure of our various
21 radionuclide barriers within our functional
22 containment approach.

23 For MAR mobilization for anticipated
24 operational occurrences, design-basis events and
25 design-basis accidents it should be emphasized that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 under design -- or under the conditions expected for
2 these events only a minor fraction of the total
3 material at risk in our plant can potentially be
4 mobilized because a majority of our material at risk
5 is contained safely within our TRISO fuel.

6 We expect no incremental fuel failures
7 below 1,600 degrees C and there are multiple inherent
8 safety features in our design to protect the fuel from
9 achieving such high temperatures.

10 The material at risk in the reactor
11 coolant as well as the material at risk presented in
12 other locations can be mobilizing in anticipated
13 operational occurrences, design-basis events, and
14 design-basis accidents particularly via aerosolization
15 of the FLiBe such as for jet breakup in a hypothetical
16 guillotine rupture of a primary pipe or vaporization
17 of chemical species within the FLiBe at elevated
18 temperatures, although there are only limited release
19 rates expected due to evaporation of soluble
20 radionuclides from FLiBe at temperatures below 816
21 degrees C, which is our vessel limit and sets the
22 upper bound of our design-basis --

23 CHAIR PETTI: Matt?

24 DR. DENMAN: Yes, sir.

25 CHAIR PETTI: Just the first sub-bullet in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 the first bullet, the way it's stated. The EPRI
2 topical report has a failure fraction at -- what's
3 called at high temperature. It's a statistical zero
4 level because the testing showed there were no
5 failures. Are you assuming that level for any
6 accident event or are you saying zero is zero?

7 DR. DENMAN: We will use the KP-BISON Fuel
8 Performance Topical Report to calculate the stresses
9 and strains on the various barriers and the
10 incremental fuel failure fraction. It is our
11 expectation that that value will be near zero, below
12 1,600 degrees C, but our methodology is to actually
13 calculate that.

14 CHAIR PETTI: So I have the same problem
15 with the last topical. If that number is lower than
16 what has been measured statistically, how do you
17 validate that number?

18 DR. DENMAN: I will pass this question
19 along to our fuel performance expert Ryan Latta.

20 Ryan, can you jump on?

21 MR. LATTA: Hello?

22 DR. DENMAN: Yes, Ryan?

23 MR. LATTA: Yes, this is Ryan Latta. Yes,
24 the current methodology is to use the Fuel Performance
25 Code. And it calculates the radiation history, uses

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 the radiation history's input, and then goes through
2 the transient analysis and uses the actual conditions
3 that are for the accident, which are significantly
4 below conditions that were tested for the furnace
5 annealing test. So we probably have a 4 to 500 degree
6 margin from the conditions that were in the furnace
7 safety testing. So when you follow that track you end
8 up with very low, near negligible failure fractions
9 during an accident event. And so that's how the --
10 that's the methodology we followed for --

11 DR. DENMAN: And I will add -- this is
12 Matthew Denman again. I will add that the methodology
13 for determining where the -- or which barriers are
14 intact are failed lies squarely within the fuel
15 performance methodology. This topical report on
16 source term basically looks only at -- once you've
17 determined which barriers are available for release,
18 how do you move radionuclides through those barriers?

19 So we kind of take the configuration of
20 the TRISO fuel as a given boundary condition from the
21 Fuel Performance Topical Report.

22 CHAIR PETTI: All right.

23 MEMBER REMPE: This is Joy. And first of
24 all, I'd like to ask people who aren't speaking to
25 mute their computers or phones because there's a lot

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 of background noise I'm hearing, but a couple of
2 questions.

3 I know the topical report says you don't
4 -- now I'm getting an echo. So again, people, please
5 mute. Okay?

6 But anyway, the topical report says you're
7 not going to deal with beyond-design-basis events, but
8 yet several times it talks about well, you'll just
9 continue things for beyond-design-basis events. So
10 could you clarify, are you planning to go ahead and
11 use these same models and extend them for beyond-
12 design-basis events or are you going to use a
13 different methodology?

14 And then I didn't ask earlier, but I was
15 curious, the topical report continues to say that, as
16 other ones did, the coolant is an important barrier
17 for release. And it doesn't talk about the fact that
18 the coolant can interact with other barriers and
19 degrade them. And how are you planning to modify this
20 methodology to consider this degradation?

21 I'm sorry. Did -- I'm not hearing any
22 response, so maybe now it's time to un-mute, whoever
23 is trying to talk or respond.

24 MEMBER BLEY: Joy, I can hear you, so they
25 ought to.

1 MEMBER REMPE: Thank you for that
2 confirmation, but I was asking a lot of people to mute
3 so maybe they haven't un-muted yet.

4 DR. DENMAN: Yes, I think I got muted
5 without my knowledge. My apologies.

6 Thank you very much, Joy, for those
7 questions. I will answer the beyond-design-basis
8 question first.

9 So the methodologies that we developed for
10 this topical report were the methodologies from
11 phenomena that we expected to exist in anticipated
12 operational occurrences, design-basis events, and
13 design-basis accident boundary conditions. It is
14 possible that in beyond-design-basis space that you
15 will experience similar boundary conditions, and in
16 those cases the methodologies may be extended into
17 beyond-design-basis conditions. However, there are
18 expected to be additional scenarios in beyond-design-
19 basis event space that extend beyond the applicability
20 of these models, and at that point we would have to
21 revise and justify the models in a future license
22 application. Does that answer your --

23 MEMBER REMPE: So you are planning to
24 extend or do something with KP-BISON? You're not just
25 going to say okay, now we're going to go and use

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 something else that's similar to MELCOR or something
2 like that, or you've just not decided yet what tool
3 you'll use?

4 MR. PEEBLES: So this is Drew Peebles with
5 Licensing. So not in this topical. So we would
6 definitely deal with that in the future application of
7 the methodology. So if we do extend beyond the
8 design-basis, then we would have to justify how we're
9 doing that in that future license application. But
10 for this particular topical report we weren't asking
11 for an NRC finding on beyond-design-basis conditions.

12 MEMBER REMPE: Again, I understand that
13 you've said that you're limiting to design-basis
14 events, but then in the report it continues to make
15 reference to beyond-design-basis events and I'm not
16 getting an answer to the question are you going to use
17 this tool or another tool, or you've not decided what
18 tool --

19 DR. DENMAN: Yes, I think the short answer
20 is we haven't decided upon the beyond-design-basis --

21 (Simultaneous speaking.)

22 MEMBER REMPE: Okay. And then what about
23 degradation due to long-term operation, from corrosion
24 or something between the coolant, which you continue
25 to say you think is a barrier, but one thing that's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 unusual about this design is that it's -- there's the
2 potential that some of the barriers can degrade other
3 barriers. And how are you planning to modify -- I
4 didn't see anything discussed about how you will
5 simulate that phenomena in this topical report.

6 DR. DENMAN: Thank you very much for that
7 question, Joy. Particularly for the fuel in transient
8 conditions we do not expect under very short time
9 horizons for there to be induced failure of the fuel
10 barrier such that you would have fuel/FLiBe
11 interactions, and that is explicitly called out in the
12 topical report.

13 Under longer term conditions if there were
14 to be fuel/FLiBe interactions, then the radionuclides
15 from the fuel would move into the FLiBe and join the
16 circulating activity. And we have a technical
17 specification on circulating activity, so as long as
18 the circulating activity remains below that technical
19 specification, our methodology would still hold.

20 MEMBER REMPE: So --

21 DR. DENMAN: Matthew. My apologies.

22 MEMBER REMPE: So you're basically saying
23 you don't model degradation with long-term operation.
24 You just think it's not going to be that important as
25 long as the coolant circulating activity stays below

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 a certain value?

2 DR. DENMAN: Correct.

3 MEMBER REMPE: That you're just not
4 simulating that phenomena? Then what about can the
5 circulating activity, if it were to start degrading
6 other subsequent barriers due to corrosion of some of
7 the structural material? Are you still -- are you
8 also going to be neglecting it? And then you'll -- is
9 this something that's built into the model, you
10 constantly do a check to make sure the circulating
11 activity stays below that value all the time so that
12 you don't ever exceed this? So is that something
13 you've put into KP-BISON to do some sort of check?

14 DR. DENMAN: So the circulating activity
15 technical specification will be a limiting condition
16 of operation. We will monitor the circulating
17 activity over the life time of the reactor operations
18 and ensure that we are below the value set forth in
19 our license.

20 MEMBER REMPE: We're talking about the
21 tool today. And so you're telling me well okay, so
22 the tool doesn't have to consider this degradation
23 interaction between the coolant barrier and the
24 barriers within the fuel. So basically you're saying
25 that if you're doing a simulation to provide some sort

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 of source term to the NRC, you're constantly doing
2 some sort of check to make sure that you don't -- if
3 you're going to do source term after long-term
4 operation, end of cycle, that you've done a check
5 always in the tool to make sure it's below that value,
6 right? Is what you're telling me?

7 DR. DENMAN: Thank you very much. Not
8 quite. We will set a technical specification in our
9 license application that sets the upper limit of
10 circulating activity in our FLiBe. We will use KP-
11 BISON to model normal buildup and diffusion of
12 radionuclides out of the fuel, but that only sets the
13 initial condition of material at risk within the fuel
14 itself.

15 In the FLiBe for any accident condition we
16 will use the technical specification -- or any design-
17 basis accident condition we will use the technical
18 specification value as the initial condition of
19 circulating activity in the FLiBe. So we will not be
20 calculating in an a priori estimating what that
21 release would be. We will use the upper bound value
22 of acceptable circulating activity as our initial
23 condition for the accident.

24 MEMBER REMPE: Okay. And then what about
25 if there's interactions between the FLiBe and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 structural material?

2 DR. DENMAN: So the Structures Topical
3 Report will ensure that the vessel is not degraded
4 with -- by the FLiBe. Within our anticipated
5 operational range any other structure system and
6 component is not safety-related, and breaks in those
7 systems would be evaluated in our postulated event
8 analysis.

9 MEMBER REMPE: Okay. Thank you.

10 DR. DENMAN: So as a part of this analysis
11 we're not explicitly modeling that.

12 MEMBER REMPE: Okay. Thank you.

13 CHAIR PETTI: Just a clarification. So
14 the tech spec on circulating activity, is that
15 basically equivalent to what the gas reactor guys are
16 talking about SARDL?

17 DR. DENMAN: They're related concepts,
18 although we do not believe that we would set a limit
19 on the circulating activity that would be the break
20 point between acceptable or unacceptable off-site
21 doses. We would choose a value that is -- that we
22 believe is achievable to be monitored and measurable
23 and ensure the safety of the system. But it might be
24 slightly -- formulated in a slightly different way
25 that the SARDLs.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 CHAIR PETTI: Okay.

2 DR. DENMAN: Okay. So and then there's
3 also going to be tritium that's going to be stored in
4 the graphite pebbles and structures that can be
5 desorbed at elevated temperatures and our methodology
6 will examine that release.

7 Our design-basis accident site boundary
8 dose will be used -- dose is going to demonstrate that
9 the KP-FHR meets dose limits in 10 C.F.R. 50.34,
10 52.79, and 100.11. Again, technical specifications
11 will be set on the activity of the FLiBe, cover gas
12 and other systems, and the system will be design to
13 preclude incremental fuel failures from DBA conditions
14 as evaluated by KP-BISON.

15 Anticipated operational occurrences and
16 design-basis event source term analyses are similar to
17 design-basis accidents, but more realistic assessments
18 of barriers, mitigation strategies and initial
19 conditions may be assumed.

20 The circulating activity technical
21 specification will be used to inform operational
22 limits on circulating activity. These operational
23 limits may be more realistic conditions for normal
24 operation effluent calculations as well as anticipated
25 operational occurrences and design-basis events.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Our radionuclide grouping and transport
2 approach is very similar to that used in light water
3 reactor safety analysis. I have the MELCOR grouping
4 structure on the right here where you can see the
5 various chemical groups and then the representative
6 element at the top that represents now the releases
7 from those groups are calculated for light water
8 reactor. We take a similar approach, although we
9 evaluate the grouping structures specifically to the
10 barrier and the release mode within that barrier.

11 So essentially our approach is we look at
12 individual isotopes within a barrier and combine them
13 into their RN groups, their radionuclide groups. We
14 calculate the release fractions for each radionuclide
15 group associated with the medium as calculated by
16 driving forces within that barrier: temperatures,
17 pressures. Release fractions are combined with
18 relevant inventories to determine the quantity of that
19 material that is mobilized.

20 Once you move from one barrier to the next
21 the radionuclide inventory is combined with any
22 radionuclides that are already present in that next
23 barrier and then regrouped for subsequent
24 mobilization. Once you reach the gas space the dose
25 consequences for radionuclides that are transferred

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 into the gas space are evaluated with RADTRAD and
2 ARCON.

3 CHAIR PETTI: So, Matthew, I had bad
4 network quality there for a minute so I missed it, but
5 the groupings are the same no matter where the fission
6 product is in the system, or does it -- when it's in
7 the fuel it's considered one way because of the
8 chemistry there. When it's in the salt it's
9 considered because of the chemistry there?

10 DR. DENMAN: Correct. Every barrier will
11 have its unique grouping structure. And specifically
12 for the fuel there is a unique grouping structure for
13 diffusion versus mechanical grinding of the fuel. So
14 different release pathways may have their own unique
15 grouping structure compared to the -- and then each
16 barrier will have its own unique grouping structure.

17 CHAIR PETTI: Okay.

18 DR. DENMAN: Okay. Our primary barrier
19 for radionuclide retention is our TRISO fuel. This
20 fuel contains an overwhelming majority of the material
21 at risk within our plant during normal and off-normal
22 operating modes. Again, a series of diverse and
23 robust barriers to radionuclide retention with
24 extensive industrial fabrication experience and
25 irradiation under a variety of conditions such as the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Advanced Gas Reactor Development Program as mentioned
2 earlier.

3 Our TRISO fuel manufacturing
4 specifications will determine how the fuel
5 configurations begin in the transient. Fission
6 products will diffuse from imperfect particles,
7 primarily particles with failed silicon carbon layers
8 or that have exposed kernels. Radionuclides from
9 heavy metal contamination from the manufacturing
10 process will have no credit for radionuclide retention
11 in steady state.

12 Minimum expected steady state diffusion of
13 radionuclides are expected from the remaining
14 configurations with intact silicon carbide layers.
15 Compromised configurations will partially or entirely
16 be depleted fission products during steady state thus
17 reducing the available material at risk within those
18 TRISO configurations during the transient.

19 For the FLiBe barrier this is the second
20 part of our functional containment for radionuclide
21 retention. Once radionuclides are in the FLiBe they
22 will be separated into either salt soluble compounds,
23 suspended oxides, noble metals or gases. And Kairos
24 Power's Fuel Development Program, or sorry, FLiBe
25 Development Program builds on radionuclide retention

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 experience in the molten salt reactor experiment with
2 the exception that our salt is going to be much, much
3 cleaner than what was experienced in MSRE, which was
4 a fuel salt system.

5 CHAIR PETTI: So, Matthew, just a question
6 on that, and if I get into proprietary stuff, just
7 tell me and we'll cover it in the closed session.

8 I noticed that you had put some fissile
9 impurities in the salt, and I was surprised at that
10 level being that high. And I wasn't sure if that was
11 just being conservative or what was done back in the
12 old days of MSRE or whether that actually is what you
13 get.

14 My experience in gas reactors is in the
15 old days stuff was just not as clean as you can get
16 today with today's technology and I wasn't sure
17 whether this was a holdover from that. I would have
18 thought you'd probably be able to get better, cleaner
19 salt than that.

20 DR. DENMAN: So the cleanest of the salt
21 is going to be dependent upon the economics of the
22 system and how much we want to pay for various grades.
23 Those decisions are not made at this point in time and
24 our methodology is designed to be flexible enough to
25 account for various levels of impurities.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 CHAIR PETTI: So that's sort of a -- let's
2 just say a conservative level. That may not be what
3 you actually see in practice.

4 DR. DENMAN: Correct.

5 CHAIR PETTI: Okay.

6 DR. DENMAN: For tritium transport,
7 tritium transport within structures is determined by
8 mass transfer coefficients from FLiBe flow
9 characteristics throughout the system. Transport
10 within structures is determined based upon material
11 properties such as diffusion within and through steel,
12 diffusion and trapping within pebbles and structural
13 graphite.

14 Salt structure boundary conditions set by
15 material tritium -- is set by material tritium
16 solubility, particularly Henry's Law for solubility of
17 tritium fluoride and tritium gas in FLiBe, and
18 Sievert's Law for solubility of tritium in steel.

19 CHAIR PETTI: So, Matthew, just a comment
20 here. The amount of literature on tritium behavior in
21 these materials, both the salt and the graphitic
22 material, is quite large and there's a lot of
23 uncertainty. These measurements are not easy to make.
24 Diffusion in liquids are notoriously difficult and
25 have high uncertainty. Solubilities are not easy.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 It is now understood better that simple
2 experiments where one injects tritium into molten
3 coolants like this show a bias. The tritium doesn't
4 actually go in. It can sit along the surface. If you
5 think of like a loop. This has been shown in Europe
6 in the Fusion Program for a different coolant that's
7 a low-solubility coolant. FLiBe is a low-solubility
8 coolant.

9 And I think it's very difficult. This is
10 exactly how I would model it. I just think the
11 validation is going to be quite challenging because
12 the experiments may have these biases that you --
13 until you get to the actual in situ generation of
14 tritium, you may be surprised. And it's just
15 something that I think when you're doing sensitivity
16 studies on the model you got to open up the window
17 here because there's a lot of stuff that even though
18 the experimentalists have done the best that they can
19 do, without in situ generating tritium it's really
20 difficult.

21 In terms of the graphitic material I would
22 again caution that the fusion experiences on graphites
23 that are not these graphites. Pebble graphitic
24 material is not a graphite, whereas the -- your
25 reflective material is a nuclear graphite. Those are

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 very different microstructures so that there's very
2 big differences potentially in trapped concentrations.
3 I believe the trapped energies are probably generic to
4 carbon materials, but the actual concentrations are
5 very strongly microstructural-dependent. Radiation
6 can affect it, too. All of these things make it much
7 more complicated than these really nice elegant
8 models.

9 And if you go back -- you have to go back
10 a little ways in the fusion world to see some of the
11 models and the differences and some of the complexity
12 there. It's just a caution that when you think about
13 the validation, you think about sensitivity, keep the
14 window open large because of these differences.

15 I also recommend that if you haven't
16 looked at complexity of models, take a look at the
17 modeling that's done to date. There has been recent
18 publications on air ingress with graphite. Oak Ridge
19 and Idaho have done a tremendous amount of modeling,
20 highly complex, and they try to bring in the
21 microstructure. And it takes you back to say, wow,
22 there's a lot there. They spent a decade getting all
23 the parameters that you need to really understand it.

24 And then you look at these models which
25 are much simpler and it just gives you a cause for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 concern. So it's worth looking at some of that as you
2 think about how you're going to bound things and do
3 sensitivity analysis and the like.

4 DR. DENMAN: Thank you very much for your
5 feedback on that. It's very valuable and insightful
6 and we'll take it as we move forward with this
7 approach.

8 For tritium from the FLiBe-free surface,
9 tritium fluoride and tritium gas can both exist as
10 dissolved gases in the FLiBe. Contributions to off-
11 site dose would either require permeation into vessel
12 or piping and then release into the reactor building
13 or evolution into the gas space which is modeled via
14 the gas transport equations influenced by the
15 experiments as shown below.

16 For gas space analysis we are using the
17 NRC codes RADTRAD and ARCON96. These are used to
18 model radionuclides traveling through the building and
19 off site. And to support dose calculations the
20 existing models and framework set forth in these codes
21 are accepted as is.

22 For RADTRAD as input we need the mobilized
23 material at risk from the previous barriers as
24 previously discussed. RADTRAD will handle all the
25 radionuclide decay and for the entire duration of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 transient and use the Henry correlation for aerosol
2 settling, and conservatively and prescriptively
3 leakage rates will be applied out of the reactor
4 building into the environment.

5 For ARCON the release definitions around
6 the release of radioactive material from the site the
7 location of the receptor and meteorological conditions
8 at the site are needed to calculate chi over qs.

9 Various limitations are set forth in this
10 topical report. They are listed on the slide, but I
11 will not read them word for word.

12 And with that are there any further
13 questions?

14 CHAIR PETTI: Just another comment in the
15 tritium realm with the nitrate salt. Whenever one is
16 dealing with lower levels of tritium, there's always
17 a waste management concern. You get to a point where
18 the concentrations are so low it's hard to find a
19 disposal route. The folks in EDA (phonetic) have been
20 struggling with this. When you have lots of tritium,
21 there's lots of technologies to be able to concentrate
22 it, move it, get it where you want it to be, put it on
23 a bed or something, but when you get to low
24 concentrations, it's above what's allowed to be
25 released, but it's so low that the technologies to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 deal with it are a problem. So it's just something to
2 put on your tickler list as your design evolves.

3 Again my information may be a little out
4 of date, but this was at least the case ten years ago,
5 but they were still struggling with some of these
6 sorts of issues.

7 DR. DENMAN: Thank you very much for that
8 feedback. It's definitely something that we'll take
9 back as we continue to mature our design.

10 I'm not able to see the chat window or
11 anything, so if there's any further questions?

12 CHAIR PETTI: Yes, members, any questions?

13 DR. DENMAN: Well, hearing none, I really
14 appreciate your time in this open session and look
15 forward to continued conversations in the closed
16 session.

17 CHAIR PETTI: Okay. Thanks.

18 Is Michelle going to talk? Who's going to
19 talk for the staff?

20 MR. CUADRADO DE JESUS: For the staff we
21 don't have presentations for the open session.

22 CHAIR PETTI: Ah, okay. Then I guess with
23 that we can move to the closed session.

24 MR. WANG: Dave?

25 CHAIR PETTI: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. WANG: We need to have public comment.

2 CHAIR PETTI: Yes, yes, yes. So okay,
3 let's open -- anybody that has a comment from the
4 public, *6 to un-mute yourself. Give us your name and
5 your comment.

6 Okay. Hearing none, I guess we will end
7 this open session. And I think all the members should
8 have the link to the closed session.

9 And, Kairos, we'll want you to make sure
10 that all the folks you think should be there should be
11 there and Weidong and our staff will handle the NRC
12 side.

13 So with that we'll see everybody in the
14 closed session.

15 (Whereupon, the above-entitled matter went
16 off the record at 9:56 a.m.)

17

18

19

20

21

22

23

24

25

Enclosure 2

**Open Session Presentation Slides for the November 19, 2021
ACRS Kairos Power Subcommittee Briefing
(Non-Proprietary)**



Kairos Power

KP-FHR Mechanistic Source Term Methodology Topical Report

ACRS Subcommittee Meeting, November 19, 2021



Kairos Power's mission is to enable the world's transition to clean energy, with the ultimate goal of dramatically improving people's quality of life while protecting the environment.

In order to achieve this mission, we must prioritize our efforts to focus on a clean energy technology that is *affordable* and *safe*.


High Level Approach

Source Term Methodology


- Decompose the problem into a series of Material at Risk (MAR) and barrier Release Fractions (RFs) that separate that MAR from a receptor at the site boundary.
- For each barrier, group radionuclides into and model release through that barrier using a representative element for that group.
 - The barriers for radionuclide release are the TRISO fuel and the Flibe coolant (i.e., functional containment).
 - Radionuclide groups are used to facilitate transport through barriers.
 - Unique grouping structures exist for specific release modes (e.g., mechanical grinding of fuel in the PHSS vs diffusion through TRISO barriers).

$$ST^i(t) = \sum_{j=1}^J MAR_j^i(t) \prod_j RF_j^i(t)$$

Sources of Steady State Material at Risk (MAR)




Sources of Steady State Material at Risk (MAR)





Steady State Tritium Inventory

- Tritium modeling will include transport and holdup in:
 - Fuel Pebbles and core moderator
 - Graphite Structures
 - Vessel Steel
 - Primary piping
 - Intermediate Heat Exchangers


- Tritium is produced in the KP-FHR through the following reactions:



Modeled Tritium
Production Reactions



Modeled Li-6
build-in Reactions



KP-FHR Specifications

Uniquely Large Margins Between Operational and Failure Temperatures

Parameter	Value/Description
Reactor Type	Fluoride-salt cooled, high temperature reactor (FHR)
Core Configuration	Pebble bed core, graphite moderator/reflector, and enriched Flibe molten salt coolant
Core Inlet and Exit Temperature	550°C / 600-650°C

Design Temperature Limits	Value
Primary Salt (Flibe) Freezing and Boiling Temperatures	459°C / 1430°C
Maximum ASME Section III, Division 5, SS316 Temperature	816°C
Peak Fuel Temperature Limit	1600°C

Our combination of fuel and coolant provides a uniquely large safety margin.

MAR Mobilization in AOOs, DBEs, and DBAs

Only minor fractions of the total MAR can be mobilized in AOOs, DBEs, or DBAs

- The vast majority of MAR is safely protected in the fuel during AOOs, DBEs, and DBAs.
 - No incremental fuel failure is expected at temperatures $<1600^{\circ}\text{C}$.
 - Multiple inherent safety features protect the fuel from achieving high temperatures.
- MAR circulating in the reactor coolant as well as MAR present in other locations (cover gas, intermediate loop, etc) can be mobilized in AOOs, DBEs, and DBAs.
 - Aerosolization of Flibe – Hypothetical guillotine pipe break or primary pump operations
 - Vaporization– chemical specific evaporation is evaluated across accident temperature profiles
 - Limited release rates are expected from evaporation of soluble radionuclides from Flibe for temperatures below 816°C .
- Tritium stored in graphite, pebbles, and structures can be desorbed at elevated temperatures.

AOO, DBE, & DBA Source Term Methodology

- DBA site boundary dose to demonstrate KP-FHR meets dose limits in 10 CFR 50.34, 10 CFR 52.79, and 10 CFR 100.11.
- A technical specification (tech spec) limit will be set on activity in the Flibe, cover gas, and other systems.
 - The system is designed to preclude incremental fuel failures due to the DBA conditions as evaluated by KP-BISON.
- AOO and DBE source term analyses similar to DBAs, but a more realistic assessment of barriers, mitigation strategies, and initial conditions may be assumed.
- The circulating activity technical spec. will be used to inform an operational limit on circulating activity. This operational limit can be used as a more realistic initial condition for normal operation effluent calculations as well as certain AOOs and DBEs.

Radionuclide Grouping and Transport Approach

- Transport of radionuclides through each medium is evaluated on an RN group basis using the following steps:
 1. Individual isotopes are combined into RN group for each barrier.
 2. Release fractions of each RN group associated with that medium is calculated given driving forces (e.g., temperature, pressure).
 3. Release fractions are combined with the relevant inventories to determine the quantity of material that is mobilized. That incoming material is then:
 1. Combined with the radionuclides already present in the next barrier and then
 2. Regrouped for subsequent mobilization
 4. The dose consequences for radionuclides that are transferred into the gas space are evaluated with RADTRAD and ARCON.


LWR Example



KP-FHR Fuel Element

The Primary Barrier of Radionuclide Retention


- The TRISO fuel form provides the first barrier to radionuclide retention in the KP-FHR for all normal and off-normal operating modes
- TRISO particles utilize a series of diverse barriers to provide robust fuel performance
- Kairos Power's fuel design builds on the AGR fuel development program
 - Extensive industrial fabrication experience
 - Validated irradiation performance under a wide variety of conditions



TRISO Fuel

Configurations for Material at Risk (MAR)

- Fuel manufacturing specifications will determine what radionuclides begin the transient in the fuel:
 - Fission products (FPs) diffusion from imperfect particles
 - Compromised SiC layer but intact IPyC and/or OPyC will release a smaller a range of FPs to the Flibe.
 - Exposed kernels and in-service TRISO failures mobilize mobile a larger range FPs transported to the Flibe at steady state.
 - Radionuclides from heavy metal contamination from the manufacturing process will have no credited retention at steady state.
 - Minimal expected steady state diffusion of radionuclides are expected from the remaining configurations.
- The compromised configurations will be partially or entirely depleted of FPs during steady state, thus reducing the MAR available for release during the transient.




TRISO Cohorts

KP-FHR Flibe Coolant

The Second Barrier of Radionuclide Retention

- The primary coolant, Flibe, provides a secondary functional containment barrier to radionuclide retention in the KP-FHR for all in-core normal and off-normal operating modes.
- Flibe can chemically react with fission and activation products, separating them into:
 - salt soluble compounds
 - suspended oxides
 - noble metals, or
 - gas phases
- Kairos Power's Flibe development program builds on radionuclide retention experience in the Molten Salt Reactor Experiment




Tritium Uptake into Structures


Metallics, Fuel and Moderator Pebbles, Structural Graphite

- Tritium transport to structures determined by mass transfer coefficients from Flibe flow characteristics
- Transport within structures determined based on material properties
 - Tritium diffusion modeled within steels
 - Tritium diffusion + trapping modeled within pebbles and structural graphite
- Salt/Structure boundary condition set by material tritium solubility
 - Henry's law solubility for TF and T₂ in Flibe
 - Sievert's law solubility for T in steel


Examples:



Heat Exchanger – Permeation through Metal



Core – Retention in Pebbles



Downcomer – Vessel Permeation and Reflector Retention

Tritium from Flibe Free Surface

Evolution into the Cover Gas

- Tritium fluoride (TF) and Tritium (T_2) can both exist as dissolved gases in Flibe.
- Contribution to offsite dose would require either:
 - Permeation into vessel or piping and then releasing to the reactor building or
 - Evolution into the cover gas which is modeled using mass transport equations influenced by experiments conducted by Suzuki et al.

$$T_2 \text{ Evolution } \left[\frac{\text{mol}}{\text{s}} \right] = k_{Evol,T_2} A_{Interface} (T_{2,Salt} - T_{2,gas}) \cong k_{Evol,T_2} A_{Interface} T_{2,Salt}$$

$$TF \text{ Evolution } \left[\frac{\text{mol}}{\text{s}} \right] \cong k_{Evol,T_2} A_{Interface} TF_{Salt} (D_{TF}/D_{T_2})$$


A. Suzuki, T. Terai and S. Tanaka, "Tritium release behavior from Li₂BeF₄ molten salt by permeation through structural materials," *Fusion Engineering and Design*, Vols. 51-52, pp. 863-868, 2000.

Gas Space Analysis

Simple and Conservative

- Codes: RADTRAD and ARCON96
 - Gas space transport
 - Dose calculations
 - Existing models are accepted as-is.
- Key Inputs:
 - RADTRAD:
 - Mobilized material-at-risk activities
 - Depletion mechanisms
 - Radioactive decay and/or
 - Henry correlation for aerosol settling.
 - Leakage rates (Conservative)
 - ARCON:
 - Release definitions
 - Receptor definitions
 - Meteorological data

KP MST Models



Limitations

- 1. Approval of KP-Bison for use in fuel performance analysis as captured in KP-TR-010-P (KP-FHR Fuel Performance Methodology).
- 2. Justification of thermodynamic data and associated vapor pressure correlations of representative species.
- 3. Validation of tritium transport modeling methodology.
- 4. Confirmation of minimal ingress of Flibe into pebble matrix carbon under normal and accident conditions, such that incremental damage to TRISO particles due to chemical interaction does not occur as captured in KP-TR-010-P (Fuel Qualification Methodology for the KP-FHR).
- 5. Establishment of operating limitations on maximum circulating activity and concentrations relative to solubility limits in the reactor coolant, intermediate coolant, cover gas, and radwaste systems that are consistent with the initial condition assumptions in the safety analysis report.
- 6. Quantification of the transport of tritium in nitrate salt and between nitrate salt and the cover gas
- 7. The phenomena associated with radionuclide retention discussed in this report is restricted to molten Flibe. The retention of radionuclides in solid Flibe is beyond the scope of the current analysis.
- 8. The methodology presented in this report is based on design features of a KP-FHR (details provided in report). Deviations from these design features will be justified by an applicant in safety analysis reports associated with license application submittals.