

Job Performance Measure**Perform Calorimetric Using Process Plant Computer
(NI Adjustment Required)**JPM Number: RA-1-06-2Revision Number: 2Date: 6/27/21Developed By: Barry Mingus / _____ / 4/23/21
Instructor: Print / Sign DateReviewed By: Benjamin Reyes / _____ / 4/28/21
SME or Instructor: Print / Sign DateReviewed By: Peter Leonhardt / _____ / _____
Operations Representative: Print / Sign DateApproved By: Brian Lewin / _____ / _____
Training Department: Print / Sign Date

JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

NOTE: All steps of this checklist should be performed upon initial validation.
 Prior to JPM usage, revalidate JPM using steps 9 and 13 below.

- | | |
|--|-------|
| 1. Task description and number, JPM description and number are identified. | BR |
| 2. Knowledge and Abilities (K/A) references are included. | BR |
| 3. Performance location specified. (in-plant, control room, simulator, or other) | BR |
| 4. Initial setup conditions are identified. | BR |
| 5. Initiating cue (and terminating cue if required) are properly identified. | BR |
| 6. Task standards identified and verified by instructor or SME review. | BR |
| 7. Critical steps meet the criteria for critical steps and are identified with an asterisk (*). | BR |
| 8. IAW NUREG 1021 Appendix C, clearly identify the task standard (i.e., the predetermined qualitative or quantitative outcome) against which task performance will be measured. | BR |
| 9. Verify the procedure(s) referenced by this JPM reflects the current revision:
Procedure: <u>1BOSR 3.1.2-1</u> Revision: <u>27</u>
Procedure: _____ Revision: _____
Procedure: _____ Revision: _____
Procedure: _____ Revision: _____ | |
| 10. Verify cues both verbal and visual are free of conflict. | BR |
| 11. Verify performance time is accurate. | N/A |
| 12. If the JPM cannot be performed as written with proper responses, then revise the JPM. | N/A |
| 13. When JPM is initially validated, sign and date JPM cover page. For subsequent validations, sign and date below: | _____ |

/	
SME / Instructor (Print/Sign)	Date

/	
SME / Instructor (Print/Sign)	Date

/	
SME / Instructor (Print/Sign)	Date

Revision Record (Summary)

Revision #	Summary
00	<ol style="list-style-type: none">1. New JPM created from N-08 rev 82. Made changes listed in the validation comments
01	<ol style="list-style-type: none">1. Updated to new template.2. Complete rewrite to match current procedure.3. Validated by Mike Lindemann and Eric Hipp.
02	<ol style="list-style-type: none">1. Updated to new template2. Added Task Standard3. Style and format changes

SETUP INSTRUCTIONS

1. Reset the simulator to IC 145

NOTE: It is acceptable to use a similar IC to the IC listed above, provided the specific IC used is verified to be compatible with this and other JPMs that are scheduled to be run concurrently.

2. At 1PM07J verify N44 is ~ 99.0% and verify N41, N42, and N43 100.0%.
3. Verify stapler and calculator available for use by the candidate.
4. Verify simulator printer has sufficient paper and ink to support printing activities.
5. When the above steps are completed for this and other JPMs to be run concurrently then validate, if not previously validated, the concurrently run JPMs using the JPM Validation Checklist.
6. This completes the setup for this JPM.

INITIAL CONDITIONS

1. You are the Unit NSO.
2. The unit is in Mode 1.

INITIATING CUE

You have been directed by the Unit Supervisor to perform a calorimetric per 1BOSR 3.1.2-1, using the Plant Process Computer.

Fill in the JPM Start Time when the student acknowledges the Initiating Cue.

.....

Information For Evaluator's Use:

UNSAT requires written comments on respective step.

* Denotes critical steps: **2, 4, 7, 13, 14, 15, 17, 18, and 20.**

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section. The comment section should be used to document: the reason that a step is marked as unsatisfactory, marginal performance relating to management expectations, or problems the candidate had while performing the JPM. Comments relating to procedural or equipment issues should be entered and tracked using the site's appropriate tracking system.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

.....

JPM Start Time: _____ JPM Sequence #: _____ of _____

<u>Task Standard:</u>					
Candidate will perform a calorimetric and identify that N44 is indicating lower than the other channels. Per 1BOSR 3.1.2-1, the candidate will adjust N44 up to ~100% to satisfy the surveillance. Data Sheet D-1 is to be completed by the applicant in the course of completing the calorimetric calibration to document the actions of the surveillance. Upon completion, all NIs will read approximately the same and the surveillance will be complete with the D-1 data sheet filled out documenting the surveillance data as shown in the KEY.					
<u>STEP</u>	<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
NOTE: Provide trainee with a copy of 1BOSR 3.1.2-1 upon request.					
1.	Refer to 1BOSR 3.1.2-1, Calorimetric Calculation Daily Surveillance	<ul style="list-style-type: none"> Open 1BOSR 3.1.2-1 	<input type="checkbox"/>	<input type="checkbox"/>	—
CUE:	All prerequisites and precautions are met				
* 2.	RECORD percent power readings for N-41, N-42, N-43, and N-44 at 1PM07J on Data Sheet D1.	<ul style="list-style-type: none"> Data obtained and recorded on Data Sheet D1. (±0.5%) <ul style="list-style-type: none"> N41 – 99.99 N42 – 99.99 N43 – 99.99 N44 – 99.00 	<input type="checkbox"/>	<input type="checkbox"/>	—
3.	From the PPC Main Menu screen, SELECT Operator Demandable.	<ul style="list-style-type: none"> Operator Demandable selected. 	<input type="checkbox"/>	<input type="checkbox"/>	—
* 4.	SELECT Calorimetric.	<ul style="list-style-type: none"> Calorimetric selected. 	<input type="checkbox"/>	<input type="checkbox"/>	—
5.	Determine if any Alerts are highlighted.	<ul style="list-style-type: none"> Alerts evaluated. 	<input type="checkbox"/>	<input type="checkbox"/>	—
CUE:	(If any Alerts are actually present) There are NO Alerts.				

<u>STEP</u>	<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
6.	VERIFY the correct Steam Generator Blowdown Flows are displayed for each Loop.	<ul style="list-style-type: none"> • Blowdown flows indicate approximately 50 gpm • Blowdown flows indicate Green on the display • No error code present – No B or S identifier next to the number value. 	<input type="checkbox"/>	<input type="checkbox"/>	—
* 7.	SELECT “Calculation Method”.	<ul style="list-style-type: none"> • Calculation method selected. 	<input type="checkbox"/>	<input type="checkbox"/>	—
8.	Determine if there are any substituted points.	<ul style="list-style-type: none"> • Determine no calculated value has an “S” string attached. 	<input type="checkbox"/>	<input type="checkbox"/>	—
9.	VERIFY desired Calorimetric Method of operation is displayed:	<ul style="list-style-type: none"> • Determine Method 1 – LEFM is displayed 	<input type="checkbox"/>	<input type="checkbox"/>	—
10.	PRINT the Calorimetric Calculation Method Control page.	<ul style="list-style-type: none"> • Calorimetric Calculation Method Control page printed. 	<input type="checkbox"/>	<input type="checkbox"/>	—
11.	DETERMINE the calorimetric time period that will be used.	<ul style="list-style-type: none"> • 10 minute value used. 	<input type="checkbox"/>	<input type="checkbox"/>	—
CUE:	(If asked) There are no flow inconsistencies				
NOTE:	The following step may be performed at any time.				
12.	ATTACH computer printout to the surveillance package.	<ul style="list-style-type: none"> • Printout attached. 	<input type="checkbox"/>	<input type="checkbox"/>	—
* 13.	OBTAIN Percent Power from Computer Printout and RECORD on Data Sheet D1.	<ul style="list-style-type: none"> • Data obtained and recorded on Data Sheet D1. • 99.93% 	<input type="checkbox"/>	<input type="checkbox"/>	—

<u>STEP</u>	<u>ELEMENT</u>	<u>STANDARD</u>	<u>SAT</u>	<u>UNSAT</u>	<u>Comment Number</u>
* 14.	CALCULATE the Power Difference for each Power Range NI Channel using the equation below. $\text{NIS Power}_{\text{(Step F.1)}} - \text{Calorimetric Power}_{\text{(Step F.5)}} = \text{Power Difference}$	<ul style="list-style-type: none"> • Correct value calculated (no margin) <ul style="list-style-type: none"> • N41 + 0.06 • N42 + 0.06 • N43 + 0.06 • N44 - 0.93 	<input type="checkbox"/>	<input type="checkbox"/>	—
* 15.	RECORD on Data Sheet D1.	<ul style="list-style-type: none"> • Correct value recorded for all 4 channels. <ul style="list-style-type: none"> • N41 + 0.06 • N42 + 0.06 • N43 + 0.06 • N44 - 0.93 	<input type="checkbox"/>	<input type="checkbox"/>	—
NOTE: The candidate may determine channels in addition to N44 require adjustment.					
16.	Determine if NIS adjustment is needed for each channel.	<ul style="list-style-type: none"> • Determine only N44 requires adjustment. 	<input type="checkbox"/>	<input type="checkbox"/>	—
CUE:	If asked, the SM does not desire to have adjustments made to NIS channels that have a positive number and are < 0.5%.				
* 17.	OBTAIN the CURRENT percent power reading from the Power Range Channel to be adjusted, at 1PM07J. RECORD on Data Sheet D1.	<ul style="list-style-type: none"> • Obtain N44 current reading and record on Data Sheet D1 ($\pm 0.5\%$) <ul style="list-style-type: none"> • 99.0% 	<input type="checkbox"/>	<input type="checkbox"/>	—
* 18.	SUBTRACT the Power Difference recorded in step F.6 from the current NIS readings recorded in step F.8 to determine the indicated power level to adjust to. RECORD results in on Data Sheet D1.	<ul style="list-style-type: none"> • Correct value recorded. <ul style="list-style-type: none"> • 99.93% 	<input type="checkbox"/>	<input type="checkbox"/>	—
19.	Place the Rod Control system in manual	<ul style="list-style-type: none"> • Verify Rods in Manual 	<input type="checkbox"/>	<input type="checkbox"/>	—
CUE:	(If asked) US acknowledges placing Rods in Manual.				

<u>STEP</u>	<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
CUE:	(If asked) There are no INOPERABLE NI channels.				
NOTE:	If the candidate determines any channels in addition to N44 require adjustment, then repeat JPM steps 20 and 21 for each channel requiring adjustment				
* 20.	Adjust the out of tolerance channels.	<ul style="list-style-type: none"> Adjust the GAIN Potentiometer on the Power Range Drawer B at 1PM07J to the reading recorded in step F.9 99.93% 	<input type="checkbox"/>	<input type="checkbox"/>	—
21.	Verify / Reset positive Rate trip.	<ul style="list-style-type: none"> Check Positive Rate trip light and reset if it is lit. 	<input type="checkbox"/>	<input type="checkbox"/>	—
22.	NI adjustment complete.	<ul style="list-style-type: none"> Initial 'Adjustment Complete' for N44 on Data Sheet D1. 	<input type="checkbox"/>	<input type="checkbox"/>	—
23.	Return Rod control system to auto	<ul style="list-style-type: none"> Place Rods in Auto. 	<input type="checkbox"/>	<input type="checkbox"/>	—
CUE:	(If asked) US acknowledges placing Rods in Auto.				
CUE:	This JPM is complete.				

JPM Stop Time: _____



JPM SUMMARY**Operator's Name:** _____ **Emp. ID#:** _____**Job Title:** EO RO SRO FS STA/IA SRO CertJPM Title: Perform: Calorimetric Using Process Plant Computer (NI Adjustment Required)JPM Number: RA-1-06-2 Revision Number: 2Task Number and Title: R-NI-004, Perform calorimetric calculation

Task Standard: Candidate will perform a calorimetric and identify that N44 is indicating lower than the other channels. Per 1BOSR 3.1.2-1, the candidate will adjust N44 up to ~100% to satisfy the surveillance. Data Sheet D-1 is to be completed by the applicant in the course of completing the calorimetric calibration to document the actions of the surveillance. Upon completion, all NIs will read approximately the same and the surveillance will be complete with the D-1 data sheet filled out documenting the surveillance data as shown in the KEY.

K/A Number and Importance: 2.1.19 (3.9) 015A1.01 (3.5 / 3.8)Suggested Testing Environment: SimulatorAlternate Path: Yes No SRO Only: Yes No Time Critical: Yes No

Reference(s):

Procedure: <u>1BOSR 3.1.2-1</u>	Revision: <u>27</u>
Procedure: _____	Revision: _____
Procedure: _____	Revision: _____
Procedure: _____	Revision: _____

Actual Testing Environment: Simulator Control Room In-Plant Other**Testing Method:** Simulate Perform**Estimated Time to Complete:** 20 minutes **Actual Time Used:** _____ minutes**EVALUATION SUMMARY:**Were all the Critical Elements performed satisfactorily? Yes NoThe operator's performance was evaluated against standards contained within this JPM and has been determined to be: Satisfactory Unsatisfactory**NOTE:** Enter finalized grading, comments, and notes relevant to this evaluation in the associated TQ-AA-150-F03A/B. (See AR [4282419](#)).**Evaluator's Name (Print):** _____**Evaluator's Signature:** _____ **Date:** _____

SRRS: 3D.105 (when utilized for operator initial or continuing training)



INITIAL CONDITIONS

1. You are the Unit NSO.
2. The unit is in Mode 1.

INITIATING CUE

You have been directed by the Unit Supervisor to perform a calorimetric per 1BOSR 3.1.2-1, using the Plant Process Computer.

NIS WORKSHEET
DATA SHEET D1

NOTE

When operating with calorimetric power $\leq 50\%$ and any power range channel is indicating $> 2\%$ of calorimetric power, then adjust the power range channel downward to just meet Technical Specification 3.3.1 requirement of 2% . Further adjustment could result in the power range channel trip setpoints being nonconservative upon a return to full power. However, if any power range channel is indicating low, then adjust it upward to match calorimetric power. **(CM-1)**

1. NIs Power	5. Calorimetric Power	6. Power Difference	7. Initial for No NIs Adjustment
N41 _____	_____	_____	_____
N42 _____	_____	_____	_____
N43 _____	_____	_____	_____
N44 _____	_____	_____	_____

8. Current NIs Power	9. (Step 8 - 6) Power to adjust NIs to	12. Adjustment Complete
N41 _____	_____	_____
N42 _____	_____	_____
N43 _____	_____	_____
N44 _____	_____	_____

NIS WORKSHEET
DATA SHEET D1

NOTE

When operating with calorimetric power $\leq 50\%$ and any power range channel is indicating $> 2\%$ of calorimetric power, then adjust the power range channel downward to just meet Technical Specification 3.3.1 requirement of 2% . Further adjustment could result in the power range channel trip setpoints being nonconservative upon a return to full power. However, if any power range channel is indicating low, then adjust it upward to match calorimetric power. **(CM-1)**

1. NIs Power	5. Calorimetric Power	6. Power Difference	7. Initial for No NIs Adjustment
N41 <u>99.99</u>	<u>99.93</u>	<u>+0.06</u>	<u>Initials</u>
N42 <u>99.99</u>		<u>+0.06</u>	<u>Initials</u>
N43 <u>99.99</u>		<u>+0.06</u>	<u>Initials</u>
N44 <u>99.00</u>		<u>- 0.93</u>	

8. Current NIs Power	9. (Step 8 - 6) Power to adjust NIs to	12. Adjustment Complete
N41 <u>na</u>	<u>na</u>	<u>N/A</u>
N42 <u>na</u>	<u>na</u>	<u>N/A</u>
N43 <u>na</u>	<u>na</u>	<u>N/A</u>
N44 <u>99.00</u>	<u>99.99</u>	<u>Initials</u>

Job Performance Measure**Perform 0BOSR CW-W1
DETERMINATION OF MAXIMUM ALLOWABLE BLOWDOWN
TEMPERATURE AND ROCK RIVER FLOW RATE**JPM Number: RA-1-07-0Revision Number: 0Date: 4/23/21Developed By: Barry Mingus / _____ 4/23/21
Instructor: Print / Sign DateReviewed By: Benjamin Reyes / _____ 5/13/21
SME or Instructor: Print / Sign DateReviewed By: Peter Leonhardt / _____ _____
Operations Representative: Print / Sign DateApproved By: Brian Lewin / _____ _____
Training Department: Print / Sign Date

JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

NOTE: All steps of this checklist should be performed upon initial validation.
 Prior to JPM usage, revalidate JPM using steps 9 and 13 below.

1. Task description and number, JPM description and number are identified. _____
2. Knowledge and Abilities (K/A) references are included. _____
3. Performance location specified. (in-plant, control room, simulator, or other) _____
4. Initial setup conditions are identified. _____
5. Initiating cue (and terminating cue if required) are properly identified. _____
6. Task standards identified and verified by instructor or SME review. _____
7. Critical steps meet the criteria for critical steps and are identified with an asterisk (*). _____
8. IAW NUREG 1021 Appendix C, clearly identify the task standard (i.e., the predetermined qualitative or quantitative outcome) against which task performance will be measured. _____
9. Verify the procedure(s) referenced by this JPM reflects the current revision:

Procedure: <u>0BOSR CW-W1</u>	Revision: <u>21</u>
Procedure: _____	Revision: _____
Procedure: _____	Revision: _____
Procedure: _____	Revision: _____
10. Verify cues both verbal and visual are free of conflict. _____
11. Verify performance time is accurate. _____
12. If the JPM cannot be performed as written with proper responses, then revise the JPM. _____
13. When JPM is initially validated, sign and date JPM cover page. For subsequent validations, sign and date below: _____

_____/_____
 SME / Instructor (Print/Sign) Date

_____/_____
 SME / Instructor (Print/Sign) Date

_____/_____
 SME / Instructor (Print/Sign) Date

Revision Record (Summary)

Revision #	Summary
00	1. New JPM created for 21-1 NRC Exam

SETUP INSTRUCTIONS

This is an administrative JPM that may be performed in any setting where the necessary procedures and support information can be provided.

Verify current revisions of the following information is available for the JPM performance:

- 0BOSR CW-W1

ENSURE the following is available during performance of the JPM:

- 0BOSR CW-W1
- Photographs, used as references
- USGS Website data
- Calculator

ENSURE the following is available during performance of the JPM:

- New clean copies of procedure and references for candidate to work from during performance

This completes the setup for this JPM.

INITIAL CONDITIONS

1. You are the Assist NSO.
2. Both units are in Mode 1.
3. All prerequisites of 0BOSR CW-W1 have been met

INITIATING CUE

You have been directed by the Unit Supervisor to perform 0BOSR CW-W1.
Use current date and time as required.

Fill in the JPM Start Time when the student acknowledges the Initiating Cue.

Information For Evaluator's Use:

UNSAT requires written comments on respective step.

* Denotes critical steps: **2, 4, 6, 7, & 10**

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section. The comment section should be used to document: the reason that a step is marked as unsatisfactory, marginal performance relating to management expectations, or problems the candidate had while performing the JPM.

Comments relating to procedural or equipment issues should be entered and tracked using the site's appropriate tracking system.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

JPM Start Time: _____ JPM Sequence #: _____ of _____

Task Standard:

The candidate will record data from MCB recorder stills per 0BOSR CW-W1. Additional data will be gathered from stills of USGS website. The candidate will use the assembled data to generate calculations to verify compliance with thermal NPDES limits for Byron Station Blowdown to the Rock River. The surveillance will be complete satisfactorily and within NPDES limits of Maximum Allowable Blowdown Temperature of < 120°F and Makeup Flow < 56,100 gpm.

<u>STEP</u>	<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
NOTE: Provide trainee with a copy of 0BOSR CW-W1, photographs of 0CD-CX4100, and USGS Website Data					
1.	Refer to 0BOSR CW-W1, DETERMINATION OF MAXIMUM ALLOWABLE BLOWDOWN TEMPERATURE AND ROCK RIVER FLOWRATE	<ul style="list-style-type: none"> Open 0BOSR CW-W1 	<input type="checkbox"/>	<input type="checkbox"/>	—
* 2.	RECORD the Circulating Water Makeup Flowrate and Temperature, and Blowdown Flowrate and Temperature.	<ul style="list-style-type: none"> Record Temperature and Flowrate from 0CD-CX4100 under F.1 Record: <ul style="list-style-type: none"> Make up <ul style="list-style-type: none"> Temp: <u>65°F</u> Flow: <u>39,300GPM</u> Blowdown <ul style="list-style-type: none"> Temp: <u>80°F</u> Flow: <u>15,800 GPM</u> 	<input type="checkbox"/>	<input type="checkbox"/>	—
3.	OBTAIN Rockton, Byron, and Como gaging station Rock River flow using the USGS Water Resources of Illinois website.	<ul style="list-style-type: none"> Record flow under F.2 Record: <ul style="list-style-type: none"> Rockton: <u>5500 cfs</u> Como: <u>6560 cfs</u> Byron: <u>6390 cfs</u> 	<input type="checkbox"/>	<input type="checkbox"/>	—

<u>STEP</u>	<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
* 4.	CALCULATE River Screenhouse Flowrate	<ul style="list-style-type: none"> Record River Screenhouse Flow under F.3.a Byron Gauge Readings RECORD: <u>6390 cfs</u> 	<input type="checkbox"/>	<input type="checkbox"/>	—
5.	DETERMINE the Maximum Allowable Temperature Rise	<ul style="list-style-type: none"> Use method F.4.a RECORD <u>83°</u> under F.4.a 	<input type="checkbox"/>	<input type="checkbox"/>	—
* 6.	CALCULATE the Maximum Allowable Blowdown Temperature. $\underline{\quad}^{\circ}\text{F} + \underline{\quad}^{\circ}\text{F} = \underline{\quad}^{\circ}\text{F}$ <p> <small>Make Up Temperature (Step F.1)</small> <small>Max Allowable Temp Rise (Step F.4)</small> <small>Max Allowable Blowdown Temp (120°F Max)</small> </p>	<ul style="list-style-type: none"> PERFORM calculation from data in steps F.1 and F.4 <ul style="list-style-type: none"> $\underline{65^{\circ}\text{F}} + \underline{83^{\circ}\text{F}} = \underline{120^{\circ}\text{F}}$ (Actual value is 148°F, but per the step, if >120°, record 120°) RECORD <u>120°F</u> (max allowed) 	<input type="checkbox"/>	<input type="checkbox"/>	—
* 7.	COMPARE the Maximum Allowable Blowdown Temperature to the Blowdown Temperature. <ul style="list-style-type: none"> Blowdown Temperature (step F.1) <120°F (Y / N) Blowdown Temperature (step F.1) <Maximum Allowable Blowdown Temperature (step F.5) (Y/N) Water Quality Standard (Table 2) - Makeup Temperature (step F.1) > 3°F (Y/N) 	<ul style="list-style-type: none"> COMPARE temperatures in F.6. RECORD <u>'Y'</u> or <u>'Yes'</u> for all comparisons. <ul style="list-style-type: none"> Blowdown Temperature (step F.1) <120°F (Y / N) Blowdown Temperature (step F.1) <Maximum Allowable Blowdown Temperature (step F.5) (Y/N) Water Quality Standard (Table 2) - Makeup Temperature (step F.1) > 3°F (Y/N) 	<input type="checkbox"/>	<input type="checkbox"/>	—

<u>STEP</u>	<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
8.	CHECK Plant Conditions on chart 1.	<ul style="list-style-type: none"> • OBSERVE conditions are BELOW the acceptable region line • RECORD <u>N/A</u> under F.7 	<input type="checkbox"/>	<input type="checkbox"/>	—
9.	Calculation of Maximum River Consumption Rate (MRCR).	<ul style="list-style-type: none"> • River Screenhouse Flow is > 679 CFS • RECORD <u>N/A</u> for F.8 	<input type="checkbox"/>	<input type="checkbox"/>	—
* 10.	Makeup Flow < 56,100 gpm	<ul style="list-style-type: none"> • Make-up flow (39,300) is less than 56,100 • RECORD '<u>Y</u>' or '<u>Yes</u>' for F.9 	<input type="checkbox"/>	<input type="checkbox"/>	—
CUE:	This JPM is complete.				

 JPM Stop Time:

JPM SUMMARY**Operator's Name:** _____ **Emp. ID#:** _____**Job Title:** EO RO SRO FS STA/IA SRO CertJPM Title: Perform 0BOSR CW-W1JPM Number: RA-1-07-0Revision Number: 0Task Number and Title: R-AM-018, Perform Mode 1, 2, & 3 shiftly and daily operating surveillances

Task Standard: The candidate will record data from MCB per 0BOSR CW-W1. Additional data will be gathered from stills of USGS website. The candidate will use the assembled data to generate calculations to verify compliance with thermal NPDES limits for Byron Station Blowdown to the Rock River. The surveillance will be complete satisfactorily and within NPDES limits of Maximum Allowable Blowdown Temperature of < 120°F and Makeup Flow < 56,100 gpm..

K/A Number and Importance: 2.1.25 (3.9/4.2)Suggested Testing Environment: Simulator or ClassroomAlternate Path: Yes No SRO Only: Yes No Time Critical: Yes No

Reference(s):

Procedure: 0BOSR CW-W1 Revision: 21

Procedure: _____ Revision: _____

Procedure: _____ Revision: _____

Procedure: _____ Revision: _____

Actual Testing Environment: Simulator Control Room In-Plant Other**Testing Method:** Simulate Perform**Estimated Time to Complete:** 20 minutes **Actual Time Used:** _____ minutes**EVALUATION SUMMARY:**Were all the Critical Elements performed satisfactorily? Yes NoThe operator's performance was evaluated against standards contained within this JPM and has been determined to be: Satisfactory Unsatisfactory**NOTE:** Enter finalized grading, comments, and notes relevant to this evaluation in the associated TQ-AA-150-F03A/B. (See AR [4282419](#)).**Evaluator's Name (Print):** _____

Evaluator's Signature: _____ **Date:** _____



INITIAL CONDITIONS

1. You are the Assist NSO.
2. Both units are in Mode 1.
3. All prerequisites of 0BOSR CW-W1 have been met

INITIATING CUE

You have been directed by the Unit Supervisor to perform 0BOSR CW-W1.
Use current date and time as required.



CCD-CX4100

YOKOGAWA ◆



1	5	9
2	6	10
3	7	11
4	8	12



MCC 133X3

CW Blowdown flow rate should be limited to less than 16,500 gpm to prevent opening of the CW blowdown vacuum breakers



BYRON STATION

PROCEDURE NO.
0BOSR CW-W1

UNIT NO.
0

REVISION NO.
21

PROCEDURE TITLE:
*** DETERMINATION OF MAXIMUM ALLOWABLE BLOWDOWN TEMPERATURE AND ROCK RIVER FLOW RATE**

Rev	Summary	IR/AT#	EC#	Procedure Database Tracking #
21	Change BOL ENTER statements to NOTIFY Supervisor to review.			27626
20	Adds a Note prior to step F.3 to channel check flows.	1470859-03		17327
19	PPC Change for 0TR-CW47A to 0CD-CX4100			16654
18	PPC Change for 0UR-CW032 to 0CD-CX4100	1410381	381169	16589
17	Clarify acceptance criteria.	1381078-03		16539
16	Correct error in step F.6.c.			16391
15	Reflect changes to NPDES permit and proactive entry into 0BOL EPA1. Delete commitment 454-411-95-IL48313.			16370
14	Update website in Attachment A.	664272-02		10206
13	Revise step F.1 to use conservation value of 32°F if the circ water warming line is in service.	574044-02		8558
12	Added additional means for determining CW Makeup Temperature.			5-2304
11	Added additional CW B/W temperature indication source from shiftily/daily.			5-1164
10	Update Attachment with new website for river flowrates.			
8	Revise method for obtaining Rock River level and discharge date.			
7	Update phone number for Corp of Engineers.			

DETERMINATION OF MAXIMUM ALLOWABLE
BLOWDOWN TEMPERATURE AND ROCK RIVER FLOW RATE (CM-1)

~~A.~~

STATEMENT OF APPLICABILITY:

This procedure determines compliance with thermal NPDES limits for Byron Station CW Blowdown to the Rock River. This procedure is applicable and may be performed in all modes. The minimum frequency for performing this procedure is weekly. The basis for the performance of this procedure is to verify that CW blowdown temperature is below the maximum allowable blowdown temperature. IF CW blowdown temperature is below the maximum allowable blowdown temperature, THEN the thermal water quality standards at the edge of the 26 acre mix zone will be met. This procedure will also be used to determine Rock River flowrate for compliance with LCO 3.7.9, Ultimate Heat Sink.

~~B.~~

REFERENCES:

1. Technical Specifications:
 - a. LCO 3.7.9
2. Station Procedures:
 - a. 0BOA ENV-2, Rock River Abnormal Water Level, Unit 0.
 - b. 0BOL 7.9, Ultimate Heat Sink (UHS).
 - c. 0BOL EPA1, NPDES - Blowdown Thermal Compliance Monitoring.
3. April 11, 1988, Letter to R. Pleniewicz from T. Hemminger, Environmental Affairs.
4. February 18, 1988, Letter to R. Querio from T. Hemminger, Environmental Affairs.
5. U.S. Dept. of Interior - Geological Survey - Water Resources Division.
6. March 7, 1977, Letter to Mr. Don Vonshme from Illinois Department of Conservation.
7. September 21, 1978, Letter to J.T. Westermeir from John H. Huges.
8. December 22, 1989, Letter to R. Pleniewicz from J. Smith, Environmental Affairs - Subject: Heat Rejection Limit.

B. continued

9. Internet Website:
<http://il.water.usgs.gov>
10. Station Commitments:
 - a. **CM-1** 454-225-90-00300
 - b. **CM-2** 454-251-88-59500
11. Byron Letter 2003-0102, dated November 11, 2003, to Mr. Tom McSwiggen, Illinois Environmental Protection Agency.

~~C.~~

PREREQUISITES:

~~1.~~

Receive permission from the Shift Manager or designated SRO licensed assistant prior to performing this surveillance by having the Data Package Cover Sheet signed and dated.

~~D.~~

PRECAUTIONS:

~~1.~~

None.

~~E.~~

LIMITATIONS AND ACTIONS:

~~1.~~

In the event an Acceptance Criteria is not met during the performance of this procedure, IMMEDIATELY notify the Shift Manager, NOTIFY Supervisor to review 0BOL EPA1 or 0BOL 7.9 and NOTIFY the NPDES Coordinator.

~~2.~~

In the event that the Rock River flowrate is less than 2400 cfs (an Admin Limit of 2600 cfs has been established to provide warning) and/or the temperature differential between the main river temperatures and the water quality standard is less than 3°F, daily calculations will be undertaken to demonstrate compliance with the water quality standard. NOTIFY the Shift Manager, NOTIFY Supervisor to review 0BOL EPA1 and NOTIFY the NPDES Coordinator (or designee).

~~3.~~

If the Rock River flowrate falls to \leq 700 cfs, notify the Shift Manager and refer to LCO 3.7.9, ULTIMATE HEAT SINK, for applicable actions.

Continuous Use

E. continued

~~4.~~

River temperature rise must not exceed 5°F outside the mixing zone. IF the actual blowdown temperature is below the calculated Maximum Allowable Blowdown Temperature, THEN the temperature at the edge of the mixing zone should be within compliance per EPA regulations, to prevent any potential for excessive environmental impact, the maximum allowable blowdown temperature under all conditions is 120°F or 83°F hotter than CW makeup temperature, whichever is less.

~~5.~~

If the actual heat rejection rate exceeds the limit of 0.5 Billion BTU/hr, adjust makeup and blowdown flowrate until within compliance. Notify NPDES Coordinator and generate an IR to document the event.

~~F.~~MAIN BODY:~~1.~~

RECORD the Circulating Water Makeup Flowrate and Temperature, and Blowdown Flowrate and Temperature. River Temperature is Makeup Temperature.

TEMPERATURE (0CD-CX4100) FLOWRATE (0CD-CX4100)

Make Up 65 °F ** 39,300 GPM

Blowdown 80 °F *** 15,800 GPM

** IF CW M/U temperature instrumentation is not functioning, THEN contact Chemistry to perform daily temperature measurement and record value obtained from Chemistry.

*** May use computer point T2418 if 0TY-CW046 is inoperable or contact Chemistry to perform daily temperature measurement and record value obtained from Chemistry.

~~2.~~

OBTAIN Rockton, Byron, and Como gaging station Rock River flow using the USGS Water Resources of Illinois website. See Attachment A for guidance, as required.

Rockton 5500 flow (cfs) Como 6560 flow (cfs) Byron 6390 flow (cfs)

F. continued

NOTE

Cold weather can affect Byron flow. Channel Check by comparing with Rockton and Como flows to determine availability for the following step.

~~3.~~

CALCULATE River Screenhouse Flowrate using one of the following methods: (c)

~~a.~~

Byron Gage reading available:

$$\text{River Screenhouse Flow} = \text{Byron Flow } \underline{6390} \text{ CFS}$$

(≥ 2600 CFS Admin Limit)

N/A

OR

~~b.~~

Byron Gage reading unavailable:

$$\text{River Screenhouse Flow} =$$
$$(0.245 \times \underline{\quad}) + (0.755 \times \underline{\quad}) = \underline{\quad} \text{ CFS}$$

(Rockton Flow) (Como Flow) (≥ 2600 CFS Admin Limit),

OR

~~c.~~

Byron and Como Gauge reading unavailable:

$$\text{River Screenhouse Flow} = \text{Rockton Flow } \underline{\quad} \text{ CFS}$$

(≥ 2600 CFS Admin Limit),

OR

~~d.~~

Byron and Rockton Gauge reading unavailable:

$$\text{River Screenhouse Flow} = (0.755) \text{ Como Flow } \underline{\quad} \text{ CFS}$$

(≥ 2600 CFS Admin Limit),

OR

~~e.~~

Byron, Como and Rockton gauge readings unavailable:

- 1). Assume Rock River Flow is < 700 CFS and **NOTIFY** Supervisor to review LCO 3.7.9 Required Action H.

F. continued

~~4.~~ **DETERMINE** the Maximum Allowable Temperature Rise using one of the following methods:

~~a.~~ River Screenhouse flowrate is \geq 2400 CFS, **RECORD** 83°F.
Maximum Allowable Temperature Rise 83 °F,

OR

N/A

~~b.~~ River Screenhouse Flow rate is $<$ 2400 CFS, **PERFORM** the following on Table 1.

~~**SELECT** the first river flow rate that is less than or equal to the screenhouse flow (e.g., for screenhouse flow of 2200 CFS, use the 2100 CFS) then come across to the first blowdown flowrate that is greater than or equal to the actual blowdown flowrate and **RECORD** below the **MAXIMUM ALLOWABLE TEMPERATURE RISE**.~~

~~Maximum Allowable Temperature Rise _____ °F.~~

~~5.~~ **CALCULATE** the Maximum Allowable Blowdown Temperature. The Maximum Allowable Blowdown Temperature under all river temperature or flow conditions is 120°F. (If greater than 120°F, record 120°F.) (¢)

$$\begin{array}{rcccl} \underline{65} & & & & \\ \text{°F} & & & & \\ \text{Make Up} & + & \underline{83} & = & \underline{120} \\ \text{Temperature} & & \text{°F} & & \text{°F} \\ \text{(Step F.1)} & & \text{Max Allowable} & & \text{Max Allowable} \\ & & \text{Temp Rise} & & \text{Blowdown Temp} \\ & & \text{(Step F.4)} & & \text{(120°F Max)} \end{array}$$

~~6.~~ **COMPARE** the Maximum Allowable Blowdown Temperature to the Blowdown Temperature. IF any of the comparisons below are answered "N" (No), THEN **NOTIFY** Supervisor to review 0BOL EPA1. (¢)

~~a.~~ Blowdown Temperature (step F.1) \leq ^(80 < 120) 120°F Y
(Y / N)

~~b.~~ Blowdown Temperature (step F.1) \leq ^(80 < 120) Maximum Allowable Blowdown Temperature (step F.5) Y
(Y/N)

~~c.~~ Water Quality Standard (Table 2) - Makeup Temperature (step F.1) \geq 3°F Y
(Y/N) ⁽⁹⁰⁻⁶⁵⁼²⁵⁾

Continuous Use

F. continued

NOTE

If existing conditions are above the acceptable region of CHART 1, perform a Heat Rejection Rate Calculation per step F.7. Otherwise mark step F.7 N/A.

N/A

7. Calculation of Heat Rejection Rate (¢)

CHECK Plant Conditions on chart 1. If BELOW the acceptable region line **RECORD** N/A. If ABOVE the acceptable region line, **PERFORM** the following calculation.

Heat Rejection Rate =

$$\frac{\text{Blowdown Flow (gpm)}}{\text{Blowdown/Make Up } \Delta T} \times 5 \times 10^{-7} = \frac{\text{Heat Rejection Rate (Billion BTU/HR)}}{\text{Heat Rejection Rate (Billion BTU/HR)}} \text{ (Max 0.5)}$$

N/A

8. Calculation of Maximum River Consumption Rate (MRCR). (Mark N/A if River Screenhouse Flow > 679 CFS. (¢))

a. $\frac{\text{Make Up Flow (Step F.1)}}{\text{GPM}} - \frac{\text{Blowdown Flow (Step F.1)}}{\text{GPM}} = \frac{\text{Rock River Consumption Rate}}{\text{GPM}}$

b. $\text{MRCR} = \frac{\text{RSH flow (Step F.3)}}{\text{CFS}} \times 40.392 = \frac{\text{MRCR}}{\text{GPM}}$

Rock River Consumption Rate \leq MRCR ____ (Y/N)

9. Makeup Flow < 56,100 gpm Y (Y/N) (39,300 < 56,100)

G. ACCEPTANCE CRITERIA:

1. The Blowdown Temperature (step F.1) MUST BE BELOW the Maximum Allowable Blowdown Temperature calculated in step F.5. (NPDES) Otherwise, NOTIFY Supervisor to review 0BOL EPA1.
2. The Blowdown Temperature MUST NOT EXCEED 120°F. (NPDES) Otherwise, NOTIFY Supervisor to review 0BOL EPA1.
3. The Rock River Flowrate is greater than or equal to 700 CFS. Refer to Tech Spec LCO 3.7.9.

Continuous Use

G. continued


4. The Rock River Flowrate is greater than or equal to 2600 CFS (Admin Limit to provide warning to 2400 CFS actual limit). Otherwise, NOTIFY Supervisor to review 0BOL EPA1 and notify the NPDES Coordinator. (NPDES)
5. The heat rejection rate must be less than or equal to 0.5 Billion BTU/hr. (NPDES) Otherwise, NOTIFY Supervisor to review 0BOL EPA1.
6. The Rock River Consumption is limited to 9% of total Rock River Flow when the Rock River Flowrate is less than or equal to 679 CFS. (IL Dept. of Conservation) Otherwise, NOTIFY Supervisor to review 0BOL EPA1.
7. Makeup temperature is at least 3°F below the water quality standard. Otherwise, NOTIFY Supervisor to review 0BOL EPA1. (NPDES)
8. The Makeup flow shall not exceed 125 cfs (56,100 gpm). (IL Dept. of Conservation) Otherwise, NOTIFY Supervisor to review 0BOL EPA1.

TABLE 1
MAXIMUM ALLOWABLE TEMPERATURE RISE (CM-1)

River Flow	BLOWDOWN FLOWRATE (GPM)						
(CFS)	<u>8976</u>	<u>11,200</u>	<u>13,464</u>	<u>15,708</u>	<u>17,952</u>	<u>20,196</u>	<u>22,440</u>
700	73.5	59.5	50.5	44.2	38.5	36.2	32.7
875	83.0	74.6	62.5	53.8	48.1	43.1	40.0
1200	83.0	83.0	83.0	72.5	64.1	59.5	54.4
1500	83.0	83.0	83.0	83.0	79.4	72.5	66.8
1800	83.0	83.0	83.0	83.0	83.0	83.0	79.4
2100	83.0	83.0	83.0	83.0	83.0	83.0	83.0
2400	83.0	83.0	83.0	83.0	83.0	83.0	83.0

Note: For blowdown flowrates less than 8976 gpm use 83.0.

CHART 1
HEAT REJECTION CHART



Heat Rejection Limit cannot be exceeded for Blowdown < 7000 gpm without violating 120°F Maximum Blowdown Temperature.

ATTACHMENT A

RETRIEVING ROCKTON, BYRON, AND COMO GAUGING STATION
READINGS VIA THE EXELON INTERNET

1. **START** Exelon Internet Explorer.
2. **OBTAIN** Rock River flow(s) as required. Recommended web locations to get flows are:
 - a. <http://www.thetent.com/thetent/aogcr/il/ilsf.index.htm>
 - b. <http://waterdata.usgs.gov/nwis/uv?05440700>
 - c. <http://waterdata.usgs.gov/nwis/uv?05443500>
 - d. <http://waterdata.usgs.gov/nwis/uv?05437500>
3. **RECORD** most recent reading for streamflow (CFS).

TABLE 2
WATER QUALITY STANDARD

Time of Year	River Temperature
January - March	60°F
April - November	90°F
December	60°F

Reference: 35 IAC 302.211.

DRAFT

OCD-CX4100

YOKOGAWA ◆



1	5	9
2	6	10
3	7	11
4	8	12

MCC 133X3

CW Blowdown flow rate should be limited to less than 16,500 gpm to prevent opening of the CW blowdown vacuum breakers

<http://waterdata.usgs.gov/nwis/uv?05437500>



[USGS Home](#)

[Contact USGS](#)

[Search USGS](#)


[National Water Information System: Web Interface](#)

[USGS Water Resources](#)

Data Category:

Geographic Area:

Click to hide News Bulletins

- Explore the New [USGS National Water Dashboard](#) interactive map to access real-time water data from over 13,500 stations nationwide.
- [Full News](#) 

* IMPORTANT: [Next Generation Station Page](#)

USGS 05437500 ROCK RIVER AT ROCKTON, IL

PROVISIONAL DATA SUBJECT TO REVISION

Available data for this site

Click to hide station-specific text

This site is operated in cooperation with the



U.S. Army Corps of Engineers
Rock Island District - Rock Island, Ill.


[NWS River Forecasts](#)

This station managed by the De Kalb Field Office.

[Summary of all available data for this site](#)
[Instantaneous-data availability statement](#)

Discharge, cubic feet per second

Most recent instantaneous value: 5500 Date: Today Time:Current Time



Add up to 2 more sites and replot for "Discharge, cubic feet per second"

[?](#)

Add site numbers

[Note](#)

Create [presentation-quality](#) / [stand-alone](#) graph. Subscribe to

[?](#)

[WaterAlert](#)

See this graph on the [Beta Monitoring Location Pages](#)

[Share this graph](#) |

[Questions about sites/data?](#)

[Feedback on this web site](#)

<http://waterdata.usgs.gov/nwis/uv?05440700>



[USGS Home](#)

[Contact USGS](#)

[Search USGS](#)


[National Water Information System: Web Interface](#)

[USGS Water Resources](#)

Data Category:

Geographic Area:

Click to hideNews Bulletins

- Explore the New [USGS National Water Dashboard](#) interactive map to access real-time water data from over 13,500 stations nationwide.
- [Full News](#) 

* IMPORTANT: [Next Generation Station Page](#)

USGS 05440700 ROCK RIVER AT BYRON, IL

PROVISIONAL DATA SUBJECT TO REVISION

Available data for this site

Click to hidestation-specific text

This site is operated in cooperation with the

USGS National Streamflow Information Program [NSIP](#)


[NWS River Forecasts](#)

This station managed by the De Kalb Field Office.

[Summary of all available data for this site](#)
[Instantaneous-data availability statement](#)

Temperature, water, degrees Celsius

Most recent instantaneous value: 18.3 Date: Today Time: Current Time



Add up to 2 more sites and replot for "Temperature, water, degrees Celsius"

?

Add site numbers

[Note](#)

Create [presentation-quality](#) / [stand-alone](#) graph. Subscribe to

?


[WaterAlert](#)

See this graph on the [Beta Monitoring Location Pages](#)

[Share this graph](#) |

Discharge, cubic feet per second

Most recent instantaneous value: 6390 Date: Today Time: Current Time



Add up to 2 more sites and replot for "Discharge, cubic feet per second"

?

Add site numbers

[Note](#)

Create [presentation-quality](#) / [stand-alone](#) graph. Subscribe to

?

[WaterAlert](#)

See this graph on the [Beta Monitoring Location Pages](#)

[Share this graph](#) |

Gage height, feet

Most recent instantaneous value: 7.03 Date: Today Time: Current Time

USGS 05440700 ROCK RIVER AT BYRON, IL



Add up to 2 more sites and replot for "Gage height, feet"

[?](#)

Add site numbers

[Note](#)

Create [presentation-quality](#) / [stand-alone](#) graph. Subscribe to

[?](#)

[WaterAlert](#)

See this graph on the [Beta Monitoring Location Pages](#)

[Share this graph](#) |

[Questions about sites/data?](#)

[Feedback on this web site](#)

[Automated retrievals](#)

[Help](#)

[Data Tips](#)

[Explanation of terms](#)

<http://waterdata.usgs.gov/nwis/uv?05443500>



[USGS Home](#)

[Contact USGS](#)

[Search USGS](#)


[National Water Information System: Web Interface](#)

[USGS Water Resources](#)

Data Category:

Geographic Area:

Click to hideNews Bulletins

- Explore the New [USGS National Water Dashboard](#) interactive map to access real-time water data from over 13,500 stations nationwide.
- [Full News](#) 

* IMPORTANT: [Next Generation Station Page](#)

USGS 05443500 ROCK RIVER AT COMO, IL

PROVISIONAL DATA SUBJECT TO REVISION

Available data for this site

Click to hidestation-specific text

This site is operated in cooperation with the



U.S. Army Corps of Engineers

Rock Island District - Rock Island, Illinois

[NWS River Forecasts](#)


This station managed by the De Kalb Field Office.

[Summary of all available data for this site](#)

[Instantaneous-data availability statement](#)

Discharge, cubic feet per second

Most recent instantaneous value: 6560 Date: Today Time: Current Time



Add up to 2 more sites and replot for "Discharge, cubic feet per second"

Add site numbers

[Note](#)

Create [presentation-quality](#) / [stand-alone](#) graph. Subscribe to [WaterAlert](#)

See this graph on the [Beta Monitoring Location Pages](#)

[Share this graph](#) |

Gage height, feet

Most recent instantaneous value: 5.02 Date: Today Time: Current Time

USGS 05443500 ROCK RIVER AT COMO, IL



Add up to 2 more sites and replot for "Gage height, feet"

?

Add site numbers

[Note](#)

Create [presentation-quality](#) / [stand-alone](#) graph. Subscribe to

?

[WaterAlert](#)

See this graph on the [Beta Monitoring Location Pages](#)

[Share this graph](#) |

Job Performance Measure

Review RWP for Dosimetry Settings and Protective Clothing RequirementsJPM Number: RA-3-02-3Revision Number: 03Date: 4/28/21Developed By: Barry Mingus / _____ 4/21/21
Instructor: Print / Sign DateReviewed By: Benjamin Reyes / _____ 6/3/21
SME or Instructor: Print / Sign DateReviewed By: Peter Leonhardt / _____ Date
Operations Representative: Print / SignApproved By: Brian Lewin / _____ Date
Training Department: Print / Sign

JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

NOTE: All steps of this checklist should be performed upon initial validation.
 Prior to JPM usage, revalidate JPM using steps 9 and 13 below.

1. Task description and number, JPM description and number are identified. _____
2. Knowledge and Abilities (K/A) references are included. _____
3. Performance location specified. (in-plant, control room, simulator, or other) _____
4. Initial setup conditions are identified. _____
5. Initiating cue (and terminating cue if required) are properly identified. _____
6. Task standards identified and verified by instructor or SME review. _____
7. Critical steps meet the criteria for critical steps and are identified with an asterisk (*). _____
8. IAW NUREG 1021 Appendix C, clearly identify the task standard (i.e., the predetermined qualitative or quantitative outcome) against which task performance will be measured. _____
9. Verify the procedure(s) referenced by this JPM reflects the current revision:

Procedure: <u>RP-AA-410</u>	Revision: <u>8</u>
Procedure: <u>RWP BY-0-21-00305</u>	Revision: <u>00</u>
Procedure: _____	Revision: _____
Procedure: _____	Revision: _____
10. Verify cues both verbal and visual are free of conflict. _____
11. Verify performance time is accurate. _____
12. If the JPM cannot be performed as written with proper responses, then revise the JPM. _____
13. When JPM is initially validated, sign and date JPM cover page. For subsequent validations, sign and date below: _____

_____/_____
 SME / Instructor (Print/Sign) Date

_____/_____
 SME / Instructor (Print/Sign) Date

_____/_____
 SME / Instructor (Print/Sign) Date

Revision Record (Summary)

Revision #	Summary
00	Initial Revision of JPM
01	<ul style="list-style-type: none"> - Changed RWP # to match current RWP - Updated to current rev. of RP-AA-410 - Took out reference to wetbulb temperature as it is no longer in att. 1
02	<ul style="list-style-type: none"> - Applied new template TQ-AA-150-J020 - Changed RWP # to match current RWP - Updated to current rev. of RP-AA-410 - Removed requirement for determining Dose Rate based on new RWP format - Changed Alarm setting values based on new RWP format and available Neutron Electronic Dosimeter. - Corrected typo
03	<ul style="list-style-type: none"> - Applied new template TQ-AA-150-J020 Rev 1 - Changed RWP # to match current RWP

SETUP INSTRUCTIONS

1. This is an administrative JPM that may be performed in any setting where the necessary procedures and support information can be provided.
2. Verify current revisions of the following information is available for the JPM performance:
 - RP-AA-410
3. ENSURE the following is available during performance of the JPM:
 - RWP BY-0-21-00305 Rev 00 Task 1
4. ENSURE the following between performances of the JPM:
 - New clean procedure copies for candidate to work from during performance
5. This completes the setup for this JPM.

INITIAL CONDITIONS

You are assigned as an Equipment Operator.

You will be entering containment to perform 1BOSR 6.6.2-1, RCFC SX flow monthly surveillance outside the missile barrier.

The work class is considered “medium”.

All areas to be entered are less than 10,000 dpm/100cm² contamination.

INITIATING CUE

Determine the following from RWP BY-0-21-00305 Task 1, U1 Containment Work @ Power, to enter the Unit 1 Containment to perform the surveillance:

- the type of dosimetry required
- the dosimetry settings required
 - o Dose
 - o Back Out Dose
 - o Dose Rate
- the required protective clothing.

Fill in the JPM Start Time when the student acknowledges the Initiating Cue.

.....

Information For Evaluator’s Use:

UNSAT requires written comments on respective step.

* Denotes critical steps. **2, 3, & 4**

Number any comments in the “Comment Number” column on the following pages. Then annotate that comment in the “Comments” section. The comment section should be used to document: the reason that a step is marked as unsatisfactory, marginal performance relating to management expectations, or problems the candidate had while performing the JPM.

Comments relating to procedural or equipment issues should be entered and tracked using the site’s appropriate tracking system.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The time clock starts when the candidate acknowledges the initiating cue.

.....

JPM Start Time: _____ JPM Sequence #: _____ of _____

<u>Task Standard:</u>					
<p>The candidate will interpret the RWP and determine the required dosimetry and dosimetry settings. The candidate will determine the required protective clothing necessary to perform medium work inside containment, using RP-AA-410 Selection, Use, and Control of Protective Clothing. The candidate will document the information as specified on the associated JPM answer sheet for the type of dosimetry required, the dosimetry settings required (Dose, Back Out Dose, and Dose Rate), and the required protective clothing.</p>					
<u>STEP</u>	<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
NOTE: In order to limit exam material exposure and unnecessary access to the facility, the following cue is provided determine candidate knowledge of RWP access.					
CUE	Where would you go to get the correct RWP?				
1.	Locate proper RWP and Non-Outage PC Matrix Attachment.	RWP will be available at the RP Desk	<input type="checkbox"/>	<input type="checkbox"/>	—
CUE	Provide the candidate with RWP BY-0-21-00305 and RP-AA-410 Selection, Use, and Control of Protective Clothing.				
NOTE: At Byron, the Dosimeter of Legal Record (DLR) is equipped with a chip for monitoring Neutron exposure					
* 2.	Determine required dosimetry	RWP Dosimetry requirements <ul style="list-style-type: none"> • Electronic Dosimeter • A Dosimeter of Legal Record (DLR) • Neutron Dosimetry 	<input type="checkbox"/>	<input type="checkbox"/>	—

<u>STEP</u>	<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
* 3.	Determine dosimetry alarm setpoints	Electronic Dosimetry alarm setpoints <ul style="list-style-type: none"> • Dose alarm <ul style="list-style-type: none"> • 35 mrem Gamma • 35 mrem Neutron • Back Out Dose <ul style="list-style-type: none"> • 28 mrem Gamma • 28 mrem Neutron • Dose rate alarm <ul style="list-style-type: none"> • 100 mrem/hour Gamma • 100 mrem/hour Neutron 	<input type="checkbox"/>	<input type="checkbox"/>	—
CUE:	If asked by candidate, RP Approval has NOT been given for inspection level garments				
CUE:	If asked by candidate, all exit monitors are operating properly.				
NOTE: (Note 1: Rubber gloves may be used in lieu of GripTech gloves if radiological conditions warrant or if GripTech inventory is low.)					
* 4.	Determine protective clothing required	(From RP-AA-410 Attachment 1) Protective clothing required <ul style="list-style-type: none"> • Modesty garments • Coveralls • Rubber shoe covers and booties • Cotton liners and GripTech gloves 	<input type="checkbox"/>	<input type="checkbox"/>	—
CUE	The JPM is complete.				

JPM Stop Time: _____



JPM SUMMARY**Operator's Name:** _____ **Emp. ID#:** _____**Job Title:** EO RO SRO FS STA/IA SRO CertJPM Title: Review RWP for Dosimetry Settings and Protective Clothing RequirementsJPM Number: RA-3-02-3 Revision Number: 3Task Number and Title: R-AM-27, Comply with radiation and contamination ALARA safety procedures

Task Standard: The candidate will interpret the RWP and determine the required dosimetry and dosimetry settings. The candidate will determine the required protective clothing necessary to perform medium work inside containment, using RP-AA-410 Selection, Use, and Control of Protective Clothing. The candidate will document the information as specified on the associated JPM answer sheet for the type of dosimetry required, the dosimetry settings required (Dose, Back Out Dose, and Dose Rate), and the required protective clothing.

K/A Number and Importance: GEN 2.3.7, Imp Factor 3.5/3.6Suggested Testing Environment: ClassroomAlternate Path: Yes No SRO Only: Yes No Time Critical: Yes No

Reference(s):

Procedure: <u>RP-AA-410</u>	Revision: <u>8</u>
Procedure: <u>RWP BY-0-21-00305</u>	Revision: <u>00</u>
Procedure: _____	Revision: _____
Procedure: _____	Revision: _____

Actual Testing Environment: Simulator Control Room In-Plant Other**Testing Method:** Simulate Perform**Estimated Time to Complete:** 10 minutes **Actual Time Used:** _____ minutes**EVALUATION SUMMARY:**Were all the Critical Elements performed satisfactorily? Yes NoThe operator's performance was evaluated against standards contained within this JPM and has been determined to be: Satisfactory Unsatisfactory**NOTE:** Enter finalized grading, comments, and notes relevant to this evaluation in the associated TQ-AA-150-F03A/B. (See AR [4282419](#)).**Evaluator's Name (Print):** _____

Evaluator's Signature: _____ **Date:** _____

ANSWER SHEET**Type of Dosimetry Required:**

Electronic dosimeter

DLR

Neutron dosimetry

Dosimetry Settings:

Dose: Gamma 35 mrem

Neutron 35 mrem

Back Out Dose:

Gamma 28 mrem

Neutron 28 mrem

Dose Rate:

Gamma 100 mrem

Neutron 100 mrem

Required Protective Clothing:

Modesty garments

Coveralls

Cotton liners and GripTech gloves

Rubber shoes and booties



INITIAL CONDITIONS

You are assigned as an Equipment Operator.

You will be entering containment to perform 1BOSR 6.6.2-1, RCFC SX flow monthly surveillance outside the missile barrier.

The work class is considered "medium".

All areas to be entered are less than 10,000 dpm/100cm² contamination.

INITIATING CUE

Determine the following from RWP BY-0-21-00305 Task 1, U1 Containment Work @ Power, to enter the Unit 1 Containment to perform the surveillance:

- the type of dosimetry required
- the dosimetry settings required
 - o Dose
 - o Back Out Dose
 - o Dose Rate
- the required protective clothing



ANSWER SHEET

Type of Dosimetry Required:

Dosimetry Settings:

Dose: _____

Back Out Dose:

Dose Rate:

Required Protective Clothing:

RADIATION WORK PERMIT
 Byron Nuclear Station

COPY

CONTAINMENT WORK @ POWER	 BY-0-21-00305 Revision: 00
---------------------------------	--

Comments: PASSPORT RWP: 10025302		
Access List Required: N	Begin Date 1/1/2021	Close On Date

Locations		
Buildings	Elevations	Rooms
All	All	All

Back Out Radiological Conditions		
Description	Value	Unit
N/A		

RWP Tasks		
Task	Description	Status
1	U-1 CONTAINMENT	Active
2	U-2 CONTAINMENT	Active
3	DO NOT USE	Inactive
4	DO NOT USE	Inactive
5	DO NOT USE	Inactive
6	DO NOT USE	Inactive

RWP Requirements	
Requirement Groups	Requirement Descriptions
N/A	

Additional Instructions

RP Brief is required prior to accessing areas greater than 7 ft.

Approvals		
Approver Title	Name	Date
RWP Approver	THOMISON, BRANDON J	12/18/2020

Attachments

N/A

FOR
INFO
ONLY

RADIATION WORK PERMIT
Byron Nuclear Station

COPY

U-1 CONTAINMENT <i>FOR INFO ONLY</i>	BY-0-21-00305	1
	Revision: 00	Task

This Task Permits HRA Access. A specific HRA brief by RP is required for entry.

Access List Required: N	Task Status: Active
-------------------------	---------------------

Alarm Settings

	Dose (mrem)	Back Out (80%) Dose (mrem)	Dose Rate (mrem/hr)
Gamma	35	28	100
Neutron	35	28	100

Back Out Radiological Conditions

Description	Value	Unit
Neutron Dose Rates General Area	>100	mrem/hr
Gamma Dose Rate General Area	>100	mrem/hr
Alpha Loose Surface Contamination General Area	>30	dpm/100 cm ²
Beta/Gamma Loose Surface Contamination General Area	>500k	dpm/100 cm ²
Particulate and Iodine DAC	>0.3	DAC

RWP Requirements

Requirement Groups	Requirement Descriptions
1. Risk Level	Medium Risk
2. Alpha Level	Alpha Level 1,2
3. RP Coverage	See ALARA Plan
4. Air Sampling	See ALARA Plan
5. Dosimetry	Electronic Dosimeter and DLR required Neutron dosimetry required in Neutron Radiation Areas
6. Contamination Control	Contact RP prior to working in wet conditions to verify protective clothing requirements.
7. Protective Clothing	See Protective Clothing Matrix (RP-AA-410) - Attachment 1
8. Respiratory Protection	See ALARA Plan
9. Exposure Control	Use LOW DOSE Areas (identified on survey maps) Check ED approximately every 15 minutes or as directed by RP
General	See ALARA Plan

Additional Instructions

RP Brief is required prior to accessing areas greater than 7 ft.

THIS RWP ALLOWS ACCESS TO LHRA'S

Each worker signing on this RWP must review the Alara Plan or MICRO Alara Plan (MAP) for instructions pertaining to his/her job or specific evolution, as applicable.

Radiological Conditions can change based on Reactor Power Level, Hydrogen Injection Rate, and Work Location.

RPM or Designee approval required for working in >1500MREM/HR and / or >500 MREM accumulated dose expected to an individual (RP-AA-460-002).

Attachments

N/A

Job Performance Measure
Activate Everbridge Notification

JPM Number: RA-4-04-0

Revision Number: 3

Date: 5/3/21

Developed By: Barry Mingus / 5/3/21
Instructor: Print / Sign Date

Reviewed By: Benjamin Reyes / 6/9/21
SME or Instructor: Print / Sign Date

Reviewed By: Peter Leonhardt /
Operations Representative: Print / Sign Date

Approved By: Brian Lewin /
Training Department: Print / Sign Date

JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

NOTE: All steps of this checklist should be performed upon initial validation.
 Prior to JPM usage, revalidate JPM using steps 9 and 13 below.

1. Task description and number, JPM description and number are identified. _____
2. Knowledge and Abilities (K/A) references are included. _____
3. Performance location specified. (in-plant, control room, simulator, or other) _____
4. Initial setup conditions are identified. _____
5. Initiating cue (and terminating cue if required) are properly identified. _____
6. Task standards identified and verified by instructor or SME review. _____
7. Critical steps meet the criteria for critical steps and are identified with an asterisk (*). _____
8. IAW NUREG 1021 Appendix C, clearly identify the task standard (i.e., the predetermined qualitative or quantitative outcome) against which task performance will be measured. _____
9. Verify the procedure(s) referenced by this JPM reflects the current revision:

Procedure: <u>EPA 17-001</u>	Revision: <u>1</u>
Procedure: _____	Revision: _____
Procedure: _____	Revision: _____
Procedure: _____	Revision: _____
10. Verify cues both verbal and visual are free of conflict. _____
11. Verify performance time is accurate. _____
12. If the JPM cannot be performed as written with proper responses, then revise the JPM. _____
13. When JPM is initially validated, sign and date JPM cover page. For subsequent validations, sign and date below: _____

_____/_____
 SME / Instructor (Print/Sign) Date

_____/_____
 SME / Instructor (Print/Sign) Date

_____/_____
 SME / Instructor (Print/Sign) Date

Revision Record (Summary)

Revision #	Summary
00	Revised format to current standard.
01	<p>Applied new template TQ-AA-150-J020</p> <p>Updated 2016 NRC Exam RA-d which from used procedure EP-AA-112-100-F-06 and computer screenshots to simulate and describe actions to be taken by now using procedure developed for training use in simulator; EPA 17-001, with different codes and password and with performance of actual actions.</p> <p>Upgrades to Everbridge and all-call implementation resulted in procedural changes in terminology of button actions and shortened timelines.</p>
02	<p>Designated as Time Critical JPM</p> <p>Added Note to calculate elapsed time.</p> <p>Added this is a Time Critical JPM to Initiating Cue</p> <p>Revised expected time of performance to 6 minutes.</p>
03	Updated to current template TQ-AA-150-J020 Rev 1

SETUP INSTRUCTIONS

1. Ensure the Paragon computer is logged into *Byrtraining* with Everbridge icon on desktop.
2. Ensure Procedure EPA 17-001, ERO NOTIFICATION OR AUGMENTATION – TRAINING USE is printed and available for JPM.
3. Ensure date and time stamp for each previous notification is CLEARED.
4. When the above steps are completed for this and other JPMs to be run concurrently then validate, if not previously validated, the concurrently run JPMs using the JPM Validation Checklist.
5. This completes the setup for this JPM.

INITIAL CONDITIONS

You are the WEC NSO.

The Shift Manager has declared an ALERT condition for Unit 1, and has assigned you to activate the ERO On Site.

INITIATING CUE

Initiate activation of the Everbridge ERO Notification System using the World Wide Web in accordance with procedure EPA 17-001.

This is a time critical JPM.

Fill in the JPM Start Time when the student acknowledges the Initiating Cue.

.....

Information For Evaluator's Use:

UNSAT requires written comments on respective step.

* Denotes critical steps. **4, 5, 7, 8 & 11**

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section. The comment section should be used to document: the reason that a step is marked as unsatisfactory, marginal performance relating to management expectations, or problems the candidate had while performing the JPM. Comments relating to procedural or equipment issues should be entered and tracked using the site's appropriate tracking system.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

.....

JPM Start Time: ___:__:___ JPM Sequence #: _____ of _____

Task Standard:

Candidate will activate the Everbridge ERO Notification System in accordance with Training Procedure EPA-17-001 within 10 minutes. The candidate will log into the Training Everbridge system to avoid a real system activation, and log into the Byron specific portion of the application. The candidate will launch a simulator notification. This will be accomplished within 10 minutes from the start of the JPM.

<u>STEP</u>	<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
NOTE: Use the simulator wall clock for noting times for this JPM. The computer and simulator time devices may not match, so do not use the computer time.					
NOTE: Ensure procedure EPA 17-001, ERO NOTIFICATION OR AUGMENTATION – TRAINING USE is used for performance of this JPM. <u>Do not use procedure EP-AA-112-100-F-06, ERO NOTIFICATION OR AUGMENTATION, which would result in actual activation of ERO network.</u>					
CUE:	Provide copy of EPA 17-001 to candidate as this procedure (equivalent) would be provided by the Emergency Director.				
1.	Refer to EPA 17-001.	• Locate and read EPA 17-001.	<input type="checkbox"/>	<input type="checkbox"/>	___
2.	1.1. CIRCLE the appropriate station specific User Name and Station Password number from the table below.	• Circle Byron specific User Name and Password	<input type="checkbox"/>	<input type="checkbox"/>	___
3.	1.2. CIRCLE the appropriate Activation / Termination Scenario event	• Circle 01A – Simulator Actual Event Respond to Facility	<input type="checkbox"/>	<input type="checkbox"/>	___
* 4.	1.3. OPEN the Everbridge shortcut icon from the desktop.	• Double-click the Everbridge shortcut on computer desktop computer.	<input type="checkbox"/>	<input type="checkbox"/>	___

<u>STEP</u>	<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
* 5.	1.4. Sign In to the Everbridge application	<ul style="list-style-type: none"> • ENTER the appropriate Byron station specific User name and Password from Step 1.1 <ul style="list-style-type: none"> • User name: blackhawk3 • Password: simulator02# • SELECT (click) "Sign In". 	<input type="checkbox"/>	<input type="checkbox"/>	—
6.	1.5. VERIFY the appropriate Station Name is displayed	<ul style="list-style-type: none"> • VERIFY Byron simulator is displayed • SELECT (click) "Proceed". 	<input type="checkbox"/>	<input type="checkbox"/>	—
* 7.	1.6. Launch Incident	<ul style="list-style-type: none"> • SELECT (click) the +Launch Incident button. 	<input type="checkbox"/>	<input type="checkbox"/>	—
* 8.	1.7. SELECT appropriate Scenario	<ul style="list-style-type: none"> • SELECT (Click) on Scenario 01A – Simulator Actual Event Respond to Facility. 	<input type="checkbox"/>	<input type="checkbox"/>	—
9.	1.8. VERIFY the appropriate Scenario is displayed	<ul style="list-style-type: none"> • VERIFY Scenario 01A – Simulator Actual Event Respond to Facility is displayed. 	<input type="checkbox"/>	<input type="checkbox"/>	—
10.	1.9. VERIFY the appropriate Scenario is displayed	<ul style="list-style-type: none"> • If the scenario displayed is not correct: <ul style="list-style-type: none"> ○ SELECT (click) correct scenario from list, Scenario 01A ○ RETURN to Step 1.8. • N/A 	<input type="checkbox"/>	<input type="checkbox"/>	—

<u>STEP</u>	<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
NOTE: Record time template is sent: ____:____:____. Time template sent – JPM start time = ____:____:____ (≤ 10 minutes)					
* 11.	1.10. “Send x template(s) Now”.	<ul style="list-style-type: none"> If the scenario displayed is correct: SELECT (click) “Send x template(s) Now”. Time template sent – JPM start time ≤ 10 minutes. 	<input type="checkbox"/>	<input type="checkbox"/>	—
NOTE: The system provides a callback to notify the sender that the system has actuated within 2 minutes of sending the notification. This will be simulated by the evaluator. The evaluator will provide the cue within 2 minutes.					
12.	1.11.VALIDATE there is a date and time stamp for each notification and RECORD	<ul style="list-style-type: none"> On the next screen: VALIDATE there is a date and time stamp for each notification listed. RECORD Time 	<input type="checkbox"/>	<input type="checkbox"/>	—
13.	1.12.Log Out to exit the Everbridge Notification program	<ul style="list-style-type: none"> SELECT “Log Out” 	<input type="checkbox"/>	<input type="checkbox"/>	—
14.	1.13. VERIFY that a call to the Control Room from the ERO notification system is received	<ul style="list-style-type: none"> VERIFY that a call to the Control Room from the ERO notification system is received within 2 minutes after the system was initiated. 			
CUE: You receive a call from the ERO Notification System one minute after the System was activated.					
15.	1.14. RECORD time of the confirmation call	<ul style="list-style-type: none"> RECORD time of the confirmation call to the Control Room. 			

<u>STEP</u>	<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
16.	1.16. INFORM the Shift Emergency Director of the status of the ERO Notification	<ul style="list-style-type: none"> • INFORM the Shift Emergency Director of the status of the ERO Notification System Initiation • EXIT this procedure 			
CUE:	This JPM is complete.				

JPM Stop Time: _____



JPM SUMMARY**Operator's Name:** _____ **Emp. ID#:** _____**Job Title:** EO RO SRO FS STA/IA SRO CertJPM Title: Activate Everbridge NotificationJPM Number: RA-4-04-0 Revision Number: 3Task Number and Title: 4F.ZP-02 USE Applicable Station Procedures During an EP Event

Task Standard: Candidate will activate the Everbridge ERO Notification System in accordance with Training Procedure EPA-17-001 within 10 minutes. The candidate will log into the Training Everbridge system, to avoid a real system activation, and log into the Byron specific portion of the application. The candidate will launch a simulator notification. This will be accomplished within 10 minutes from the start of the JPM.

K/A Number and Importance: 2.4.43, importance 3.2Suggested Testing Environment: SimulatorAlternate Path: Yes No SRO Only: Yes No Time Critical: Yes No

Reference(s):

Procedure: <u>EPA 17-001</u>	Revision: <u>1</u>
Procedure: _____	Revision: _____
Procedure: _____	Revision: _____
Procedure: _____	Revision: _____

Actual Testing Environment: Simulator Control Room In-Plant Other**Testing Method:** Simulate Perform**Estimated Time to Complete:** 6 minutes **Actual Time Used:** _____ minutes**EVALUATION SUMMARY:**Were all the Critical Elements performed satisfactorily? Yes NoThe operator's performance was evaluated against standards contained within this JPM and has been determined to be: Satisfactory Unsatisfactory**NOTE:** Enter finalized grading, comments, and notes relevant to this evaluation in the associated TQ-AA-150-F03A/B. (See AR [4282419](#)).**Evaluator's Name (Print):** _____**Evaluator's Signature:** _____ **Date:** _____



INITIAL CONDITIONS

- You are the WEC NSO.
- The Shift Manager has declared an ALERT condition for Unit 1, and has assigned you to activate the ERO On Site.

INITIATING CUE

- Initiate activation of the Everbridge ERO Notification System using the World Wide Web in accordance with procedure EPA 17-001.

- This is a time critical JPM.

ERO NOTIFICATION OR AUGMENTATION – TRAINING USE

The automated system will initiate the call out of management and bargaining unit personnel required to meet the ERO staffing requirements. Additional staffing of personnel shall be the responsibility of the individual Managers and Directors in the TSC / OSC / EOF / ENC / JIC following initial activation of those facilities.

Section 1 – Initiate Activation / Termination of Notification System using World Wide Web

Section 2 – Initiate Activation / Termination of Notification System using live Everbridge Agent

1.	<u>INITIATE ACTIVATION / TERMINATION OF NOTIFICATION SYSTEM USING THE WORLD WIDE WEB</u>																																		
1.1.	CIRCLE the appropriate station specific User Name and Station Password number from the table below.	<input type="checkbox"/>																																	
	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 25%;">Station</th> <th style="width: 25%;">User Name</th> <th style="width: 25%;">Password</th> </tr> </thead> <tbody> <tr> <td>Braidwood</td> <td>braidwood3</td> <td>simulator01#</td> </tr> <tr> <td>Byron</td> <td>blackhawk3</td> <td>simulator02#</td> </tr> <tr> <td>Clinton</td> <td>clinton3</td> <td>simulator03#</td> </tr> <tr> <td>Dresden</td> <td>dresden3</td> <td>simulator04#</td> </tr> <tr> <td>LaSalle</td> <td>lasalle3</td> <td>simulator05#</td> </tr> <tr> <td>Limerick</td> <td>limerick3</td> <td>simulator06#</td> </tr> <tr> <td>Oyster Creek</td> <td>oystercreek3</td> <td>simulator07#</td> </tr> <tr> <td>Peach Bottom</td> <td>peachbottom3</td> <td>simulator08#</td> </tr> <tr> <td>Quad Cities</td> <td>quadcities3</td> <td>simulator09#</td> </tr> <tr> <td>TMI</td> <td>threemileisland3</td> <td>simulator10#</td> </tr> </tbody> </table>	Station	User Name	Password	Braidwood	braidwood3	simulator01#	Byron	blackhawk3	simulator02#	Clinton	clinton3	simulator03#	Dresden	dresden3	simulator04#	LaSalle	lasalle3	simulator05#	Limerick	limerick3	simulator06#	Oyster Creek	oystercreek3	simulator07#	Peach Bottom	peachbottom3	simulator08#	Quad Cities	quadcities3	simulator09#	TMI	threemileisland3	simulator10#	
Station	User Name	Password																																	
Braidwood	braidwood3	simulator01#																																	
Byron	blackhawk3	simulator02#																																	
Clinton	clinton3	simulator03#																																	
Dresden	dresden3	simulator04#																																	
LaSalle	lasalle3	simulator05#																																	
Limerick	limerick3	simulator06#																																	
Oyster Creek	oystercreek3	simulator07#																																	
Peach Bottom	peachbottom3	simulator08#																																	
Quad Cities	quadcities3	simulator09#																																	
TMI	threemileisland3	simulator10#																																	

THIS IS A DRILL

ERO NOTIFICATION OR AUGMENTATION

<p>1.2. CIRCLE the appropriate Activation / Termination Scenario event from the table below.</p>					<input type="checkbox"/>
<p>01A – Simulator Actual Event Respond to Facility</p> <p>For Alert, Site Area, or General Emergency, or Security Events with On Site ERO reporting</p> <p>*Optional for all other unusual Events</p>	<p>02A - Simulator Unusual Event</p> <p>Unusual Events excluding Security Events (HU1)</p> <p>CM-1</p>	<p>03A - Simulator Actual Event Alternative Facility Response</p> <p>For Events with Off Site ERO reporting location requirements as determined by the Emergency Director</p>	<p>04A - Simulator Event Termination</p> <p>Notification to all ERO Members, Station Management and EOF Responders that event has been terminated.</p>	<p>05A - Simulator Activation Cancellation</p> <p>Notification to all ERO Members, Station Management and EOF Responders that activation has been cancelled.</p>	

THIS IS A DRILL

ERO NOTIFICATION OR AUGMENTATION

<p>1.3. OPEN (double-click) the Everbridge shortcut icon from your desktop computer. If shortcut Icon is not available or is not functioning, then OPEN a web browser, then TYPE https://manager.everbridge.net/login.</p> <p>A. If internet is not available, then GO TO Step 2.</p>	<input type="checkbox"/>
<p>NOTE: User Name and Passwords are case sensitive and will lock out after four (4) failed attempts.</p>	
<p>1.4. ENTER the appropriate station specific User name and Password from Step 1.1 and SELECT (click) "Sign In".</p>	<input type="checkbox"/>
<p>1.5. VERIFY the appropriate Station Name is displayed, SELECT (click) "Proceed".</p>	<input type="checkbox"/>
<p>1.6. SELECT (click) the +Launch Incident button.</p>	<input type="checkbox"/>
<p>1.7. SELECT (Click) on the appropriate Scenario from Step 1.2.</p>	<input type="checkbox"/>
<p>1.8. VERIFY the appropriate Scenario is displayed.</p>	<input type="checkbox"/>
<p>1.9. If the scenario displayed is not correct, then SELECT (click) correct scenario from list and RETURN to Step 1.8.</p>	<input type="checkbox"/>
<p>1.10. If the scenario displayed is correct, then SELECT (click) "Send x template(s) Now".</p>	<input type="checkbox"/>
<p>1.11. On the next screen, VALIDATE there is a date and time stamp for each notification listed.</p> <p>RECORD Time _____</p>	<input type="checkbox"/>
<p>1.12. SELECT "Log Out" to exit the Everbridge Notification program.</p>	<input type="checkbox"/>
<p>1.13. VERIFY that a call to the Control Room from the ERO notification system is received within 2 minutes after the system was initiated.</p>	<input type="checkbox"/>
<p>1.14. RECORD time of the confirmation call to the Control Room_____.</p>	<input type="checkbox"/>
<p>1.15. If a confirmation call is not received in the Control Room within 2 minutes confirming scenario activation, then PROCEED to Section 2, Initiate Activation / Termination of Notification System Using Live Everbridge Agent.</p>	<input type="checkbox"/>
<p>1.16. INFORM the Shift Emergency Director of the status of the ERO Notification System Initiation and EXIT this procedure.</p>	<input type="checkbox"/>

THIS IS A DRILL

ERO NOTIFICATION OR AUGMENTATION

2. **INITIATE ACTIVATION / TERMINATION OF NOTIFICATION SYSTEM USING LIVE EVERBRIDGE AGENT**

2.1. **CIRCLE** the appropriate station specific Account Name, Organization Name, First name, Last name and response to Hint Question from the table below.



Account Name	Organization Name (Station)	First Name	Last name	Response to Hint Question
<p>Exelon Generation Company LLC</p> <p>NOTE: Everbridge will then ask for your organization. Provide your station name for your response.</p>	Braidwood	Braidwood	ERONS Activator	Exelon
	Byron	Byron	ERONS Activator	Exelon
	Clinton	Clinton	ERONS Activator	Exelon
	Dresden	Dresden	ERONS Activator	Exelon
	LaSalle	LaSalle	ERONS Activator	Exelon
	Limerick	Limerick	ERONS Activator	Exelon
	Oyster Creek	Oyster Creek	ERONS Activator	Exelon
	Peach Bottom	Peach Bottom	ERONS Activator	Exelon
	Quad Cities	Quad Cities	ERONS Activator	Exelon
	TMI	TMI	ERONS Activator	Exelon

THIS IS A DRILL

ERO NOTIFICATION OR AUGMENTATION

2.2. CIRCLE the appropriate Activation Scenario Number for the event from the table below.					<input type="checkbox"/>
<p>01A - Simulator Actual Event Respond to Facility</p> <p>For Alert, Site Area, or General Emergency, or Security Events with On Site ERO reporting</p> <p>*Optional for all other unusual Events</p>	<p>02A - Simulator Unusual Event</p> <p>Unusual Events excluding Security Events (HU1)</p> <p align="center">CM-1</p>	<p>03A - Simulator Actual Event Alternative Facility Response</p> <p>For Events with Off Site ERO reporting location requirements as determined by the Emergency Director</p>	<p>04A - Simulator Event Termination</p> <p>Notification to all ERO Members, Station Management and EOF Responders that event has been terminated.</p>	<p>05A - Simulator Activation Cancellation</p> <p>Notification to all ERO Members, Station Management and EOF Responders that activation has been cancelled.</p>	

THIS IS A DRILL

ERO NOTIFICATION OR AUGMENTATION

2.3.	DIAL the ERO Notification System Activation phone number: x-4155 (Simulator Booth) .	<input type="checkbox"/>
2.4.	When asked for your Everbridge Account Name, Organization Name, First name, Last Name and Hint question, then PROVIDE the appropriate information from step 2.1.	<input type="checkbox"/>
2.5.	ASK the Live Everbridge Agent if there is a current "Incident" Broadcast running for your station.	<input type="checkbox"/>
2.6.	If the Live Everbridge Agent confirms the appropriate scenario has been activated, then STOP here and do not proceed with steps 2.8 to 2.16 below.	<input type="checkbox"/>
2.7.	If the Live Everbridge Agent confirms that the appropriate scenario has not been activated, then PROCEED to step 2.9.	<input type="checkbox"/>
2.8.	INFORM the Everbridge Agent that you would like to Launch a Scenario.	<input type="checkbox"/>
2.9.	When asked for the Scenario number, then STATE the appropriate Scenario number followed by the corresponding name of the Scenario you wish to launch. PROVIDE the appropriate information from step 2.2.	<input type="checkbox"/>
2.10.	When asked by the Everbridge Agent "Would you like me to send this scenario (message) now?", then REPLY Yes.	<input type="checkbox"/>
2.11.	VERIFY with the Everbridge Agent that the ERO Activation scenario has been successfully initiated.	<input type="checkbox"/>
2.12.	RECORD the Broadcast ID number _____ time _____	<input type="checkbox"/>
2.13.	VERIFY that a call to the Control Room from the ERO notification system is received within 2 minutes after the system was initiated.	<input type="checkbox"/>
2.14.	RECORD time of the confirmation call to the Control Room_____.	<input type="checkbox"/>
2.15.	INFORM the Shift Emergency Director of the status of the ERO Notification System Initiation and EXIT this procedure.	<input type="checkbox"/>

3. REFERENCES

3.1. Commitment

CM-1: Regulatory Commitment Number 5 identified in Attachment 11 of Letter to NRC dated Aug 17, 2005, (RS-05-101). (Steps 1.2, 2.2, 3.2)

THIS IS A DRILL