

**PSL SLRA: Breakout Questions**

SLRA Section 2.4 – Structural Scoping and Screening

Note: Breakout Questions are provided to the applicant and will be incorporated into the publicly-available audit report.

<b>Technical Reviewer</b>	Bryce Lehman	12/17/21
<b>Technical Branch Chief</b>	Joseph Colaccino	12/20/21
<b>Breakout Session</b>	<i>Date/Time</i>	<i>To be filled in by PM</i>

Applicant Staff	NRC staff
<i>To be filled out by PM during breakout</i>	

Question Number	SLRA Section	SLRA Page	Background / Issue (As applicable/needed)	Discussion Question / Request	Outcome of Discussion
1	2.4.9	2.4-20	<p>SLRA Section 2.4.9 notes that water enters the intake structure and passes through stationary and traveling screens.</p> <p>SLRA Table 2.4-9 shows the structural scoping results for the intake structure but does not list intake screens as a component receiving an AMR. It also does not list 'filter' as an intended function for any of the components in the table.</p>	<p>Explain if the intake screens are within in the scope of SLR. If they are not within scope provide a technical justification. If they are in-scope, identify the AMR that addresses these components.</p>	