

JAN 21 2022

Docket No.: 52-025

ND-22-0049  
10 CFR 52.99(c)(1)U.S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555-0001Southern Nuclear Operating Company  
Vogtle Electric Generating Plant Unit 3  
ITAAC Closure Notification on Completion of ITAAC 2.6.09.13c [Index Number 654]


Ladies and Gentlemen:

In accordance with 10 CFR 52.99(c)(1), the purpose of this letter is to notify the Nuclear Regulatory Commission (NRC) of the completion of Vogtle Electric Generating Plant (VEGP) Unit 3 Inspections, Tests, Analyses, and Acceptance Criteria (ITAAC) Item 2.6.09.13c [Index Number 654]. This ITAAC confirms that non-portable communication devices (including conventional telephone systems) in the central and secondary alarm stations are wired to an independent power supply that enables the system to remain operable in the event of loss of normal power. The closure process for this ITAAC is based on the guidance described in Nuclear Energy Institute (NEI) 08-01, "Industry Guideline for the ITAAC Closure Process Under 10 CFR Part 52," which was endorsed by the NRC in Regulatory Guide 1.215.

This letter contains no new NRC regulatory commitments. Southern Nuclear Operating Company (SNC) requests NRC staff confirmation of this determination and publication of the required notice in the Federal Register per 10 CFR 52.99.

If there are any questions, please contact Kelli Roberts at 706-848-6991.

Respectfully submitted,

Michael J. Yox  
Regulatory Affairs Director Vogtle 3 & 4Enclosure: Vogtle Electric Generating Plant (VEGP) Unit 3  
Completion of ITAAC 2.6.09.13c [Index Number 654]

MJY/RLB/sfr

**To:**

**Southern Nuclear Operating Company/ Georgia Power Company**

Mr. Peter P. Sena III

Mr. D. L. McKinney

Mr. H. Nieh

Mr. G. Chick

Mr. S. Stimac

Mr. P. Martino

Mr. J. B. Williams

Mr. M. J. Yox

Mr. A. S. Parton

Ms. K. A. Roberts

Ms. J.M. Coleman

Mr. C. T. Defnall

Mr. C. E. Morrow

Mr. K. J. Drudy

Mr. J. M. Fisher

Mr. R. L. Beilke

Mr. S. Leighty

Ms. A. C. Chamberlain

Mr. J. C. Haswell

Document Services RTYPE: VND.LI.L06

File AR.01.02.06

cc:

**Nuclear Regulatory Commission**

Ms. M. Bailey

Mr. M. King

Mr. G. Bowman

Ms. A. Veil

Mr. C. P. Patel

Mr. G. J. Khouri

Mr. C. J. Even

Mr. B. J. Kemker

Ms. N. C. Covert

Mr. C. Welch

Mr. J. Gaslevic

Mr. O. Lopez-Santiago

Mr. G. Armstrong

Mr. M. Webb

Mr. T. Fredette

Mr. C. Santos

Mr. B. Davis

Mr. J. Vasquez

Mr. J. Eargle

Mr. T. Fanelli

Ms. K. McCurry

Mr. J. Parent

Mr. B. Griman

Mr. V. Hall

U.S. Nuclear Regulatory Commission

ND-22-0049

Page 3 of 3

**Oglethorpe Power Corporation**

Mr. R. B. Brinkman

Mr. E. Rasmussen

**Municipal Electric Authority of Georgia**

Mr. J. E. Fuller

Mr. S. M. Jackson

**Dalton Utilities**

Mr. T. Bundros

**Westinghouse Electric Company, LLC**

Dr. L. Oriani

Mr. D. C. Durham

Mr. M. M. Corletti

Mr. Z. S. Harper

Mr. J. L. Coward

**Other**

Mr. S. W. Kline, *Bechtel Power Corporation*

Ms. L. Matis, *Tetra Tech NUS, Inc.*

Dr. W. R. Jacobs, Jr., Ph.D., *GDS Associates, Inc.*

Mr. S. Roetger, *Georgia Public Service Commission*

Mr. R. L. Trokey, *Georgia Public Service Commission*

Mr. K. C. Greene, *Troutman Sanders*

Mr. S. Blanton, *Balch Bingham*

**Southern Nuclear Operating Company  
ND-22-0049  
Enclosure**

**Vogtle Electric Generating Plant (VEGP) Unit 3  
Completion of ITAAC 2.6.09.13c [Index Number 654]**

## **ITAAC Statement**

### **Design Commitment**

13.c) Non-portable communication equipment in the central and secondary alarm stations remains operable from an independent power source in the event of loss of normal power.

### **Inspections/Tests/Analyses**

Tests, inspections, or a combination of tests and inspections of the non-portable communications equipment will be performed.

### **Acceptance Criteria**

Non-portable communication devices (including conventional telephone systems) in the central and secondary alarm stations are wired to an independent power supply that enables the system to remain operable in the event of loss of normal power.

## **ITAAC Determination Basis**

A test of the non-portable communications equipment in the Vogtle Electric Generating Plant (VEGP) Unit 3 central alarm station (CAS) and secondary alarm station (SAS) was performed to confirm the non-portable communication devices (including conventional telephone systems) in the Unit 3 CAS and SAS are wired to an independent power supply that enables the system to remain operable in the event of loss of normal power, and satisfy the applicable CAS and SAS non-portable communications equipment power supply requirements of the VEGP Unit 3 and Unit 4 Physical Security Plan associated with 10 CFR 73.55(j)(5). The VEGP Unit 3 Plant Security System ITAACs only cover the Unit 3 plant security system design commitment scope.

Testing was performed per ITAAC Technical Report SV3-SES-ITR-800654 (Reference 1) and involved securing the normal power supply to the CAS and SAS non-portable communication devices, and then verifying that the power supply to the CAS and SAS non-portable communication devices transfers to an independent power supply such that the associated system remains operable in the event of loss of normal power. The non-portable communication devices included in the scope of this testing include the CAS/SAS conventional (dedicated) telephone, CAS/SAS security base station radio and CAS/SAS security intercom station.

The testing documented in Reference 1 confirms that the non-portable communication devices (including conventional telephone systems) in the Unit 3 CAS and SAS are wired to an independent power supply that enables the system to remain operable in the event of loss of normal power.

Reference 1 is available for NRC inspection as part of the Unit 3 ITAAC 2.6.09.13c Completion Package (Reference 2).

## **ITAAC Finding Review**

In accordance with plant procedures for ITAAC completion, Southern Nuclear Operating Company (SNC) performed a review of all findings pertaining to the subject ITAAC and associated corrective actions. This review found there were no relevant ITAAC findings associated with this ITAAC. The ITAAC completion review is documented in the ITAAC Completion Package for ITAAC 2.6.09.13c (Reference 2) and is available for NRC review.

**ITAAC Completion Statement**

Based on the above information, SNC hereby notifies the NRC that ITAAC 2.6.09.13c was performed for VEGP Unit 3 and that the prescribed acceptance criteria was met.

Systems, structures, and components verified as part of this ITAAC are being maintained in their as-designed, ITAAC compliant condition in accordance with approved plant programs and procedures.

**References (available for NRC inspection)**

1. SV3-SES-ITR-800654, SES Communications on UPS: ITAAC 2.6.09.13c, Rev 0 (SRI)
2. 2.6.09.13c-U3-CP-Rev0, ITAAC Completion Package